

This Document Posted By
Public.Resource.Org, Inc.,
a California Nonprofit
Organization.

Not Affiliated Or
Authorized by NFPA
or by the federal or
state government.

Vermont

Fire & Building Safety Code

2005



VERMONT DEPARTMENT OF PUBLIC SAFETY
DIVISION OF FIRE SAFETY
OFFICE OF THE FIRE MARSHAL AND FIRE ACADEMY
vtfiresafety.org

Effective Date October 22, 2005

PLEASE NOTE: THIS CODE MAY BE OUTDATED.
Check with your local authorities for the current codes.

2005 Vermont Fire & Building Safety Code

Introduction

Since 1972 the State of Vermont has adopted nationally recognized safety standards to protect the public from fire and explosion hazards and establish standards for fire safety. Standards for boiler safety have been in place even longer. Vermont is able to benefit from the research and fire safety experience from experts across the nation in every area of expertise by using nationally recognized safety standards in this *Code*. The national standards are amended only when necessary to address conditions specific to Vermont, stay within the limits set by law or to clarify interpretations of certain sections.

The *2005 Vermont Fire & Building Safety Code* establishes the process to obtain a construction or operating permit, lists the codes and standards that are adopted and describes the process used to evaluate and grant a variance or exemption from the *Code*. The annexes to this *Code* are designed to help people understand the state laws related to fire, explosion, hazardous materials, structural safety and carbon monoxide, and enable people to understand and take advantage of the flexibility built into this *Code* for historic buildings.

This *Code* establishes separate minimum standards for new and existing buildings, and existing buildings that are used for a new purpose. This *Code* recognizes the need to protect the public when the use of a building changes putting more people at risk or introducing new hazards to a building. But, this *Code* is also written to facilitate the adaptive reuse of buildings recognizing certain limitations of existing buildings. This *Code* has less restrictive requirements for low risk occupancies and promotes the use of alternative solutions for safety.

The *Life Safety Code (NFPA 101)* is the most widely used standard adopted under this *Code* and applies to all buildings and premises regulated under this *Code*. The *Life Safety Code* regulates construction, fire protection and occupancy features necessary to minimize danger to life from fire and to allow escape from fire and non-fire emergencies.

The *Uniform Fire Code (NFPA 1)* applies to new and existing conditions including general fire safety provisions, fire protection including sprinkler systems, fire department access to buildings and special material and process fire hazards. The *Uniform Fire Code* functions as a guide to determine what other specialty codes and state amendments apply to a building, premise, or condition.

The *International Building Code (IBC)* applies to new construction and structural requirements. It is used to determine the allowable size of new construction, structural design features such as the snow load, and to ensure compliance with the performance requirements of other adopted standards.

The *National Board Inspection Code (NBIC)* is focused on the installation, maintenance and inspection of boilers and pressure vessels. The American Society of Mechanical Engineers (ASME) standards referenced in section 3 (b) regulates the design and manufacture of boilers and pressure vessels. Prior to this adoption of this *Code* there had been a separate set of rules for boilers and pressure vessels. By combining the boiler rules with the fire prevention rules there will be a simplified administrative process and better coordination for inspections regarding heating systems.

Information on how to contact the Division of Fire Safety and obtain copies of the adopted codes are in Annex V at the end of this *Code*.

TABLE OF CONTENTS

Introduction

Section 1. Title, Intent and Authority... *page 4*

Section 2. Adoption of Nationally Recognized Standards... *page 4*

Fire Prevention Code, NFPA 1, amendments to the 2003 edition... *page 4*

Certificate of Fitness - Classifications, Qualifications... *page 4*

Amendments to the 2002 edition of NFPA 13 and NFPA 25... *page 7*

Information Regarding Explosives and Fireworks... *page 9*

Amendments to the 2001 edition of NFPA 58... *page 10*

Life Safety Code, NFPA 101, amendments to the 2003 edition... *page 10*

National Board Inspection Code, amendments to the 2004 edition... *page 14*

International Building Code, amendments to the 2003 edition... *page 14*

Cross-Reference to Adopted Standards... *page 14*

Section 3. Boiler and Pressure Vessel Inspection... *page 16*

Section 4. Application for a Construction Permit... *page 18*

Certification of Construction Documents... *page 18*

Section 5. Variance, Exemption, and Reconsideration... *page 19*

Section 6. Municipal Enforcement and Coordination... *page 20*

Section 7. Effective Dates and Severability... *page 20*

Annex I - Sections of Vermont Law Pertaining to the Vermont Fire & Building Safety Code

Definition of Public Building... *page 21*

Definition of Historic Building... *page 22*

Construction Permit Fee... *page 23*

Cooperative Municipal Inspection Agreements... *page 25*

Reports to the Fire Marshal... *page 27*

Explosives and Fireworks... *page 28*

Annex II -Excerpts from the Architects and Professional Engineers Licensing Laws... *page 29*

Annex III - Smoke & Carbon Monoxide Detector Law for Single-Family Owner Occupied

Dwellings... *page 31*

Annex IV - Information for Historic Buildings... *page 32*

Annex V - Contact Information... *page 34*

Annex VI - Index by Topic and Occupancy... *page 35*

Annex VII - Snow Load Information... *page 37*

Section 1.

Title, Intent and Authority

(a) These rules are adopted under 20 V.S.A. Chapter 173, Subchapter 2 “Fire Safety Division”, Subchapter 3 “Fire Hazards and Dangerous Substances”, Subchapter 5 “Boilers and Pressure Vessels” and Chapter 177 “Explosives and Fireworks”, and shall be known and cited as the Vermont Fire & Building Safety Code - 2005. It is the intent of these rules to provide for the public safety as directed by these sections of the law.

(b) This *Code* shall be administered and enforced by the Commissioner of Public Safety and staff members of the Division of Fire Safety that are hereby designated to enforce this *Code* and utilize discretionary authority regarding the details of the application of this *Code*. Hereafter the Commissioner, or designated representative, or in the case of a cooperative municipal inspection agreement, the approved inspector(s), are designated as the **Authority Having Jurisdiction** (AHJ). For the purpose of NFPA 1 section 1.13, Certificates of Fitness, the Commissioner and staff members of the Division of Fire Safety are designated as the AHJ.

(c) The AHJ may establish priorities for enforcing these rules and standards based on the relative risk to people and property.

Section 2.

Adoption of Nationally Recognized Standards

The following nationally recognized safety standards, as amended herein, are adopted for the purpose of making rules regarding the safeguarding of people and property in case of fire, explosion, hazardous materials, dangerous structural conditions and the generation of carbon monoxide.

This *Code* has been designed to minimize any conflict or difference between standards. Where there is a conflict between an adopted code and its referenced code or standard the adopted code shall apply. Where there is a conflict between the Life Safety Code (NFPA 101) and another code or standard the Life Safety Code shall apply. Where there is conflict between the Uniform Fire Code (NFPA 1) and the International Building Code or the National Board Inspection Code the Uniform Fire Code

shall apply. Where one code or standard has a requirement and another code or standard does not have a requirement the code or standard with a requirement shall apply. When there is a conflict between a general requirement and a specific requirement the specific requirement shall apply.

(a) National Fire Protection Association, standard **NFPA 1, Uniform Fire Code**, 2003 edition, including those standards referenced in Chapter 2 that shall be considered part of this *Code*.

-delete- section 1.8 Duties and Powers of the Incident Commander

-delete & replace- section 1.10 Appeals: Requests for variances, exemptions and reconsideration of the interpretation of this *Code*, shall be made and processed in accordance with Section 5 of this *Code*.

-delete & replace- section 1.13.1 Certificate of Fitness: A certificate of fitness is required for all individuals performing activities related to fire or life safety based on the qualifications as follows:

(1) Use of explosive materials – A current explosive license issued in accordance with Title 20 V.S.A. 3072 by the Vermont State Police is required for the use of explosive materials in Vermont.

(2) Blasting operations – A current explosive license issued in accordance with Title 20 V.S.A. 3072 by the Vermont State Police is required for blasting operations in Vermont.

(3) Fireworks displays – (Reserved)

(4) Inspection, servicing or recharging of portable fire extinguishers -(Reserved)

(5) Design, installation, inspection, servicing or recharging of **fixed fire extinguishing systems** – A current certificate from the National Institute for Certificate in Engineering Technologies (NICET) for fire suppression; or training by the manufacturer of fire suppression systems acceptable to the authority having jurisdiction. Eight hours of related instruction is required for certificate renewal.

(6) Design, installation, inspection, maintenance and testing of **fire alarm** and detection systems and equipment – A current master electrician, journeyman electrician or type S journeyman commercial fire alarm license, issued in accordance with Title 26 V.S.A. chapter 15. Eight hours of related instruction is required for certificate renewal. [72:4.3.3 is deleted and replace by this section]

(7) (a) **Delivery of liquid propane (LP) gas** – Successful completion of the LP gas Certified Employee Training Program (CETP) books 1.0, 2.2 and 2.4. [re-lighting a pilot light after an interruption of service is permitted under this certification]

(b) **Plant Operations for LP gas** – Successful completion of CETP books 1.0, 3.1, 3.2, 3.3 & 3.4

(c) **Design & Selection of LP gas Vapor Distribution System** – Successful completion of CETP books 1.0 & 4.1.

(d) **Preparing & Installing of LP gas Vapor Distribution Components** – Successful completion of CETP books 1.0 & 4.2

(e) **LP gas Transfer Systems operations** – Successful completion of CETP books 1.0 & 5.0

(f) **Installation, Inspection and Service of LP gas Appliances** – Successful completion of CETP books 1.0, 4.2, 6.0 and 7.0. Eight hours of related instruction is required for certificate renewal including at least two hours regarding the prevention of CO leakage and the procedure for safety inspection of an existing appliance – NFPA 54 (annex H).

(g) The installation, inspection and service of **both natural fuel gas systems and equipment, and LP gas systems and equipment** - Successful completion of the AGA course of study including "The Fundamentals of Combustion, Gas Appliance Venting, Electricity, Gas Controls, and Gas Appliances" and CETP books 1.0 and 4.2. Eight hours of related instruction is required for certificate renewal including at least two hours regarding the prevention of CO leakage and the procedure for safety inspection of an existing appliance – NFPA 54 (annex H).

(h) Installation, inspection and service of **natural fuel gas** systems and equipment - Successful completion of the American Gas Association (AGA) course of study including "The Fundamentals of Combustion, Gas Appliance Venting, Electricity, Gas Controls, and Gas Appliances". Eight hours of related instruction is required for certificate renewal including at least two hours regarding the prevention of CO leakage and the procedure for safety inspection of an existing appliance – NFPA 54 (annex H)

(i) Installation, inspection and service of **oil burning equipment** – A Silver certificate from the National Oilheat Research Alliance (NORA). Eight hours of related instruction is required for certificate renewal including at least two hours regarding the prevention of CO leakage and the procedure for inspection.

(j) **LIMITED** installation, repair and maintenance of **oil burning equipment** not including placing a new unit in service – A Bronze certificate from NORA. Eight hours of related instruction is required for certificate renewal including at least two hours regarding the prevention of CO leakage and the procedure for inspection.

(8) Cleaning, maintenance and evaluation of **chimneys** – A current certificate from the Chimney Safety Institute of America.

(9) Installation, inspection or servicing of range hood systems - (Reserved)

(10) **Calculations and design, for fire sprinkler and standpipe systems**, including private underground

and aboveground fire mains and fire pumps - A current level III certificate, or higher, for automatic fire sprinkler systems from NICET or a fire protection engineer license issued in accordance with Title 26 V.S.A. chapter 20. A person with a certificate of fitness under this section shall also be permitted to install, maintain, repair and test fire sprinkler and standpipe systems under section 1.13.1 (11).

(11) **Installation, maintenance, repair and testing for fire sprinkler** and standpipe systems, including private underground and aboveground fire mains and fire pumps – Completion of an approved fire sprinkler apprentice program or meeting the testing requirements established by the AHJ. Fifteen hours of related instruction is required for certificate renewal.

(12) **LIMITED** installation, maintenance, inspection and testing for **domestic fire sprinkler systems** with not more than 6 sprinklers for any isolated hazard area in accordance with 101:9.7.1.2 or an automatic fire sprinkler system in accordance with NFPA 13D, Standard for the Installation of Sprinkler Systems in One and Two Family Dwellings and Manufactured Homes, including multipurpose piping systems – Documented competency and experience acceptable to the AHJ. Eight hours of related instruction is required for certificate renewal.

(13) Installation, maintenance, repair and testing for **emergency generators** – Documented competency and experience through training by the manufacturer or acceptable by the AHJ. Eight hours of related instruction is required for certificate renewal.

[Information on the periodic inspection & tests of fire protection systems is found in NFPA 1 amended section 4.5.8.4]

-add- section 1.13.4.1 Experience & Training: The AHJ may accept successful completion of appropriate examination or certification other than those listed in this section when the examination or certification demonstrates an equivalent level of experience and training.

-add- section 1.13.8.1 Documentation for **Renewal**: An application for renewal shall include:

(1) Documentation of having completed the required hours of approved related instruction regarding this *Code* during the previous certificate period, and

(2) A completed and signed tax certification form in accordance with Title 32 V.S.A.3113, and

(3) A completed and signed child support certification form in accordance with Title 15 V.S.A. section 795.

-add- section 1.13.12.4 Due Process: A person who has a certificate of fitness revoked or suspended shall be given written notification and the opportunity for a hearing following due process.

-add referenced standards- section 2.2 Referenced Publications: the following standards are added to section 2.2;

NFPA 53, Recommended Practice on Materials, Equipment, and Systems in Oxygen-Enriched Atmospheres, 1999 Edition.

NFPA 73, Residential Safety Code, as adopted by the Vermont Electrician's Licensing Board.

NFPA 92A, Recommended Practice for Smoke Control Systems, 1996 edition.

NFPA 92B, Guide for Smoke Management Systems in Malls, Atria and Large Areas, 2002 edition

NFPA 101A, A guide on Alternative Approaches to Life Safety 2001 edition.

NFPA 291, Recommended Practice for Fire Flow Testing and Marking of Hydrants, 2002 Edition.

NFPA 601, Standard for Security Services in Fire Loss, Loss Prevention, 2000 edition.

NFPA 720, Standard for the Installation of Carbon Monoxide Warning (CO) Equipment in Dwelling Units, 2005 edition.

NFPA 820 Standard for Fire Protection in Wastewater Treatment and Collection Facilities, 1999 edition.

NFPA 914, Code for Fire Protection of Historic Structures, 2001 edition

-delete & replace in part - section 2.2 Reference Publications:

Any reference to NFPA 5000, Building Construction and Safety Code, 2003 Edition, shall be to the International Building Code, 2003 edition, as amended in this *code*

-cross-reference – section 3.3.138.11 Health Care Occupancy to section 101:3.3.152.7 as amended

-cross-reference – section 3.3.138.22 Residential Board & Care Occupancy to 101.3.3.152.13 as amended

-add- section 4.5.2.1 **Historic Buildings:** NFPA 914, Code for Fire Protection of Historic Structures, 2001 edition, provides guidance to the AHJ in exercising the discretionary authority granted in section 4.5.2.

-add- section 4.5.7.3 Place of Assembly: A **place of assembly that changes ownership**, or increases the occupant load, shall not be occupied or used until a permit for use and occupancy has been issued by the authority having jurisdiction

-delete & replace- section 4.5.8.4 **Periodic Inspection and Test** of Fire Protection Systems: Inspections and tests of fire sprinkler (other than multipurpose piping systems), suppression, emergency electrical generation, alarm, detection and any other fire protection systems, devices and equipment shall be conducted for the owner by a technically qualified person who has obtained the required certificate of fitness according to section

1.13. Inspections and tests shall be conducted at least annually and cover all intervals of testing frequency for the system. Annual testing by a technically qualified person does not relieve the owner of the responsibility of maintenance, inspection and testing at more frequent intervals as required by this code. A technically qualified person shall file a written inspection report with the AHJ within 14 days of completion of each inspection.

-add- section 4.5.8.5 **Identification of fire protection systems:** A fire protection system identification number, provided by the AHJ, shall be affixed to the control panel, control valve or riser of the fire protection system to provide a unique identification number for the fire protection system.

-add- section 4.5.8.6 **Proof of Inspection:** Proof of inspection, approved by the AHJ shall be affixed by a technically qualified person to the control panel, control valve or riser of the fire protection system after the required inspection has been completed as evidence of that inspection. The proof of inspection fee for fire suppression, alarm, detection and any other fire protection systems shall be \$10.00.

-add- section 10.13.4 Truss Construction: All buildings containing truss construction assemblies shall be provided with signage permanently affixed at a height 4 feet above the ground located at the left side of the main entrance door on the address side of the building, at the location of the remote fire alarm annunciation panel or at the fire department connection for the fire sprinkler system. The sign shall be triangular in shape measuring 12 inches horizontally and 6 inches vertically and of contrasting color to the background containing the letter "F" for the truss floor assemblies, the letter "R" for truss roof assemblies and "FR" for truss floor and roof assemblies.

-delete & replace- Section 10.11.1 Permits for Open Fires & Burning: A permit is not required for an open fire where a permit has been obtained from the Town Forest Fire Warden in accordance with Title 10 V.S.A. chapter 83; 2645.

-add- section 10.15.1.1 **Combustible Vegetation:** In other than Health Care, Detention and Correctional occupancies, combustible vegetation, including natural cut Christmas trees otherwise prohibited under table 10.15.1 shall be permitted when located in areas protected by an approved automatic fire sprinkler system.

-delete- section 10.18.1 Permits for Parade Floats

-cross-reference – section 11.1.2 Electrical Installations to 101:9.1.2 as amended

[Information regarding natural fuel gas- section 11.4: The Department of Public Service regulates the

transportation of natural and other gas by **pipeline**. For additional information contact the Vermont Department of Public Service at (802) 828-2811]

-add- section 11.5.1.4.2 **Interruption or Discontinuance of Gas Service:** Whenever service to a customer is discontinued one of the following must be complied with:

- (a) The valve that is closed to prevent the flow of gas to the customer must be provided with a locking device or other means designated to prevent the opening of the valve by persons other than those authorized by the operator.
- (b) A mechanical device or fitting that will prevent the flow of gas must be installed in the service line or in the meter assembly.
- (c) The customer's piping must be physically disconnected from the gas supply and the open pipe ends sealed. [reference 54:4.2.1 & 4.2.2]

-add- section 11.5.1.4.3 **Change in LP Gas Delivery Service:** The building owner, tenant, or responsible party shall obtain a safety inspection that meets or exceeds NFPA 54 annex H, for gas utilization equipment in accordance with section 1.13, when new fuel delivery service is provided. [reference 54:8.1.2]

-add- section 11.5.1.4.4 **Room Heater Installations: Unvented room heaters** and unvented fireplaces shall not be used in any building or structure regulated under this code. [54:9.23.1 is deleted & replaced by this subsection. It is not the intent of this section to prohibit heaters defined under NFPA 54 sections 3.3.67, Direct Gas-Fired Makeup Air Heater, 3.3.130, Industrial Air Heaters, Direct Gas-Fired Non-Recirculating, or 3.3.131, Industrial Air Heaters, Direct Gas-Fired Recirculating, used for large well ventilated areas.]

-add- section 11.5.1.4.5 **Water Heater Installations:** Water heaters installed in bedrooms or bathrooms shall be of the direct vent type. [54:9.28.1.1 is deleted & replaced by this subsection]

-add- section 13.3.1.2.1 **Approval of NFPA 13D Sprinkler Systems:** For all sprinkler systems designed in accordance with 13D, the technically qualified person certified under section 1.13 shall perform all required acceptance tests as required for NFPA 13R sprinkler systems, perform a water flow test for the most remote area, complete the Contractor's Material and Test Certificate(s), and forward the certificate(s) to the AHJ prior to asking for approval of the installation. Where the AHJ desires to be present during the conducting of acceptance tests, the installer shall provide the AHJ 15 day notification of the time and date of the testing. [13D:4.3 is deleted & replaced by this subsection]

-add- section 13.3.1.2.2 **Arrangement of Fire Department Connections:** All new & existing fire department connections shall be arranged so that water from the fire department connection shall reach the sprinkler system regardless of any manually closed control valve. [NFPA 13:8.16.2.4.3 and 8.16.2.4.4 are amended by this section.]

-add- section 13.3.1.3.1 **Fire Department Connections for Existing Sprinkler Systems:** Where there is no fire department connection for an existing NFPA 13 or 13R sprinkler system, or the threads do not meet NFPA 13 section 6.8, it shall be listed as a deficiency under NFPA 25: 5.1.1 by the technically qualified person conducting the annual inspection and corrected by the owner or occupant in accordance with NFPA 25: 4.1.4.

-add- section 13.3.1.3.2 **Backflow Prevention for Existing Sprinkler Systems:** A backflow prevention device shall not be added to an existing fire sprinkler system that reduces the water supply or water pressure to a point lower than the minimum sprinkler system design. Sprinkler calculations verifying the modified sprinkler design shall be submitted to the AHJ.

-add- section 13.3.2.1.1 **Sprinkler Protection for Elevator Hoistways:** Sprinkler protection for elevator hoistways shall be in accordance with NFPA 13 as amended in this section for 13:8.14.5:

8.14.5.1 Sidewall spray sprinklers shall be installed at the bottom of each elevator hoistway not more than 2' above the floor of the pit.

8.14.5.2 section deleted

8.14.5.3 Automatic sprinklers are not required for machine rooms constructed of noncombustible construction with the required fire protection rating.

8.14.5.4 Upright or pendent spray sprinklers shall be installed at the top of elevator hoistways. Automatic sprinklers at the top of hoistways shall be of ordinary or intermediate temperature rating.

8.14.5.5 In other than high rise buildings the sprinkler required at the top of the elevator hoistway by 8.14.5.4 shall not be required where the hoistway for passenger elevators is noncombustible and the car enclosure materials meet the requirements of ASME A17.1, Safety Code for Elevators and Escalators.

8.14.5.6 For the purpose of this section elevator hoistways serving 3 stories or less, and machine rooms, shall be considered noncombustible where constructed of independent metal framework and material meeting the definition for limited combustible material under 101:3.3.135.2.

-cross-reference- section 13.3.2.14.2 **Sprinkler Systems in New Apartment Buildings with Direct Access to 101:30.3.5.2**

-add- section 13.6.1.2.1 **Portable Fire Extinguishers for One and Two Family Dwellings:** Portable fire

extinguishers shall be provided in accordance with section 13.6 in dwelling units regulated under NFPA 101:24

-cross-reference- section 13.7.1.4.9.2.1 Power for Smoke Alarms to 101:9.6.2.10.2 as amended

-cross-reference- section 13.7.1.4.11.2 Means of Emergency Forces Notification by Fire Alarm to 101:9.6.4.2 as amended

-add- section 14.4.1.1 **Snow Removal:** All portions of the means of egress, including outside stairs and fire escapes, shall be kept clear of any accumulation of snow and ice at all times that the building is occupied. For multi-family dwellings with direct exit access to the outside and one and two family dwellings snow and ice shall be removed as soon as practicable.

-cross-reference- section 14.10.2 Impediments to Egress to 101:7.1.10.1.1

-delete- section 16.6.1 Permits for Torch Applied Roofing Systems

-delete- section 16.7.1.2 Permits for the Placement of Tar Kettles

-delete- section 16.8 Asbestos Removal: *[The Vermont Department of Health regulates the removal of asbestos containing materials, as well as the training for persons who remove asbestos containing materials. For additional information, contact the Vermont Department of Health, Health Protection Division (1-800-439-8550).]*

-delete- Chapter 17 Wildland Urban Interface

-delete- section 19.1.1 Commercial Rubbish-Handling Operations Permit

-add- section 20.1.4.6.5 **Means of Egress Inspection, Bars & Nightclubs:** The building owner or agent shall inspect all means of egress in assembly occupancies identified as bars, dance halls, discotheques, nightclubs or where festival seating is used, to ensure all means of egress are maintained free of obstructions, and correct any deficiencies found, prior to each opening of the building to the public. A record, available to the AHJ, shall be kept of all inspections, deficiencies found, and actions taken to correct them.

-cross-reference- section 20.2.3.1.2(1) Emergency Egress and Relocation Drills in Schools to 101:14.7.2.2(1)

-add- section 20.4.2.7 Alcohol-based Hand-rub Solutions: Alcohol-based Hand-rub solutions shall be

permitted in health care occupancies when used and stored in accordance with the following:

(1) The maximum individual dispenser fluid capacity shall be 0.3 gallons (1.2 liters) for dispensers in rooms, corridors and areas open to corridors.

(2) The location of dispensers in corridors shall be minimized.

(3) Where multiple dispensers are necessary the minimum horizontal spacing between dispensers shall be 4 ft.

(4) Dispensers shall not be installed over or directly adjacent to an ignition source.

(5) Storage of quantities greater than 5 gallons shall be in accordance with NFPA 30, Flammable & Combustible Liquids Code.

-delete & replace- sections 20.9.2.2, 20.10.2 & 20.11.2 Unvented Fuel-fired Heaters: Unvented fuel-fired heaters shall not be used. *[101: 30.5.2.2; 31.5.2.2; 26.5.2.2 and 24.5.1.2 are deleted and replaced by this section]*

-delete- section 22.2 Automobile Wrecking Yard Permit

-delete & replace- section 25.1.2 **Permits for Membrane Structures, Tents and Canopies:** Permits for an air-supported membrane structure, tent or canopy in excess of 1200 sq. ft. shall comply with 1.12.19.

-add- section 29.1.3 Ventilation for Occupied Spaces Adjacent or Accessory to Parking Structures: In addition to ventilation requirements under 88A:5.3 for enclosed parking structures, all connecting spaces or contained spaces such as offices, waiting areas, ticket booths and similar areas shall be maintained at a positive pressure. *(see section 7 for transition effective date)*

-delete- section 41.1.5 Permits for Welding, Cutting & other Hot Work

-delete & replace- section 42.2.3.3.2 Aboveground Storage Tanks for Fuel Dispensing: All aboveground storage tanks involved with fuel dispensing shall meet all applicable requirements of Chapter 2 and 3 of NFPA 30, Flammable and Combustible Liquids Code. All aboveground tanks storing Class I liquids shall be **fire resistant tanks** in accordance with Section 42.2.3.4.2.

[30A:4.3.2 is deleted & replaced by this section]

-delete & replace- section 42.2.3.3.2.4 Location of Aboveground Tanks for Fuel Dispensing: Tanks involved with fuel dispensing storing Class I liquids shall be located in accordance with Table 42.2.3.3.2.4. Tanks containing other liquids regulated under this chapter shall be permitted to be located with minimum separation requirements ½ of the

distances in Table 42.2.3.3.2.4. [30A:4.3.2.4 is deleted & replaced by this section]

-add- section 42.2.5.2.1.1 Lighting: Adequate lighting shall be provided for all fuel dispensing locations.

-add- section 50.1.1.1 Isolated **Cooking Operations**: The requirements for the hood, grease removal devices, duct and fixed fire extinguishing system may be modified by the AHJ for cooking operations in free standing tents, mobile units or other small buildings located greater than 30' from grandstands or other public buildings and occupied by employees only, when the clearance to combustibles, safety controls, portable fire extinguishers, staff training, fuel use, storage and shut-off, and electrical shut off for equipment are in compliance with this Code.

-delete & replace- section 51.1.2.1 Permits for Industrial Ovens and Furnaces: Permits for new installations, alterations or extensions to existing equipment shall comply with 1.12.19.

-add- section 53.4.1.1 Permits for Mechanical Refrigeration: A permit is not required for an existing facility that is in compliance with reporting requirements under the Vermont Community Right to Know Law, Title 20 V.S.A. Chapter 1.

-add- section 60.1.6.1.1 Permits for Hazardous Materials: A permit is not required for an existing facility that is in compliance with reporting requirements under the Vermont Community Right to Know Law, Title 20 V.S.A. Chapter 1.

[Information regarding chapter 65 **Explosives and Fireworks**- A license is required to possess, purchase, store, use, transport, give, transfer or sell explosives. For license applications or additional information contact the Division of State Police at (802) 244-8781.

The Division of Fire Safety regulates the safekeeping, storage, use, manufacturing, sale, handling, and other disposition of explosive material under this Code. The Division of Fire Safety also regulates the construction, manufacturing, storage, handling and use of fireworks for supervised public displays and pyrotechnic special effects under this Code.

It is unlawful for any person to offer for sale, sell at retail or wholesale, possess, use or explode any fireworks except as permitted for a supervised public display of fireworks.

A permit for a supervised public display of fireworks may be obtained from the Chief of the Fire Department, or in towns where there is no Fire Department from the board of selectman, where it is determined the display would not be hazardous to property or endanger the public. Application for a

permit must be made at least 15 days in advance of the public fireworks display.

Sparklers less than 14 inches long with no more than 20 grams of pyrotechnic mixture and novelty sparkling items limited to snakes, party poppers, glow worms, smoke devices, string poppers, snappers, or drop pops with no more than 0.25 grains of explosive mixture, that are in compliance with United States Consumer Product Safety Commission regulations, are legal for sale and use in Vermont.]

-delete & replace - section 65.2.3 **Permits for Public Fireworks Displays**: A permit for a supervised public display of fireworks shall be obtained from the chief of the fire department, or in towns where there is no fire department the board of selectmen, after determining the display would not be hazardous to property or endanger the public.

-delete & replace- section 65.11.1.1 **Consumer Fireworks**: The sale, handling and storage of consumer fireworks, including sparklers permitted for sale in Vermont, in both new and existing buildings, structures and facilities shall comply with NFPA 1124 and section 65.11.

-delete & replace- section 65.11.1.3.1 Exempt Amounts of **Consumer Fireworks**:

Consumer fireworks retail sales facilities or stores where the fireworks and sparklers are in packages in accordance with the U. S. Consumer Product Safety Commission and where the total quantity of consumer fireworks and sparklers in the building does not exceed 125 lb (net) of pyrotechnic composition shall be exempt from the following sections:

-65.11.3[1124:7.3] Permits

-65.11.4[1124:7.4] Construction

-65.11.5.1[1124:7.5.1] Automatic Sprinkler System

-65.11.5.3[1124:7.5.3] Fire Alarms

-65.11.5.4[1124:7.5.4] Smoke Control

-65.11.7[1124:7.7] Separation distances

-add- section 66.1.5.1 Permits for Flammable & Combustible Liquids: A permit is not required for an **underground storage tank** regulated by the Agency of Natural Resources, Department of Environmental Conservation, according to NFPA 30. [The Agency of Natural Resources, Department of Environmental Conservation (DEC) regulates petroleum and chemical Underground Storage Tanks (USTs) that are 10 percent or more beneath the surface of the ground. All USTs are required to be registered with the Agency except for: (a) Tanks less than 1100 gallons containing fuel oil (#2-#6) which is used for on premises heating and domestic hot water, and (b) farm and residential tanks less than 1100 gallons containing motor fuel which is used for noncommercial purposes. In addition, certain

registered USTs are required to have permits for their operation and are subject to other operational standards. All USTs are subject to closure (removal) requirements upon being taken permanently out of service. For additional information contact the Vermont DEC at (802) 241-3888.]

-add- section 69.1.1.4 **Record of Installation for LP Gas Containers:** Installers shall maintain a record of all installations for which a permit is not required by section 69.1.1.3, but not including replacing of portable cylinders, available for inspection by the AHJ.

- add- section 69.3.2.6.5 LP Gas, Container Valves: Containers over 4,000 gallon (15.2m³) water capacity shall be equipped as required in section 58:2.3.3.2(b) (1) & (2). Internal valves with pneumatic shut-offs, or other approved safety designs, shall be required for new installations. [58:2.3.3.2(b) is amended by this section]

-delete & replace- section 69.3.2.4.2 **LP Gas Systems, Protection from Damage:** Where physical damage to LP Gas containers or systems of which they are a part, from vehicles is a possibility, physical protective barriers shall be provided to protect against such damage. [58:3.2.4.2 is deleted & replaced by this section]

-add- section 69.3.2.4.2.1 **Underground LP Gas Systems, Protection from Damage:** Where containers are installed underground within 10' of where vehicular traffic can be expected, physical protective barriers shall be provided for the fitting housing, housing cover, tank connections, and piping, to protect against vehicular damage. All other underground containers shall be provided with a reflective marker or other readily visible marker acceptable to the authority having jurisdiction, at 4' in height to mark the location of the housing cover. [58:3.2.9.1(c) is deleted & replaced by this subsection]

-delete & replace- Section 70.1.2.1 Permits for Oxidizers and Organic Peroxides: A permit is not required for an existing facility that is in compliance with reporting requirements under the Vermont Community Right to Know Law, Title 20 V.S.A. Chapter 1.

(b) National Fire Protection Association standard **NFPA 101, Life Safety Code**, 2003 edition, including those standards referenced in Chapter 2, that shall be considered part of this Code.

-delete & replace in part- section 2.2 National Electrical Code & Residential Electrical Safety Code: Any reference to NFPA 70 and 73 in this Code shall

be to the edition adopted by the Vermont Electricians Licensing Board.

-delete & replace in part - section 2.2 Reference Publications: Any reference to NFPA 5000, Building Construction and Safety Code, 2003 Edition, shall be to the International Building Code, 2003 edition, as amended in this code

-delete & replace in part- section 2.3.4 Safety Code for Elevators: Any reference to ASME 17.1 or 17.3 in this Code shall be to the edition adopted by Vermont Elevator Safety Review Board.

-delete & replace- section 3.3.152.7 Definition of **Health Care Occupancy:** An occupancy used for purposes of medical or other treatment or care of three or more persons where such occupants are mostly incapable of self-preservation due to age, physical or mental disability, or because of security measures not under the occupant's control.

-delete & replace- section 3.3.152.13 Definition of **Residential Board & Care Occupancy:** A building or portion thereof that is used for lodging or boarding of three or more residents, not related by blood or marriage to the owners or operators, for the purpose of providing personal care services.

-add- section 7.1.10.1.1 Clearance for **Inclined Lifts on Stairways:** Where a platform or chair lift is installed on an exit stair in an existing building the minimum clear width on the stair when the inclined lift is in the down position shall be

- 18" when the stair serves fewer than 10 people
- 22" where the stair serves fewer than 50 people
- as required by this Code when the stair serves 50 or more people

Where a platform or chair lift is installed on an exit stair in a new building the minimum clear width on the stair when the inclined lift is in the down position shall be as required by this Code.

-delete & replace- section 7.2.2.6.5 Outside Stairs, Accumulation of Snow, Ice or Water: New outside stairs and landings, other than the primary entrance, shall be designed to minimize the accumulation of snow, ice and water by a roof or other approved means. [cross reference to 1:14.4.1.1]

-cross-reference- amendments to NFPA 54, Fuel Gas Code, and NFPA 58, LP Gas Code, 1: 11.5.1.4

-add- section 7.12.3 **Boiler Room Exits:** Two means of egress shall be provided for boiler rooms exceeding 500 sq. ft. floor area and containing one or more boilers having a fuel capacity of 1,000,000 BTU/HR or more. Each elevation shall be provided with at least two means of egress, each to be remotely located from the other. A platform at the top

of a single boiler is not considered an elevation.
[reference NBIC I-2341]

-delete & replace- section 9.1.2 **Electrical Systems:** All electrical wiring and equipment shall installed and maintained in accordance with NFPA 70, National Electrical Code and NFPA 73, Residential Safety Code, as adopted by the Electricians' Licensing Board.

-delete & replace- section 9.6.2.10.2 **Power for Smoke Alarms:** All newly installed smoke alarms in one & two family dwellings, multiple unit dwellings, lodging or rooming houses, hotels and dormitories shall be directly wired to a non-dedicated electrical branch circuit for the building and by battery.

- delete & replace- section 9.6.4.2 Means of Emergency Forces Notification: Where fire department notification is required by another Section of this *Code*, the fire alarm system shall be arranged to transmit the alarm automatically via the most acceptable means available and in accordance with NFPA 72, *National Fire Alarm Code*.

Listed in order by the most acceptable to the least acceptable means of notification:

- (1) Fire Department Master or Radio Box.
 - (2) Leased direct line to the Fire Department.
 - (3) Leased direct line to the Police Department or dispatching agency for the Fire Department.
 - (4) Approved Central Station - UUFEX providing protective signaling services.
 - (5) Approved Central Station - CVSU providing monitoring services.
 - (6) Proprietary system.
 - (7) Recognized remote station.
 - (8) Digital dialer connected to approved remote station.
 - (9) Listed commercial digital dialer.
- [1:13.7.1.4.11.2 is deleted & replaced by this subsection]

-cross-reference- section 9.7.1 Back Flow Prevention for Existing Sprinkler Systems to 1:13.3.1.3.2

-delete & replace- section 9.7.4.1 **Portable Fire Extinguishers:** Portable fire extinguishers shall be located, installed, inspected and maintained in accordance with NFPA 1 section 13.6.

-add- section 9.9.1 **Carbon Monoxide Detection:** Where required by another section of this *Code* carbon monoxide alarms (detectors) shall be installed in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide Warning (CO) Equipment in Dwelling Units, 2005 edition. NFPA 720 covers the selection, application, installation, location, testing and maintenance of carbon monoxide warning equipment in all buildings in

which people sleep. [section 720:1.1.2 is amended by this section]

-add- section 9.9.2 **Power for Carbon Monoxide Alarms:** All newly installed carbon monoxide alarms (detectors) in multiple unit dwellings, lodging or rooming houses, hotels and dormitories, or other buildings in which people sleep, shall be directly wired to a non-dedicated electrical branch circuit for the building and by battery. Carbon monoxide detectors in existing one-two family dwellings shall be permitted to be powered by any approved source. [for existing construction see section 7 for transition effective date]

-add- section 12.3.5.4 New Assembly Occupancies: In addition to the fire sprinkler requirements of 101:12.1.6 & 101:12.3.5 all assembly occupancies where the occupant load exceeds 100, identified as bars, dance halls, discotheques, **nightclubs** or where festival seating is used, shall be protected throughout by an approved, supervised, automatic fire sprinkler system.

-cross-reference- section 13.1 Permit for Place of Assembly with Change of Ownership to 1:4.5.7.3

-add- section 13.3.5.4 Existing Assembly Occupancies: In addition to the fire sprinkler requirements of 101:13.1.6 & 101:13.3.5 all assembly occupancies where the occupant load exceeds 100, identified as bars, dance halls, discotheques, **nightclubs** or where festival seating is used, shall be protected throughout by an approved, supervised, automatic fire sprinkler system (see section 7 for transition effective date)

[Bars, dance halls, discotheques, nightclubs and the use of festival seating (where no seating other than the floor is provided for the audience) are characterized by some or all of the following: a high density of people, alcohol consumption, late operating times, live or recorded entertainment, dance areas, low lighting levels and stage or platform areas for performing. A theater or opera house with fixed seating is not classified under this section]

-delete & replace- section 14.7.2.2(1) Emergency Egress and Relocation Drills: Not less than one emergency egress and relocation drill, in accordance with the school's emergency preparedness plan, shall be conducted every month the facility is in session.

-delete & replace- section 15.2.1.2 Student Occupied Space: Rooms normally occupied by preschool, kindergarten or first grade students shall be located on a level of exit discharge, unless otherwise permitted by 15.2.1.4. Rooms with 4 or fewer students, where the ratio of students to teachers or aides does not exceed 2:1 at any time, are not considered normally occupied by students in regards to this section.

-delete & replace- section 15.7.2.2(1) **Emergency Egress and Relocation Drills:** Not less than one emergency egress and relocation drill, in accordance with the school's emergency preparedness plan, shall be conducted every month the facility is in session.

-add - section 16.3.4.6 **Carbon Monoxide Detection in New Daycare:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in the immediate vicinity of each separate sleeping area.

-add - section 17.3.4.6 **Carbon Monoxide Detection in Existing Daycare:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in the immediate vicinity of each separate sleeping area.

-add - section 18.3.4.6 **Carbon Monoxide Detection in New Health Care:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in each nursing station.

-add - section 19.3.4.6 **Carbon Monoxide Detection in Existing Health Care:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in each nursing station.

-delete & replace- section 19.3.5.1 **Existing Health Care:** Existing health care facilities shall be protected throughout by an approved supervised automatic fire sprinkler system installed in accordance with section 9.7.

-add - section 22.3.4.5 **Carbon Monoxide Detection in New Detention and Correctional Facilities:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in control rooms used by the facility.

-delete- section 22.4.4 **Renovations for Existing Non-sprinklered Detention and Correctional Facilities**

-add - section 23.3.4.5 **Carbon Monoxide Detection in Existing Detention and Correctional Facilities:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in control rooms used by the facility.

-delete and replace- section 23.3.5.2 **Existing Detention & Correctional:** Existing detention & correctional facilities classified as Use Condition II, III, IV or V shall be protected throughout by an approved supervised automatic fire sprinkler system installed in accordance with section 9.7.

-add- section 24.1.1.1.1 **One & Two Family Dwellings used for Transient Lodging:** A building that provides sleeping accommodations for a total of

more than 6 people on a transient basis shall be classified as a lodging or rooming house or a hotel or dormitory under this code.

-add- section 24.2.2.3.1 **Existing Means of Escape:** The clear opening of an existing means of escape (*escape window*) under 24.2.2.3 (C) shall be permitted to be not less than 5.0 square feet.

-add- section 24.2.5.7 **Stair riser heights and tread depths:** Maximum riser heights of 7 ¾ in. and minimum tread depths of 10 in. shall be permitted in new construction.

-add - section 24.3.4.4 **Carbon Monoxide Detection, One-Two Family Dwellings:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 outside of each separate sleeping area in the immediate vicinity of the bedrooms. An additional carbon monoxide alarm (detector) shall be installed in any sleeping room that contains a fuel-burning appliance.

[Manufactured housing that is built on a chassis to conform to the Housing and Urban Development (HUD) Standard are preempted by that federal standard and not subject to additional requirements under this Code. Manufactured housing built to the HUD standard has an identification plate. Smoke detectors installed in accordance with NFPA 501:5.8 are considered in compliance with Title 9 V.S.A. Chapter 77. An owner may contact the U.S. Department of Housing and Urban Development (HUD) in Washington, D.C. at 1-800-927-2891 or the Consumer Assistance Program of the Vermont Office of Attorney General at 1-800-649-2424 for additional information.]

-delete & replace- section 24.5.1.2 **Unvented Fuel-fired Heaters:** Unvented room heaters and unvented fireplaces shall not be used.

-add- section 24.6 **Subdivision of Building Spaces in One-Two Family Dwellings:** New one-two family dwellings shall be provided with dwelling unit separation in accordance with 30.3.7.

-add- section 26.1.1.1.1 **Small Lodging & Rooming Houses:** A building that provides sleeping accommodations for a total of 6 or fewer persons, and is occupied by the proprietor, may be classified as a one and two family dwelling by the AHJ.

-add - section 26.3.3.5.4 **Carbon Monoxide Detection, Lodging & Rooming:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 outside of each separate sleeping area in the immediate vicinity of the bedrooms. An additional carbon monoxide alarm (detector) shall be installed in any bedroom that contains a fuel-burning appliance.

-delete- section 26.3.5.2 Exception for Automatic Sprinkler Protection for New Lodging & Rooming Houses with Direct Access

-delete & replace- section 26.5.2.2 Unvented Fuel-fired Heaters: Unvented room heaters and unvented fireplaces shall not be used.

-add - section 28.3.4.6 **Carbon Monoxide Detection in New Hotels & Dormitories:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in any section of corridor or common area that is in the immediate vicinity of sleeping rooms, or where there is no corridor, in each sleeping room. An additional carbon monoxide alarm (detector) shall be installed in any sleeping room that contains a fuel-burning appliance.

-delete - section 28.3.5.2 Exception for Automatic Sprinkler Protection for New Hotels & Dormitories with Direct Access

add- section 29.3.4.4 Detection for Existing Hotels & Dormitories: A corridor smoke detection system in accordance with section 9.6 shall be installed in existing hotels & dormitories other than those protected throughout by an approved supervised automatic sprinkler system in accordance with section 9.7.

-add - section 29.3.4.6 **Carbon Monoxide Detection in Existing Hotels & Dormitories:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in any section of corridor or common area that is in the immediate vicinity of sleeping rooms, or where there is no corridor, in each sleeping room. An additional carbon monoxide alarm (detector) shall be installed in any sleeping room that contains a fuel-burning appliance.

-delete & replace- section 30.3.4.5.2 **Smoke Alarms in Sleeping Rooms:** Approved smoke alarms shall be provided in each sleeping room in accordance with 9.6.2.10.

-add - section 30.3.4.6 **Carbon Monoxide Detection, New Apartment Buildings:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 outside of each separate sleeping area in the immediate vicinity of the bedrooms. An additional carbon monoxide alarm (detector) shall be installed in any bedroom that contains a fuel-burning appliance.

-delete & replace- section 30.5.2.2 Unvented Fuel-fired Heaters: Unvented room heaters and unvented fireplaces shall not be used.

-add - section 31.3.4.6 **Carbon Monoxide Detection, Existing Apartment Buildings:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 outside of each separate sleeping area in the immediate vicinity of the bedrooms. An additional carbon monoxide alarm (detector) shall be installed in any bedroom that contains a fuel-burning appliance.

-delete & replace- section 31.5.2.2 Unvented Fuel-fired Heaters: Unvented room heaters and unvented fireplaces shall not be used.

-add- section 32.1.1.2 **Assisted Living Facilities:** In addition to the requirements of this chapter a facility licensed under the Department of Aging & Disabilities Rules for Assisted Living Residences shall comply with the following:

(1) All facilities shall be fully sheathed (15 min. fire rating) in addition to having complete automatic fire sprinkler protection.

(2) Emergency lighting shall be provided for the means of egress and in the vicinity of doors equipped with delayed egress locks.

(3) & (4) (reserved)

(5) The fire alarm system shall provide emergency forces notification.

(6) All automatic fire sprinkler systems shall be electronically supervised.

(7) (reserved)

(8) Corridors for large facilities shall not be less than 48”.

(9) Subdivision of building spaces in accordance with 101:18.2.2.5 shall be provided in common areas of large facilities using the same criteria as used for limited care facilities (15 square feet per resident).

-add - section 32.1.1.2.1 **Carbon Monoxide Detection in New Residential Care:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in any section of a corridor or common area that is in the immediate vicinity of sleeping rooms.

-delete & replace- section 32.2.3.5.1 **New Residential Board & Care:** All new residential board & care facilities shall be protected throughout by an approved supervised automatic fire sprinkler system installed in accordance with section 9.7.

-delete- section 32.2.3.5.2 Exception for Sprinkler Protection for New Small Board and Care Facilities

-add - section 33.1.1.2.1 **Carbon Monoxide Detection in Existing Residential Care:** Carbon Monoxide alarms (detectors) shall be installed in accordance with section 9.9.1 and 9.9.2 in any section of corridor or common area that is in the immediate vicinity of sleeping rooms.

-delete & replace- section 33.2.3.4.3.1 **Smoke Alarms in Sleeping Rooms:** Approved smoke alarms shall be provided in each sleeping room in accordance with 9.6.2.10.

-delete- section 33.2.3.4.3.5 Exception for Smoke Alarms in Residential Care with Sprinkler Protection

-delete- section 33.2.3.4.3.6 Exception for Smoke Alarms in Residential Care with Sprinkler Protection – Battery Operated -

-add- section 38.2.4.2.1 **Single exit for New Small Business:** A single exit shall be permitted to be unenclosed in two-story buildings when the travel distance does not exceed 75' and all areas opening to the exit access stairs are provided with smoke alarms in accordance with 9.6.2.10.

-add- section 38.3.1.1(3) **Protection of Vertical Opening in New Small Business:** Unenclosed vertical openings shall be permitted to be unenclosed in two-story buildings when the travel distance does not exceed 75' and all areas opening to the exit access stairs are provided with smoke alarms in accordance with 9.6.2.10. -

-add- section 39.2.4.2.1 **Single Exit for Existing Small Business:** A single exit shall be permitted to be unenclosed in two-story buildings when the travel distance does not exceed 75' and all areas opening to the exit access stairs are provided with smoke alarms in accordance with 9.6.2.10. -

-add- section 39.3.1.1 (4) **Exception for Protection of Vertical Openings for Existing Small Business:** Exit access stairs shall be permitted to be unenclosed in two-story buildings when the travel distance does not exceed 75' and all areas opening to the exit access stairs are provided with smoke alarms in accordance with 9.6.2.10.

(c) National Board of Boiler and Pressure Vessel Inspectors, **National Board Inspection Code**, Part RA – RE, Appendix 1-9 and A-K, 2004 edition

-delete & replace- section I-3724(a) **Low Water Cutoff:** Each automatically fired low pressure hot water boiler shall have an automatic low-water fuel cutoff which has been designed for hot water service, and it shall be so located as to automatically cut off the fuel supply when the surface of the water falls to the level established in I-3724(b).

(d) International Code Council, **International Building Code (IBC)**, 2003 edition, including those standards referenced in Chapter 35 to the prescribed extent of each reference by adopted sections of the IBC. The IBC is adopted to the extent necessary to ensure compliance with the performance

requirements of this *Code* and the intent of this *Code* regarding safeguarding of people and property in case of fire, explosion, dangerous structural conditions and the generation of carbon monoxide.

-delete- chapter 1 Administration except for section 106.3.4 and the following sections:

-delete & replace- section 101.4 Referenced Codes: Where referenced under the IBC any reference to the:
* **ICC Electrical Code**, shall be to the National Electrical Code, NFPA 70, as adopted by the Electricians Licensing Board

* **International Fuel Gas Code**, shall be to the National Fuel Gas Code, NFPA 54, 2002 edition, as adopted under this *Code*

* **International Mechanical Code**, shall be to the Uniform Fire Code, NFPA 1, 2003 edition, including NFPA 90A, as adopted under this *Code*

* **International Plumbing Code** shall be as adopted by the Plumbers Examining Board

* **International Property Maintenance Code**, shall be to the Uniform Fire Code, NFPA 1, 2003 edition and the Life Safety Code, NFPA 101, 2003 edition, as adopted under this *Code*

* **International Fire Code**, shall be to the Uniform Fire Code, NFPA 1, 2003 edition, as adopted under this *Code*

* **International Energy Code**, shall be to the Vermont Guidelines for Energy Efficient Construction, as published by the Vermont Department of Public Service, and shall only apply to new state-funded buildings or additions

* **International Residential Code**, or to R-3 Occupancy Classification for one & two family dwellings, shall be to the Life Safety Code, NFPA 101, 2003 edition as adopted under this *Code*

-delete & replace- section 105 Construction Permits: Permits shall be obtained in accordance with section 4 of the Vermont Fire & Building Safety Code

-delete & replace- section 308.2 Group I-1, Residential Board & Care Facilities: Assisted Living Facilities and similar use: Residential care facilities, assisted living facilities and similar use in which three or more clients receive care shall be classified and regulated in accordance with the Life Safety Code, NFPA 101, and the IBC, chapter 16.

-delete & replace- section 308.5 Day Care Facilities: Day care facilities in which four or more clients receive care shall be classified and regulated in accordance with the Life Safety Code, NFPA 101, and the IBC, chapter 16.

-delete & replace- section 310.1 R-3 Detached **one & two Family Dwellings:** Detached one & two family dwellings shall be classified and regulated in accordance with the Life Safety Code, NFPA 101.

-delete & replace- section 415.9.1 Protection of **Semiconductor Fabrication Facilities**: In addition to requirements set elsewhere in this code semiconductor fabrication facilities shall be in accordance with the Uniform Fire Code, NFPA 1, and NFPA 318.

- Construction Correlation Table -

96 NBC 03 IBC 101/1 NFPA

1A	none	I(443)
1B	IA	I(332)
2A	IB	II(222)
2B	IIA	II(111)
2C	IIB	II(000)
3A	IIIA	III(211)
3B	IIIB	III(200)
4	IV	IV(2HH)
5A	VA	V(111)
5B	VB	V(000)

-delete & replace- section 506.2.2 Open Space for Area Increase: Such open space shall be either on the same lot or dedicated for public use, clear and unobstructed at all times, usable for fire department operations and accessed from a street or fire department access road in accordance with NFPA 1: chapter 18.

-add- section 507.10 Open Space for Unlimited Area Buildings: Open space required under section 507 shall be either on the same lot or dedicated for public use, clear and unobstructed at all times, usable for fire department operations and accessed from a street or fire department access road in accordance with NFPA 1: chapter 18.

-delete & replace- section 705 **Fire Walls**: The design and construction of new firewalls shall be in accordance with NFPA 1:12.3 and NFPA 221. The minimum fire resistance ratings of firewalls located in a building with a complete automatic sprinkler system shall be two hours and the minimum fire resistance ratings of firewalls located in a building without a complete automatic sprinkler system shall be three hours.

-delete & replace- chapter 8 Interior Finishes: Interior finishes shall be in accordance with the Life Safety Code, NFPA 101, as adopted under this *Code*.

-delete & replace- chapter 10 Means of Egress: Means of Egress shall be in accordance with the Life Safety Code, NFPA 101, as adopted under this *Code*.

-delete & replace- chapter 11 **Accessibility**: All new construction and alterations shall be in accordance with the “Accessibility in Public Buildings - Rules for New Construction and for Alterations to Existing Buildings” as adopted by the Vermont Access Board and 20 V.S.A. 2907 regarding residential construction.

-delete- chapter 12 Interior Environment except for section 1209 Access to Unoccupied Spaces

-delete- & replace- chapter 13 **Energy Efficiency**: New state-funded buildings or additions shall be designed in accordance with the Vermont Guidelines for Energy Efficient Construction, as published by the Vermont Department of Public Service. *[The Department of Public Service provides technical assistance and expert advice regarding the energy standard requirements for new construction. This includes criteria that builders may use in lieu of computer or systems analysis of the building. For additional information contact the Vermont Department of Public Service at 1-888-373-2255.]*

-add- section 1608.2.1 Local **Snow Load**: The Minimum Ground Snow Load Map and the Average Yearly Snowfall Map shall be used in determining the ground snow load. *[The snow load map is located in the Annex to this Code]*

-add- section 1608.3.6 Minimum **Snow Load**: The resultant flat roof snow load on a roof with a slope equal to or less than 5 degrees shall not be less than 40 pounds/square foot.

-delete & replace- sections 2111 through 2113: Masonry Fireplaces, Heaters and Chimneys: Masonry fireplaces, heaters and chimneys shall be in accordance with the Standard for Chimneys, Fireplaces, Vents and Solid Fuel-Burning Appliances, NFPA 211, as adopted under this *Code*

-delete & replace- chapter 27 **Electrical**: Electrical components, equipment and systems shall be in accordance with the National Electrical Code, NFPA 70, as adopted by the Electricians’ Licensing Board

-delete & replace- chapter 28 **Mechanical Systems**: Mechanical equipment and systems shall be installed in accordance with the Uniform Fire Code, NFPA 1, including NFPA 90A as adopted under this *Code*.

-delete & replace- chapter 29 Plumbing Systems: Plumbing work is regulated under the International Plumbing Code as adopted by the Plumbers Examining Board.

-delete & replace- chapter 30 **Elevators** and Conveying Systems, except sections 3002.1, Hoistway Enclosure Protection, 3004, Hoistway Venting and 3006, Machine Room Enclosure: Elevator and conveyance work is regulated under the Elevator Safety Rules as adopted by the Elevator Safety Review Board.

-delete- section 3108 Radio and television Towers

-delete- section 3109 Swimming Pool Enclosure and Safety Devices

-delete- chapter 32 Encroachments into the Public Right-of-Way

-delete & replace - chapter 33 Safeguards During Construction: Safety during construction shall be in accordance with the Standard for Safeguarding Construction, Alteration and Demolition Operations, NFPA 241, as adopted under this *Code*.

-delete & replace- chapter 34 **Existing Buildings**: Existing buildings shall be in accordance with section 3403.2, the Life Safety Code and the Uniform Fire Code. An existing building plus additions shall comply with the height and area provisions of Chapter 5.

Section 3.

Boiler and Pressure Vessel Inspection

(a) A boiler is defined as a closed vessel in which water is heated, steam is generated, steam is super heated, or any combination thereof, under pressure or vacuum by the direct application of heat from the combustion of fuel or from electricity. The term includes a fired unit for the heating or vaporizing of liquids other than water where the unit is separate from a processing system and is complete within itself. An unfired pressure vessel is defined as a container of pressure obtained from an external source that exceeds 15 psi. This section shall apply to all boilers, and pressure vessels identified in the National Board Inspection Code except:

(1) A boiler or pressure vessel located on a common carrier subject to regulations under the Surface Transportation Board, Department of Transportation, Federal Railroad Administration or Nuclear Regulatory Commission.

(2) Pressure containers that are integral parts or components of rotating or reciprocating mechanical devices such as pumps, compressors, turbines, generators, engines and hydraulic or pneumatic cylinders where the primary design consideration and /or stress is derived from the functional requirements of the device.

(3) Hot **water heaters** and portable water storage tanks with a heat input of less than 200,000 BTU/HR, water temperature less than 210 degrees (F) and less than 120 gallons aggregate water capacity. Units otherwise exempted under this section shall be equipped with approved pressure/temperature safety relief devices in accordance with NBIC I 3837.

(4) Steam cleaners or coil type boilers without steam space where water flashes into steam when manually released through a nozzle for cleaning machinery, equipment, etc.; when the water capacity is less than 6 gallons and the water temperature less than 350 degrees (F). Units otherwise exempted under this section shall be equipped with approved pressure/temperature safety relief devices in accordance with NBIC.

(b) All boilers and pressure vessels shall be manufactured, constructed and assembled in accordance with the appropriate American Society of Mechanical Engineers (**ASME**) **standards**, or equivalent standard recognized by the National Board of Boiler & Pressure Vessel Inspectors, in place at the time of manufacture. The manufacturer of a boiler or pressure vessel shall register the type of unit with the National Board of Boiler and Pressure Vessel Inspectors.

(c) The owner or person installing a boiler or pressure vessel shall report to the AHJ the location, type, capacity, age and date of installation of any boiler or pressure vessel.

(d) Prior to being placed in service **any boiler or pressure vessel shall be inspected** by a commissioned inspector. When the boiler or pressure vessel is found to be in compliance with this *Code* the commissioned inspector shall attach an identification number, approved by the AHJ, and an initial inspection certificate issued by the AHJ. The inspection certificate shall be posted at the site of operation. The identification number, initial inspection by a commissioned inspector and operating certificate shall not be required for boilers designed to heat individual dwelling units in buildings containing less than 6 dwelling units.

(e) The **periodic inspection of boilers and pressure vessels** shall be performed by a commissioned inspector at intervals listed in this section. A commissioned inspector may require additional external (an inspection made when a boiler or pressure vessel is fully intact so all safety features can be inspected) or internal (an inspection made when a boiler or pressure vessel is shut down and handholes, manholes or other inspection openings are opened for inspection of the interior) inspections when unsafe conditions or operations are observed or suspected. The AHJ may order the owner or user to stop operation of a boiler or pressure vessel operating in violation of this *Code*.

(1) Each high pressure power boiler in which steam is generated at a pressure of more than 15 pounds per square inch shall be inspected both internally and externally while not under pressure on an annual basis, and externally, while under pressure, approximately six months from the internal inspection.

(2) Each low-pressure hot water heating boiler installed to operate at pressures not to exceed 160 pounds per square inch and/or temperatures not exceeding 250 degrees (F), and each steam heating boiler operating at a pressure not exceeding 15 pounds per square inch, shall be inspected externally, and internally where construction permits, every two years. An inspection shall not be required for boilers designed to heat individual dwelling units in buildings containing less than 6 dwelling units.

(3) Each pressure vessel greater than 5 cubic feet and operating with a relieving pressure greater than 125 pounds per square inch shall be inspected externally, and internally where construction permits, every three years. An internal inspection is not required for a rubber lined pressure vessel.

(f) An employee of an insurance company, licensed to insure boilers and pressure vessels in Vermont, shall obtain a current Vermont commission to inspect boilers and pressure vessels prior to conducting any inspections. A current certification from the National Board of Boiler and Pressure Vessel Inspectors is required to obtain a Vermont commission. A Vermont commission may be revoked or suspended for violation or misrepresentation of responsibilities established under this *Code*. A person who has a Vermont commission revoked or suspended shall be given written notification and the opportunity for a hearing following due process.

(g) An employee of an insurance company, licensed to insure boilers and pressure vessels in Vermont, who has obtained a Vermont commission, and/or the insurance company, licensed to insure boilers and pressure vessels in Vermont shall:

(1) Inspect all boilers and pressure vessels insured by the insurance company in accordance with this *Code* and at time frames established under this *Code*.

(2) Report the results of all inspections to the AHJ within 30 days of the inspection in a format approved by the AHJ.

(3) Notify the AHJ of new boilers or pressure vessels insured, insurance cancelled or not renewed or refused within 30 days.

(4) Participate in training as may be directed by the AHJ.

(5) Not engage in the sale of, or have any interest in, any appliance or device related in any way to the construction, operation or maintenance of boilers and pressure vessels covered under this *Code*.

(h) The owner, user or commissioned inspector shall immediately **report any accident, incident or explosion** involving a boiler or pressure vessel that involves personal injury to the AHJ at 1-800-347-0488 and secure the scene to prevent any change that would hamper the investigation of the incident. Where the accident, incident or explosion does not involve personal injury the report shall be made within 48 hours.

(i) The insurance company of record shall pay a fee of \$20.00 to the Division of Fire Safety for each **inspection certificate** or periodic inspection sticker

Section 4.

Application for a Construction Permit

(a) The owner, or a designated representative, of a building or premises shall obtain a construction permit before beginning any construction, addition, alteration, demolition or installation of fixed building equipment at the building site unless specifically waived by the AHJ.

(b) To obtain a construction permit the applicant shall:

(1) Complete a Construction Permit Application form and submit it along with the required construction permit fee to the Division of Fire Safety regional office.

(2) Provide construction documents relating to the construction work and equipment under consideration unless specifically waived by the AHJ based on the size, use, occupancy or complexity of the work.

(3) For buildings where the applicant is requesting special consideration for a **historic building, documentation** shall be included on the historic designation of the building, including identification and evaluation of historic adjacent structures and site elements such as sheds, walkways, and fencing; historic construction features such as sheathing, facade or roofing materials, chimneys, skylights, cornices or molding, windows or doors, wainscoting, cabinets and finishes; and historic spaces such as archways, lobbies or rooms which are important to the understanding and application of the building.

(c) The **construction documents shall include an express certification that the design meets or exceeds this code** as indicated in the following sections. Construction documents stamped and signed by an architect or professional engineer consistent with the professional licensing and registration laws of Vermont meets the intent of this section without additional certification.

(1) For new state-funded buildings and additions; certification indicating compliance with the "Vermont Guidelines for Energy Efficient Commercial Construction" as published by the Department of Public Service.

(2) For new buildings and additions; certification indicating the building is designed to prevent normally anticipated unstable or dangerous structural conditions.

(d) Plans required under this *Code* shall be drawn to scale, using customary inch-pound units and English language, and shall be sufficiently clear, comprehensive, detailed and legible when submitted to the AHJ so that, together with any accompanying specifications and data, the AHJ can readily determine whether or not the proposed building, addition, or alteration, and all proposed building equipment will conform to this *Code*.

(e) The AHJ shall review the application for a construction permit and the construction

documents where applicable and shall issue a permit, a conditional permit with specific terms and conditions, or deny the application. The AHJ may require additional information before issuing, or denying the application for a construction permit. Any conditions of the permit or reasons for denial of the permit shall be transmitted to the applicant in writing.

(f) The AHJ may provide consultation or preliminary plan review for proposed construction to identify high priority code issues when deemed warranted by the significance or complexity of the project.

(g) A construction permit shall expire if the work authorized under the permit is not commenced, or is suspended or abandoned, for a time period of 12 months.

(h) Construction permit fees are established by the Vermont Legislature under Title 20 V.S.A. section 2731. The current construction permit fees are available on the Division's website or by contacting any office of the Division.

(1) The Commissioner or designated representative may rebate up to \$2,000 of the construction permit fee paid the department toward the cost of a qualified fire sprinkler system installed in an existing building in a designated downtown area.

(2) In the case of abandonment or discontinuance of a building project involving a construction permit fee greater than \$150 the construction permit fee may be refunded, upon written request to the AHJ, prorated on construction work, services, reviews and inspections conducted prior to such abandonment. Such request shall be received within 12 months of the date that the construction permit was issued.

(3) The AHJ may refuse to issue a construction or occupancy permit if the owner or a designated representative owes the Department fees or penalties.

(j) The AHJ shall be authorized to require the owner to engage, and designate on the construction permit application, a registered design professional who shall act as the **design professional in responsible charge** in accordance IBC 106.3.4, who shall be responsible for reviewing and coordinating submittal documents prepared by others for compatibility with the approved design of the building.

(k) The AHJ shall be authorized to order all, or part of, work regulated under this *Code* to stop when the work is unsafe or being performed contrary to the provisions of this *Code*.

Section 5.

Variance, Exemption and Reconsideration

(a) The Commissioner may grant a variance approving a different solution to compliance that meets the intent of this code, or may exempt a portion of a building, or equipment including non-standard boilers and pressure vessels, from the requirements of this Code. It is the policy of the Commissioner that whenever possible the determination of a variance or exemption request be made by the Regional Managers or Chief Fire Prevention Officer.

(b) In order for a variance or exemption request to be reviewed the owner or designated representative shall submit:

1. Evidence that the proposed or existing building or premises is not in compliance with this Code.
2. Evidence, letters, statements, test results, construction documents, computations, chemical and physical properties or other supporting information as prepared by licensed or certified professionals that is required to justify the request.
3. Evidence that strict compliance with the Code would entail practical difficulty, unnecessary hardship or otherwise found unwarranted.
4. Evidence that any such variance or exemption secures the public safety and health and that the methods, means or practices proposed provide equal protection of the public safety and health.

(c) Review of the variance or exemption request shall consider evidence that the code or standard from which the variance or exemption is sought has not been promulgated as a rule or standard under the Vermont Occupational Safety and Health Act.

(d) The determination on the variance or exemption request shall be made in writing to

the applicant and shall advise the applicant of the reconsideration process as contained in Section (e).

(e) The Director may reconsider an interpretation or decision made by a designated representative pursuant to this Section. To request reconsideration the owner or designated representative shall submit a written request including:

1. Evidence the proposed or existing building or premises is not in compliance with this Code.
2. Evidence, letters, statements, test results, construction documents or other supporting information as required to justify the request.
3. Evidence that the true intent of the Code has been incorrectly interpreted, or the provisions of the Code do not fully apply; or the decision is unreasonable or arbitrary as it applies to alternatives or new materials.

(f) The request for reconsideration shall be submitted no later than 30 days after receiving the variance or exemption decision.

(g) A request for variance, exemption, or reconsideration shall not relieve a person from complying with this *Code*, permit or occupancy requirements, unless the Commissioner expressly authorizes an extension of compliance period pending review of the request.

(h) A request for a variance relating to access to a public building for people with disabilities shall be referred for decision to the Access Board established under Title 20 V.S.A. chapter 174.

(i) A request for a variance from this *Code* for historical buildings that is not resolved under section 5(a) shall be determined by the Historic Variance Appeals Board as established by 20 V.S.A. 2732.

Section 6.

Municipal Enforcement and Coordination

(a) Each municipality shall provide information regarding building permits issued by the municipality to the AHJ upon request.

(b) The Commissioner may assign the responsibility for the enforcement of all or part of these rules to municipalities that meet the qualifications established in 20 V.S.A. sections 2736 and 2884.

(c) Any fire, building or similar code standards adopted by any municipality shall be consistent with the standards adopted under this *Code*.

effect of making void or illegal any of the other parts or provisions of these rules. Under section 2 of this *code* certain Vermont amendments have been cross-referenced for clarity and ease of use. Failure to cross-reference an amendment does not affect the enforcement of that amendment.

(e) Upon adoption of the Vermont Fire & Building Safety Code - 2005 the “Vermont Fire Prevention and Building Code – 1999” and the “1990 Vermont Boiler & Pressure Vessel Rules” are repealed.

Section 7.

Effective Dates and Severability

- (a) (a) These rules shall take effect October 22, 2005 and shall be known as the Vermont Fire & Building Safety Code - 2005.
- (b) (b) To achieve an orderly transition for compliance with these rules:
 - NFPA 1 section 29.1.3 shall take effect October 1, 2006
 - NFPA 101 section 9.9.2 shall take effect October 1, 2007
 - NFPA 101 section 13.3.5.4 shall take effect October 1, 2007 where the occupant load exceeds 300
 - NFPA 101 section 13.3.5.4 shall take effect October 1, 2009 where the occupant load exceeds 100
- (c) This *Code* shall not require changes in the construction documents or construction of a building or portions of a building for which a construction permit has been issued and construction has started within 90 days of the effective date of this *Code*, or as otherwise approved by the AHJ, provided that the building or portions of the building meet or exceed the requirements for existing buildings under this *Code*.
- (d) In the event any part or provision of these rules is held to be illegal, this shall not have the

Annex I – Excerpts from Vermont Law Pertaining to the Vermont Fire & Building Safety Code

Chapter 173: PREVENTION AND INVESTIGATION OF FIRES

§ 2729. General provisions

- (a) A person shall not build or cause to be built any structure that is unsafe or likely to be unsafe to other persons or property in case of fire or generation and leakage of carbon monoxide.
- (b) A person shall not maintain, keep or operate any premises or any part thereof, or cause or permit to be maintained, kept, or operated, any premises or part thereof, under his or her control or ownership in a manner that causes or is likely to cause harm to other persons or property in case of fire or generation and leakage of carbon monoxide.
- (c) On premises under a person's control, excluding single family owner-occupied houses and premises, that person shall observe rules adopted under this subchapter for the prevention of fires and carbon monoxide leakage that may cause harm to other persons or property.
- (d) Any condominium or multiple unit dwelling using a common roof, or row houses so-called, or other residential buildings in which people sleep, including hotels, motels, and tourist homes, excluding single family owner-occupied houses and premises, whether the units are owned or leased or rented, shall be subject to the rules adopted under this subchapter and shall be provided with one or more carbon monoxide detectors, as defined in 9 V.S.A. section 2881(3), properly installed according to the manufacturer's requirements..

§ 2730. Definitions

(a) As used in this subchapter, "**public building**" means:

- (1)(A) a building owned or occupied by a public utility; hospital; school; house of worship; convalescent center or home for the aged, infirm, or disabled; nursery; kindergarten; or day care;
- (B) a building in which two or more persons is employed, or occasionally enter as part of their employment or are entertained, including private clubs and societies;
- (C) a cooperative or condominium; [*A condominium is described as a building or complex in which units of property, such as apartments, are owned by individuals and common parts of the property, such as the grounds and building structure, are owned jointly by the unit owners. A unit in such a complex.*]
- (D) a building in which people rent accommodations, whether overnight or for a longer term;
- (E) a restaurant, retail outlet, office or office building, hotel, tent, or other structure for public assembly, including outdoor assembly, such as a grandstand;
- (F) a building owned or occupied by the state of Vermont, a county, a municipality, a village, or any public entity, including a school or fire district.
- (2) Use of any portion of a building in a manner described in this subsection shall make the entire building a "public building" for purposes of this subsection. For purposes of this subsection, a "person" does not include an individual who is directly related to the employer and who resides in the employment-related building.

(b) The term "public building" does not include:

- (1) an owner-occupied single family residence, unless used for a purpose described in subsection (a) of this section;
- (2) a family residence registered as a day care home under chapter 35 of Title 33, or specifically exempted from registration by subdivision 3502(b)(1) of Title 33;
- (3) farm buildings on a working farm or farms. For purposes of this subchapter and subchapter 3 of this chapter, the term "working farm or farms" means farms with fewer than the equivalent of 10 full-time employees who are not family members and who do not work more than 26 weeks a year. In addition, the term means a farm or farms:
 - (A) whose owner is actively engaged in farming; or
 - (B) if the farm or farms are owned by a partnership or a corporation, one which includes at least one partner or principal of the corporation who is actively engaged in farming;

(C) where the farm or farms are leased, the lessee is actively engaged in farming. The term "farming" means:

(i) the cultivation or other use of land for growing food, fiber, Christmas trees, maple sap, or horticultural and orchard crops;

(ii) the raising, feeding, or management of livestock, poultry, equines, fish, or bees;

(iii) the production of maple syrup;

(iv) the operation of greenhouses;

(v) the on-site storage, preparation, and sale of agricultural products principally produced on the farm. Notwithstanding this definition of farming, housing provided to farm employees other than family members shall be treated as rental housing and shall be subject to the provisions of this chapter. In addition, any farm building which is open for public tours and for which a fee is charged for those tours shall be considered a public building.

(4) a single family residence with an **accessory dwelling unit** as permitted under subdivision 4406(4)(D) of Title 24. *[reference 24 vsa 4412(E) An accessory dwelling unit is an efficiency or one-bedroom apartment that is clearly subordinate to a single-family dwelling, and has facilities and provisions for independent living, including sleeping, food preparation, and sanitation, and does not exceed 30 percent of the total habitable floor area of the single-family dwelling.]*

(c) For the purpose of this subchapter, subchapter 3 of this chapter, and chapter 174 of Title 20, the words "premises," "building," and "structure," or any part thereof shall mean "public building" as defined in this section.

[Buildings classified as public buildings and owned by a federal agency are not exempt from state and municipal codes but there are limitations on how this Code is applied. 40 U.S.C.A, section 3312 requires that a federal agency consult with local code officials, submit plans for review and permit inspection of the construction project. The federal agency is required to give due consideration to any recommendations made by the local code official and build in compliance with nationally recognized building, electrical, fire, life safety and plumbing codes. A federal agency is exempt from any fees and no enforcement action can be brought against the federal agency for failure to comply with the law.]

(d) "**Historic building**" or "historic structure" means any structure which has been listed in the National Register of Historic Places or the state register of historic properties or which has been determined to be historically significant by the Vermont advisory council on historic preservation or which meets the standards adopted by the division for historic preservation pursuant to subsection 723(a) of Title 22.

(e) The phrase "damage or destroy the historic architectural integrity of the historic building or structure" means to have an undue adverse impact on historically significant features of the historic architectural integrity of the building.

§ 2731. Rules; inspections; variances

(a) The commissioner is authorized to adopt rules regarding the construction of buildings, maintenance, and operation of premises, and prevention of fires and removal of fire hazards, and to prescribe standards necessary to protect the public, employees, and property against harm arising out of or likely to arise out of fire.

(b) The commissioner shall conduct inspections of premises to assure that the rules adopted under this subchapter are being observed and may establish priorities for enforcing these rules and standards based on the relative risks to persons and property from fire of particular types of premises. The commissioner may also conduct inspections to assure that buildings are constructed in accordance with approved plans and drawings.

(c) The following fire prevention and building code fees are established:

(1) The permit application fee for a construction plan approval shall be:

(A) based on **\$4.50 per each \$1,000.00** of the total valuation of the construction work proposed to be done for renovation to buildings constructed before 1983, but in no event shall the permit application fee exceed \$135,000.00;

(B) based on **\$5.50 per each \$1,000.00** of the total valuation of the construction work proposed to be done for all other buildings, but in no event shall the permit application fee exceed \$135,000.00.

(2) When an inspection is required due to the **change in use** of a public building, the fee shall be \$25.00.

(3) The **proof of inspection fee** for fire suppression, alarm, detection, and any other fire protection systems shall be \$10.00.

(d) The commissioner shall make all practical efforts to process permits in a prompt manner. The commissioner shall establish time limits for permit processing as well as procedures and time periods within which to notify applicants whether an application is complete.

(e) The commissioner may grant variances or exemptions from rules adopted under this subchapter where strict compliance would entail practical difficulty, unnecessary hardship, or is otherwise found unwarranted, provided that:

(1) any such variance or exemption secures the public safety and health; and

(2) any petitioner for such a variance or exemption can demonstrate that the methods, means, or practices proposed to be taken in lieu of compliance with the rule or rules provide, in the opinion of the commissioner, equal protection of the public safety and health as provided by the rule or rules; and

(3) the rule or rules from which the variance or exemption is sought has not also been adopted as a rule or standard under subchapters 4 and 5 of chapter 3 of Title 21; and

(4) any such variance or exemption does not violate any of the provisions of chapters 3 and 20 of Title 26 or any rules adopted thereunder.

(f) The commissioner shall, in state-funded buildings or new additions to state-funded buildings on which construction is begun after June 30, 2001, meet the standards contained in "The Vermont Guidelines for Energy Efficient Commercial Construction" as published in its most recent edition by the department of public service.

(h) A building owner or contractor engaged in an older and historic renovation project may propose innovative, performance-based alternatives in lieu of strict fire and building code compliance. The commissioner shall consider such alternatives and shall accept those that provide equivalent protection of the public safety and health. A decision to accept or deny a proposed alternative shall be in writing and explain the reasons for accepting or denying the alternative.

(i)(1) The department approves stamped architectural plans by issuing a plan review letter. If, upon final inspection, the department requires structural changes, additional life safety modifications, or state-mandated accessibility modifications, and the modifications or changes are not the result of design or construction changes by the owner, the owner or architect:

(A) may apply for a variance or exemption as provided in subsection (e) of this section, section 2732 of this title, and section 2902 of this title; and

(B) if the variance or exemption request is denied, upon the completion of the structural changes or additional life safety, or state-mandated accessibility modifications, as the case may be, may apply to the commissioner for a reimbursement of some or all of the plan review fee paid for the project.

(2) The decisions of the commissioner, pursuant to this subsection, shall be final. The commissioner shall adopt rules to carry out the provisions of this subsection. This subsection shall not apply to design or construction changes necessary to comply with an alternative method of life safety code or state-mandated accessibility compliance requested by the owner after the plan review.

§ 2732. Historic variance appeals board; variances; exemptions

(a) An historic variance appeals board is created. The board shall consist of the following three members: the commissioner of public safety or designee, who shall be chair; the state historic preservation officer or designee; and a representative of the Vermont historic preservation community appointed by the governor. A board member who is not a state employee shall be entitled to compensation and expenses as provided by section 1010 of Title 32.

(b) The board shall hear and determine all requests for variances or exemptions from the rules adopted by the commissioner under this subchapter for historic buildings and structures. A request for a variance or exemption may be granted where an applicant has demonstrated that strict compliance would entail practical difficulty, or unnecessary hardship, or would damage or destroy the historic architectural integrity of the historic building or structure, or is otherwise found unwarranted, provided that:

(1) any such variance or exemption secures the public safety and health;

(2) any petitioner for such a variance or exemption can demonstrate that the methods, means, or practices proposed to be taken in lieu of compliance with the rule or rules provide, in the opinion of the board, equal protection of the public safety and health as provided by rule or rules;

(3) the rule or rules from which the variance or exemption is sought have not also been adopted as a rule or standard under subchapters 4 and 5 of chapter 3 of Title 21; and

(4) any such variance or exemption does not violate any of the provisions of chapters 3 and 20 of Title 26 or any rules adopted thereunder.

(c) The board may permit a person seeking a variance or exemption to phase in compliance with the rules adopted under this subchapter in lieu of or in addition to granting the variance or exemption requested. The period of phased in compliance shall be reasonable but shall state a date by which compliance shall be achieved.

(d) Any person seeking a variance or exemption for work involving an historic building shall file a written request with the commissioner. The request shall describe the rule or rules from which the variance or exemption is sought, the reasons why a variance or exemption is sought, and a description as to how any alternative means of protecting the public safety and health is to be provided. The board shall meet and consider such requests within 15 working days of the request being filed with the commissioner. In deciding whether to grant or deny the request, the board shall take testimony or receive information from the applicant or his or her representatives, and from fire safety division staff. A decision of the board based on a majority vote of those members present shall be binding. The board shall issue a written determination granting or denying, in whole or in part, any variance or exemption request, or permission to phase in compliance, within 60 days of hearing the request. If a grant is conditional, the condition shall be clearly stated in writing. Failure to act on a request within 60 days shall be deemed approval of the request, provided that the public safety and health is not imminently threatened.

(e) The board may adopt, amend, or repeal procedural rules to carry out the provisions of this section.

(f) The board is attached to the department of public safety for administrative purposes.

(g) The board shall be subject to the requirements of subchapters 2 and 3 of chapter 5 of Title 1.

§ 2733. Orders to repair, rehabilitate, or remove structure

(a) Whenever the commissioner finds that premises or any part of them does not meet the standards adopted under this subchapter, the commissioner may order it repaired or rehabilitated. If it is not repaired or rehabilitated within a reasonable time as specified by the commissioner in his or her order, the commissioner may order the premises or part of them closed, if by doing so the public safety will not be imperiled; otherwise he or she shall order demolition and removal of the structure, or fencing of the premises. Whenever a violation of the rules is deemed to be imminently hazardous to persons or property, the commissioner shall order the violation corrected immediately. If the violation is not corrected, the commissioner may then order the premises or part of them immediately closed and to remain closed until the violation is corrected.

(b) Whenever a structure, by reason of age, neglect, want of repair, action of the elements, destruction, either partial or total by fire or other casualty or other cause, is so dilapidated, ruinous, decayed, filthy, unstable, or dangerous as to constitute a material menace or damage in any way to adjacent property, or to the public, and has so remained for a period of not less than one week, the commissioner may order such structure demolished and removed.

(c) Orders issued under this section shall be served by certified mail with return receipt requested or in the discretion of the commissioner, shall be served in the same manner as summonses are served under the Vermont Rules of Civil Procedure promulgated by the supreme court, to all persons who have a recorded interest in the property recorded in the place where land records for the property are recorded, including owners, tenants, mortgagees, attaching creditors, lien holders, and public utilities or water companies serving the premises.

§ 2734. Penalties

(a) A person who violates any provision of this subchapter or any order or rule issued pursuant thereto shall be fined not more than \$10,000.00. The state's attorney of the county in which such violation occurs shall prosecute the violation and may commence a proceeding in the superior court to compel compliance with such order or rule, and such court may make orders and decrees therein by way of writ of injunction or otherwise.

(b) A person who fails to comply with a lawful order issued under authority of this subchapter in case of sudden emergency shall be fined not more than \$20,000.00. A person who fails to comply with an order requiring notice shall be fined \$200.00 for each day's neglect commencing with the effective date of such order or the date such order is finally determined if an appeal has been filed.

(c) The commissioner may, after notice and opportunity for hearing, assess an administrative penalty of not more than \$1,000.00 for each violation of this subchapter or any rule adopted under this subchapter. Penalties assessed pursuant to this subsection shall be based on the severity of the violation. An election by the commissioner to proceed under this subsection shall not limit or restrict the commissioner's authority under subsection (a) of this section.

(d) Violation of any rule adopted under this subchapter shall be prima facie evidence of negligence in any civil action for damage or injury which is the result of the violation.

§ 2736. Municipal enforcement

(a) The legislative body of a municipality may appoint one or more trained and qualified officials and may establish procedures to enforce rules and standards adopted under subsection 2731(a) of this title. After considering the type of buildings within the municipality, if the commissioner determines that the training, qualifications and procedures are sufficient, he or she may assign responsibility to the municipality for enforcement of some or all of these rules and standards. The commissioner may also assign responsibility for enforcement of the rules of the access board adopted under section 2902 of this title. The commissioner shall provide continuing review, consultation, and assistance as may be necessary. The assignment of responsibility may be revoked by the commissioner after notice and an opportunity for hearing if the commissioner determines that the training, qualifications, or procedures are insufficient. The assignment of responsibility shall not affect the commissioner's authority under this subchapter.

(b) If a municipality assumes responsibility under subsection (a) of this section for performing any functions that would be subject to a fee established under subsection 2731(a) of this title, the municipality may establish and collect reasonable fees for its own use, and no fee shall be charged for the benefit of the state.

(c) Subject to rules adopted under section 2731 of this title, municipal officials appointed under this section may enter any premises in order to carry out the responsibilities of this section. The officials may order the repair, rehabilitation, closing, demolition, or removal of any premises to the same extent as the commissioner may under section 2732 of this title.

(d) Upon a determination by the commissioner that a municipality has established sufficient procedures for granting variances and exemptions, such variances and exemptions may be granted to the same extent authorized under subsection 2731(b) of this title.

(e) The results of all activities conducted by municipal officials under this section shall be reported to the commissioner periodically upon request.

(f) Nothing in this section shall be interpreted to decrease the authority of municipal officials under other laws, including laws concerning building codes and laws concerning housing codes

Current cooperative municipal inspection agreements include:

Barre - Responsibility for the enforcement of the Code for existing one-two family dwellings.

Bellows Falls - Responsibility for the enforcement of the Code for all existing public buildings except federally certified health care facilities, high-rise buildings, state owned buildings, and the testing and reporting of fire protection systems by technically qualified people.

Bennington - Responsibility for the enforcement of the Code for all new & existing public buildings except federally certified health care facilities, high-rise buildings, state owned buildings, and the testing and reporting of fire protection systems by technically qualified people.

Brattleboro - Responsibility for the enforcement of the Code for all existing public buildings except federally certified health care facilities, high-rise buildings, state owned buildings, and the testing and reporting of fire protection systems by technically qualified people.

Burlington - Responsibility for the enforcement of the Code for all new and existing public buildings except federally certified health care facilities, state owned buildings, and the testing and reporting of fire protection systems by technically qualified people.

Hartford - Responsibility for the enforcement of the Code for all new and existing public buildings except federally certified health care facilities, state owned buildings, and the testing and reporting of fire protection systems by technically qualified people.

Winooski - Responsibility for the enforcement of the Code for existing public buildings with selected uses.

§ 2737. Building permits

Each municipality shall provide to the commissioner upon request information regarding building permits issued by the municipality.

§ 2799. Definitions

As used in this subchapter:

(1) "Explosive material" includes "explosives," "explosive material," "blasting agents," and "detonators," as defined in section 841 of Title 18 of the United States Code, as amended at any time, and regulations promulgated thereunder.

(2) "Flammable material" means, in addition to its ordinary meaning, motion picture film.

(3) "Hazardous material" means any substance having such properties that it may spontaneously or acting under the influence of any thing contiguous or of any chemical or physical agency ignite or generate flammable or explosive vapors or gases to a dangerous extent.

(4) "Petroleum product" includes without limitation liquid petroleum gas, explosive flammable gases, and flammable fluids, compounds, or tablets, derived in whole or in part from petroleum.

§ 2800. Rules and standards

The commissioner may adopt rules and standards for explosion prevention, fire prevention, and public safety with respect to the safekeeping, storage, use, manufacturing, sale, handling, transportation, and other disposition of explosive materials, flammable materials, hazardous materials, petroleum, and petroleum products. The commissioner may prescribe the location, materials, and construction of buildings and other facilities to be used for these purposes.

§ 2801. Seizure of materials

Without warrant, the commissioner, a member of the state police, a sheriff, a deputy sheriff, a police officer, or a constable may seize materials held by a person in violation of rules adopted under this subchapter and hold the same subject to the order of the court taking jurisdiction of the offense.

§ 2802. Orders

After an inspection, the commissioner may issue an appropriate order to remove or abate a condition dangerous to persons or property involving explosive materials, flammable materials, or hazardous materials. This order shall be served on the owner or occupant of the premises on which the condition exists.

§ 2685. Record of fires

The fire marshal shall keep in his office a record of every fire occurring in this state which causes serious injury to any person or loss or damage to property in excess of \$200.00. He shall record all the facts concerning these fires, including statistics as to their extent and the damage caused thereby, and whether the losses were covered by insurance and, if so, in what amount. The record shall be made daily from the reports made to him under the provisions of this chapter. All such records shall be public, except information and testimony taken where arson is suspected.

§ 2833. Reports to fire marshal

(a) The chief of a volunteer or paid fire department or, if there is no fire department, the first selectman of a town, shall within five days of the occurrence of a fire within his jurisdiction which causes serious injury to any person or loss or damage to property which exceeds \$200.00, forward a report of the fire to the state fire marshal on forms to be furnished by him. If the reporting officer has reason to believe that a fire is of suspicious origin, he shall report that fact to the state fire marshal immediately. No fee shall be paid or allowed any officer for rendering the report required by this subsection.

(b) An officer referred to in subsection (a) of this section who wilfully neglects to comply with any of the requirements of this subchapter shall be fined not more than \$100.00.

§ 2881. General provisions

(a) A person shall not install or maintain a boiler or pressure vessel which is unsafe or likely to be unsafe to other persons or property.

(b) A person shall not operate, cause to be operated, or permit to be operated any boiler or pressure vessel under his or her control or ownership, in a manner which causes or is likely to cause harm to other persons or property.

§ 2882. Rules

The commissioner may adopt rules pertaining to boilers and pressure vessels, and standards to be observed, necessary for the safety and protection of the public, employees and property. All standards adopted by the commissioner shall conform to the codes of the American Society of Mechanical Engineers and the National Board of Boiler and Pressure Vessel Inspectors. The commissioner may provide for operating certificates to be issued before a boiler or pressure vessel may be used.

§ 2883. Inspections by insurance companies

The commissioner has authority to obtain specific information from boiler insurance companies, on forms furnished by them, which shall first be approved by the commissioner. The commissioner may authorize qualified inspectors in the employ of insurance companies to conduct inspections under his or her control and under such rules as the commissioner may prescribe. In case the inspection is made by such an inspector, no fee shall be charged, except a process fee of \$20.00 for issuance of an operating certificate.

§ 2884. Qualifications of inspectors

All boiler inspectors, employed by the state and insurance companies, shall have passed the examination required by the National Board of Boiler and Pressure Vessel Inspectors, and hold annual certification from such board.

§ 2885. Penalties

The commissioner may assess penalties pursuant to section 2734 of this title against a person who violates this subchapter or any rule adopted under this subchapter

Chapter 177 § 3131. Definitions

The term "fireworks" means any combustible or explosive composition, or any substance or combination of substances, or article prepared for the purpose of producing a visible or an audible effect by combustion, explosion, deflagration or detonation, including blank cartridges, toy pistols, toy cannons, toy canes, or toy guns in which explosives are used, balloons that are propelled by explosives, firecrackers, torpedoes, sky rockets, Roman candles, cherry bombs, or other fireworks of like construction and any fireworks containing any explosive or flammable compound, or any tablets or other device containing any explosive substance, except sparklers. The term "fireworks" does not include toy pistols, toy canes, toy guns, or other devices in which paper caps containing 0.25 grains or less of explosive compound are used, providing they are so constructed that the hand cannot come in contact with the cap when in place for use, and toy pistol paper caps that contain less than 0.2 grains of explosive mixture. The term "fireworks" does not include fixed ammunition for firearms, or primers for firearms. The term "sparkler" means a sparkling item that is in compliance with the United States Consumer Product Safety Commission regulations and is one of the following:

3132. Prohibitions; permits

(a) Except as provided in this section, it shall be unlawful for any person, firm, co-partnership, or corporation to do any of the following:

(1) Offer for sale, expose for sale, sell at retail or wholesale, or possess fireworks unless the person has been issued a permit by both the U.S. Bureau of Alcohol, Tobacco, and Firearms and the municipality in which the person offers for sale and stores the fireworks.

(2) Use, possess, or explode any fireworks unless the person has been issued a permit to display fireworks pursuant to subsection (c) of this section.

(3) Transport fireworks except in interstate commerce.

(4) Offer for sale or sell hand-held sparklers as described in subdivision 3131(1) of this title to a minor.

(5) Offer for sale or sell sparklers that are not in compliance with the United States Consumer Product Safety Commission regulations.

(b) The state fire marshal shall have power to adopt reasonable rules and regulations for granting permits for supervised public displays of fireworks by municipalities, fair associations, amusement parks, and other organizations or groups of individuals.

(c) Any display for which a permit is issued shall be handled by a competent operator to be approved by the chiefs of police and fire departments of the municipality in which the display is to be held and shall be of a character, and so located, discharged or fired as, in the opinion of the chief of the fire department, or in a municipality with no fire department, the selectboard, after proper inspection, shall not be hazardous to property or endanger any person or persons.

(d) Application for permits shall be made to the chief of the fire department, or in municipalities with no fire department, the selectboard, in writing, at least 15 days in advance of the date of the display. After the permit has been granted, sales, possessions, use and distribution of fireworks for the display shall be lawful for that purpose only. No permit granted under this section shall be transferable.

§ 3136. Construction

Being in the interest of public safety the provisions of this subchapter shall be liberally construed.

Annex II – Excerpts from the Architects and Professional Engineering Licensing and Registration Laws

§ 121. Definitions

(5) The "practice of architecture" means providing professional services such as consultation, investigation, evaluation, planning, designing (including structural design), or responsible supervision of construction in connection with any building or structure which has as its principal purpose human occupancy or habitation.

§ 124. Construction; exemptions

(a) This chapter shall not be construed to affect or prevent:

(1) the practice of engineering by a professional engineer licensed under the laws of this state;

(2) the preparation of working drawings, details and shop drawings by persons other than architects for use in connection with the execution of their work;

(3) employees of those lawfully practicing as architects under the provisions of this chapter from acting under the instruction, control, or supervision of their employers;

(4) supervision by builders or superintendents employed by such builders, of the construction or structural alteration of buildings or structures;

(5) design and construction, and the provision of services related thereto, of the following if the structure is:

(A) a detached single, two-family, three-family, or four-family dwelling, or a shed, storage building or garage incidental to that dwelling;

(B) a farm building, including barns, silos, sheds or housing for farm equipment and machinery, livestock, poultry or storage; or

(C) a pre-engineered building, or a building, plans for which have been stamped or sealed by a licensed professional in the appropriate field.

(b) The provisions of this section shall not be construed to permit any person not licensed as provided in this chapter to use the title architect, or any title, sign, card, or device to indicate that such person is an architect.

(c) This chapter shall not be construed to limit or restrict in any manner the right of a practitioner of another profession or occupation from carrying on in the usual manner any of the functions incidental to that profession or occupation.

§ 208. Seal

Each licensee shall obtain a seal of such design as the board shall authorize and direct. Plans and specifications prepared by, or under the direct supervision of, a licensed architect shall be stamped with the licensee's seal.

§ 1161. Definitions

(2) "Professional engineering services" means any service or creative work, the adequate performance of which requires engineering education, training and experience in the application of special knowledge of the mathematical, physical and engineering sciences. This includes consultation, investigation, evaluation, planning and design of engineering works and systems, planning the use of land and water and accomplishing engineering surveys. Such services or work may be either for public or private purposes, and may be performed in connection with any utilities, structures, buildings, machines, equipment, processes, work systems, projects, and equipment systems of a mechanical, electrical, hydraulic, pneumatic or thermal nature, insofar as they involve safeguarding life, health or property.

(6) "Professional engineer" means a person licensed under this chapter.

§ 1163. Exemptions

(a) Persons exempt. Section 1162 of this title does not prohibit acts constituting the practice of engineering performed as a necessary part of the duties of:

- (1) An officer or employee of the federal government.
- (2) An officer or a full-time employee of the state.
- (3) An officer or full-time employee of a municipality.
- (4) Certain classes of licensed potable water supply and wastewater system designers, as designated by rule of the secretary of the agency of natural resources, who design supplies or systems with a design flow of up to 1,350 gallons per day and who are licensed under chapter 64 of Title 10.
- (5) An officer or employee of a corporation engaged in interstate commerce as defined in the act of Congress entitled "An Act to Regulate Commerce" approved February 4, 1887, as amended.
- (6) An officer or employee of a corporation in interstate communications as defined in the act of Congress entitled "Communications Act of 1934" or of a telephone company under the supervision and regulation of the department of public service.
- (7) An employee of a professional engineer.
- (8) Students of engineering acting under the supervision of a professional engineer.

(b) Other professions. Section 1162 does not prohibit acts constituting the practice of any other legally recognized profession or occupation, including the activity of site technicians licensed by the agency of natural resources.

(b) Other professions. Section 1162 of this title does not prohibit acts constituting the practice of any other legally recognized profession or occupation.

(c) Purposes exempt. Section 1162 does not prohibit any person from performing acts constituting the practice of engineering for the purpose of:

- (1) Designing or fabricating a manufactured product.
- (2) Designing or constructing a building which is not a public building as defined in Title 18.
- (3) Designing or constructing a building which contains only one, two or three dwelling units, or accessory outbuildings.
- (4) Construction of public works by a municipality.
- (5) Designing or constructing recreational trails and trail-related structures by a not-for-profit organization whose trails have been recognized by the agency of natural resources as part of the Vermont trails system; provided such organization purchases and maintains liability insurance in the amount required by law or under a contract with the state of Vermont, but in no event in an amount that is less than \$100,000.00.

(e) Temporary practice. Section 1162 does not prohibit a person who has become a resident of this state within the preceding six months from performing acts constituting the practice of engineering, provided that:

- (1) the person has filed an application for a license under this chapter; and
- (2) the person is licensed or registered as a professional engineer in another state which, in the opinion of the board, has licensing standards substantially equivalent to those applicable under this chapter.

§ 1181a. Transient practice

A person who is not a resident of this state may obtain a transient practice permit to perform acts constituting the practice of engineering, provided that:

- (1) the practice in this state does not exceed 30 days in any calendar year; and

(2) the person is licensed or registered as a professional engineer in another state which, in the opinion of the board, has regulatory standards substantially equivalent to those applicable under this chapter.

§ 1188. Seal

(a) Each licensee shall obtain a seal of a design authorized or approved by the board. The seal shall bear the licensee's name and the title "professional engineer."

(b) Plans, specifications, plats and reports issued by a licensee shall be stamped with his seal and shall also be signed by the licensee.

Annex III - Smoke & Carbon Monoxide Detection for Single-Family Owner Occupied Dwellings

§ 2881. Definitions

For the purpose of this chapter:

(1) "Single-family dwelling" means any building or structure in which a family, families or households reside that contains sleeping facilities and is not otherwise classified as a "public building" as defined in section 20 V.S.A. section 2730 or as a "condominium" or "multiple unit dwelling" as defined in section 20 V.S.A. section 2729(d).

(2) "Smoke detector" means a device that detects visible or invisible particles of combustion and sounds a warning alarm, is operated from a power supply, within the unit or wired to it from an outside source, and is approved or listed for the purpose by Underwriters Laboratory or by another nationally recognized independent testing laboratory.

(3) "Carbon monoxide detector" means a device with an assembly that incorporates a sensor control component and an alarm notification that detects elevations in carbon monoxide levels and sounds a warning alarm, is operated from a power supply within the unit or wired to it from an outside source, and is approved or listed for the purpose by Underwriters Laboratory or by another nationally recognized independent testing laboratory.

§ 2882. Installation

(a) A person who constructs a single-family dwelling shall install one or more smoke detectors, and one or more carbon monoxide detectors in the vicinity of any bedrooms in the dwelling in accordance with the manufacturer's instructions. In a dwelling provided with electrical power, the detectors shall be powered by the electrical service in the building and by battery.

(b) A single-family dwelling transferred by sale or exchange shall contain one or more smoke detectors, and one or more carbon monoxide detectors powered by the electrical service in the building or by battery, or by a combination of both, and installed in accordance with the manufacturer's instructions.

(c) Nothing in this section shall require an owner or occupant of a single-family dwelling to maintain or use a smoke detector or a carbon monoxide detector after installation.

§ 2883. Requirements for transfer of dwelling

(a) The seller of a single-family dwelling, whether by sale or exchange, shall certify to the buyer at the closing of the transaction that the dwelling is provided with one or more smoke detectors and one or more carbon monoxide detectors in accordance with this chapter. This certification shall be signed and dated by the seller.

(b) If the buyer notifies the seller within ten days by certified mail from the date of conveyance of the dwelling that the dwelling lacks a smoke detector or a carbon monoxide detector or that either detector is not operable, the seller shall comply with this chapter within ten days after notification.

(c) Violation of this section or of the installation requirements of section 2882 shall not create a defect in title.

Annex IV - Information for Historic Buildings

Vermont has an unusually high proportion of older buildings. These buildings contribute substantially to the sense of community and place that makes Vermont unique. At the same time, these buildings may be particularly challenging to adaptively reuse. Owners of older and historic buildings should seek the assistance of experienced designers specializing in the preservation of these structures. Division for Historic Preservation and Division of Fire Safety staff will assist in using the features of this *Code* to preserve and enhance historic buildings. Clear and comprehensive information on the significant historic features needs to be provided to the Division to facilitate review.

There are a number of codes that are part of this *Code* specifically written for existing and historic buildings;

* NFPA 1, Fire Prevention Code, primarily addresses maintenance and the operation of buildings with performance guidelines for historic buildings.

* NFPA 73, Residential Electrical Code, addresses electrical code requirements in existing residential units.

* NFPA 101, Life Safety Code, principally addresses life safety issues and has specific chapters for existing buildings.

* NFPA 909, Protection of Cultural Resources including Museums, Libraries and places of worship, brings together the design and implementation of fire protection plans designed to protect both people and property.

*NFPA 914, Code for Fire Protection of Historic Structures, addresses the identification of existing conditions, planning and fire protection practices for historic buildings.

The regional offices of the Division of Fire Safety are staffed with safety professionals who have training and experience in developing solutions to meet both safety and historic preservation concerns. If a solution to a problem has not been developed after plan review or inspection, the owner or designated representative should contact the regional manager for assistance. With more experience and resources to draw on the regional manager often will develop a solution without requesting a formal variance.

For many buildings there are alternatives for certain code requirements that will provide an equivalent level of safety for the people using the building. To facilitate the review process for historic buildings, a fire safety plan should be developed. Guidance for that plan is found in Section 11.3.2 of NFPA 914 and Section 2.2 of NFPA 909. Additional flexibility is provided for historic buildings having the option to use the Alternative Approaches to Life Safety contained in NFPA 101A.

Fire Alarm and Detection Systems

Fire alarm and detection systems provide early warning of a fire allowing for safe evacuation of the building and a prompt response of fire suppression activities. There are numerous types, styles and designs of fire alarm and detection equipment that provide options and flexibility for sympathetic installation in historic buildings. (See NFPA 914, Appendix F or NFPA 909, Appendix F for a general discussion of fire alarm systems and NFPA 101 Section 9.6)

Fire Extinguishing Systems

Automatic fire sprinkler systems and other types of automatic fire extinguishing systems provide early warning of a fire allowing for safe evacuation of the building and provide prompt suppression of the fire using a minimal amount of water. Each sprinkler head has to be heated to a certain temperature by a fire before water is released. Most fires are extinguished by the operation of just one or two sprinkler heads due to the prompt response by the sprinkler system. The amount of water applied to a fire is much less than what would need to be applied by a fire hose line. (See NFPA 914, Appendix F or NFPA 909 Appendix F for a general discussion of fire extinguishing systems and NFPA 101 Section 9.7)

Automatic fire sprinkler systems have an excellent record of success in saving both people and property. Because of the excellent experience of automatic fire sprinkler systems the Codes have fewer requirements for buildings that have automatic fire sprinkler systems. For example, the Codes would drop or “trade off” certain requirements for historic buildings that have an automatic fire sprinkler system.

To promote the installation of fire sprinkler systems in existing buildings in designated downtown areas, a rebate of up to \$2,000 of the construction permit fee is available to applicants where a complete fire sprinkler system is installed. The process for receiving the rebate includes providing documentation from the City or Town Clerk that the building is in a designated downtown area; completion of the fire sprinkler system in accordance with appropriate codes and final acceptance testing and approval of the fire sprinkler system. Vermont tax credits are also available for the installation of sprinkler systems and elevators in designated downtown areas, contact the Agency of Commerce & Community Development at 800-622-4553.

Maintenance and Testing of Fire Protection Systems

To help assure that fire protection systems will function properly when needed, all fire protection systems such as a fire alarm, sprinkler or kitchen hood exhaust systems are required to be tested periodically by a technically qualified person who is certified by the Division of Fire Safety. Upon completion of the test, the technically qualified person will affix an inspection sticker and notify the Division of Fire Safety of the results of the inspection.

Use of Archaic Building Materials

Building materials used within buildings are evaluated for “interior finish ratings” and “fire resistance ratings.”

1) Interior finish ratings include evaluations for flame spread, fuel contribution and smoke development. Interior finish ratings are classified as A, B or C. Common archaic finish material such as plaster, tile flooring, wood flooring and metal ceilings will normally meet the standards for interior finish. Wood trim and incidental finish which is less than 10% of the aggregate wall and ceiling areas will also meet the standards for interior finish. Wood paneling which consists of more than 10% of the aggregate wall and ceiling areas will also meet the standards for interior finish in a number of historic buildings such as a bed and breakfast with 16 or fewer guests. However, in some buildings such as schools, the wood paneling would need to be treated with a fire retardant finish. The fire retardant finishes are available in both clear and solid color. The application of a fire retardant finish would not be required for wood paneling in a building provided with an automatic fire sprinkler system.

2) Fire resistance ratings evaluate building walls, ceilings or doors for the amount of time that it would resist the passage of fire. Construction assemblies can be evaluated by standard tests, rating guidelines published by nationally recognized authorities or by engineering analysis. Many common archaic construction assemblies have substantial resistance ratings while other assemblies may need to be enhanced to meet fire resistance requirements. Fire resistance requirements are commonly found in the code for separation walls that separate a more hazardous area from the rest of the building, such as a boiler room or stairway walls which protect the means of egress from a building. The requirements for construction or wall assemblies with fire resistance ratings in a building are reduced or totally eliminated for existing buildings with an automatic fire sprinkler system.

Field Guide for Historic Buildings

The Field Guide is designed to be used by those involved at all levels in the alteration process of historic and older buildings, including: trades persons, planners, architects, engineers, and property owners. The purpose of the Field Guide is to illustrate and describe successful examples of code compliance that reconcile safety considerations with preservation goals. In addition to explaining the code requirements and listing sources for further referencing, this guide also encourages and outlines the early and continued cooperation between those directly involved in the project with local code and preservation officials.

Annex V – Contact Information:

The Division of Fire Safety's four regional offices are located in:

[Barre](#)

[Rutland](#)

McFarland State Office Bldg.
5 Perry Street, Suite 200
Barre, VT 05641
802.479.4434
Fax: 802.479.4446

Fourth Floor
Asa Bloomer Build Suite 430
88 Merchants Row
Rutland, VT 05701
802.786.5867
Fax: 802.786.5872

Springfield

100 Mineral Street, Suite 307 Springfield, VT 05156
802.885.8883
Fax: 802.885.8885

Williston

372 Hurricane Lane, Suite 102
Williston, VT 05495-7151
802.879.2300
Fax: 802.879.2312

The Vermont Fire Academy is located at:

317 Sanitorium Road
Pittsford, VT 05763
802.483.2755
Toll Free 800.615.3473
Fax: 802.483.2464

The Division of Fire Safety Main Office is located at:

1311 U. S. Route 302 - Berlin
Suite 600
Barre, Vermont 05641-2351

802.479.7561
Toll Free 800.640.2106
Fax: 802.479.7562

Codes and Standards Adopted and referenced under this **Code** are available at:

National Fire Protection Association
1 Batterymarch Park
Quincy Mass 02169-9101
1-800-344-3555
www.nfpa.org/

550 N.W. Lejunne Road
P.O. Box 351040
Miami FL 33135
1-800-443-9353
www.aws.com

American Society of Heating Refrigeration
and Air Condition Engineers
1791 Tullie Circle N.E.
Atlanta, GA 30329
404-636-8400
www.ashrae.org/

Compressed Gas Association, Inc.
4221 Walney Road, 5th Floor
Chantilly, VA 20151-2923
703-788-2700
www.cganet.com/default.html

American Society of Mechanical Engineers
22 Law Drive, Box 2900
Fairfield, NJ 07007
1-800-843-2763
www.asme.org/

International Code Council, Publications
4051 West Flossmoor Road
Country Club Hills
Illinois, 60478-5795
888-422-7233

American Society for Testing and Materials
100 Barr Harbor Drive
West Conshohocken PA 19428-2959
610-832-9585
www.astm.org/

National Board of Boiler & Pressure Vessel Inspectors
1055 Crupper Ave.
Columbus, Ohio 43229-1183
614-888-8320
nationalboard.org

American Welding Society, Inc.

Petroleum Equipment Institute

P.O. Box 2380
Tulsa OK 74101-2380
1-918-494-9696
www.pei.org

Underwriters Laboratories Inc.
333 Pfingsten Road
Northbrook IL 60062
847-272-8800
www.ul.com/

Annex VI - Index by Topic & Occupancy

Access for People With Disabilities
Clearance for Stairway Lifts... page 10
IBC Cross Reference... page 15
Accessory Dwelling Unit, Definition... page 22
Adoption of National Standards... page 4
International Building Code (IBC)... page 14
Life Safety Code (NFPA 101)... page 10
National Board Inspection Code... page 14
Uniform Fire Code (NFPA 1)... page 4
Architecture, Practice of
Definition... page 29
Exemptions... page 29
Seal... page 30
Assembly Occupancy
Change of Ownership... page 6
Nightclubs, Egress Inspection... page 8
Nightclubs, Sprinkler Protection... page 11
Assisted Living Occupancy... page 13
Authority for Code... page 4
Authority Having Jurisdiction, definition... page 4
Boiler & Pressure Vessel
ASME Standards... page 16
Boiler Room Exits... page 11
Inspection Certificate... page 17
Inspection, Initial... page 16
Inspection, Periodic... page 17
Low Water Cutoff... page 14
Report Incident or Explosion... page 17
Business Occupancy
Single Exit Exception... page 14
Carbon Monoxide Detectors
NFPA Standard 720... page 11
Power Supply... page 11
Power Supply, Date for Existing Buildings... page 20
Location, Apartments... page 13
Location, Correctional Facilities... page 12
Location, Daycare... page 12
Location, Healthcare... page 12
Location, Hotels & Dormitories... page 13
Location, Lodging & Rooming... page 13

Location, Residential Care... page 13
Location, One & Two Family... page 12
Single Family Owner Occupied Dwellings... page 31
Certificate of Fitness
Both Natural & LP Gas Appliances... page 5
Chimney Evaluation & Maintenance... page 5
Delivery of LP Gas... page 5
Design of LP Gas System... page 5
Emergency Generators... page 5
Fire alarm... page 4
Fixed Fire Extinguishing Systems... page 4
Installation of LP Gas Appliances... page 5
Installation of LP Gas Systems... page 5
Natural Fuel Gas Systems... page 5
Oil Burning Equipment... page 5
Plant Operations for LP Gas... page 5
Renewal... page 5
Sprinkler Design... page 5
Sprinkler, Limited & Domestic... page 5
Sprinkler Installation... page 5
Transfer Operations for LP Gas... page 5
Certification of Plans... page 18
Code Books, Ordering... page 34
Combustible Vegetation, Christmas Trees... page 6
Construction Classification Correlation Table... page 15
Contact Information, Division of Fire Safety... page 34
Cooking Operations, Exemptions... page 9
Design Professional in Responsible Charge... page 19
Electrical
Electrical Codes Adopted... page 11
IBC Cross Reference... page 16
Elevator
Hoistway Enclosure & Venting... page 16
Sprinkler Protection of Hoistways... page 7
Energy Efficiency... page 15
Engineering, Professional Services
Definition... page 30
Exemptions... page 30
Seal... page 31
Transient Practice... page 31
Existing Buildings... page 16
Explosives & Fireworks
General Information... page 9
Permit for Public Fireworks Display... page 9
Sparkler Information... page 9
Sparkler, Sales and Storage... page 9
Federal Building, Application of Code... page 22
Fire Extinguishers, Portable... page 11
Fire Protection Systems
Identification Number... page 6
Periodic Inspection & Test... page 6
Proof of Inspection... page 6
Proof of Inspection Fee... page 23
Fire Walls... page 15
Fuel Dispensing
Fire Resistant Tanks... page 8
Gas, LP & Natural
Change in LP Gas Service... page 7
Discontinuance, Interruption of Service... page 7
Pipeline Regulations... page 7
Protection of LP Gas Containers... page 10
Record of Installation... page 10
Health Care Occupancy
CO Detection, Location... page 12
Definition... page 10
Hotel & Dormitory Occupancy
CO Detector, Location... page 13

Smoke Alarms in Sleeping Rooms... page 13
Historic Building
Archaic Building Materials... page 33
Definition... page 22
Documentation for Plans... page 18
Information... page 32
Reference to NFPA 914... page 6
International Code Council Standards... page 14
Lodging & Rooming Occupancy
Classification, Small... page 12
CO Detector, Location... page 13
Manufactured Housing, Information... page 12
Municipal Enforcement... page 25

One & Two Family Occupancy
CO Detection... page 12
Dwelling Unit Separation... page 12
IBC Cross Reference... page 15
Stair Riser & Tread... page 12

Penalties... page 25

Permits

Fee, Change in Use... page 23
Fee, Construction Permit... page 23
Tents, Membrane Structures... page 8

Public Building, Definition... page 21

Residential Care Occupancy

CO Detector, Location... page 13
Definition... page 10
Smoke Alarms in Sleeping Rooms... page 14
Sprinkler Protection... page 13

Semiconductor Fabrication Facilities... page 15

Smoke Alarms

Power... page 11
Single Family Owner Occupied Dwellings... page 31

Snow Load... page 15

Snow Removal... page 8

Sprinkler Systems

Backflow Prevention, Existing Systems... page 7
FD Connections, Existing Systems... page 7
Protection of Elevator Hoistways... page 7
Protection of Nightclubs... page 11
Stair, Riser & Tread, 1 & 2 Family... page 12
Transient Lodging, Classification... page 12
Underground Storage Tank Information... page 9
Unvented Room Heaters... page 7
Variance, Exemption, Reconsideration... page 19
Water Heaters... page 16
Window, Escape, Existing... 12

NFPA 101®

LIFE SAFETY CODE®

2003

LIFE SAFETY CODE®

2003 EDITION



NFPA 101®

NFPA Logo Removed

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

Notice and Disclaimer of Liability Concerning the Use of NFPA Documents

NFPA codes, standards, recommended practices, and guides, of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in its codes and standards.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the NFPA list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

Important Notices and Disclaimers continued on inside back cover.

Copyright © 2003, National Fire Protection Association, All Rights Reserved

NFPA 101®

Life Safety Code®

2003 Edition

This edition of NFPA 101®, *Life Safety Code*®, was adopted by the National Fire Protection Association, Inc., at its November Association Technical Meeting held November 16–20, 2002, in Atlanta, GA. It was issued by the Standards Council on January 17, 2003, with an effective date of February 6, 2003, and supersedes all previous editions.

This edition of NFPA 101 was approved as an American National Standard on January 17, 2003.

IMPORTANT NOTE: *This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Documents." They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.*

Origin and Development of NFPA 101

The *Life Safety Code* had its origin in the work of the Committee on Safety to Life of the National Fire Protection Association, which was appointed in 1913. In 1912 a pamphlet titled *Exit Drills in Factories, Schools, Department Stores and Theaters* was published following its presentation by the late Committee member R. H. Newbern at the 1911 Annual Meeting of the Association. Although the pamphlet's publication antedated the organization of the Committee, it was considered a Committee publication.

For the first few years of its existence, the Committee on Safety to Life devoted its attention to a study of the notable fires involving loss of life and to analyzing the causes of this loss of life. This work led to the preparation of standards for the construction of stairways, fire escapes, and other egress routes for fire drills in various occupancies, and for the construction and arrangement of exit facilities for factories, schools, and other occupancies. These reports were adopted by the National Fire Protection Association and published in pamphlet form as *Outside Stairs for Fire Exits* (1916) and *Safeguarding Factory Workers from Fire* (1918). These pamphlets served as a groundwork for the present *Code*. These pamphlets were widely circulated and put into general use.

In 1921 the Committee on Safety to Life was enlarged to include representatives of certain interested groups not previously participating in the standard's development. The Committee then began to further develop and integrate previous Committee publications to provide a comprehensive guide to exits and related features of life safety from fire in all classes of occupancy. Known as the *Building Exits Code*, various drafts were published, circulated, and discussed over a period of years, and the first edition of the *Building Exits Code* was published by the National Fire Protection Association in 1927. Thereafter, the Committee continued its deliberations, adding new material on features not originally covered and revising various details in the light of fire experience and practical experience in the use of the *Code*. New editions were published in 1929, 1934, 1936, 1938, 1939, 1942, and 1946 to incorporate the amendments adopted by the National Fire Protection Association.

National attention was focused on the importance of adequate exits and related fire safety features after the Cocoanut Grove Night Club fire in Boston in 1942 in which 492 lives were lost. Public attention to exit matters was further stimulated by the series of hotel fires in 1946 (LaSalle, Chicago — 61 dead; Canfield, Dubuque — 19 dead; and the Winecoff, Atlanta — 119 dead). The *Building Exits Code*, thereafter, was used to an increasing extent for regulatory purposes. However, the *Code* was not written in language suitable for adoption into law, because it had been drafted as a reference document and contained advisory provisions that were useful to building designers but inappropriate for legal use. This led to a decision by the Committee to re-edit the entire *Code*, limiting the body of the text to requirements suitable for mandatory application and placing advisory and explanatory material in notes. The re-editing expanded *Code* provisions to cover additional occupancies and building features to produce a complete document. The *Code* expansion was carried on concurrently with development of the 1948, 1949, 1951, and 1952 editions. The results were incorporated in the 1956 edition and further refined in subsequent editions dated 1957, 1958, 1959, 1960, 1961, and 1963.

In 1955, NFPA 101B, on nursing homes and NFPA 101C, on interior finish, were published. NFPA 101C was revised in 1956. These publications have since been withdrawn.

In 1963 the Committee on Safety to Life was restructured to represent all interested factions and to include only those members with broad knowledge of fire matters. The Committee served as a review and correlating committee for seven sectional committees whose personnel included members having a special knowledge and interest in various portions of the *Code*.

Under the revised structure, the sectional committees, through the Committee on Safety to Life, prepared the 1966 edition of the *Code*, which was a complete revision of the 1963 edition. The *Code* title was changed from *Building Exits Code* to the *Code for Safety to Life from Fire in Buildings and Structures*. The *Code* text was written in enforceable "code language," and all explanatory notes were placed in an appendix.

The *Code* was placed on a three-year revision schedule, with new editions adopted in 1967, 1970, 1973, and 1976.

In 1977 the Committee on Safety to Life was reorganized as a Technical Committee, with an Executive Committee and standing subcommittees responsible for various chapters and sections. The 1981 edition contained major editorial changes, including reorganization within the occupancy chapters, to make them parallel to each other, and the splitting of requirements for new and existing buildings into separate chapters. Chapters on detention and correctional facilities were added, as well as new sections for ambulatory health care centers.

The 1985 edition contained a new Chapter 21 on residential board and care occupancies with related Appendixes F and G, a new Appendix D on alternative calculations for stair width, and Appendix E — a Fire Safety Evaluation System (FSES) for detention and correctional facilities.

The 1988 edition contained a major change in the method of determining egress capacity with the deletion of the traditional units of exit width and the substitution of a straight linear approach to calculating egress capacity. Appendixes C through G were moved from NFPA 101 into a new document, NFPA 101M.

The 1991 edition contained numerous new requirements for mandatory sprinklers in new health care facilities, hotels, apartment buildings, lodging and room houses, and board and care facilities, as well as mandatory sprinkler requirements for existing high-rise hotels and apartment buildings. The requirements for board and care facilities were split into two chapters, Chapter 22 for new construction and Chapter 23 for existing buildings.

The 1994 edition contained new requirements for accessible means of egress, areas of refuge, and ramps, putting the *Code* in substantial agreement with the Americans with Disabilities Act Accessibility Guidelines (ADAAG).

The 1997 edition relocated the material on day-care occupancies from Chapter 10 and Chapter 11, Educational Occupancies, to new Chapter 30 and Chapter 31. The operating features requirements, previously contained in Chapter 31, were interspersed throughout the *Code*, as applicable.

The 2000 edition introduced a performance-based option via Section 4.4 and new Chapter 5. That edition also reformatted the *Code* for substantial compliance with the NFPA *Manual of Style*: (1) former Chapter 1, General, was split into Chapter 1, Administration, and Chapter 4, General; (2) the mandatory references list was moved from Chapter 33 to Chapter 2; (3) all definitions were moved in Chapter 3 and each defined term was numbered; (4) the paragraph numbering scheme that separated the chapter number from the section number by a hyphen was changed to use a decimal point as the separator; and (5) the appendixes were renamed annexes. Former Chapter 32 on special structures and high-rise buildings was moved to Chapter 11 to join the core chapters (i.e., the chapters that are not occupancy specific). The subject of interior finish, contents, and furnishings was moved from Section 6.5 into a separate new chapter, Chapter 10. The occupancy chapter numbers, formerly 8 through 32, became 12 through 42 with some repositioning of chapters. For example, the day-care occupancies chapters were renumbered from 30/31 to 16/17 so as to be positioned immediately after the chapters for educational occupancies.

The 2003 edition reformats all exceptions into numbered or lettered paragraphs. Some reformatting of paragraphs with multiple requirements was done for additional compliance with the NFPA *Manual of Style*.

To the User

The following comments are offered to assist in the use of the *Life Safety Code*. Additional help on using the *Life Safety Code* can be obtained by attending one of the seminars NFPA conducts on the *Life Safety Code* or by using the *Life Safety Code Handbook* available from NFPA. Further information on these seminars is available through NFPA's Division of Continuing Education.

Essentially, the *Code* is comprised of four major parts. The first part consists of Chapter 1 through Chapter 4 and Chapter 6 through Chapter 11; these are often referred to as the base chapters or fundamental chapters. The second part is Chapter 5, which details the performance-based option. The next part consists of Chapter 12 through Chapter 42, which are the occupancy chapters. The fourth and last part consists of Annex A and Annex B, which contain useful additional information.

A thorough understanding of Chapter 1 through Chapter 4 and Chapter 6 through Chapter 11 is necessary to use the *Code* effectively, because these chapters provide the building blocks on which the requirements of the occupancy chapters are based. Note that many of the provisions of Chapter 1 through Chapter 4 and Chapter 6 through Chapter 11 are mandatory for all occupancies. Some provisions are mandated only when referenced by a specific occupancy, while others are exempted for specific occupancies. Often, in one of the base chapters, especially in Chapter 7, the term “where permitted by Chapter 12 through Chapter 42” appears. In this case, that provision can be used only where specifically allowed by an occupancy chapter. For example, the provisions of 7.2.1.6.1 on delayed egress locks are allowed only when permitted by Chapter 12 through Chapter 42. Permission to use the delayed egress lock is normally found in the “____.2.2” subsection of each occupancy chapter. For example, 12.2.2.2.5 specifically allows the use of delayed egress locks in new assembly occupancies. If this permission is not found in an occupancy chapter, the delayed egress lock cannot be used. Similar types of restricted permission are found for such items as security grilles, double cylinder locks, revolving doors, and so forth. In other locations in the base chapters, the term “unless prohibited by Chapter 12 through Chapter 42” is used. In this case, the provision is allowed in all occupancies unless specifically prohibited by an occupancy chapter.

Metric units of measurement in this *Code* are in accordance with the modernized metric system known as the International System of Units (SI). The unit liter, which is outside of but recognized by SI, is commonly used and is therefore used in this *Code*. In this *Code*, SI values for measurements are followed by an equivalent in inch-pound units, as noted in 1.5.2. The SI value and the inch-pound value are each acceptable for use as primary units for satisfying the requirements of this *Code*.

Technical Correlating Committee (SAF-AAC)

James R. Quiter, *Chair*
Arup Fire, CA [SE]

Ron Coté, *Nonvoting Secretary*
NFPA, MA

John L. Bryan, Frederick, MD [SE]
Richard W. Bukowski, U.S. National Institute of
Standards & Technology, MD [RT]
Rep. National Fire Alarm Code Committee
Kenneth E. Bush, Maryland State Fire Marshals Office,
MD [E]
Rep. International Fire Marshals Association
Lee J. Dosedlo, Underwriters Laboratories Inc., IL [RT]
Gene B. Endthoff, National Fire Sprinkler Association,
IL [M]
Jackie T. Gibbs, Marietta Fire Department, GA [U]
Rep. International Association of Fire Chiefs
J. Edmund Kalie, Jr., Prince George's County
Government MD [E]

Ronald K. Mengel, System Sensor, IL [M]
Rep. National Electrical Manufacturers Association
Jake Pauls, Jake Pauls Consulting Services in Building
Use & Safety, MD [C]
Rep. American Public Health Association
Kirby W. Perry, Kirby W. Perry Architects & Associates
Inc, TX [SE]
Rep. American Institute of Architects
Lawrence G. Perry, Building Owners & Managers Assn.
Int'l, MD [U]
David L. Wismer, Philadelphia Department of Licenses
& Inspections, PA [E]

Alternates

Andrew Brian Bowman, Gage-Babcock & Associates, Inc.,
IL [U]
(Alt. to AHCA Rep.)
Howard Hopper, Underwriters Laboratories Inc., CA [RT]
(Alt. to L. J. Dosedlo)
Ronald H. Minter, Thomas & Betts, TN [M]
(Alt. to R. K. Mengel)

Martin H. Reiss, The RJA Group, Inc., MA [SE]
(Alt. to J. R. Quiter)
Michael D. Tomy, Heery International Inc., GA [SE]
(Alt. to K. W. Perry)
Robert B. Treiber, National Fire Sprinkler Association,
Inc., OH [M]
(Alt. to G. B. Endthoff)

Nonvoting

William E. Fitch, Chair SAF-FUR, Omega Point
Laboratories Inc., TX
Ralph Gerdes, Chair SAF-AXM, Ralph Gerdes
Consultants, LLC, IN
Wayne D. Holmes, Chair SAF-IND, HSB Professional Loss
Control, CT
Morgan J. Hurley, Chair SAF-FUN, Society of Fire
Protection Engineers, MD
Thomas W. Jaeger, Chair SAF-DET, Gage-Babcock
& Associates Inc., VA
Philip R. Jose, Chair SAF-BCF, U.S. Department of
Veterans Affairs, NY
Richard L. Klinker, Chair SAF-BSF, Klinker & Associates,
Inc., MD

William E. Koffel, Chair SAF-MEA, Koffel Associates,
Inc., MD
James K. Lathrop, Chair SAF-RES, Koffel Associates, Inc.,
CT
John W. McCormick, Chair SAF-FIR, Code Consultants,
Inc., MO
Harold E. Nelson, Hughes Associates, Inc., VA
(Member Emeritus)
Daniel J. O'Connor, Chair SAF-HEA, Schirmer
Engineering Corporation, IL
Ed Schultz, Chair SAF-MER, Code Consultants, Inc., MO
Catherine L. Stashak, Chair SAF-END, Schirmer
Engineering Corporation, IL
David W. Stroup, Chair SAF-ALS, U.S. National Institute
of Standards and Technology, MD

Ron Coté, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on the protection of human life from fire and other circumstances capable of producing similar consequences and for the non-emergency and emergency movement of people.

Technical Committee on Assembly Occupancies and Membrane Structures (SAF-AXM)

Ralph Gerdes, Chair

Ralph Gerdes Consultants, LLC, IN [SE]

Ron Coté, Nonvoting Secretary

NFPA, MA

Stanton M. Alexander, North American Testing Company, FL [M]

Weston E. Bacon, Jr., Bacon Hedland Management, Inc., IL [U]

Rep. International Association of Exposition Management

Scott R. Bartlett, Simplex Time Recorder Co., MA [M]

Rep. National Electrical Manufacturers Association

George D. Bushey, Rosser International, GA [SE]

William Conner, Schuler & Shook Inc., IL [SE]

Rep. American Society of Theater Consultants

Bhola Dhume, City of New Orleans, LA [E]

Robert D. Fiedler, City of Lincoln, NE [E]

William E. Fitch, Omega Point Laboratories Inc., TX [RT]

Vern L. Martindale, Church of Jesus Christ of Latter-Day Saints, UT [U]

Daniel M. McGee, American Iron and Steel Institute, NJ [M]

Joseph J. Messersmith, Jr., Portland Cement Association, VA [M]

Gregory R. Miller, Code Consultants Inc., MO [U]

Rep. National Association of Theatre Owners

Keith C. Nagelski, Soft Play, L.L.C., NC [M]

Rep. International Play Equipment Manufacturers Association

Jake Pauls, Jake Pauls Consulting Services in Building Use & Safety, MD [SE]

John William Pritchett, Athens-Clarke County Fire Department, GA [E]

Joseph Psuik, III, San Diego Convention Center, CA [U]

Rep. International Association of Assembly Managers, Inc.

Ed Roether, HOK Sport, MO [U]

Karl G. Ruling, Entertainment Services and Technology Assn., NY [U]

Rep. U.S. Institute for Theatre Technology

Philip R. Sherman, P. R. Sherman Incorporated, NH [SE]

Jeffrey S. Tubbs, Arup Fire, MA [SE]

Daniel R. Victor, Interkal, Incorporated, MI [M]

Rep. National School Supply & Equipment Assn.

Paul L. Wertheimer, Crowd Management Strategies, IL [SE]

Alternates

Gene Boecker, Code Consultants, Inc., MO [U]

(Alt. to G. R. Miller)

David Cook, Ralph Gerdes Consultants, IN [SE]

(Alt. to R. Gerdes)

Mike Hayward, Little Tikes Commercial Play Systems Inc., MO [M]

(Alt. to K. C. Nagelski)

Jonathan Humble, American Iron and Steel Institute, CT [M]

(Alt. to D. M. McGee)

Vern T. Lewis, Church of Jesus Christ of Latter-Day Saints, UT [U]

(Alt. to V. L. Martindale)

Stephen V. Skalko, Portland Cement Association, GA [M]

(Alt. to J. J. Messersmith, Jr.)

Ron Coté, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on protection of human life and property from fire and other circumstances capable of producing similar consequences, and on the non-emergency and emergency movement of people in assembly occupancies, tents, and membrane structures.

Technical Committee on Board and Care Facilities (SAF-BCF)

Philip R. Jose, Chair

U.S. Department of Veterans Affairs, NY [U]

Gregory E. Harrington, Nonvoting Secretary
NFPA, MA

Gregory J. Austin, Gentex Corporation, MI [M]
Rep. National Electrical Manufacturers Association
James R. Bell, Marriott International, Inc., DC [U]
Rep. American Hotel & Lodging Association
Warren D. Bonisch, Schirmer Engineering Corporation,
TX [SE]
Harry L. Bradley, Maryland State Fire Marshals Office,
MD [E]
Rep. International Fire Marshals Association
Philip C. Favro, Philip C. Favro & Associates, CA [SE]
Thomas W. Gardner, Gage-Babcock & Associates, VA [U]
Rep. American Health Care Association

Laura A. Hoffman, Nashville Tennessee Fire
Department, TN [E]
Kenneth E. Isman, National Fire Sprinkler Association,
NY [M]
David Ray Kiely, Sullivan County ARC, NY [U]
Rep. American Network of Community Options and
Resources
James K. Lathrop, Koffel Associates, Inc., CT [SE]
Bernard M. Levin, Rockville, MD [SE]
Paul E. Patty, Underwriters Laboratories Inc., IL [RT]
Francis G. Reuer, U.S. Department of Health & Human
Services, CO [E]

Alternates

Kerry M. Bell, Underwriters Laboratories Inc., IL [RT]
(Alt. to P. E. Patty)
Gene B. Endthoff, National Fire Sprinkler Association,
IL [M]
(Alt. to K. E. Isman)
Harold E. Nelson, Hughes Associates, Inc., VA [SE]
(Alt. to B. M. Levin)
Daniel J. Schoeps, U.S. Department of Veterans Affairs,
DC [U]
(Alt. to P. R. Jose)

James F. Woodford, Simplex Time Recorder Co., MA [M]
(Alt. to G. Austin)
Mayer D. Zimmerman, U.S. Dept. of Health and Human
Services, MD [E]
(Alt. to F. G. Reuer)

Gregory E. Harrington, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on protection of human life and property from fire and other circumstances capable of producing similar consequences, and on the emergency movement of people, in residential board and care facilities.

Technical Committee on Building Service and Fire Protection Equipment (SAF-BSF)

Richard L. Klinker, *Chair*
Klinker & Associates, Inc, MD [SE]

Gregory E. Harrington, *Nonvoting Secretary*
NFPA, MA

Keith A. Ball, SimplexGrinnell, FL [M]
Rep. National Electrical Manufacturers Association
Harry L. Bradley, Maryland State Fire Marshals Office,
MD [E]
Rep. International Fire Marshals Association
Pat D. Brock, Oklahoma State University, OK [SE]
Phillip A. Brown, American Fire Sprinkler Association,
Inc., TX [IM]
Paul M. Donga, Boston Fire Department, MA [E]
Edward A. Donoghue, Edward A. Donoghue Associates,
Inc., NY [M]
Rep. National Elevator Industry Inc
Dale A. Harshbarger, Hebron Fire Protection District, KY
[E]
Kenneth E. Isman, National Fire Sprinkler Association,
NY [M]
Joseph M. Jardin, New York City Fire Dept., NY [C]
Rep. NFPA Fire Service Section

Ignacy A. Kapalczynski, Connecticut Department of
Public Safety, CT [E]
David P. Klein, U.S. Department of Veterans Affairs, MD
[U]
Dennis A. Lockard, Newport Beach Fire Department, CA
[E]
Roger L. McDaniel, Florida Department of Corrections,
FL [U]
L. L. (Larry) Neibauer, Automatic Fire Alarm Association,
FL [M]
Richard R. Osman, Schirmer Engineering Corporation,
IL [I]
Dinesh K. Patel, U.S. Department of the Navy, CA [U]
Martin H. Reiss, The RJA Group, Inc., MA [SE]
James Tizzano, Township of Old Bridge, NJ [E]
William A. Webb, Performance Technology Consulting,
Ltd., IL [SE]
Carl Dewayne Wren, Austin Fire Department, TX [E]

Alternates

Ronald S. Berger, Low Voltage Systems Technology [M]
(Alt. to L. L. Neibauer)
Lisa Marie Bossert, Schirmer Engineering Corporation,
NC [I]
(Alt. to R. R. Osman)
James D. Brown, Oklahoma State University, OK [SE]
(Alt. to P. D. Brock)
Davie J. Camp, Thyssen Krupp Elevator, TN [M]
(Alt. to E. A. Donoghue)
Greg Gottlieb, Hauppauge Fire District, NY [C]
(Alt. to J. M. Jardin)

Claudia Hagood, Klinker and Associates, Inc., MD [SE]
(Alt. to R. L. Klinker)
Kevin Kelly, National Fire Sprinkler Association, NY [M]
(Alt. to K. E. Isman)
Peter A. Larrimer, U.S. Department of Veterans Affairs,
PA [U]
(Alt. to D. P. Klein)
Randolph W. Tucker, The RJA Group, Inc., TX [SE]
(Alt. to M. H. Reiss)

Gregory E. Harrington, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on the application of fire protection systems including detection, alarm, and suppression, and the life safety impact of various building systems.

Technical Committee on Detention and Correctional Occupancies (SAF-DET)

Thomas W. Jaeger, Chair
Gage-Babcock & Associates Inc., VA [SE]

Ron Coté, Nonvoting Secretary
NFPA, MA

James R. Ambrose, Code Consultants Inc., MO [SE]
Kevin Bailey, Folger Adam Security Inc., IL [M]
Rep. Builders Hardware Manufacturers Association
David L. Bondor, St. Paul Fire and Marine, TX [I]
Rep. American Society of Safety Engineers
Peter J. Collins, U.S. Department of Justice, DC [U]
Michael DiMascio, Solutions Engineering Inc., MA [SE]
Randy Gaw, Correctional Service of Canada, ON [E]
Patrick G. Gordon, Philadelphia Prison System, PA [U]
Larry Harrison, Office of the Illinois State Fire Marshal, IL [E]
Kenneth E. Isman, National Fire Sprinkler Association, NY [M]
William E. Koffel, Koffel Associates, Inc., MD [SE]

Roger L. McDaniel, Florida Department of Corrections, FL [U]
E. Eugene Miller, Washington, DC [SE]
Jerry Nealy, Cumulus Fibres, Inc., NC [M]
Rep. Institutional Bedding Manufacturers Association
Robert R. Perry, Robert Perry Associates Inc., IL [M]
Rep. Door & Hardware Institute
Kenneth J. Schwartz, Schirmer Engineering Corporation, IL [SE]
Wayne S. Smith, Texas State Fire Marshal, TX [E]
Rep. International Fire Marshals Association
David W. Spence, Corrections Corporation of America, TN [U]

Alternates

A. Larry Iseminger, Jr., Maryland State Fire Marshals Office [E]
(Alt. to W. S. Smith)
Kevin Kelly, National Fire Sprinkler Association, NY [M]
(Alt. to K. E. Isman)
Fred G. Kerley, Office of the Illinois State Fire Marshal, IL [E]
(Alt. to L. E. Harrison)

Michael Tierney, Builders Hardware Manufacturers Association, CT [M]
(Alt. to K. Bailey)
Ralph R. Winter, Code Consultants, Inc., MO [SE]
(Alt. to J. R. Ambrose)

Ron Coté, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on protection of human life and property from fire and other circumstances capable of producing similar consequences, and on the emergency movement of people in detention and correctional occupancies.

Technical Committee on Educational and Day-Care Occupancies (SAF-END)

Catherine L. Stashak, *Chair*
Schirmer Engineering Corporation, IL [SE]

Ron Côté, *Nonvoting Secretary*
NFPA, MA

Scott R. Bartlett, Simplex Time Recorder Co., MA [M]
Samuel S. Dannaway, S. S. Dannaway Associates, Inc., HI [SE]
Victor L. Dubrowski, Code Consultants Inc., MO [SE]
Gene B. Endthoff, National Fire Sprinkler Association, IL [M]
Douglas R. Freels, Performance Design Technologies, TN [SE]
Vern L. Martindale, Church of Jesus Christ of Latter-Day Saints, UT [U]

Erin A. M. Oneisom, U.S. Air Force, AE [U]
Michael L. Sinsigalli, Windsor Locks Fire Department, CT [E]
Aleksy L. Szachnowicz, Anne Arundel County Public Schools, MD [U]
Robert T. Trotter, Franklin Fire Department, TN [E]
Ralph J. Warburton, University of Miami, FL [SE]
Kenneth Wood, Office of the Illinois State Fire Marshal, IL [E]

Alternates

Kevin Kelly, National Fire Sprinkler Association, NY [M]
(Alt. to G. B. Endthoff)
Amy J. McGarry, Code Consultants, Inc., MO [SE]
(Alt. to V. L. Dubrowski)
Roger B. Rudy, Performance Design Technologies, LLC, TN [SE]
(Alt. to D. R. Freels)

Fred K. Walker, U.S. Air Force, FL [U]
(Alt. to E. A. M. Oneisom)

Ron Côté, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on protection of human life and property from fire and other circumstances capable of producing similar consequences, and on the emergency movement of people in educational occupancies and day-care occupancies.

Technical Committee on Fire Protection Features (SAF-FIR)

John W. McCormick, *Chair*
Code Consultants Inc., MO [SE]

Walter P. Sterling, *Nonvoting Secretary*
NFPA, MA

Carl F. Baldassarra, Schirmer Engineering Corporation,
IL [I]

John F. Bender, Maryland Office of State Fire Marshal,
MD [E]

Rep. International Fire Marshals Association

Robert M. Berhinig, Underwriters Laboratories Inc., IL
[RT]

Edward K. Budnick, Hughes Associates Inc., MD [SE]

Gregory J. Cahanin, St. Petersburg, FL [U]

Rep. Louisiana State Fireman's Association

Eric H. Cote, The RJA Group, Inc., MA [SE]

Paul L. Dove, City of Coldwater Fire Department, MI [E]

Brian L. Eklow, Aon Risk Consultants, IL [I]

Gene B. Endthoff, National Fire Sprinkler Association,
IL [M]

Sam W. Francis, American Forest & Paper Association, PA
[M]

Ralph Gerdes, Ralph Gerdes Consultants, LLC, IN [SE]

Donald Murray Goff, Hillsborough County Fire Rescue,
FL [E]

Rep. Florida Fire Marshals & Inspectors Assn.

Miles J. Haber, Monument Construction, Inc., MD [U]

Rep. National Association of Home Builders

Wayne D. Holmes, HSB Professional Loss Control, CT [I]

Jonathan Humble, American Iron and Steel Institute, CT
[M]

Ignacy A. Kapalczynski, Connecticut Department of
Public Safety, CT [E]

Waseem A. Khan, Brick Industry Association, VA [M]

Marshall A. Klein, Marshall A. Klein & Associates, Inc.,
MD [SE]

William E. Koffel, Koffel Associates, Inc., MD [M]

Rep. Glazing Industry Code Committee

Vickie Lovell, Intecode Incorporated (ICI), FL [M]

Rep. Air Movement and Control Assn/Int'l FireStop
Council

Joseph J. Messersmith, Jr., Portland Cement Association,
VA [M]

Kurt A. Roeper, Ingersoll Rand Security and Safety, OH
[M]

Rep. Steel Door Institute

Kathleen Taraba, Rolling Plains Construction, Inc., CO
[IM]

Rep. Firestop Contractors International Association

Kenneth Wood, Office of the Illinois State Fire Marshal,
IL [E]

Alternates

Donald W. Belles, Koffel Associates, Inc., TN [M]

(Alt. to W. E. Koffel)

Joseph A. Brooks, Air Movement and Control Association
International, Inc., IL [M]

(Alt. to V. Lovell)

David Cook, Ralph Gerdes Consultants, IN [SE]

(Alt. to R. Gerdes)

John F. Devlin, Schirmer Engineering Corporation, VA [SE]

(Alt. to C. F. Baldassarra)

Jack Gump, HSB Professional Loss Control, TN [I]

(Alt. to W. D. Holmes)

David M. Hammerman, Marshall A. Klein & Associates,
Inc., MD [SE]

(Alt. to M. A. Klein)

Thomas R. Janicak, Ceco Door Products, TN [M]

(Alt. to K. A. Roeper)

Mark Kluver, Portland Cement Association, CA [M]

(Alt. to J. J. Messersmith, Jr.)

David A. Lewis, Code Consultants Inc., MO [SE]

(Alt. to J. W. McCormick)

Jeffrey A. Maddox, The RJA Group, Inc., CA [SE]

(Alt. to E. H. Cote)

Eric Rosenbaum, Hughes Associates, Inc., MD [SE]

(Alt. to E. K. Budnick)

David P. Tyree, American Forest & Paper Association, CO
[M]

(Alt. to S. W. Francis)

Robert J. Wills, American Iron and Steel Institute, AL [M]

(Alt. to J. Humble)

Nonvoting

Michael Earl Dillon, Dillon Consulting Engineers, Inc., CA

Rep. TC on Air Conditioning

Walter P. Sterling, NFPA Staff Liaison

Committee Scope: of This Committee shall have primary responsibility for documents on construction compartmentation, including the performance of assemblies, openings, and penetrations, as related to the protection of life and property from fire and other circumstances capable of producing similar consequences.

Technical Committee on Fundamentals (SAF-FUN)

Morgan J. Hurley, *Chair*
Society of Fire Protection Engineers, MD [U]

Ron Côté, *Nonvoting Secretary*
NFPA, MA

Thomas H. Allen, Smoke Guard Corporation, ID [U]
Rep. American Institute of Architects
Wayne G. Carson, Carson Associates, Inc., VA [SE]
James E. Churchill, Schirmer Engineering Corporation,
CA [SE]
Barbara Ebstein, Vinick Associates, Inc., CT [U]
Rep. American Society of Interior Designers
Ben Greene, City of Englewood, CO [E]
Norman E. Groner, Santa Cruz, CA [SE]
Howard Hopper, Underwriters Laboratories Inc., CA
[RT]
David P. Klein, U.S. Department of Veterans Affairs, MD
[U]
James A. Landmesser, U.S. Department of Energy, TN [E]

James K. Lathrop, Koffel Associates, CT [SE]
David H. MacKinnon, Canadian Steel Construction
Council, ON [M]
Rep. American Iron and Steel Institute
Richard A. Morris, National Association of Home
Builders, DC [U]
Jake Pauls, Jake Pauls Consulting Services in Building
Use & Safety, MD [C]
Rep. American Public Health Association
Milosh T. Puchovsky, Arup Fire, MA [SE]
Stephen V. Skalko, Portland Cement Association, GA [M]
Jeffrey B. Stone, American Forest & Paper Association,
FL [M]
Amal Tamim, W. R. Grace & Company-Conn, MA [M]
John M. Watts, Jr., Fire Safety Institute, VT [SE]

Alternates

Eugene A. Cable, U.S. Department of Veterans Affairs, NY
[U]
(Alt. to D. P. Klein)
Robert M. Carasitti, Schirmer Engineering Corporation,
MA [SE]
(Alt. to J. E. Churchill)
Robert J. Eugene, Underwriters Laboratories Inc., WA [RT]
(Alt. to H. Hopper)
Mark Kluver, Portland Cement Association, CA [M]
(Alt. to S. V. Skalko)

Kimberly A. Marks, The Marks Design Group, Inc., TX [U]
(Alt. to B. Ebstein)
Eric N. Mayl, Koffel Associates, Inc., MD
(Alt. to J. K. Lathrop)
Rodney A. McPhee, Canadian Wood Council, ON [M]
(Alt. to J. B. Stone)
Richard P. Thornberry, The Code Consortium, Inc. CA [M]
(Alt. to A. Tamim)
Robert J. Wills, American Iron and Steel Institute, AL [M]
(Alt. to D. H. MacKinnon)

Nonvoting

Carol A. Caldwell, Caldwell Consulting, Ltd, New
Zealand

Pichaya Chantranuwat, Fusion Consultants Co. Ltd.,
Thailand

Ron Côté, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on the basic goals, objectives, performance requirements, and definitions for protection of human life and property from fire, earthquake, flood, wind, and other circumstances capable of producing similar consequences and on the nonemergency and emergency movement of people.

Technical Committee on Furnishings and Contents (SAF-FUR)

William E. Fitch, *Chair*
Omega Point Laboratories Inc., TX [RT]

Steven E. Younis, *Nonvoting Secretary*
NFPA, MA

Patty K. Adair, American Textile Manufacturers Institute,
DC [M]
Alastair J. M. Aikman, National Research Council of
Canada, ON [RT]
Vytenis (Vyto) Babrauskas, Fire Science and Technology
Inc., WA [SE]
Lisa Bonneville, Bonneville Design, MA [U]
Rep. American Society of Interior Designers
Eugene A. Cable, U.S. Department of Veterans Affairs, NY
[U]

Frederic B. Clarke, Benjamin Clarke Associates, Inc., VA
[SE]
Paul Dillon, Southern Polytechnic State University, GA [M]
Pravinray D. Gandhi, Underwriters Laboratories Inc., IL
[RT]
Marcelo M. Hirschler, GBH International, CA [SE]
E. Ken McIntosh, Carpet and Rug Institute, GA [M]
T. Hugh Talley, Hugh Talley Company, TN [M]
Rep. American Furniture Manufacturers Association

Alternates

Raman B. Chauhan, National Research Council of
Canada, ON [RT]
(Alt. to A. J. M. Aikman)
James K. Lathrop, Koffel Associates, Inc., CT [M]
(Alt. to E. K. McIntosh)

James V. Ryan, MD [SE]
(Alt. to F. B. Clarke)
Shelley Siegel, Accessible Interiors' Network, Inc., FL [U]
(Alt. to L. Bonneville)

Nonvoting

Hammad Malik, U.S. Consumer Product Safety
Commission, MD

Ron Côté, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on limiting the impact of furnishings and building contents effect on protection of human life and property from fire and other circumstances capable of producing similar consequences and on the emergency movement of people.

Technical Committee on Health Care Occupancies (SAF-HEA)

Daniel J. O'Connor, *Chair*
Schirmer Engineering Corporation, IL [SE]

Ron Coté, *Nonvoting Secretary*
NFPA, MA

James R. Ambrose, Code Consultants, Inc., MO [SE]
William N. Brooks, Eichleay Engineers, Inc., PA [SE]
Kenneth E. Bush, Maryland State Fire Marshals Office,
MD [E]
 Rep. International Fire Marshals Association
Wayne G. Carson, Carson Associates, Inc., VA [SE]
Michael Crowley, The RJA Group, Inc., TX [SE]
Douglas S. Erickson, American Society for Healthcare
Engineering, VI [U]
Kenneth S. Faulstich, U.S. Department of Veterans
Affairs, DC [U]
John E. Fishbeck, Joint Commission on Accreditation of
Healthcare Organizations, IL [E]
Curt Fogel, Vaaler Insurance, Inc., ND [I]
Antonio Freire, Axa Courtage, France [I]
Donald W. Harris, California Office of Health Planning
& Development, CA [E]
Thomas W. Jaeger, Gage-Babcock & Associates, Inc., VA
[U]
 Rep. American Health Care Association

Ronald K. Mengel, System Sensor, IL [M]
 Rep. National Electrical Manufacturers Association
John I. Mills, Beery, Rio & Associates, VA [SE]
Kirby W. Perry, Kirby W. Perry Architects & Associates,
Inc., TX [SE]
 Rep. American Institute of Architects
Peter P. Petresky, Pennsylvania Department of Health,
PA [E]
 Rep. Association of Health Facility Survey Agencies
Brian Prediger, U.S. Department of the Army, MD [U]
Thomas A. Salamone, Healthcare & Life Safety Concepts,
NY [I]
 Rep. Kemper Insurance Companies
David M. Sine, David M. Sine & Associates, TX [U]
 Rep. National Association of Psychiatric Health
Systems
Richard D. Strub, Life Care Centers of America, TN [U]
 Rep. NFPA Health Care Section
Mayer D. Zimmerman, U.S. Department of Health and
Human Services, MD [E]

Alternates

James H. Antell, The RJA Group, Inc., IL [SE]
 (Alt. to M. Crowley)
John F. Deubler, Schirmer Engineering Corporation, VA
[SE]
 (Alt. to D. J. O'Connor)
Lori Drexler, Code Consultants, Inc., MO [SE]
 (Alt. to J. R. Ambrose)
J. Richard Fruth, Hayes Large Architects, PA [SE]
 (Alt. to K. W. Perry)

Thomas W. Gardner, Gage-Babcock & Associates, Inc., VA
[SE]
 (Alt. to T. W. Jaeger)
Philip R. Jose, U.S. Department of Veterans Affairs, NY [U]
 (Alt. to K. Faulstich)
William E. Koffel, Koffel Associates, Inc., MD [U]
 (Alt. to D. S. Erickson)
John S. Taylor, St. Vincent's Hospital, AL [U]
 (Alt. to R. D. Strub)

Nonvoting

Pichaya Chantranuwat, Fusion Consultants Co. Ltd.,
Thailand

Ron Coté, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on protection of human life and property from fire and other circumstances capable of producing similar consequences, and on the emergency movement of people, in health care occupancies.

Technical Committee on Industrial, Storage and Miscellaneous Occupancies (SAF-IND)

Wayne D. Holmes, *Chair*
HSB Professional Loss Control, CT [I]

Walter P. Sterling, *Nonvoting Secretary*
NFPA, MA

John A. Alderman, RRS Engineering, TX [SE]
Rep. American Society of Safety Engineers
Raymond E. Arntson, Rayden Research LLC, WI [SE]
Donald C. Birchler, FP&C Consultants Inc., MO [SE]
Howard M. Bucci, U.S. Department of Energy, WA [U]
Timothy T. Callas, Ralph Gerdes Consultants, LLC, IN [SE]
John F. Farney, Jr., Sargent & Lundy Engineers, IL [SE]
Larry L. Fluor, Fluor, Incorporated, CA [M]
Rep. Compressed Gas Association
Larry N. Garrett, Delphi Automotive Systems Corp., IN [U]
Rep. NFPA Industrial Fire Protection Section
James Golinveaux, Tyco Fire Products, RI [M]
Rep. American Fire Sprinkler Association, Inc.
Dale A. Harshbarger, Hebron Fire Protection District, KY [E]
Bruce W. Hisley, Fairfield, PA [E]
Rep. International Fire Marshals Association
Jonathan Humble, American Iron and Steel Institute, CT [M]

Ronald Keefer, Menlo Park Fire Protection District, CA [E]
Marshall A. Klein, Marshall A. Klein & Associates, Inc., MD [U]
Rep. Automotive Oil Change Association
Neal W. Krantz, Siemens Fire Safety, MI [M]
Rep. National Electrical Manufacturers Association
Raymond W. Lonabaugh, National Fire Sprinkler Association, PA [M]
Patrick A. McLaughlin, McLaughlin & Associates, CA [U]
Rep. Semiconductor Industry Association
Jeffrey M. Shapiro, International Code Consultants, TX [M]
Rep. The Chlorine Institute
Stephen V. Skalko, Portland Cement Association, GA [M]
David C. Tabar, The Sherwin-Williams Company, OH [U]
Gregory W. Thomas, Liberty Mutual Group, CT [I]
Rep. Alliance of American Insurers
Carl Dewayne Wren, Austin Fire Department, TX [E]

Alternates

Thomas L. Allison, Westinghouse Savannah River Company, SC [U]
(Vot. Alt. to Westinghouse Savannah River Co. Rep.)
Clarence D. (Dale) Eggen, U.S. Department of Energy, WA [U]
(Alt. to H. M. Bucci)
Jack Gump, HSB Professional Loss Control, TN [I]
(Alt. to W. D. Holmes)
David M. Hammerman, Marshall A. Klein & Associates, Inc., MD [U]
(Alt. to M. A. Klein)
Roland J. Huggins, American Fire Sprinkler Association, Inc., TX [M]
(Alt. to J. Golinveaux)

Mark Kluver, Portland Cement Association, CA [M]
(Alt. to S. V. Skalko)
William E. Koffel, Koffel Associates, Inc., MD [U]
(Alt. to P. A. McLaughlin)
Michael E. Lyden, The Chlorine Institute, Inc., DC [M]
(Alt. to J. M. Shapiro)
Roger A. Smith, Compressed Gas Association, Inc., VA [M]
(Alt. to L. L. Fluor)
Robert J. Wills, American Iron and Steel Institute, AL [M]
(Alt. to J. Humble)

Walter P. Sterling, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on protection of human life and property from fire and other circumstances capable of producing similar consequences, and on the emergency movement of people, in industrial and storage occupancies, special structures, windowless and underground buildings, and high-rise buildings.

Technical Committee on Means of Egress (SAF-MEA)

William E. Koffel, Jr., Chair
Koffel Associates, Inc., MD [SE]

Ron Côté, Nonvoting Secretary
NFPA, MA

John L. Barrios, Tampa Department of Business and Community Services, FL [E]
Rep. Southern Building Code Congress Intl Inc./International Code Council, Inc.
John L. Bryan, Frederick, MD [SE]
Kenneth E. Bush, Maryland State Fire Marshals Office, MD [E]
Rep. International Fire Marshals Association
Davie J. Camp, Thyssen Krupp Elevator, TN [M]
Rep. National Elevator Industry Inc.
Steven DiPilla, ACE USA/ESIS Risk Control Services, NJ [I]
Rep. American Society of Safety Engineers
Joshua W. Elvove, U.S. Department of Veterans Affairs, CO [U]
Gene B. Endthoff, National Fire Sprinkler Association, IL [M]
Philip C. Favro, Philip C. Favro & Associates, CA [SE]
Edward L. Fixen, Schirmer Engineering Corporation, CA [I]
David W. Frable, U.S. General Services Administration, IL [U]
Rita C. Guest, Carson Guest, Inc., GA [U]
Rep. American Society of Interior Designers

Billy G. Helton, Lithonia Emergency Systems, GA [M]
Rep. National Electrical Manufacturers Association
Lawrence J. McGinty, U.S. Central Intelligence Agency, DC [U]
Wayne Menuz, Underwriters Laboratories Inc., CA [RT]
Richard A. Morris, National Association of Home Builders, DC [U]
Jake Pauls, Jake Pauls Consulting Services in Building Use & Safety, MD [C]
Rep. American Public Health Association
Robert R. Perry, Robert Perry Associates Inc., IL [M]
Rep. Door & Hardware Institute
Eric Rosenbaum, Hughes Associates, Inc., MD [SE]
Leslie Strull, The RJA Group, Inc., IL [SE]
Michael Tierney, Builders Hardware Manufacturers Association, CT [M]
Michael D. Tomy, Heery International Inc., GA [SE]
Rep. American Institute of Architects
Joseph H. Versteeg, Versteeg Associates, CT [E]
Rep. Fairfield CT Fire Marshal's Office
David L. Wismer, Philadelphia Department of Licenses & Inspections, PA [E]

Alternates

John R. Battles, Southern Building Code Congress International, AL [E]
(Alt. to J. L. Barrios)
Charles H. Berry, Baltimore VA Medical Center, MD [U]
(Alt. to J. W. Elvove)
Warren D. Bonisch, Schirmer Engineering Corporation, TX [SE]
(Alt. to E. L. Fixen)
Edward A. Donoghue, Edward A. Donoghue Associates, Inc., NY [M]
(Alt. to D. J. Camp)
Barbara Ebstein, Vinick Associates, Inc., CT [U]
(Alt. to R. C. Guest)
David A. Gilda, Builders Hardware Manufacturers Association, CT [M]
(Alt. to M. Tierney)
Miles J. Haber, Monument Construction Inc., MD [M]
(Alt. to R. A. Morris)

James K. Lathrop, Koffel Associates, Inc., CT [SE]
(Alt. to W. E. Koffel, Jr.)
R. T. Leicht, Delaware Fire Marshal's Office, DE [E]
(Alt. to K. E. Bush)
James A. Milke, University of Maryland, MD [SE]
(Alt. to J. L. Bryan)
Ronald H. Minter, Thomas & Betts, TN [M]
(Alt. to B. G. Helton)
Harold E. Nelson, Hughes Associates, Inc., VA [SE]
(Alt. to E. R. Rosenbaum)
Roy W. Schwarzenberg, U.S. Central Intelligence Agency, DC [U]
(Alt. to L. J. McGinty)
Michael S. Shulman, Underwriters Laboratories Inc., CA [RT]
(Alt. to W. Menuz)

Nonvoting

Pichaya Chantranuwat, Fusion Consultants Co. Ltd., Thailand

Ron Côté, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on the general requirements for safe egress for protection of human life from fire and other circumstances capable of producing similar consequences and on the nonemergency and emergency movement of people.

Technical Committee on Mercantile and Business Occupancies (SAF-MER)

Ed Schultz, Chair
Code Consultants Inc., MO [SE]

Walter P. Sterling, Nonvoting Secretary
NFPA, MA

David M. Banwarth, David M. Banwarth Associates, LLC, MD [SE]
E. Joseph Bocci, U.S. Department of the Treasury, DC [U]
Kenneth E. Bush, Maryland State Fire Marshals Office, MD [E]
Rep. International Fire Marshals Association
David A. Dodge, Safety and Forensic Consulting, ME [SE]
Rep. American Society of Safety Engineers
Douglas S. Erickson, American Society for Healthcare Engineering, VI [U]
Sam W. Francis, American Forest & Paper Association, PA [M]
Douglas R. Freels, Performance Design Technologies, TN [SE]
Daniel J. Gauvin, Simplex Time Recorder Co., MA [M]
Rep. National Electrical Manufacturers Association
William Hiotaky, The Taubman Company, MI [U]

Wayne D. Holmes, HSB Professional Loss Control, CT [I]
Jonathan Humble, American Iron and Steel Institute, CT [M]
Michael J. Laderoute, MJL Associates, Inc., VA [M]
Rep. Fire Equipment Manufacturers' Association
Brian L. Marburger, Kemper Insurance Companies, IL [I]
Rep. American Insurance Services Group
Richard V. Moon, Insurance Services Office, NJ [I]
Lawrence G. Perry, Building Owners & Managers Assn. International, MD [U]
Sheldon S. Rucinski, Schirmer Engineering Corporation, IL [I]
David C. Tabar, The Sherwin-Williams Company, OH [U]
Richard P. Thornberry, The Code Consortium, Inc., CA [SE]
William J. Tomes, TVA Fire and Life Safety, GA [U]
Rep. The Home Depot

Alternates

Tracey D. Bellamy, TVA Fire and Life Safety, GA [U]
(Alt. to W. J. Tomes)
Darryl Thomas Brown, Performance Design Technologies, TN [SE]
(Alt. to D. R. Freels)
Lawrence G. Danielkiewicz, The Taubman Company, MI [U]
(Alt. to W. Hiotaky)
Jack Gump, HSB Professional Loss Control, TN [I]
(Alt. to W. D. Holmes)
Patrick A. McLaughlin, McLaughlin & Associates, RI [U]
(Alt. to D. C. Tabar)
Richard R. Osman, Schirmer Engineering Corporation, IL [SE]
(Alt. to S. S. Rucinski)

Dennis L. Pitts, American Forest & Paper Association, TX [M]
(Alt. to S. W. Francis)
Terry Schultz, Code Consultants, Inc., MO [SE]
(Alt. to E. Schultz)
Robert J. Wills, American Iron and Steel Institute, AL [M]
(Alt. to J. Humble)
Dale Woodin, American Society for Healthcare Engineering, IL [U]
(Alt. to D. S. Erickson)

Walter P. Sterling, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on protection of human life and property from fire and other circumstances capable of producing similar consequences, and for the emergency movement of people, in mercantile and business occupancies.

Technical Committee on Residential Occupancies (SAF-RES)

James K. Lathrop, *Chair*
Koffel Associates, Inc., CT [SE]

Gregory E. Harrington, *Nonvoting Secretary*
NFPA, MA

Warren D. Bonisch, Schirmer Engineering Corporation,
TX [I]

H. Wayne Boyd, U.S. Safety & Engineering Corp., CA
[M]

Harry L. Bradley, Maryland State Fire Marshals Office,
MD [E]

Rep. International Fire Marshals Association

Phillip A. Brown, American Fire Sprinkler Association,
Inc., TX [IM]

James J. Convery, Gage-Babcock & Associates, Inc., VA
[SE]

Thomas G. Daly, Hilton Hotels Corporation, CA [U]

Rep. NFPA Lodging Industry Section

Matthew D. Dobson, National Association of Home
Builders, DC [U]

Sam W. Francis, American Forest & Paper Association, PA
[M]

Ralph Gerdes, Ralph Gerdes Consultants, LLC, IN [SE]

Kenneth E. Isman, National Fire Sprinkler Association,
NY [M]

Marshall A. Klein, Marshall A. Klein & Associates, Inc.,
MD [SE]

Joseph J. Messersmith, Jr., Portland Cement Association,
VA [M]

Ronald G. Nickson, National Multi Housing Council, DC
[U]

Michael A. O'Hara, The MountainStar Group, MN [SE]

Erin A. M. Oneisom, U.S. Air Force, Germany [U]

Jake Pauls, Jake Pauls Consulting Services in Building
Use & Safety, MD [C]

Rep. American Public Health Association

Peter Puhlick, University of Connecticut, CT [U]

Jim Ray, Marriott International, Inc., DC [U]

Rep. American Hotel & Lodging Association

T. Hugh Talley, Hugh Talley Company, TN [M]

Rep. American Furniture Manufacturers Association

Alternates

Carl F. Baldassarra, Schirmer Engineering Corporation,
IL [I]

(Alt. to W. Bonisch)

James R. Bell, Marriott International, Inc., DC [U]

(Alt. to J. Ray)

Byron L. Bariese, The RJA Group, Inc., VA [U]

(Alt. to T. G. Daly)

David Cook, Ralph Gerdes Consultants, IN [SE]

(Alt. to R. Gerdes)

Thomas W. Gardner, Gage-Babcock & Associates, Inc., VA
[SE]

(Alt. to J. J. Convery)

Greg Gottlieb, Hauppauge Fire District, NY [C]

(Alt. to NFPA/FSS Rep.)

David M. Hammerman, Marshall A. Klein and Associates,
Inc., MD [SE]

(Alt. to M. A. Klein)

Stanley C. Harbuck, School of Building Inspection, UT [C]

(Alt. to J. Pauls)

Robert Howe, Vermont Department of Labor & Industry,
VT [E]

(Alt. to H. L. Bradley)

Mark Kluver, Portland Cement Association, CA [M]

(Alt. to J. J. Messersmith, Jr.)

Dennis L. Pitts, American Forest & Paper Association, TX
[M]

(Alt. to S. W. Francis)

Jeffrey M. Shapiro, International Code Consultants, TX
[U]

(Alt. to R. G. Nickson)

Victoria Valentine, National Fire Sprinkler Association,
NY [M]

(Alt. to K. E. Isman)

Fred K. Walker, U.S. Air Force, FL [U]

(Alt. to E. A. M. Oneisom)

Gregory E. Harrington, NFPA Staff Liaison

Committee Scope: This Committee shall have primary responsibility for documents on protection of human life and property from fire and other circumstances capable of producing similar consequences, and on the emergency movement of people, in hotels, dormitories, apartments, lodging and rooming houses, and one- and two-family dwellings.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

These lists represent the membership at the time the Committees were balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

Contents

Chapter 1 Administration	101- 21	7.9 Emergency Lighting	101- 67
1.1 Scope	101- 21	7.10 Marking of Means of Egress	101- 68
1.2 Purpose	101- 21	7.11 Special Provisions for Occupancies with High Hazard Contents	101- 69
1.3 Application	101- 21	7.12 Mechanical Equipment Rooms, Boiler Rooms, and Furnace Rooms	101- 70
1.4 Equivalency	101- 21		
1.5 Units and Formulas	101- 21	Chapter 8 Features of Fire Protection	101- 70
1.6 Enforcement	101- 21	8.1 General	101- 70
Chapter 2 Referenced Publications	101- 21	8.2 Construction and Compartmentation ...	101- 70
2.1 General	101- 21	8.3 Fire Barriers	101- 71
2.2 NFPA Publications	101- 21	8.4 Smoke Partitions	101- 73
2.3 Other Publications	101- 22	8.5 Smoke Barriers	101- 74
Chapter 3 Definitions	101- 23	8.6 Vertical Openings	101- 75
3.1 General	101- 23	8.7 Special Hazard Protection	101- 78
3.2 NFPA Official Definitions	101- 23		
3.3 General Definitions	101- 23	Chapter 9 Building Service and Fire Protection Equipment	101- 78
Chapter 4 General	101- 32	9.1 Utilities	101- 78
4.1 Goals	101- 32	9.2 Heating, Ventilating, and Air-Conditioning	101- 78
4.2 Objectives	101- 32	9.3 Smoke Control	101- 79
4.3 Assumption	101- 32	9.4 Elevators, Escalators, and Conveyors ...	101- 79
4.4 Life Safety Compliance Options	101- 32	9.5 Rubbish Chutes, Incinerators, and Laundry Chutes	101- 79
4.5 Fundamental Requirements	101- 32	9.6 Fire Detection, Alarm, and Communications Systems	101- 80
4.6 General Requirements	101- 33	9.7 Automatic Sprinklers and Other Extinguishing Equipment	101- 82
4.7 Fire Drills	101- 34	9.8 Special Inspections and Tests	101- 83
4.8 Emergency Plan	101- 34		
Chapter 5 Performance-Based Option	101- 34	Chapter 10 Interior Finish, Contents, and Furnishings	101- 83
5.1 General Requirements	101- 34	10.1 General	101- 83
5.2 Performance Criteria	101- 35	10.2 Interior Finish	101- 84
5.3 Retained Prescriptive Requirements ...	101- 35	10.3 Contents and Furnishings	101- 86
5.4 Design Specifications and Other Conditions	101- 35		
5.5 Design Fire Scenarios	101- 36	Chapter 11 Special Structures and High-Rise Buildings	101- 86
5.6 Evaluation of Proposed Designs	101- 36	11.1 General Requirements	101- 86
5.7 Safety Factors	101- 37	11.2 Open Structures	101- 87
5.8 Documentation Requirements	101- 37	11.3 Towers	101- 87
Chapter 6 Classification of Occupancy and Hazard of Contents	101- 37	11.4 Water-Surrounded Structures	101- 88
6.1 Classification of Occupancy	101- 37	11.5 Piers	101- 89
6.2 Hazard of Contents	101- 39	11.6 Vehicles and Vessels	101- 89
Chapter 7 Means of Egress	101- 41	11.7 Underground and Limited Access Structures	101- 89
7.1 General	101- 41	11.8 High-Rise Buildings	101- 90
7.2 Means of Egress Components	101- 43	11.9 Permanent Membrane Structures	101- 90
7.3 Capacity of Means of Egress	101- 61	11.10 Temporary Membrane Structures	101- 92
7.4 Number of Means of Egress	101- 63	11.11 Tents	101- 93
7.5 Arrangement of Means of Egress	101- 63		
7.6 Measurement of Travel Distance to Exits	101- 65		
7.7 Discharge from Exits	101- 65		
7.8 Illumination of Means of Egress	101- 66		

Chapter 12 New Assembly Occupancies	101- 94	Chapter 18 New Health Care Occupancies	101-154
12.1 General Requirements	101- 94	18.1 General Requirements	101-154
12.2 Means of Egress Requirements	101- 94	18.2 Means of Egress Requirements	101-156
12.3 Protection	101-101	18.3 Protection	101-159
12.4 Special Provisions	101-103	18.4 Special Provisions	101-162
12.5 Building Services	101-110	18.5 Building Services	101-164
12.6 Reserved	101-110	18.6 Reserved	101-164
12.7 Operating Features	101-110	18.7 Operating Features	101-164
Chapter 13 Existing Assembly Occupancies	101-113	Chapter 19 Existing Health Care Occupancies ...	101-166
13.1 General Requirements	101-113	19.1 General Requirements	101-166
13.2 Means of Egress Requirements	101-115	19.2 Means of Egress Requirements	101-168
13.3 Protection	101-120	19.3 Protection	101-170
13.4 Special Provisions	101-122	19.4 Special Provisions	101-175
13.5 Building Services	101-128	19.5 Building Services	101-175
13.6 Reserved	101-128	19.6 Reserved	101-176
13.7 Operating Features	101-128	19.7 Operating Features	101-176
Chapter 14 New Educational Occupancies	101-132	Chapter 20 New Ambulatory Health Care	
14.1 General Requirements	101-132	Occupancies	101-177
14.2 Means of Egress Requirements	101-132	20.1 General Requirements	101-177
14.3 Protection	101-134	20.2 Means of Egress Requirements	101-179
14.4 Special Provisions	101-135	20.3 Protection	101-179
14.5 Building Services	101-136	20.4 Special Provisions	101-181
14.6 Reserved	101-136	20.5 Building Services	101-181
14.7 Operating Features	101-136	20.6 Reserved	101-181
Chapter 15 Existing Educational Occupancies ...	101-136	20.7 Operating Features	101-181
15.1 General Requirements	101-136	Chapter 21 Existing Ambulatory Health Care	
15.2 Means of Egress Requirements	101-137	Occupancies	101-182
15.3 Protection	101-139	21.1 General Requirements	101-182
15.4 Special Provisions	101-140	21.2 Means of Egress Requirements	101-184
15.5 Building Services	101-141	21.3 Protection	101-185
15.6 Reserved	101-141	21.4 Special Provisions	101-186
15.7 Operating Features	101-141	21.5 Building Services	101-186
Chapter 16 New Day-Care Occupancies	101-141	21.6 Reserved	101-186
16.1 General Requirements	101-141	21.7 Operating Features	101-186
16.2 Means of Egress Requirements	101-142	Chapter 22 New Detention and Correctional	
16.3 Protection	101-143	Occupancies	101-187
16.4 Special Provisions	101-145	22.1 General Requirements	101-187
16.5 Building Services	101-145	22.2 Means of Egress Requirements	101-189
16.6 Day-Care Homes	101-145	22.3 Protection	101-191
16.7 Operating Features	101-147	22.4 Special Provisions	101-193
Chapter 17 Existing Day-Care Occupancies	101-147	22.5 Building Services	101-196
17.1 General Requirements	101-147	22.6 Reserved	101-197
17.2 Means of Egress Requirements	101-148	22.7 Operating Features	101-197
17.3 Protection	101-150	Chapter 23 Existing Detention and Correctional	
17.4 Special Provisions	101-151	Occupancies	101-198
17.5 Building Services	101-151	23.1 General Requirements	101-198
17.6 Day-Care Homes	101-152	23.2 Means of Egress Requirements	101-200
17.7 Operating Features	101-153	23.3 Protection	101-202
		23.4 Special Provisions	101-205
		23.5 Building Services	101-205

23.6	(Reserved)	101-206	31.6	Reserved	101-229
23.7	Operating Features	101-206	31.7	Operating Features: Emergency Instructions for Residents of Apartment Buildings	101-229
Chapter 24	One- and Two-Family Dwellings	101-207	Chapter 32	New Residential Board and Care Occupancies	101-229
24.1	General Requirements	101-207	32.1	General Requirements	101-229
24.2	Means of Escape Requirements	101-207	32.2	Small Facilities	101-230
24.3	Protection	101-209	32.3	Large Facilities	101-233
24.4	Reserved	101-209	32.4	Suitability of an Apartment Building to House a Board and Care Occupancy	101-236
24.5	Building Services	101-209	32.5	Reserved	101-236
Chapter 25	Reserved	101-209	32.6	Reserved	101-236
Chapter 26	Lodging or Rooming Houses	101-209	32.7	Operating Features	101-236
26.1	General Requirements	101-209	Chapter 33	Existing Residential Board and Care Occupancies	101-237
26.2	Means of Escape Requirements	101-210	33.1	General Requirements	101-237
26.3	Protection	101-210	33.2	Small Facilities	101-238
26.4	Reserved	101-211	33.3	Large Facilities	101-242
26.5	Building Services	101-211	33.4	Suitability of an Apartment Building to House a Board and Care Occupancy	101-246
Chapter 27	Reserved	101-211	33.5	Reserved	101-246
Chapter 28	New Hotels and Dormitories	101-211	33.6	Reserved	101-246
28.1	General Requirements	101-211	33.7	Operating Features	101-246
28.2	Means of Egress Requirements	101-212	Chapter 34	Reserved	101-247
28.3	Protection	101-214	Chapter 35	Reserved	101-247
28.4	Special Provisions	101-215	Chapter 36	New Mercantile Occupancies	101-247
28.5	Building Services	101-215	36.1	General Requirements	101-247
28.6	Reserved	101-215	36.2	Means of Egress Requirements	101-248
28.7	Operating Features	101-216	36.3	Protection	101-250
Chapter 29	Existing Hotels and Dormitories	101-216	36.4	Special Provisions	101-251
29.1	General Requirements	101-216	36.5	Building Services	101-254
29.2	Means of Egress Requirements	101-216	36.6	Reserved	101-254
29.3	Protection	101-218	36.7	Operating Features	101-254
29.4	Special Provisions	101-220	Chapter 37	Existing Mercantile Occupancies	101-254
29.5	Building Services	101-220	37.1	General Requirements	101-254
29.6	Reserved	101-220	37.2	Means of Egress Requirements	101-255
29.7	Operating Features	101-220	37.3	Protection	101-257
Chapter 30	New Apartment Buildings	101-220	37.4	Special Provisions	101-258
30.1	General Requirements	101-220	37.5	Building Services	101-260
30.2	Means of Egress Requirements	101-221	37.6	Reserved	101-260
30.3	Protection	101-222	37.7	Operating Features	101-260
30.4	Special Provisions	101-224	Chapter 38	New Business Occupancies	101-260
30.5	Building Services	101-224	38.1	General Requirements	101-260
30.6	Reserved	101-225	38.2	Means of Egress Requirements	101-261
30.7	Operating Features: Emergency Instructions for Residents of Apartment Buildings	101-225	38.3	Protection	101-263
Chapter 31	Existing Apartment Buildings	101-225	38.4	Special Provisions	101-263
31.1	General Requirements	101-225			
31.2	Means of Egress Requirements	101-225			
31.3	Protection	101-227			
31.4	Special Provisions	101-229			
31.5	Building Services	101-229			

38.5	Building Services	101-264	Chapter 41	Reserved	101-271
38.6	Reserved	101-264	Chapter 42	Storage Occupancies	101-271
38.7	Operating Features	101-264	42.1	General Requirements	101-271
Chapter 39	Existing Business Occupancies	101-264	42.2	Means of Egress Requirements	101-271
39.1	General Requirements	101-264	42.3	Protection	101-273
39.2	Means of Egress Requirements	101-264	42.4	Special Provisions	101-274
39.3	Protection	101-266	42.5	Building Services	101-274
39.4	Special Provisions	101-267	42.6	Special Provisions for Aircraft Storage Hangars	101-274
39.5	Building Services	101-267	42.7	Special Provisions for Grain or Other Bulk Storage Elevators	101-274
39.6	Reserved	101-267	42.8	Special Provisions for Parking Structures	101-274
39.7	Operating Features	101-267	Annex A	Explanatory Material	101-276
Chapter 40	Industrial Occupancies	101-267	Annex B	Informational References	101-357
40.1	General Requirements	101-267	Index	101-360	
40.2	Means of Egress Requirements	101-268			
40.3	Protection	101-270			
40.4	Special Provisions: High-Rise Buildings ...	101-271			
40.5	Building Services	101-271			
40.6	Special Provisions for Aircraft Servicing Hangars	101-271			

NFPA 101® Life Safety Code®

2003 Edition

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

Changes other than editorial are indicated by a vertical rule beside the paragraph, table, or figure in which the change occurred. These rules are included as an aid to the user in identifying changes from the previous edition. Where one or more complete paragraphs have been deleted, the deletion is indicated by a bullet (•) between the paragraphs that remain.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, Annex B lists the complete title and edition of the source documents for both mandatory and nonmandatory extracts. Editorial changes to extracted material consist of revising references to an appropriate division in this document or the inclusion of the document number with the division number when the reference is to the original document. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration

1.1* Scope.

1.1.1 Title. NFPA 101®, *Life Safety Code*® shall be known as the *Life Safety Code*®, is cited as such, and shall be referred to herein as “this Code” or “the Code.”

1.1.2* Danger to Life from Fire. The Code addresses those construction, protection, and occupancy features necessary to minimize danger to life from fire, including smoke, fumes, or panic.

1.1.3 Egress Facilities. The Code establishes minimum criteria for the design of egress facilities so as to allow prompt escape of occupants from buildings or, where desirable, into safe areas within buildings.

1.1.4 Other Fire-Related Considerations. The Code addresses other considerations that are essential to life safety in recognition of the fact that life safety is more than a matter of egress. The Code also addresses protective features and systems, building services, operating features, maintenance activities, and other provisions in recognition of the fact that achieving an acceptable degree of life safety depends on additional safeguards to provide adequate egress time or protection for people exposed to fire.

1.1.5* Considerations Not Related to Fire. The Code also addresses other considerations that, while important in fire conditions, provide an ongoing benefit in other conditions of use, including non-fire emergencies.

1.1.6 Areas Not Addressed. The Code does not address the following:

- (1)*General fire prevention or building construction features that are normally a function of fire prevention codes and building codes

- (2) Prevention of injury incurred by an individual due to that individual’s failure to use reasonable care
- (3) Preservation of property from loss by fire

1.2* Purpose. The purpose of this Code is to provide minimum requirements, with due regard to function, for the design, operation, and maintenance of buildings and structures for safety to life from fire. Its provisions will also aid life safety in similar emergencies.

1.3* Application.

1.3.1* New and Existing Buildings and Structures. The Code shall apply to both new construction and existing buildings and existing structures.

1.3.2 Vehicles and Vessels. The Code shall apply to vehicles, vessels, or other similar conveyances, as specified in Section 11.6, in which case such vehicles and vessels shall be treated as buildings.

1.4* Equivalency. Nothing in this Code is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety over those prescribed by this Code.

1.4.1 Technical Documentation. Technical documentation shall be submitted to the authority having jurisdiction to demonstrate equivalency.

1.4.2 Approval. The system, method, or device shall be approved for the intended purpose by the authority having jurisdiction.

1.4.3* Equivalent Compliance. Alternative systems, methods, or devices approved as equivalent by the authority having jurisdiction shall be recognized as being in compliance with this Code.

1.5 Units and Formulas.

1.5.1 SI Units. Metric units of measurement in this Code are in accordance with the modernized metric system known as the International System of Units (SI).

1.5.2 Primary Values. The SI value for a measurement, and the inch-pound value given in parentheses, shall each be acceptable for use as primary units for satisfying the requirements of this Code.

1.6 Enforcement. This Code shall be administered and enforced by the authority having jurisdiction designated by the governing authority.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this Code and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2002 edition.

NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2002 edition.

NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, 2002 edition.

NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, 2002 edition.

NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*, 2003 edition.

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2002 edition.

NFPA 30, *Flammable and Combustible Liquids Code*, 2000 edition.

NFPA 30B, *Code for the Manufacture and Storage of Aerosol Products*, 2002 edition.

NFPA 31, *Standard for the Installation of Oil-Burning Equipment*, 2001 edition.

NFPA 40, *Standard for the Storage and Handling of Cellulose Nitrate Film*, 2001 edition.

NFPA 45, *Standard on Fire Protection for Laboratories Using Chemicals*, 2000 edition.

NFPA 54, *National Fuel Gas Code*, 2002 edition.

NFPA 58, *Liquefied Petroleum Gas Code*, 2001 edition.

NFPA 70, *National Electrical Code*®, 2002 edition.

NFPA 72®, *National Fire Alarm Code*®, 2002 edition.

NFPA 80, *Standard for Fire Doors and Fire Windows*, 1999 edition.

NFPA 82, *Standard on Incinerators and Waste and Linen Handling Systems and Equipment*, 1999 edition.

NFPA 88A, *Standard for Parking Structures*, 2002 edition.

NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, 2002 edition.

NFPA 90B, *Standard for the Installation of Warm Air Heating and Air-Conditioning Systems*, 2002 edition.

NFPA 91, *Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Noncombustible Particulate Solids*, 1999 edition.

NFPA 96, *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*, 2001 edition.

NFPA 99, *Standard for Health Care Facilities*, 2002 edition.

NFPA 101A, *Guide on Alternative Approaches to Life Safety*, 2001 edition.

NFPA 110, *Standard for Emergency and Standby Power Systems*, 2002 edition.

NFPA 111, *Standard on Stored Electrical Energy Emergency and Standby Power Systems*, 2001 edition.

NFPA 160, *Standard for Flame Effects Before an Audience*, 2001 edition.

NFPA 211, *Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances*, 2003 edition.

NFPA 220, *Standard on Types of Building Construction*, 1999 edition.

NFPA 221, *Standard for Fire Walls and Fire Barrier Walls*, 2000 edition.

NFPA 230, *Standard for the Fire Protection of Storage*, 2003 edition.

NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*, 2000 edition.

NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*, 1999 edition.

NFPA 252, *Standard Methods of Fire Tests of Door Assemblies*, 1999 edition.

NFPA 253, *Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source*, 2000 edition.

NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, 2000 edition.

NFPA 256, *Standard Methods of Fire Tests of Roof Coverings*, 1998 edition.

NFPA 257, *Standard on Fire Test for Window and Glass Block Assemblies*, 2000 edition.

NFPA 259, *Standard Test Method for Potential Heat of Building Materials*, 2003 edition.

NFPA 260, *Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture*, 1998 edition.

NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*, 1998 edition.

NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*, 2002 edition.

NFPA 267, *Standard Method of Test for Fire Characteristics of Mattresses and Bedding Assemblies Exposed to Flaming Ignition Source*, 1998 edition.

NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, 2000 edition.

NFPA 288, *Standard Methods of Fire Tests of Floor Fire Door Assemblies Installed Horizontally in Fire Resistance-Rated Floor Systems*, 2001 edition.

NFPA 418, *Standard for Heliports*, 2001 edition.

NFPA 430, *Code for the Storage of Liquid and Solid Oxidizers*, 2000 edition.

NFPA 432, *Code for the Storage of Organic Peroxide Formulations*, 2002 edition.

NFPA 434, *Code for the Storage of Pesticides*, 2002 edition.

NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*, 1999 edition.

NFPA 703, *Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*, 2000 edition.

NFPA 1126, *Standard for the Use of Pyrotechnics before a Proximate Audience*, 2001 edition.

NFPA 5000™, *Building Construction and Safety Code*™, 2003 edition.

2.3 Other Publications.

2.3.1 ACI Publication. American Concrete Institute, P.O. Box 9094, Farmington Hills, MI 48333.

ACI 216.1/TMS 0216.1, *Standard Method for Determining Fire Resistance of Concrete and Masonry Assemblies*.

2.3.2 ANSI Publications. American National Standards Institute, Inc., 11 West 42nd Street, 13th floor, New York, NY 10036.

ANSI A14.3, *Safety Requirements for Fixed Ladders*, 1992.

ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*, 1998.

BHMA/ANSI A156.19, *American National Standard for Power Assist and Low Energy Power Operated Doors*, 1997.

ANSI A1264.1, *Safety Requirements for Workplace Floor and Wall Openings, Stairs, and Railing Systems*, 1995.

ANSI/UL 1479, *Standard for Fire Tests of Through-Penetration Firestops*, 1995.

ANSI/UL 2079, *Tests of Fire Resistance of Building Joint Systems*, 1998. Underwriters Laboratories Inc., 333 Pfingsten Road., Northbrook, IL 60062.

2.3.3 ASCE Publication. American Society of Civil Engineers, 12801 Alexander Bell Drive, Reston, VA 20191.

ASCE/SFPE 29, *Standard Calculation Methods for Structural Fire Protection*, 1999.

2.3.4 ASME Publications. American Society of Mechanical Engineers, Three Park Avenue, New York, NY 10016-5990.

ASME A17.1, *Safety Code for Elevators and Escalators*, 2000.

ASME A17.3, *Safety Code for Existing Elevators and Escalators*, including Addenda A17.3a-2000, 1996.

2.3.5 ASTM Publications. American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

ASTM D 2859, *Flammability of Finished Textile Floor Covering Materials*.

ASTM D 2898, *Standard Test Methods for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing*, 1994 (1999).

ASTM E 136, *Standard Test Method for Behavior of Materials in a Vertical Tube Furnace at 750°C*, 1999.

ASTM E 814, *Standard Test Method for Fire Tests of Through Penetration Fire Stops*, 2002.

ASTM E 1537, *Standard Test Method for Fire Testing of Upholstered Furniture*, 2001.

ASTM E 1590, *Standard Test Method for Fire Testing of Mattresses*, 2001.

ASTM E 1591, *Standard Guide for Obtaining Data for Deterministic Fire Models*, 2000.

ASTM F 851, *Standard Test Method for Self-Rising Seat Mechanisms*, 1987.

ASTM G 155, *Standard Practice for Operating Xenon Light Apparatus for Exposure of Non-Metallic Materials*, 2000A e1.

2.3.6 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.

UL 555, *Standard for Fire Dampers*, 1999.

UL 555S, *Standard for Smoke Dampers*, 1996.

UL 924, *Emergency Lighting and Power Equipment*, 1995.

UL 1784, *Standard for Air-Leakage Tests of Door Assemblies*, 2001.

UL 1975, *Fire Tests for Foamed Plastics Used for Decorative Purposes*, 1996.

2.3.7 U.S. Government Publication. U.S. Government Printing Office, Washington, DC 20402.

Title 16, *Code of Federal Regulations*, Part 1632.

Third New International Dictionary of the English Language, Unabridged, shall be a source for ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). The organization, office, or individual responsible for approving equipment, materials, an installation, or a procedure.

3.2.3* Code. A standard that is an extensive compilation of provisions covering broad subject matter or that is suitable for adoption into law independently of other codes and standards.

3.2.4 Labeled. Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

3.2.5* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

3.2.6 Shall. Indicates a mandatory requirement.

3.2.7 Should. Indicates a recommendation or that which is advised but not required.

3.3 General Definitions.

3.3.1 Accessible Area of Refuge. See 3.3.17.1.

3.3.2 Accessible Means of Egress. See 3.3.136.1.

3.3.3 Addition. An increase in the building area, aggregate floor area, height or number of stories of a structure. [ASCE 7:9.2.1]

3.3.4 Air-Inflated Structure. See 3.3.217.1.

3.3.5 Airport Loading Walkway. An aboveground device through which passengers move between a point in an airport terminal building and an aircraft. Included in this category are walkways that are essentially fixed and permanently placed, or walkways that are essentially mobile in nature and that fold, telescope, or pivot from a fixed point at the airport terminal building. [415:1.4]

3.3.6 Airport Terminal Building. See 3.3.27.1.

3.3.7* Air-Supported Structure. See 3.3.217.2.

3.3.8* Aisle Accessway. The initial portion of an exit access that leads to an aisle.

3.3.9 Alarm.

3.3.9.1 Single Station Alarm. A detector comprising an assembly that incorporates a sensor, control components, and an alarm notification appliance in one unit operated from a power source either located in the unit or obtained at the point of installation. [72:1.4]

3.3.9.2 Smoke Alarm. A single- or multiple-station alarm responsive to smoke. [72:1.4]

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this code. Where terms are not included, common usage of the terms shall apply. The following terms, for the purposes of this *Code*, shall have the meanings given in this chapter, if not otherwise modified by another chapter. Words used in the present tense shall include the future; words used in the masculine gender shall include the feminine and neuter; the singular number shall include the plural, and the plural number shall include the singular. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Webster's*

3.3.10 Alternative Calculation Procedure. A calculation procedure that differs from the procedure originally employed by the design team but that provides predictions for the same variables of interest.

3.3.11 Ambulatory Health Care Occupancy. See 3.3.152.1.

3.3.12 Analysis.

3.3.12.1 Sensitivity Analysis. An analysis performed to determine the degree to which a predicted output will vary given a specified change in an input parameter, usually in relation to models.

3.3.12.2 Uncertainty Analysis. An analysis performed to determine the degree to which a predicted value will vary.

3.3.13 Anchor Building. See 3.3.27.2.

3.3.14 Apartment Building. See 3.3.27.3.

3.3.15 Approved Existing. See 3.3.60.1.

3.3.16 Area.

3.3.16.1 Detention and Correctional Residential Housing Area. Sleeping areas and any contiguous day room, group activity space, or other common space for customary access of residents.

3.3.16.2 Floor Area.

3.3.16.2.1* Gross Floor Area. The floor area within the inside perimeter of the outside walls of the building under consideration with no deduction for hallways, stairs, closets, thickness of interior walls, columns, or other features.

3.3.16.2.2 Net Floor Area. The floor area within the inside perimeter of the outside walls, or the outside walls and fire walls of the building under consideration with deductions for hallways, stairs, closets, thickness of interior walls, columns, or other features.

3.3.16.3 Gross Leasable Area. The total floor area designed for tenant occupancy and exclusive use. The area of tenant occupancy is measured from the centerlines of joint partitions to the outside of the tenant walls.

3.3.16.4* Hazardous Area. An area of a structure or building that poses a degree of hazard greater than that normal to the general occupancy of the building or structure.

3.3.16.5 Living Area. Any normally occupiable space in a residential occupancy, other than sleeping rooms or rooms that are intended for combination sleeping/living, bathrooms, toilet compartments, kitchens, closets, halls, storage or utility spaces, and similar areas.

3.3.17* Area of Refuge. An area that is either (1) a story in a building where the building is protected throughout by an approved, supervised automatic sprinkler system and has not less than two accessible rooms or spaces separated from each other by smoke-resisting partitions; or (2) a space located in a path of travel leading to a public way that is protected from the effects of fire, either by means of separation from other spaces in the same building or by virtue of location, thereby permitting a delay in egress travel from any level.

3.3.17.1 Accessible Area of Refuge. An area of refuge that complies with the accessible route requirements of ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*.

3.3.18 Assembly.

3.3.18.1 Fire Door Assembly. Any combination of a fire door, a frame, hardware, and other accessories that together provide a specific degree of fire protection to the opening. [80:1.4]

3.3.18.1.1 Floor Fire Door Assembly. A combination of a fire door, a frame, hardware, and other accessories installed in a horizontal plane, which together provide a specific degree of fire protection to a through-opening in a fire-rated floor.

3.3.18.2 Fire Window Assembly. A window or glass block assembly having a fire protection rating. [80:1.4]

3.3.19 Assembly Occupancy. See 3.3.152.2.

3.3.20 Atmosphere.

3.3.20.1 Common Atmosphere. The atmosphere that exists between rooms, spaces, or areas within a building that are not separated by an approved smoke barrier.

3.3.20.2 Separate Atmosphere. The atmosphere that exists between rooms, spaces, or areas that are separated by an approved smoke barrier.

3.3.21* Atrium. A large-volume space created by a floor opening or series of floor openings connecting two or more stories that is covered at the top of the series of openings and is used for purposes other than an enclosed stairway; an elevator hoistway; an escalator opening; or as a utility shaft used for plumbing, electrical, air-conditioning, or communications facilities.

3.3.22 Automatic. That which provides a function without the necessity of human intervention.

3.3.23 Barrier.

3.3.23.1* Fire Barrier. A continuous membrane or a membrane with discontinuities created by protected openings with a specified fire protection rating, where such membrane is designed and constructed with a specified fire resistance rating to limit the spread of fire, that also restricts the movement of smoke.

3.3.23.2* Smoke Barrier. A continuous membrane, or a membrane with discontinuities created by protected openings, where such membrane is designed and constructed to restrict the movement of smoke.

3.3.23.3* Thermal Barrier. A material that limits the average temperature rise of an unexposed surface to not more than 139°C (250°F) for a specified fire exposure complying with the standard time-temperature curve of NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*.

3.3.24* Birth Center. A facility in which low-risk births are expected following normal, uncomplicated pregnancies, and in which professional midwifery care is provided to women during pregnancy, birth, and postpartum.

3.3.25 Bleachers. A grandstand in which the seats are not provided with backrests.

3.3.26 Board and Care. See 3.3.152.13.

3.3.27* Building. Any structure used or intended for supporting or sheltering any use or occupancy.

3.3.27.1 Airport Terminal Building. A structure used primarily for air passenger enplaning or deplaning, including ticket sales, flight information, baggage handling, and

other necessary functions in connection with air transport operation. This term includes any extensions and satellite buildings used for passenger handling or aircraft service functions. Aircraft loading walkways and "mobile lounges" are excluded. [415:1.4]

3.3.27.2 Anchor Building. An exterior perimeter building of low or ordinary combustible contents having direct access to a mall building, but having all required means of egress independent of the mall.

3.3.27.3* Apartment Building. A building or portion thereof containing three or more dwelling units with independent cooking and bathroom facilities.

3.3.27.4 Bulk Merchandising Retail Building. A building in which the sales area includes the storage of combustible materials on pallets, in solid piles, or in racks in excess of 3660 mm (144 in.) in storage height.

3.3.27.5* Existing Building. A building erected or officially authorized prior to the effective date of the adoption of this edition of the *Code* by the agency or jurisdiction.

3.3.27.6* Flexible Plan and Open Plan Educational or Day-Care Building. A building or portion of a building designed for multiple teaching stations.

3.3.27.7* High-Rise Building. A building greater than 23 m (75 ft) in height where the building height is measured from the lowest level of fire department vehicle access to the floor of the highest occupiable story.

3.3.27.8* Historic Building. A building or facility deemed to have historical, architectural, or cultural significance by a local, regional, or national jurisdiction.

3.3.27.9* Mall Building. A building, including the mall, enclosing a number of tenants and occupancies wherein two or more tenants have a main entrance into the mall.

3.3.27.10* Special Amusement Building. A building that is temporary, permanent, or mobile that contains a device or system that conveys passengers or provides a walkway along, around, or over a course in any direction as a form of amusement arranged so that the egress path is not readily apparent due to visual or audio distractions or an intentionally confounded egress path; or is not readily available due to the mode of conveyance through the building or structure.

3.3.28 Bulk Merchandising Retail Building. See 3.3.27.4.

3.3.29 Business Occupancy. See 3.3.152.3.

3.3.30* Cellular or Foamed Plastic. A heterogeneous system comprised of not less than two phases, one of which is a continuous polymeric organic material, and the second of which is deliberately introduced for the purpose of distributing gas in voids throughout the material.

3.3.31 Combustible (Material). See 3.3.135.1.

3.3.32 Combustion. A chemical process that involves oxidation sufficient to produce light or heat.

3.3.33 Common Atmosphere. See 3.3.20.1.

3.3.34* Common Path of Travel. The portion of exit access that must be traversed before two separate and distinct paths of travel to two exits are available.

3.3.35 Compartment.

3.3.35.1* Fire Compartment. A space within a building that is enclosed by fire barriers on all sides, including the top and bottom.

3.3.35.2* Smoke Compartment. A space within a building enclosed by smoke barriers on all sides, including the top and bottom.

3.3.36 Contents and Furnishings. Objects, goods, or products placed inside a structure for functional, operational, or decorative reasons, excluding parts of the building structure, building service equipment, and items meeting the definition of interior finish.

3.3.37 Court. An open, uncovered, unoccupied space, unobstructed to the sky, bounded on three or more sides by exterior building walls.

3.3.37.1 Enclosed Court. A court bounded on all sides by the exterior walls of a building or by the exterior walls and lot lines on which walls are permitted.

3.3.37.2 Food Court. A public seating area located in a mall that serves adjacent food preparation tenant spaces.

3.3.38* Critical Radiant Flux. The level of incident radiant heat energy on a floor-covering system at the most distant flameout point.

3.3.39 Data Conversion. The process of developing the input data set for the assessment method of choice.

3.3.40 Day-Care Home. See 3.3.110.1.

3.3.41 Day-Care Occupancy. See 3.3.152.4.

3.3.42 Design Fire Scenario. See 3.3.80.1.

3.3.43 Design Specification. See 3.3.208.1.

3.3.44 Design Team. A group of stakeholders including, but not limited to, representatives of the architect, client, and any pertinent engineers and other designers.

3.3.45 Detention and Correctional Occupancy. See 3.3.152.5.

3.3.46 Detention and Correctional Residential Housing Area. See 3.3.16.1.

3.3.47 Door.

3.3.47.1 Elevator Lobby Door. A door between an elevator lobby and another building space other than the elevator shaft.

3.3.47.2 Fire Door. The door component of a fire door assembly. [80:1.4]

3.3.48* Dormitory. A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, but without individual cooking facilities.

3.3.49 Draft Stop. A continuous membrane used to subdivide a concealed space to resist the passage of smoke and heat.

3.3.50 Dwelling Unit. One or more rooms arranged for the use of one or more individuals living together, providing complete, independent living facilities, including permanent provisions for living, sleeping, eating, cooking, and sanitation.

3.3.50.1 One- and Two-Family Dwelling Unit. A building that contains not more than two dwelling units with independent cooking and bathroom facilities.

3.3.50.2 One-Family Dwelling Unit. A building that consists solely of one dwelling unit with independent cooking and bathroom facilities.

3.3.50.3 Two-Family Dwelling Unit. A building that consists solely of two dwelling units with independent cooking and bathroom facilities.

3.3.51 Educational Occupancy. See 3.3.152.6.

3.3.52* Electroluminescent. Refers to a light-emitting capacitor in which alternating current excites phosphor atoms placed between electrically conductive surfaces and produces light.

3.3.53 Elevator Evacuation System. See 3.3.218.1.

3.3.54 Elevator Lobby. A space from which people directly enter an elevator car(s) and into which people directly enter upon leaving an elevator car(s).

3.3.55 Elevator Lobby Door. See 3.3.47.1.

3.3.56 Enclosed Court. See 3.3.37.1.

3.3.57* Evacuation Capability. The ability of occupants, residents, and staff as a group either to evacuate a building or to relocate from the point of occupancy to a point of safety.

3.3.57.1 Impractical Evacuation Capability. The inability of a group to reliably move to a point of safety in a timely manner.

3.3.57.2 Prompt Evacuation Capability. The ability of a group to move reliably to a point of safety in a timely manner that is equivalent to the capacity of a household in the general population.

3.3.57.3 Slow Evacuation Capability. The ability of a group to move reliably to a point of safety in a timely manner, but not as rapidly as members of a household in the general population.

3.3.58 Exhibit. A space or portable structure used for the display of products or services.

3.3.59 Exhibitor. An individual or entity engaged in the display of the products or services offered.

3.3.60* Existing. That which is already in existence on the date this edition of the *Code* goes into effect.

3.3.60.1 Approved Existing. That which is already in existence on the date this edition of the *Code* goes into effect and is acceptable to the authority having jurisdiction.

3.3.61 Existing Building. See 3.3.27.5.

3.3.62* Exit. That portion of a means of egress that is separated from all other spaces of a building or structure by construction or equipment as required to provide a protected way of travel to the exit discharge.

3.3.62.1* Horizontal Exit. A way of passage from one building to an area of refuge in another building on approximately the same level, or a way of passage through or around a fire barrier to an area of refuge on approximately the same level in the same building that affords safety from fire and smoke originating from the area of incidence and areas communicating therewith.

3.3.63 Exit Access. That portion of a means of egress that leads to an exit.

3.3.64 Exit Discharge. That portion of a means of egress between the termination of an exit and a public way.

3.3.64.1 Level of Exit Discharge. (1) The lowest story from which not less than 50 percent of the required number of exits and not less than 50 percent of the required egress capacity from such a story discharge directly outside at grade; (2) the story with the smallest elevation change needed to reach grade where no story has 50 percent or more of the required number of exits and 50 percent or more of the required egress capacity from such a story discharge directly outside at grade.

3.3.65 Exposition. An event in which the display of products or services is organized to bring together the provider and user of the products or services.

3.3.66 Exposition Facility. See 3.3.69.1.

3.3.67* Exposure Fire. A fire that starts at a location that is remote from the area being protected and grows to expose that which is being protected.

3.3.68 Externally Illuminated. See 3.3.114.1.

3.3.69 Facility.

3.3.69.1 Exposition Facility. A convention center, hotel, or other building at which exposition events are held.

3.3.69.2* Limited Care Facility. A building or portion of a building used on a 24-hour basis for the housing of four or more persons who are incapable of self-preservation because of age; physical limitations due to accident or illness; or limitations such as mental retardation/developmental disability, mental illness, or chemical dependency.

3.3.70 Festival Seating. See 3.3.188.1.

3.3.71 Fire Barrier. See 3.3.23.1.

3.3.72 Fire Barrier Wall. See 3.3.229.1.

3.3.73 Fire Compartment. See 3.3.35.1.

3.3.74 Fire Door. See 3.3.47.2.

3.3.75 Fire Door Assembly. See 3.3.18.1.

3.3.76 Fire Exit Hardware. See 3.3.103.1.

3.3.77* Fire Model. A structured approach to predicting one or more effects of a fire.

3.3.78 Fire Protection Rating. See 3.3.177.1.

3.3.79 Fire Resistance Rating. See 3.3.177.2.

3.3.80* Fire Scenario. A set of conditions that defines the development of fire, the spread of combustion products throughout a building or portion of a building, the reactions of people to fire, and the effects of combustion products.

3.3.80.1 Design Fire Scenario. A fire scenario used for evaluation of a proposed design.

3.3.81* Fire Watch. A person or persons assigned to an area for the purpose of protecting the occupants from fire or similar emergencies.

3.3.82 Fire Window Assembly. See 3.3.18.2.

3.3.83 Fixed Seating. See 3.3.188.2.

3.3.84* Flame Spread. The propagation of flame over a surface.

3.3.85* Flashover. A stage in the development of a contained fire in which all exposed surfaces reach ignition temperatures more or less simultaneously and fire spreads rapidly throughout the space.

3.3.86 Flexible Plan and Open Plan Educational or Day-Care Building. See 3.3.27.6.

3.3.87 Floor Fire Door Assembly. See 3.3.18.1.1.

3.3.88 Flow Time. A component of total evacuation time that is the time during which there is crowd flow past a point in the means of egress system.

3.3.89 Fly Gallery. A raised floor area above a stage from which the movement of scenery and operation of other stage effects are controlled.

3.3.90 Folding and Telescopic Seating. See 3.3.188.3.

3.3.91 Food Court. See 3.3.37.2.

3.3.92 Fuel Load. See 3.3.131.1.

3.3.93 General Industrial Occupancy. See 3.3.152.8.1.

3.3.94 Goal. A nonspecific overall outcome to be achieved that is measured on a qualitative basis.

3.3.95* Grandstand. A structure that provides tiered or stepped seating.

3.3.96 Gridiron. The structural framing over a stage supporting equipment for hanging or flying scenery and other stage effects.

3.3.97 Gross Floor Area. See 3.3.16.2.1.

3.3.98 Gross Leasable Area. See 3.3.16.3.

3.3.99 Guard. A vertical protective barrier erected along exposed edges of stairways, balconies, and similar areas.

3.3.100 Guest Room. An accommodation combining living, sleeping, sanitary, and storage facilities within a compartment.

3.3.101 Guest Suite. An accommodation with two or more contiguous rooms comprising a compartment, with or without doors between such rooms, that provides living, sleeping, sanitary, and storage facilities.

3.3.102 Handrail. A bar, pipe, or similar member designed to furnish persons with a handhold.

3.3.103 Hardware.

3.3.103.1 Fire Exit Hardware. A door-latching assembly incorporating a device that releases the latch upon the application of a force in the direction of egress travel and provides fire protection where used as part of a fire door assembly.

3.3.103.2 Panic Hardware. A door-latching assembly incorporating a device that releases the latch upon the application of a force in the direction of egress travel.

3.3.104 Hazardous Area. See 3.3.16.4.

3.3.105 Health Care Occupancy. See 3.3.152.7.

3.3.106* Heat Release Rate (HRR). The rate at which heat energy is generated by burning.

3.3.107 High Hazard Industrial Occupancy. See 3.3.152.8.2.

3.3.108 High-Rise Building. See 3.3.27.7.

3.3.109 Historic Building. See 3.3.27.8.

3.3.110 Home.

3.3.110.1* Day-Care Home. A building or portion of a building in which more than 3 but not more than 12 clients receive care, maintenance, and supervision, by other than their relative(s) or legal guardians(s), for less than 24 hours per day.

3.3.110.2 Nursing Home. A building or portion of a building used on a 24-hour basis for the housing and nursing care of four or more persons who, because of mental or physical incapacity, might be unable to provide for their own needs and safety without the assistance of another person.

3.3.111 Horizontal Exit. See 3.3.62.1.

3.3.112 Hospital. A building or portion thereof used on a 24-hour basis for the medical, psychiatric, obstetrical, or surgical care of four or more inpatients.

3.3.113* Hotel. A building or groups of buildings under the same management in which there are sleeping accommodations for more than 16 persons and primarily used by transients for lodging with or without meals.

3.3.114 Illuminated.

3.3.114.1* Externally Illuminated. Refers to an illumination source that is contained outside of the device or sign legend area that is to be illuminated.

3.3.114.2* Internally Illuminated. Refers to an illumination source that is contained inside the device or legend that is illuminated.

3.3.115 Impractical Evacuation Capability. See 3.3.57.1.

3.3.116 Incapacitation. A condition under which humans do not function adequately and become unable to escape untenable conditions.

3.3.117 Industrial Occupancy. See 3.3.152.8.

3.3.118 Input Data Specification. See 3.3.208.2.

3.3.119 Interior Ceiling Finish. See 3.3.120.1.

3.3.120* Interior Finish. The exposed surfaces of walls, ceilings, and floors within buildings.

3.3.120.1 Interior Ceiling Finish. The interior finish of ceilings.

3.3.120.2* Interior Floor Finish. The interior finish of floors, ramps, stair treads and risers, and other walking surfaces.

3.3.120.3 Interior Wall Finish. The interior finish of columns, fixed or movable walls, and fixed or movable partitions.

3.3.121 Interior Floor Finish. See 3.3.120.2.

3.3.122 Interior Wall Finish. See 3.3.120.3.

3.3.123 Internally Illuminated. See 3.3.114.2.

3.3.124 Legitimate Stage. See 3.3.210.1.

3.3.125 Level of Exit Discharge. See 3.3.64.1.

3.3.126 Life Safety Evaluation. A written review dealing with the adequacy of life safety features relative to fire, storm, collapse, crowd behavior, and other related safety considerations.

3.3.127 Limited Access Structure. See 3.3.217.3.

3.3.128 Limited Care Facility. See 3.3.69.2.

3.3.129 Limited-Combustible (Material). See 3.3.135.2.

3.3.130 Living Area. See 3.3.16.5.

3.3.131 Load.

3.3.131.1* Fuel Load. The total quantity of combustible contents of a building, space, or fire area.

3.3.131.2 Occupant Load. The total number of persons that might occupy a building or portion thereof at any one time.

3.3.132 Lodging or Rooming House. A building or portion thereof that does not qualify as a one- or two-family dwelling, that provides sleeping accommodations for a total of 16 or fewer people on a transient or permanent basis, without personal care services, with or without meals, but without separate cooking facilities for individual occupants.

3.3.133 Mall. A roofed or covered common pedestrian area within a mall building that serves as access for two or more tenants and does not exceed three levels that are open to each other.

3.3.134 Mall Building. See 3.3.27.9.

3.3.135 Material.

3.3.135.1 Combustible (Material). A material that, in the form in which it is used and under the conditions anticipated, will ignite and burn; a material that does not meet the definition of noncombustible or limited-combustible.

3.3.135.2* Limited-Combustible (Material). Refers to a building construction material not complying with the definition of *noncombustible* (see 3.3.135.3) that, in the form in which it is used, has a potential heat value not exceeding 8140 kJ/kg (3500 Btu/lb), where tested in accordance with NFPA 259, *Standard Test Method for Potential Heat of Building Materials*, and includes (1) materials having a structural base of noncombustible material, with a surfacing not exceeding a thickness of 3.2 mm (1/8 in.) that has a flame spread index not greater than 50; and (2) materials, in the form and thickness used, other than as described in (1), having neither a flame spread index greater than 25 nor evidence of continued progressive combustion, and of such composition that surfaces that would be exposed by cutting through the material on any plane would have neither a flame spread index greater than 25 nor evidence of continued progressive combustion. [220:2.1]

3.3.135.3 Noncombustible (Material). Refers to a material that, in the form in which it is used and under the conditions anticipated, does not ignite, burn, support combustion, or release flammable vapors, when subjected to fire or heat. Materials that are reported as passing ASTM E 136, *Standard Test Method for Behavior of Materials in a Vertical Tube Furnace at 750 Degrees C*, are considered noncombustible materials.

3.3.135.4 Weathered-Membrane Material. Membrane material that has been subjected to not less than 3000 hours in a weatherometer in accordance with ASTM G 155, *Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Non-Metallic Materials*, or approved equivalent.

3.3.136* Means of Egress. A continuous and unobstructed way of travel from any point in a building or structure to a public way consisting of three separate and distinct parts: (1) the exit access, (2) the exit, and (3) the exit discharge.

3.3.136.1 Accessible Means of Egress. A means of egress that provides an accessible route to an area of refuge, a horizontal exit, or a public way.

3.3.137 Means of Escape. A way out of a building or structure that does not conform to the strict definition of *means of egress* but does provide an alternate way out.

3.3.138 Membrane. For the purposes of membrane structures, thin, flexible, water-impervious material capable of being supported by an air pressure of 38 mm (1½ in.) water column.

3.3.139 Membrane Structure. See 3.3.217.4.

3.3.140 Mercantile Occupancy. See 3.3.152.9.

3.3.141 Mezzanine. An intermediate level between the floor and the ceiling of any room or space.

3.3.142 Mixed Occupancy. See 3.3.152.10.

3.3.143* Modification. The reconfiguration of any space, the addition or elimination of any door or window, the reconfiguration or extension of any system, or the installation of any additional equipment.

3.3.144 Multilevel Play Structure. See 3.3.217.5.

3.3.145 Multiple Occupancy. See 3.3.152.11.

3.3.146 Multiple Station Alarm Device. Two or more single-station alarm devices that can be interconnected so that actuation of one causes all integral audible alarms to operate; or one single-station alarm device having connections to other detectors or to a manual fire alarm box. [72:1.4]

3.3.147 Multipurpose Assembly Occupancy. See 3.3.152.2.1.

3.3.148 Net Floor Area. See 3.3.16.2.2.

3.3.149 Noncombustible (Material). See 3.3.135.3.

3.3.150 Nursing Home. See 3.3.110.2.

3.3.151* Objective. A requirement that needs to be met to achieve a goal.

3.3.152 Occupancy. The purpose for which a building or portion thereof is used or intended to be used.

3.3.152.1* Ambulatory Health Care Occupancy. A building or portion thereof used to provide services or treatment simultaneously to four or more patients that provides, on an outpatient basis, one or more of the following: (1) Treatment for patients that renders the patients incapable of taking action for self-preservation under emergency conditions without the assistance of others; (2) Anesthesia that renders the patients incapable of taking action for self-preservation under emergency conditions without the assistance of others; (3) Emergency or urgent care for patients who, due to the nature of their injury or illness, are incapable of taking action for self-preservation under emergency conditions without the assistance of others.

3.3.152.2* Assembly Occupancy. An occupancy (1) used for a gathering of 50 or more persons for deliberation, worship, entertainment, eating, drinking, amusement, awaiting transportation, or similar uses; or (2) used as a special amusement building, regardless of occupant load.

3.3.152.2.1 Multipurpose Assembly Occupancy. An assembly room designed to accommodate temporarily any of several possible assembly uses.

3.3.152.3* Business Occupancy. An occupancy used for account and record keeping or the transaction of business other than mercantile.

3.3.152.4* Day-Care Occupancy. An occupancy in which four or more clients receive care, maintenance, and supervision, by other than their relatives or legal guardians, for less than 24 hours per day.

3.3.152.5* Detention and Correctional Occupancy. An occupancy used to house four or more persons under varied degrees of restraint or security where such occupants are mostly incapable of self-preservation because of security measures not under the occupants' control.

3.3.152.6* Educational Occupancy. An occupancy used for educational purposes through the twelfth grade by six or more persons for 4 or more hours per day or more than 12 hours per week.

3.3.152.7* Health Care Occupancy. An occupancy used for purposes of medical or other treatment or care of four or more persons where such occupants are mostly incapable of self-preservation due to age, physical or mental disability, or because of security measures not under the occupants' control.

3.3.152.8* Industrial Occupancy. An occupancy in which products are manufactured or in which processing, assembling, mixing, packaging, finishing, decorating, or repair operations are conducted.

3.3.152.8.1* General Industrial Occupancy. An industrial occupancy in which ordinary and low hazard industrial operations are conducted in buildings of conventional design suitable for various types of industrial processes.

3.3.152.8.2* High Hazard Industrial Occupancy. An industrial occupancy in which industrial operations that include high hazard materials, processes, or contents are conducted.

3.3.152.8.3 Special-Purpose Industrial Occupancy. An industrial occupancy in which ordinary and low hazard industrial operations are conducted in buildings designed for, and suitable only for, particular types of operations, characterized by a relatively low density of employee population, with much of the area occupied by machinery or equipment.

3.3.152.9* Mercantile Occupancy. An occupancy used for the display and sale of merchandise.

3.3.152.10 Mixed Occupancy. A multiple occupancy where the occupancies are intermingled.

3.3.152.11 Multiple Occupancy. A building or structure in which two or more classes of occupancy exist.

3.3.152.12* Residential Occupancy. An occupancy that provides sleeping accommodations for purposes other than health care or detention and correctional.

3.3.152.13* Residential Board and Care Occupancy. A building or portion thereof that is used for lodging and boarding of four or more residents, not related by blood or marriage to the owners or operators, for the purpose of providing personal care services.

3.3.152.14 Separated Occupancy. A multiple occupancy where the occupancies are separated by fire resistance-rated assemblies.

3.3.152.15* Storage Occupancy. An occupancy used primarily for the storage or sheltering of goods, merchandise, products, vehicles, or animals.

3.3.153 Occupant Characteristics. The abilities or behaviors of people before and during a fire.

3.3.154 Occupant Load. See 3.3.131.2.

3.3.155 Occupiable Story. See 3.3.214.1.

3.3.156 Open-Air Mercantile Operation. An operation conducted outside of all structures, with the operations area devoid of all walls and roofs except for small, individual, weather canopies.

3.3.157 Open Parking Structure. See 3.3.217.7.

3.3.158 Open Structure. See 3.3.217.6.

3.3.159* Outside Stair. A stair with not less than one side open to the outer air.

3.3.160 Panic Hardware. See 3.3.103.2.

3.3.161* Performance Criteria. Threshold values on measurement scales that are based on quantified performance objectives.

3.3.162 Permanent Structure. See 3.3.217.8.

3.3.163* Personal Care. The care of residents who do not require chronic or convalescent medical or nursing care.

3.3.164* Photoluminescent. Having the property of emitting light that continues for a length of time after excitation by visible or invisible light has been removed.

3.3.165 Pinrail. A rail on or above a stage through which belaying pins are inserted and to which lines are fastened.

3.3.166* Platform. The raised area within a building used for the presentation of music, plays, or other entertainment.

3.3.166.1 Temporary Platform. A platform erected within an area for not more than 30 days.

3.3.167 Plenum. A compartment or chamber to which one or more air ducts are connected and that forms part of the air-distribution system.

3.3.168 Point of Safety. A location that (a) is exterior to and away from a building; or (b) is within a building of any type construction protected throughout by an approved automatic sprinkler system and that is either (1) within an exit enclosure meeting the requirements of this *Code*, or (2) within another portion of the building that is separated by smoke barriers in accordance with Section 8.5, with not less than a ½-hour fire resistance rating, and that portion of the building has access to a means of escape or exit that conforms to the requirements of this *Code* and does not necessitate return to the area of fire involvement; or (c) is within a building of Type I, Type II(222), Type II(111), Type III(211), Type IV, or Type V(111) construction (see 8.2.1.2) and is either (1) within an exit enclosure meeting the requirements of this *Code*, or (2) within another portion of the building that is separated by smoke barriers in accordance with Section 8.5, with not less than a ½-hour fire resistance rating, and that portion of the building has access to a means of escape or exit that conforms to the requirements of this *Code* and does not necessitate return to the area of fire involvement.

3.3.169 Previously Approved. That which was acceptable to the authority having jurisdiction prior to the date this edition of the *Code* went into effect.

3.3.170 Private Party Tent. See 3.3.222.1.

3.3.171 Professional Engineer. A person registered or licensed to practice engineering in a jurisdiction, subject to all laws and limitations imposed by the jurisdiction.

3.3.172 Prompt Evacuation Capability. See 3.3.57.2.

3.3.173* Proposed Design. A design developed by a design team and submitted to the authority having jurisdiction for approval.

3.3.174 Proscenium Wall. See 3.3.229.2.

3.3.175 Public Way. A street, alley, or other similar parcel of land essentially open to the outside air deeded, dedicated, or otherwise permanently appropriated to the public for public use and having a clear width and height of not less than 3050 mm (120 in.).

3.3.176* Ramp. A walking surface that has a slope steeper than 1 in 20.

3.3.177 Rating.

3.3.177.1 Fire Protection Rating. The designation indicating the duration of the fire test exposure to which a fire door assembly or fire window assembly was exposed and for which it met all the acceptance criteria as determined in accordance with NFPA 252, *Standard Methods of Fire Tests of Door Assemblies*, or NFPA 257, *Standard on Fire Test for Window and Glass Block Assemblies*, respectively.

3.3.177.2 Fire Resistance Rating. The time, in minutes or hours, that materials or assemblies have withstood a fire exposure as determined by the tests or methods based on tests, prescribed by this *Code*.

3.3.178 Registered Architect. A person licensed to practice architecture in a jurisdiction, subject to all laws and limitations imposed by the jurisdiction.

3.3.179 Registered Design Professional (RDP). An individual who is registered or licensed to practice his/her respective design profession as defined by the statutory requirements of the professional registration laws of the state or jurisdiction in which the project is to be constructed.

3.3.180 Regular Stage. See 3.3.210.2.

3.3.181 Residential Board and Care Occupancy. See 3.3.152.13.

3.3.182 Residential Board and Care Resident. A person who receives personal care and resides in a residential board and care facility.

3.3.183 Residential Occupancy. See 3.3.152.12.

3.3.184 Safe Location. A location remote or separated from the effects of a fire so that such effects no longer pose a threat.

3.3.185 Safety Factor. A factor applied to a predicted value to ensure that a sufficient safety margin is maintained.

3.3.186 Safety Margin. The difference between a predicted value and the actual value where a fault condition is expected.

3.3.187 Sally Port (Security Vestibule). A compartment provided with two or more doors where the intended purpose is to prevent continuous and unobstructed passage by allowing the release of only one door at a time.

3.3.188 Seating.

3.3.188.1* Festival Seating. A form of audience/spectator accommodation in which no seating, other than a floor or ground surface, is provided for the audience/spectators gathered to observe a performance.

3.3.188.2 Fixed Seating. Seating that is secured to the building structure.

3.3.188.3 Folding and Telescopic Seating. A structure that is used for tiered seating of persons and whose overall shape and size can be reduced, without being dismantled, for purposes of moving or storing.

3.3.188.4 Smoke-Protected Assembly Seating. Seating served by means of egress that is not subject to smoke accumulation within or under the structure.

3.3.189 Self-Closing. Equipped with an approved device that ensures closing after opening.

3.3.190* Self-Luminous. Illuminated by a self-contained power source and operated independently of external power sources.

3.3.191* Self-Preservation (Day-Care Occupancy). The ability of a client to evacuate a day-care occupancy without direct intervention by a staff member.

3.3.192 Sensitivity Analysis. See 3.3.12.1.

3.3.193 Separate Atmosphere. See 3.3.20.2.

3.3.194 Separated Occupancy. See 3.3.152.14.

3.3.195 Severe Mobility Impairment. The ability to move to stairs but without the ability to use the stairs.

3.3.196 Single-Station Alarm. See 3.3.9.1.

3.3.197 Slow Evacuation Capability. See 3.3.57.3.

3.3.198 Smoke Alarm. See 3.3.9.2.

3.3.199 Smoke Barrier. See 3.3.23.2.

3.3.200 Smoke Compartment. See 3.3.35.2.

3.3.201 Smoke Detector. A device that detects visible or invisible particles of combustion. [72:1.4]

3.3.202* Smoke Partition. A continuous membrane that is designed to form a barrier to limit the transfer of smoke.

3.3.203* Smokeproof Enclosure. A stair enclosure designed to limit the movement of products of combustion produced by a fire.

3.3.204 Smoke-Protected Assembly Seating. See 3.3.188.4.

3.3.205 Special Amusement Building. See 3.3.27.10.

3.3.206 Special Inspection. Services provided by a qualified person, retained by the owner and approved by the authority having jurisdiction, who observes the installation and witnesses the pretesting and operation of the system or systems.

3.3.207 Special-Purpose Industrial Occupancy. See 3.3.152.8.3.

3.3.208 Specification.

3.3.208.1* Design Specification. A building characteristic and other conditions that are under the control of the design team.

3.3.208.2 Input Data Specification. Information required by the verification method.

3.3.209 Staff (Residential Board and Care). Persons who provide personal care services, supervision, or assistance.

3.3.210 Stage. A space within a building used for entertainment and utilizing drops or scenery or other stage effects.

3.3.210.1 Legitimate Stage. A stage with a height greater than 15 m (50 ft) measured from the lowest point on the stage floor to the highest point of the roof or floor deck above.

3.3.210.2 Regular Stage. A stage with a height of 15 m (50 ft) or less measured from the lowest point on the deck above.

3.3.211 Stakeholder. An individual, or representative of same, having an interest in the successful completion of a project.

3.3.212 Standpipe System. See 3.3.218.2.

3.3.213 Storage Occupancy. See 3.3.152.15.

3.3.214 Story. The portion of a building located between the upper surface of a floor and the upper surface of the floor or roof next above.

3.3.214.1* Occupiable Story. A story occupied by people on a regular basis.

3.3.215 Street. A public thoroughfare that has been dedicated for vehicular use by the public and can be used for access by fire department vehicles.

3.3.216* Street Floor. A story or floor level accessible from the street or from outside a building at ground level, with the floor level at the main entrance located not more than three risers above or below ground level and arranged and utilized to qualify as the main floor.

3.3.217* Structure. That which is built or constructed.

3.3.217.1 Air-Inflated Structure. A structure whose shape is maintained by air pressure in cells or tubes forming all or part of the enclosure of the usable area and in which the occupants are not within the pressurized area used to support the structure.

3.3.217.2* Air-Supported Structure. A structure whose shape is maintained by air pressure and in which occupants are within the elevated pressure area.

3.3.217.3 Limited Access Structure. A structure or portion of a structure lacking access openings.

3.3.217.4 Membrane Structure. A building or portion of a building incorporating an air-inflated, air-supported, tensioned-membrane structure; a membrane roof; or a membrane-covered rigid frame to protect habitable or usable space.

3.3.217.5 Multilevel Play Structure. A structure that consists of tubes, slides, crawling areas, and jumping areas that is located within a building and is used for climbing and entertainment, generally by children.

3.3.217.6* Open Structure. A structure that supports equipment and operations not enclosed within building walls.

3.3.217.7 Open Parking Structure. A parking structure that, at each parking level, has wall openings open to the atmosphere, for an area of not less than 0.13 m² (1.4 ft²) for each linear 305 mm (12 in.) of its exterior perimeter. Such openings are distributed over at least 40 percent of the building perimeter or uniformly over two opposing sides. Interior wall lines and column lines are at least 20 percent open, with openings distributed to provide ventilation.

3.3.217.8 Permanent Structure. A building or structure that is intended to remain in place for a period of more than 180 consecutive days.

3.3.217.9 Temporary Structure. A building or structure not meeting the definition of *permanent structure*. (See also 3.3.217.8.)

3.3.217.10 Tensioned-Membrane Structure. A membrane structure incorporating a membrane and a structural support system such as arches, columns and cables, or beams wherein the stresses developed in the tensioned membrane interact with those in the structural support so that the entire assembly acts together to resist the applied loads.

3.3.217.11* Underground Structure. A structure or portions of a structure in which the floor level is below the level of exit discharge.

3.3.217.12 Water-Surrounded Structure. A structure fully surrounded by water.

3.3.218 System.

3.3.218.1 Elevator Evacuation System. A system, including a vertical series of elevator lobbies and associated elevator lobby doors, an elevator shaft(s), and a machine room(s), that provides protection from fire effects for elevator passengers, people waiting to use elevators, and elevator equipment so that elevators can be used safely for egress.

3.3.218.2 Standpipe System. An arrangement of piping, valves, hose connections, and allied equipment installed in a building or structure, with the hose connections located in such a manner that water can be discharged in streams or spray patterns through attached hose and nozzles, for the purpose of extinguishing a fire, thereby protecting a building or structure and its contents in addition to protecting the occupants. This is accomplished by means of connections to water supply systems or by means of pumps, tanks, and other equipment necessary to provide an adequate supply of water to the hose connections. [14:1.4].

3.3.219 Temporary Platform. See 3.3.166.1.

3.3.220 Temporary Structure. See 3.3.217.9.

3.3.221 Tensioned-Membrane Structure. See 3.3.217.10.

3.3.222* Tent. A temporary structure, the covering of which is made of pliable material that achieves its support by mechanical means such as beams, columns, poles, or arches, or by rope or cables, or both.

3.3.222.1 Private Party Tent. A tent erected in the yard of a private residence for entertainment, recreation, dining, a reception, or similar function.

3.3.223 Thermal Barrier. See 3.3.23.3.

3.3.224 Tower. An enclosed independent structure or portion of a building with elevated levels for support of equipment or occupied for observation, control, operation, signaling, or similar limited use.

3.3.225 Uncertainty Analysis. See 3.3.12.2.

3.3.226 Underground Structure. See 3.3.217.11.

3.3.227 Verification Method. A procedure or process used to demonstrate or confirm that the proposed design meets the specified criteria.

3.3.228 Vertical Opening. An opening through a floor or roof.

3.3.229 Wall.

3.3.229.1 Fire Barrier Wall. A wall, other than a fire wall, that has a fire resistance rating.

3.3.229.2 Proscenium Wall. The wall that separates the stage from the auditorium or house.

3.3.230 Water-Surrounded Structure See 3.3.217.12.

3.3.231 Weathered-Membrane Material. See 3.3.135.4.

3.3.232 Yard. An open, unoccupied space other than a court, unobstructed from the ground to the sky on the lot on which a building is situated.

Chapter 4 General

4.1* Goals.

4.1.1* Fire and Similar Emergency. The goal of this *Code* is to provide an environment for the occupants that is reasonably safe from fire and similar emergencies by the following means:

- (1) *Protection of occupants not intimate with the initial fire development
- (2) Improvement of the survivability of occupants intimate with the initial fire development

4.1.2* Crowd Movement. An additional goal is to provide for reasonably safe emergency crowd movement and, where required, reasonably safe nonemergency crowd movement.

4.2 Objectives.

4.2.1 Occupant Protection. A structure shall be designed, constructed, and maintained to protect occupants who are not intimate with the initial fire development for the time needed to evacuate, relocate, or defend in place.

4.2.2 Structural Integrity. Structural integrity shall be maintained for the time needed to evacuate, relocate, or defend in place occupants who are not intimate with the initial fire development.

4.2.3 Systems Effectiveness. Systems utilized to achieve the goals of Section 4.1 shall be effective in mitigating the hazard or condition for which they are being used, shall be reliable, shall be maintained to the level at which they were designed to operate, and shall remain operational.

4.3* Assumption. The protection methods of this *Code* assume a single fire source.

4.4 Life Safety Compliance Options.

4.4.1 Options. Life safety meeting the goals and objectives of Section 4.1 and Section 4.2 shall be provided in accordance with either of the following:

- (1) Prescriptive-based provisions per 4.4.2
- (2) Performance-based provisions per 4.4.3

4.4.2 Prescriptive-Based Option.

4.4.2.1 A prescriptive-based life safety design shall be in accordance with Chapter 1 through Chapter 4, Chapter 6 through Chapter 11, and the applicable occupancy chapter, Chapter 12 through Chapter 42.

4.4.2.2 Where specific requirements contained in Chapter 11 through Chapter 42 differ from general requirements contained in Chapter 1 through Chapter 4, and Chapter 6 through Chapter 10, the requirements of Chapter 11 through Chapter 42 shall govern.

4.4.3 Performance-Based Option. A performance-based life safety design shall be in accordance with Chapter 1 through Chapter 5.

4.5 Fundamental Requirements.

4.5.1 Multiple Safeguards. The design of every building or structure intended for human occupancy shall be such that reliance for safety to life does not depend solely on any single safeguard. An additional safeguard(s) shall be provided for life safety in case any single safeguard is ineffective due to inappropriate human actions or system failure.

4.5.2 Appropriateness of Safeguards. Every building or structure shall be provided with means of egress and other safeguards of the kinds, numbers, locations, and capacities appropriate to the individual building or structure, with due regard to the following:

- (1) Character of the occupancy
- (2) Capabilities of the occupants
- (3) Number of persons exposed
- (4) Fire protection available
- (5) Height and type of construction of the building or structure
- (6) Other factors necessary to provide occupants with a reasonable degree of safety

4.5.3 Means of Egress.

4.5.3.1 Number of Means of Egress. Two means of egress, as a minimum, shall be provided in every building or structure, section, and area where size, occupancy, and arrangement endanger occupants attempting to use a single means of egress that is blocked by fire or smoke. The two means of egress shall be arranged to minimize the possibility that both might be rendered impassable by the same emergency condition.

4.5.3.2 Unobstructed Egress. In every occupied building or structure, means of egress from all parts of the building shall be maintained free and unobstructed. No lock or fastening shall be permitted that prevents free escape from the inside of any building other than in health care occupancies and detention and correctional occupancies where staff are continually on duty and effective provisions are made to remove occupants in case of fire or other emergency. Means of egress shall be accessible to the extent necessary to ensure reasonable safety for occupants having impaired mobility.

4.5.3.3 Awareness of Egress System. Every exit shall be clearly visible, or the route to reach every exit shall be conspicuously indicated. Each means of egress, in its entirety, shall be arranged or marked so that the way to a place of safety is indicated in a clear manner.

4.5.3.4 Lighting. Where artificial illumination is needed in a building or structure, egress facilities shall be included in the lighting design.

4.5.4* Occupant Notification. In every building or structure of such size, arrangement, or occupancy that a fire itself might not provide adequate occupant warning, fire alarm facilities shall be provided where necessary to warn occupants of the existence of fire.

4.5.5 Vertical Openings. Every vertical opening between the floors of a building shall be suitably enclosed or protected, as necessary, to afford reasonable safety to occupants while using the means of egress and to prevent the spread of fire, smoke, or fumes through vertical openings from floor to floor before occupants have entered exits.

4.5.6 System Design/Installation. Any fire protection system, building service equipment, feature of protection, or safeguard provided for life safety shall be designed, installed, and approved in accordance with applicable NFPA standards.

4.5.7 Maintenance. Whenever or wherever any device, equipment, system, condition, arrangement, level of protection, or any other feature is required for compliance with the provisions of this *Code*, such device, equipment, system, condition, arrangement, level of protection, or other feature shall thereafter be maintained unless the *Code* exempts such maintenance.

4.6 General Requirements.

4.6.1 Authority Having Jurisdiction.

4.6.1.1 The authority having jurisdiction shall determine whether the provisions of this *Code* are met.

4.6.1.2 Any requirements that are essential for the safety of building occupants and that are not specifically provided for by this *Code* shall be determined by the authority having jurisdiction.

4.6.1.3 Where it is evident that a reasonable degree of safety is provided, any requirement shall be permitted to be modified if, in the judgment of the authority having jurisdiction, its application would be hazardous under normal occupancy conditions.

4.6.2 Previously Approved Features. Where another provision of this *Code* exempts a previously approved feature from a requirement, the exemption shall be permitted even where the following conditions exist:

- (1) The area is being modernized, renovated, or otherwise altered.
- (2) A change of occupancy has occurred, provided that the feature's continued use is approved by the authority having jurisdiction.

4.6.3* Historic Buildings. The provisions of this *Code* shall be permitted to be modified by the authority having jurisdiction for buildings or structures identified and classified as historic buildings or structures where it is evident that a reasonable degree of safety is provided.

4.6.4* Modification of Requirements for Existing Buildings. Where it is evident that a reasonable degree of safety is provided, the requirements for existing buildings shall be permitted to be modified if their application would be impractical in the judgment of the authority having jurisdiction.

4.6.5 Time Allowed for Compliance. A limited but reasonable time, commensurate with the magnitude of expenditure, disruption of services, and degree of hazard, shall be allowed for compliance with any part of this *Code* for existing buildings.

4.6.6 Referenced Publications. Existing buildings or installations that do not comply with the provisions of the standards referenced in this document (*see Chapter 2*) shall be permitted to be continued in service, provided that the lack of conformity with these standards does not present a serious hazard to the occupants as determined by the authority having jurisdiction.

4.6.7 Additions. Additions shall conform to the provisions for new construction.

4.6.8* Modernization or Renovation. Any alteration or any installation of new equipment shall meet, as nearly as practicable, the requirements for new construction. Only the altered, renovated, or modernized portion of an existing building, system, or individual component shall be required to meet the provisions of this *Code* that are applicable to new construction. If the alteration, renovation, or modernization adversely impacts required life safety features, additional upgrading shall be required. Except where another provision of this *Code* exempts a previously approved feature from a requirement, the resulting feature shall be not less than that required for existing buildings. Existing life safety features that do not meet the requirements for new buildings, but that exceed the requirements for existing buildings, shall not be further diminished.

4.6.9 Provisions in Excess of Code Requirements. Nothing in this *Code* shall be construed to prohibit a better type of building construction, an additional means of egress, or an otherwise safer condition than that specified by the minimum requirements of this *Code*.

4.6.10 Conditions for Occupancy.

4.6.10.1 No new construction or existing building shall be occupied in whole or in part in violation of the provisions of this *Code*, unless the following conditions exist:

- (1) A plan of correction has been approved.
- (2) The occupancy classification remains the same.
- (3) No serious life safety hazard exists as judged by the authority having jurisdiction.

4.6.10.2 Where compliance with this *Code* is effected by means of a performance-based design, the owner shall annually certify compliance with the conditions and limitations of the design by submitting a warrant of fitness acceptable to the authority having jurisdiction. The warrant of fitness shall attest that the building features, systems, and use have been inspected and confirmed to remain consistent with design specifications outlined in the documentation required by Section 5.8 and that such features, systems, and use continue to satisfy the goals and objectives specified in Section 4.1 and Section 4.2. (*See Chapter 5.*)

4.6.11 Construction, Repair, and Improvement Operations.

4.6.11.1* Buildings or portions of buildings shall be permitted to be occupied during construction, repair, alterations, or additions only where required means of egress and required fire protection features are in place and continuously maintained for the portion occupied or where alternative life safety measures acceptable to the authority having jurisdiction are in place.

4.6.11.2* In buildings under construction, adequate escape facilities shall be maintained at all times for the use of construction workers. Escape facilities shall consist of doors, walkways, stairs, ramps, fire escapes, ladders, or other approved means or devices arranged in accordance with the general principles of the *Code* insofar as they can reasonably be applied to buildings under construction.

4.6.11.3 Flammable or explosive substances or equipment for repairs or alterations shall be permitted in a building while the building is occupied if the condition of use and safeguards provided do not create any additional danger or impediment to egress beyond the normally permissible conditions in the building.

4.6.12* Changes of Occupancy. In any building or structure, whether or not a physical alteration is needed, a change from one occupancy classification to another shall be permitted only where such a building, structure, or portion thereof conforms with the requirements of this *Code* that apply to new construction for the proposed new use or, where specifically permitted elsewhere in the *Code*, existing construction features shall be permitted to be continued in use in conversions.

4.6.13 Maintenance and Testing.

4.6.13.1 Whenever or wherever any device, equipment, system, condition, arrangement, level of protection, or any other feature is required for compliance with the provisions of this *Code*, such device, equipment, system, condition, arrangement, level of protection, or other feature shall thereafter be continuously maintained in accordance with applicable NFPA requirements or as directed by the authority having jurisdiction.

4.6.13.2* Existing life safety features obvious to the public, if not required by the *Code*, shall be either maintained or removed.

4.6.13.3 Equipment requiring periodic testing or operation to ensure its maintenance shall be tested or operated as specified elsewhere in this *Code* or as directed by the authority having jurisdiction.

4.6.13.4 Maintenance and testing shall be performed under the supervision of a responsible person who shall ensure that testing and maintenance are made at specified intervals in accordance with applicable NFPA standards or as directed by the authority having jurisdiction.

4.7* Fire Drills.

4.7.1 Where Required. Emergency egress and relocation drills conforming to the provisions of this *Code* shall be conducted as specified by the provisions of Chapter 11 through Chapter 42, or by appropriate action of the authority having jurisdiction. Drills shall be designed in cooperation with the local authorities.

4.7.2* Drill Frequency. Emergency egress and relocation drills, where required by Chapter 11 through Chapter 42 or the authority having jurisdiction, shall be held with sufficient frequency to familiarize occupants with the drill procedure and to establish conduct of the drill as a matter of routine. Drills shall include suitable procedures to ensure that all persons subject to the drill participate.

4.7.3 Orderly Evacuation. When conducting drills, emphasis shall be placed on orderly evacuation rather than on speed.

4.7.4* Simulated Conditions. Drills shall be held at expected and unexpected times and under varying conditions to simulate the unusual conditions that can occur in an actual emergency.

4.7.5 Relocation Area. Drill participants shall relocate to a predetermined location and remain at such location until a recall or dismissal signal is given.

4.7.6* A written record of each drill shall be completed by the person responsible for conducting the drill and maintained in an approved manner.

4.8 Emergency Plan.

4.8.1 Where Required. Emergency plans shall be provided as follows:

- (1) Where required by the provisions of Chapter 11 through Chapter 42
- (2) Where required by action of the authority having jurisdiction

4.8.2 Plan Requirements.

4.8.2.1 Emergency plans shall include the following:

- (1) Procedures for reporting of emergencies
- (2) Occupant and staff response to emergencies
- (3) Design and conduct of fire drills
- (4) Type and coverage of building fire protection systems
- (5) Other items required by the authority having jurisdiction

4.8.2.2 Required emergency plans shall be submitted to the authority having jurisdiction for review.

4.8.2.3 Emergency plans shall be reviewed and updated as required by the authority having jurisdiction.

Chapter 5 Performance-Based Option

5.1 General Requirements.

5.1.1* Application. The requirements of this chapter shall apply to life safety systems designed to the performance-based option permitted by 4.4.1 and 4.4.3.

5.1.2 Goals and Objectives. The performance-based design shall meet the goals and objectives of this *Code* in accordance with Section 4.1 and Section 4.2.

5.1.3 Qualifications. The performance-based design shall be prepared by a registered design professional.

5.1.4* Independent Review. The authority having jurisdiction shall be permitted to require an approved, independent third party to review the proposed design and provide an evaluation of the design to the authority having jurisdiction.

5.1.5 Sources of Data. Data sources shall be identified and documented for each input data requirement that must be met using a source other than a design fire scenario, an assumption, or a building design specification. The degree of conservatism reflected in such data shall be specified, and a justification for the source shall be provided.

5.1.6 Final Determination. The authority having jurisdiction shall make the final determination as to whether the performance objectives have been met.

5.1.7* Maintenance of Design Features. The design features required for the building to continue to meet the performance goals and objectives of this *Code* shall be maintained for the life of the building. Such performance goals and objectives shall include complying with all documented assumptions and design specifications. Any variations shall require the approval of the authority having jurisdiction prior to the actual change. (See also 4.6.10.2.)

5.1.8 Definitions. A list of terms used in this chapter follows:

- (1) **Alternative Calculation Procedure.** See 3.3.10.
- (2) **Data Conversion.** See 3.3.39.
- (3) **Design Fire Scenario.** See 3.3.80.1.
- (4) **Design Specifications.** See 3.3.208.1.
- (5) **Design Team.** See 3.3.44.
- (6) **Exposure Fire.** See 3.3.67.
- (7) **Fire Model.** See 3.3.77.
- (8) **Fire Scenario.** See 3.3.80.
- (9) **Fuel Load.** See 3.3.131.1.
- (10) **Incapacitation.** See 3.3.116.
- (11) **Input Data Specification.** See 3.3.208.2.
- (12) **Occupant Characteristics.** See 3.3.153.

- (13) **Performance Criteria.** See 3.3.161.
- (14) **Proposed Design.** See 3.3.173.
- (15) **Safe Location.** See 3.3.184.
- (16) **Safety Factor.** See 3.3.185.
- (17) **Safety Margin.** See 3.3.186.
- (18) **Sensitivity Analysis.** See 3.3.12.1.
- (19) **Stakeholder.** See 3.3.211.
- (20) **Uncertainty Analysis.** See 3.3.12.2.
- (21) **Verification Method.** See 3.3.227.

5.2 Performance Criteria.

5.2.1 General. A design shall meet the objectives specified in Section 4.2 if, for each design fire scenario, assumption, and design specification, the performance criterion in 5.2.2 is met.

5.2.2* Performance Criterion. Any occupant who is not intimate with ignition shall not be exposed to instantaneous or cumulative untenable conditions.

5.3 Retained Prescriptive Requirements.

5.3.1* Systems and Features. All fire protection systems and features of the building shall comply with applicable NFPA standards for those systems and features.

5.3.2 Means of Egress. The design shall comply with the following requirements in addition to the performance criteria of Section 5.2 and the methods of Section 5.4 through Section 5.8:

- (1) Changes in level in means of egress — 7.1.7
- (2) Guards — 7.1.8
- (3) Doors — 7.2.1
- (4) Stairs — 7.2.2, excluding the provisions of 7.2.2.5.1, 7.2.2.5.2, 7.2.2.6.2, 7.2.2.6.3 and 7.2.2.6.4
- (5) Ramps — 7.2.5, excluding the provisions of 7.2.5.3.1, 7.2.5.5, and 7.2.5.6.1
- (6) Fire escape ladders — 7.2.9
- (7) Alternating tread devices — 7.2.11
- (8) Capacity of means of egress — Section 7.3, excluding the provisions of 7.3.3 and 7.3.4
- (9) Impediments to egress — 7.5.2
- (10) Illumination of means of egress — Section 7.8
- (11) Emergency lighting — Section 7.9
- (12) Marking of means of egress — Section 7.10

5.3.3 Equivalency. Equivalent designs for the features covered in the retained prescriptive requirements mandated by 5.3.2 shall be addressed in accordance with the equivalency provisions of Section 1.4.

5.4 Design Specifications and Other Conditions.

5.4.1* Clear Statement. Design specifications and other conditions used in the performance-based design shall be clearly stated and shown to be realistic and sustainable.

5.4.2 Assumptions and Design Specifications Data.

5.4.2.1 Each assumption and design specification used in the design shall be accurately translated into input data specifications, as appropriate for the calculation method or model.

5.4.2.2 Any assumption and design specifications that the design analyses do not explicitly address or incorporate and that are, therefore, omitted from input data specifications shall be identified, and a sensitivity analysis of the consequences of that omission shall be performed.

5.4.2.3 Any assumption and design specifications modified in the input data specifications, because of limitations in test methods or other data-generation procedures, shall be

identified, and a sensitivity analysis of the consequences of the modification shall be performed.

5.4.3 Building Characteristics. Characteristics of the building or its contents, equipment, or operations that are not inherent in the design specifications, but that affect occupant behavior or the rate of hazard development, shall be explicitly identified.

5.4.4* Operational Status and Effectiveness of Building Features and Systems. The performance of fire protection systems and building features shall reflect the documented performance and reliability of the components of those systems or features, unless design specifications are incorporated to modify the expected performance.

5.4.5 Occupant Characteristics.

5.4.5.1* General. The selection of occupant characteristics to be used in the design calculations shall be approved by the authority having jurisdiction and shall provide an accurate reflection of the expected population of building users. Occupant characteristics shall represent the normal occupant profile, unless design specifications are used to modify the expected occupant features. Occupant characteristics shall not vary across fire scenarios except as authorized by the authority having jurisdiction.

5.4.5.2* Response Characteristics. The basic response characteristics of sensibility, reactivity, mobility, and susceptibility shall be evaluated. Such evaluation shall include the expected distribution of characteristics of a population appropriate to the use of the building. The source of data for these characteristics shall be documented.

5.4.5.3 Location. It shall be assumed that, in every normally occupied room or area, at least one person shall be located at the most remote point from the exits.

5.4.5.4* Number of Occupants. The design shall be based on the maximum number of people that every occupied room or area is expected to contain. Where the success or failure of the design is contingent on the number of occupants not exceeding a specified maximum, operational controls shall be used to ensure that the maximum number of occupants is not exceeded.

5.4.5.5* Staff Assistance. The inclusion of trained employees as part of the fire safety system shall be identified and documented.

5.4.6 Emergency Response Personnel. Design characteristics or other conditions related to the availability, speed of response, effectiveness, roles, and other characteristics of emergency response personnel shall be specified, estimated, or characterized sufficiently for evaluation of the design.

5.4.7* Post-construction Conditions. Design characteristics or other conditions related to activities during the life of a building that affect the ability of the building to meet the stated goals and objectives shall be specified, estimated, or characterized sufficiently for evaluation of the design.

5.4.8 Off-Site Conditions. Design characteristics or other conditions related to resources or conditions outside the property being designed that affect the ability of the building to meet the stated goals and objectives shall be specified, estimated, or characterized sufficiently for evaluation of the design.

5.4.9* Consistency of Assumptions. The design shall not include mutually inconsistent assumptions, specifications, or statements of conditions.

5.4.10* Special Provisions. Additional provisions that are not covered by the design specifications, conditions, estimations, and assumptions provided in Section 5.4, but that are required for the design to comply with the performance objectives, shall be documented.

5.5* Design Fire Scenarios.

5.5.1 Approval of Parameters. The authority having jurisdiction shall approve the parameters involved in design fire scenarios. The proposed design shall be considered to meet the goals and objectives if it achieves the performance criteria for each required design fire scenario. (See 5.5.3.)

5.5.2* Evaluation. Design fire scenarios shall be evaluated using a method acceptable to the authority having jurisdiction and appropriate for the conditions. Each design fire scenario shall be as challenging as any that could occur in the building, but shall be realistic, with respect to at least one of the following scenario specifications:

- (1) Initial fire location
- (2) Early rate of growth in fire severity
- (3) Smoke generation

5.5.3* Required Design Fire Scenarios. Design fire scenarios shall comply with the following:

- (1) Scenarios selected as design fire scenarios shall include, but shall not be limited to, those specified in 5.5.3.1 through 5.5.3.8.
- (2) Design fire scenarios demonstrated by the design team to the satisfaction of the authority having jurisdiction as inappropriate for the building use and conditions shall not be required to be evaluated fully.

5.5.3.1* Design Fire Scenario 1. Design fire scenario 1 shall be as follows:

- (1) It is an occupancy-specific fire representative of a typical fire for the occupancy.
- (2) It explicitly accounts for the following:
 - (a) Occupant activities
 - (b) Number and location
 - (c) Room size
 - (d) Furnishings and contents
 - (e) Fuel properties and ignition sources
 - (f) Ventilation conditions
 - (g) Identification of the first item ignited and its location

5.5.3.2* Design Fire Scenario 2. Design fire scenario 2 shall be as follows:

- (1) It is an ultrafast-developing fire, in the primary means of egress, with interior doors open at the start of the fire.
- (2) It addresses the concern regarding a reduction in the number of available means of egress.

5.5.3.3* Design Fire Scenario 3. Design fire scenario 3 shall be as follows:

- (1) It is a fire that starts in a normally unoccupied room, potentially endangering a large number of occupants in a large room or other area.
- (2) It addresses the concern regarding a fire starting in a normally unoccupied room and migrating into the space that potentially holds the greatest number of occupants in the building.

5.5.3.4* Design Fire Scenario 4. Design fire scenario 4 shall be as follows:

- (1) It is a fire that originates in a concealed wall or ceiling space adjacent to a large occupied room.
- (2) It addresses the concern regarding a fire originating in a concealed space that does not have either a detection system or a suppression system and then spreading into the room within the building that potentially holds the greatest number of occupants.

5.5.3.5* Design Fire Scenario 5. Design fire scenario 5 shall be as follows:

- (1) It is a slowly developing fire, shielded from fire protection systems, in close proximity to a high occupancy area.
- (2) It addresses the concern regarding a relatively small ignition source, causing a significant fire.

5.5.3.6* Design Fire Scenario 6. Design fire scenario 6 shall be as follows:

- (1) It is the most severe fire resulting from the largest possible fuel load characteristic of the normal operation of the building.
- (2) It addresses the concern regarding a rapidly developing fire with occupants present.

5.5.3.7* Design Fire Scenario 7. Design fire scenario 7 shall be as follows:

- (1) It is an outside exposure fire.
- (2) It addresses the concern regarding a fire starting at a location remote from the area of concern and either spreading into the area, blocking escape from the area, or developing untenable conditions within the area.

5.5.3.8* Design Fire Scenario 8. Design fire scenario 8 shall be as follows:

- (1) It is a fire originating in ordinary combustibles in a room or area with each passive or active fire protection system independently rendered ineffective.
- (2) It addresses concerns regarding the unreliability or unavailability of each fire protection system or fire protection feature, considered individually.
- (3)*It is not required to be applied to fire protection systems for which both the level of reliability and the design performance in the absence of the system are acceptable to the authority having jurisdiction.

5.5.4 Design Fire Scenarios Data.

5.5.4.1 Each design fire scenario used in the performance-based design proposal shall be translated into input data specifications, as appropriate for the calculation method or model.

5.5.4.2 Any design fire scenario specifications that the design analyses do not explicitly address or incorporate and that are, therefore, omitted from input data specifications shall be identified, and a sensitivity analysis of the consequences of that omission shall be performed.

5.5.4.3 Any design fire scenario specifications modified in input data specifications, because of limitations in test methods or other data-generation procedures, shall be identified, and a sensitivity analysis of the consequences of the modification shall be performed.

5.6* Evaluation of Proposed Designs.

5.6.1 General. A proposed design's performance shall be assessed relative to each performance objective in Section 4.2 and each applicable scenario in 5.5.3, with the assessment conducted through the use of appropriate calculation methods.

The authority having jurisdiction shall approve the choice of assessment methods.

5.6.2 Use. The design professional shall use the assessment methods to demonstrate that the proposed design will achieve the goals and objectives, as measured by the performance criteria in light of the safety margins and uncertainty analysis, for each scenario, given the assumptions.

5.6.3 Input Data.

5.6.3.1 Data. Input data for computer fire models shall be obtained in accordance with ASTM E 1591, *Standard Guide for Data for Fire Models*. Data for use in analytical models that are not computer-based fire models shall be obtained using appropriate measurement, recording, and storage techniques to ensure the applicability of the data to the analytical method being used.

5.6.3.2 Data Requirements. A complete listing of input data requirements for all models, engineering methods, and other calculation or verification methods required or proposed as part of the performance-based design shall be provided.

5.6.3.3* Uncertainty and Conservatism of Data. Uncertainty in input data shall be analyzed and, as determined appropriate by the authority having jurisdiction, addressed through the use of conservative values.

5.6.4* Output Data. The assessment methods used shall accurately and appropriately produce the required output data from input data based on the design specifications, assumptions, and scenarios.

5.6.5 Validity. Evidence shall be provided to confirm that the assessment methods are valid and appropriate for the proposed building, use, and conditions.

5.7* Safety Factors. Approved safety factors shall be included in the design methods and calculations to reflect uncertainty in the assumptions, data, and other factors associated with the performance-based design.

5.8 Documentation Requirements.

5.8.1* General. All aspects of the design, including those described in 5.8.2 through 5.8.14, shall be documented. The format and content of the documentation shall be acceptable to the authority having jurisdiction.

5.8.2* Technical References and Resources. The authority having jurisdiction shall be provided with sufficient documentation to support the validity, accuracy, relevance, and precision of the proposed methods. The engineering standards, calculation methods, and other forms of scientific information provided shall be appropriate for the particular application and methodologies used.

5.8.3 Building Design Specifications. All details of the proposed building design that affect the ability of the building to meet the stated goals and objectives shall be documented.

5.8.4 Performance Criteria. Performance criteria, with sources, shall be documented.

5.8.5 Occupant Characteristics. Assumptions about occupant characteristics shall be documented.

5.8.6 Design Fire Scenarios. Descriptions of design fire scenarios shall be documented.

5.8.7 Input Data. Input data to models and assessment methods, including sensitivity analyses, shall be documented.

5.8.8 Output Data. Output data from models and assessment methods, including sensitivity analyses, shall be documented.

5.8.9 Safety Factors. The safety factors utilized shall be documented.

5.8.10 Prescriptive Requirements. Retained prescriptive requirements shall be documented.

5.8.11* Modeling Features.

5.8.11.1 Assumptions made by the model user, and descriptions of models and methods used, including known limitations, shall be documented.

5.8.11.2 Documentation shall be provided to verify that the assessment methods have been used validly and appropriately to address the design specifications, assumptions, and scenarios.

5.8.12 Evidence of Modeler Capability. The design team's relevant experience with the models, test methods, databases, and other assessment methods used in the performance-based design proposal shall be documented.

5.8.13 Performance Evaluation. The performance evaluation summary shall be documented.

5.8.14 Use of Performance-Based Design Option. Design proposals shall include documentation that provides anyone involved in the ownership or management of the building with notification of the following:

- (1) Approval of the building as a performance-based design with certain specified design criteria and assumptions
- (2) Need for required re-evaluation and reapproval in cases of remodeling, modification, renovation, change in use, or change in established assumptions

Chapter 6 Classification of Occupancy and Hazard of Contents

6.1 Classification of Occupancy.

6.1.1 General.

6.1.1.1 Occupancy Classification. The occupancy of a building or structure, or portion of a building or structure, shall be classified in accordance with 6.1.2 through 6.1.13. Occupancy classification shall be subject to the ruling of the authority having jurisdiction where there is a question of proper classification in any individual case.

6.1.1.2 Special Structures. Occupancies in special structures shall conform to the requirements of the specific occupancy chapter, Chapter 12 through Chapter 42, except as modified by Chapter 11.

6.1.2 Assembly. For requirements, see Chapter 12 and Chapter 13.

6.1.2.1* Definition — Assembly Occupancy. An occupancy (1) used for a gathering of 50 or more persons for deliberation, worship, entertainment, eating, drinking, amusement, awaiting transportation, or similar uses; or (2) used as a special amusement building, regardless of occupant load.

6.1.2.2 Small Assembly Uses. Occupancy of any room or space for assembly purposes by fewer than 50 persons in another occupancy and incidental to such other occupancy shall be classified as part of the other occupancy and shall be subject to the provisions applicable thereto.

6.1.3 Educational. For requirements, see Chapter 14 and Chapter 15.

6.1.3.1* Definition — Educational Occupancy. An occupancy used for educational purposes through the twelfth grade by six or more persons for 4 or more hours per day or more than 12 hours per week.

6.1.3.2 Other Occupancies. Other occupancies associated with educational institutions shall be in accordance with the appropriate parts of this *Code*.

6.1.3.3 Incidental Instruction. In cases where instruction is incidental to some other occupancy, the section of this *Code* governing such other occupancy shall apply.

6.1.4 Day Care. For requirements, see Chapter 16 and Chapter 17.

6.1.4.1* Definition — Day-Care Occupancy. An occupancy in which four or more clients receive care, maintenance, and supervision, by other than their relatives or legal guardians, for less than 24 hours per day.

6.1.4.2 Other. (Reserved)

6.1.5 Health Care. For requirements, see Chapter 18 and Chapter 19.

6.1.5.1* Definition — Health Care Occupancy. An occupancy used for purposes of medical or other treatment or care of four or more persons where such occupants are mostly incapable of self-preservation due to age, physical or mental disability, or because of security measures not under the occupants' control.

6.1.5.2 Other. (Reserved)

6.1.6 Ambulatory Health Care. For requirements, see Chapter 20 and Chapter 21.

6.1.6.1* Definition — Ambulatory Health Care Occupancy. A building or portion thereof used to provide services or treatment simultaneously to four or more patients that provides, on an outpatient basis, one or more of the following:

- (1) Treatment for patients that renders the patients incapable of taking action for self-preservation under emergency conditions without the assistance of others
- (2) Anesthesia that renders the patients incapable of taking action for self-preservation under emergency conditions without the assistance of others
- (3) Emergency or urgent care for patients who, due to the nature of their injury or illness, are incapable of taking action for self-preservation under emergency conditions without the assistance of others

6.1.6.2 Other. (Reserved)

6.1.7 Detention and Correctional. For requirements, see Chapter 22 and Chapter 23.

6.1.7.1* Definition — Detention and Correctional Occupancy. An occupancy used to house four or more persons under varied degrees of restraint or security where such occupants are mostly incapable of self-preservation because of security measures not under the occupants' control.

6.1.7.2* Nonresidential Uses. Within detention and correctional facilities, uses other than residential housing shall be in accordance with the appropriate chapter of the *Code*. (See 22.1.2.3 and 23.1.2.3.)

6.1.8 Residential. For requirements, see Chapter 24 through Chapter 31.

6.1.8.1 Definition — Residential Occupancy. An occupancy that provides sleeping accommodations for purposes other than health care or detention and correctional.

6.1.8.1.1* Definition — One- and Two-Family Dwelling Unit. A building that contains not more than two dwelling units with independent cooking and bathroom facilities.

6.1.8.1.2 Definition — Lodging or Rooming House. A building or portion thereof that does not qualify as a one- or two-family dwelling, that provides sleeping accommodations for a total of 16 or fewer people on a transient or permanent basis, without personal care services, with or without meals, but without separate cooking facilities for individual occupants.

6.1.8.1.3* Definition — Hotel. A building or groups of buildings under the same management in which there are sleeping accommodations for more than 16 persons and primarily used by transients for lodging with or without meals.

6.1.8.1.4* Definition — Dormitory. A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, but without individual cooking facilities.

6.1.8.1.5 Definition — Apartment Building. A building or portion thereof containing three or more dwelling units with independent cooking and bathroom facilities.

6.1.8.2 Other. (Reserved)

6.1.9 Residential Board and Care. For requirements, see Chapter 32 and Chapter 33.

6.1.9.1* Definition — Residential Board and Care Occupancy. A building or portion thereof that is used for lodging and boarding of four or more residents, not related by blood or marriage to the owners or operators, for the purpose of providing personal care services.

6.1.9.2 Other. (Reserved)

6.1.10 Mercantile. For requirements, see Chapter 36 and Chapter 37.

6.1.10.1* Definition — Mercantile Occupancy. An occupancy used for the display and sale of merchandise.

6.1.10.2 Other. (Reserved)

6.1.11 Business. For requirements, see Chapter 38 and Chapter 39.

6.1.11.1* Definition — Business Occupancy. An occupancy used for account and record keeping or the transaction of business other than mercantile.

6.1.11.2 Other. (Reserved)

6.1.12 Industrial. For requirements, see Chapter 40.

6.1.12.1* Definition — Industrial Occupancy. An occupancy in which products are manufactured or in which processing, assembling, mixing, packaging, finishing, decorating, or repair operations are conducted.

6.1.12.2 Other. (Reserved)

6.1.13 Storage. For requirements, see Chapter 42.

6.1.13.1* Definition — Storage Occupancy. An occupancy used primarily for the storage or sheltering of goods, merchandise, products, vehicles, or animals.

6.1.13.2 Other. (Reserved)

6.1.14 Multiple Occupancies.

6.1.14.1 General.

6.1.14.1.1 Multiple occupancies shall comply with the requirements of 6.1.14.1 and one of the following:

- (1) Mixed occupancies — 6.1.14.3
- (2) Separated occupancies — 6.1.14.4

6.1.14.1.2* Where incidental to another occupancy, areas used as follows shall be permitted to be considered part of the predominant occupancy and shall be subject to the provisions of the *Code* that apply to the predominant occupancy:

- (1) Mercantile, business, industrial, or storage use
- (2)*Nonresidential use with an occupant load fewer than that established by Section 6.1 for the occupancy threshold

6.1.14.1.3 The following accessory occupancies shall not be required to be separated from the primary occupancy as required in 6.1.14.4:

- (1) An area used solely as a public dining room having an occupant load of not more than 300 persons and accessory to a retail sales area
- (2) An assembly room not over 70 m² (750 ft²), where not accessory to an occupancy with high hazard contents
- (3) Administrative, clerical, or other office rooms that, in the aggregate, are not more than 25 percent of the principal occupancy, where not accessory to an occupancy with high hazard contents

6.1.14.2 Definitions.

6.1.14.2.1 Multiple Occupancy. A building or structure in which two or more classes of occupancy exist.

6.1.14.2.2 Mixed Occupancy. A multiple occupancy where the occupancies are intermingled.

6.1.14.2.3 Separated Occupancy. A multiple occupancy where the occupancies are separated by fire resistance-rated assemblies.

6.1.14.3 Mixed Occupancies.

6.1.14.3.1 Each portion of the building shall be classified as to its use in accordance with Section 6.1.

6.1.14.3.2 The means of egress facilities, type of construction, protection, and other safeguards in the building shall comply with the most restrictive fire and life safety requirements of the occupancies involved.

6.1.14.4 Separated Occupancies.

6.1.14.4.1 Where separated occupancies are provided, each part of the building comprising a distinct occupancy, as described in this chapter, shall be completely separated from other occupancies by fire-resistive assemblies as specified in 6.1.14.4.2, 6.1.14.4.3, and Table 6.1.14.4.1, unless separation is provided by approved existing separations.

6.1.14.4.2 Occupancy separations shall be classified as 3-hour fire resistance-rated, 2-hour fire resistance-rated, or 1-hour fire resistance-rated, and shall meet the requirements of Chapter 8.

6.1.14.4.3 The fire resistance rating specified in Table 6.1.14.4.1 shall be permitted to be reduced by 1 hour, but in no case shall it be reduced to less than 1 hour, where the building is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

6.1.14.4.4 Occupancy separations shall be vertical, horizontal, or both or, when necessary, of such other form as required to provide complete separation between occupancy divisions in the building.

6.2 Hazard of Contents.

6.2.1 General.

6.2.1.1 For the purpose of this *Code*, the hazard of contents shall be the relative danger of the start and spread of fire, the danger of smoke or gases generated, and the danger of explosion or other occurrence potentially endangering the lives and safety of the occupants of the building or structure.

Table 6.1.14.4.1 Required Separation of Occupancies (hours)^a

	Assembly ≤300	Assembly >300 to ≤1000	Assembly >1000	Educational	Day-Care >12 Clients	Day-Care Homes	Health Care	Ambulatory Health Care	Detention & Correctional	One- & Two-Family Dwellings	Lodging & Rooming Houses	Hotels & Dormitories
Assembly ≤ 300		0	0	2	2	1	2 ^b	2	2 ^b	2	2	2
Assembly >300 to ≤1000			0	2	2	2	2 ^b	2	2 ^b	2	2	2
Assembly >1000				2	2	2	2 ^b	2	2 ^b	2	2	2
Educational					2	2	2 ^b	2	2 ^b	2	2	2
Day-Care Homes							2 ^b	2	2 ^b	2	2	2
Day-Care >12						1	2 ^b	2	2 ^b	2	2	2
Health Care								2 ^b	2 ^b	2 ^b	2 ^b	2 ^b
Ambulatory Health Care									2 ^b	2	2	2
Detention & Correctional										2 ^b	2 ^b	2 ^b
One- & Two-Family Dwellings											1	1

(continues)

Table 6.1.14.4.1 *Continued*

	Assembly ≤300	Assembly >300 to ≤1000	Assembly >1000	Educational	Day-Care >12 Clients	Day-Care Homes	Health Care	Ambulatory Health Care	Detention & Correctional	One- & Two-Family Dwellings	Lodging & Rooming Houses	Hotels & Dormitories
Lodging & Rooming Houses												1
	Apartment Buildings	Board & Care, Small	Board & Care, Large	Mercantile	Mercantile, Mall	Mercantile, Bulk Retail	Business	Industrial, General Purpose	Industrial, Special Purpose	Industrial, High Hazard	Storage, Low & Ordinary Hazard	Storage, High Hazard
Assembly ≤ 300	2	2	2	2	2	3	1	2	2	3	2	3
Assembly >300 to ≤1000	2	2	2	2	2	3	2	2	2	3	2	3
Assembly >1000	2	2	2	2	2	3	2	3	2	3	3	3
Educational	2	2	2	2	2	3	2	3	3	3	3	3
Day-Care >12 Clients	2	2	2	2	2	3	2	3	3	3	3	3
Day-Care Homes	2	2	2	2	2	3	2	3	3	3	2	3
Health Care	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b
Ambulatory Health Care	2	2	2	2	2	2 ^b	1	2	2	2 ^b	2	2 ^b
Detention & Correctional	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	2 ^b	NP	2 ^b	NP
One- & Two-Family Dwellings	1	1	2	2	2	3	2	2	2	3	2	3
Lodging & Rooming Houses	1	2	2	2	2	3	2	2	2	3	2	3
Hotels & Dormitories	1	2	2	2	2	3	2	2	2	3	2	3
Apartment Buildings		2	2	2	2	3	2	2	2	3	2	3
Board & Care, Small			1	2	2	3	2	3	3	3	3	3
Board & Care, Large				2	2	3	2	3	3	3	3	3
Mercantile					0	3	2	2	2	3	2	3
Mercantile, Mall						3	2	3	3	3	2	3
Mercantile, Bulk Retail							2	2	2	3	2	2
Business								2	2	2	2	2
Industrial, General Purpose									1	1	1	1
Industrial, Special Purpose										1	1	1
Industrial, High Hazard											1	1
Storage, Low & Ordinary Hazard												1
Storage, High Hazard												

NP = Not permitted

^a The fire resistance rating is permitted to be reduced by 1 hour, but in no case to less than 1 hour, where the building is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.^b The 1-hour reduction due to the presence of sprinklers in accordance with footnote a is not permitted.

6.2.1.2 Hazard of contents shall be determined by the authority having jurisdiction on the basis of the character of the contents and the processes or operations conducted in the building or structure.

6.2.1.3* For the purpose of this *Code*, where different degrees of hazard of contents exist in different parts of a building or structure, the most hazardous shall govern the classification, unless hazardous areas are separated or protected as specified in Section 8.7 and the applicable sections of Chapter 11 through Chapter 42.

6.2.2 Classification of Hazard of Contents.

6.2.2.1* The hazard of contents of any building or structure shall be classified as low, ordinary, or high in accordance with 6.2.2.2, 6.2.2.3, and 6.2.2.4.

6.2.2.2* **Low Hazard.** Low hazard contents shall be classified as those of such low combustibility that no self-propagating fire therein can occur.

6.2.2.3* **Ordinary Hazard.** Ordinary hazard contents shall be classified as those that are likely to burn with moderate rapidity or to give off a considerable volume of smoke.

6.2.2.4* **High Hazard.** High hazard contents shall be classified as those that are likely to burn with extreme rapidity or from which explosions are likely. (*For means of egress requirements, see Section 7.11.*)

Chapter 7 Means of Egress

7.1 General.

7.1.1* **Application.** Means of egress for both new and existing buildings shall comply with this chapter. (*See also 4.5.3.*)

7.1.2 **Definitions.** The following is a list of terms used in this chapter:

- (1) **Accessible Area of Refuge.** See 3.3.17.1.
- (2) **Accessible Means of Egress.** See 3.3.136.1.
- (3) **Area of Refuge.** See 3.3.17.
- (4) **Common Path of Travel.** See 3.3.34.
- (5) **Electroluminescent.** See 3.3.52.
- (6) **Elevator Evacuation System.** See 3.3.218.1.
- (7) **Elevator Lobby.** See 3.3.54.
- (8) **Elevator Lobby Door.** See 3.3.47.1.
- (9) **Exit.** See 3.3.62.
- (10) **Exit Access.** See 3.3.63.
- (11) **Exit Discharge.** See 3.3.64.
- (12) **Externally Illuminated.** See 3.3.114.1.
- (13) **Horizontal Exit.** See 3.3.62.1.
- (14) **Internally Illuminated.** See 3.3.114.2.
- (15) **Means of Egress.** See 3.3.136.
- (16) **Photoluminescent.** See 3.3.164.
- (17) **Ramp.** See 3.3.176.
- (18) **Self-Luminous.** See 3.3.190.
- (19) **Severe Mobility Impairment.** See 3.3.195.
- (20) **Smokeproof Enclosure.** See 3.3.203.

7.1.3 **Separation of Means of Egress.** See also Section 8.2.

7.1.3.1 **Exit Access Corridors.** Corridors used as exit access and serving an area having an occupant load exceeding 30 shall be separated from other parts of the building by walls having not less than a 1-hour fire resistance rating in accordance with Section 8.3, unless otherwise permitted by the following:

- (1) This requirement shall not apply to existing buildings, provided that the occupancy classification does not change.
- (2) This requirement shall not apply where otherwise provided in Chapter 12 through Chapter 42.

7.1.3.2 Exits.

7.1.3.2.1 Where this *Code* requires an exit to be separated from other parts of the building, the separating construction shall meet the requirements of Section 8.2 and the following:

- (1)*The separation shall have not less than a 1-hour fire resistance rating where the exit connects three stories or less.
- (2)*The separation shall have not less than a 2-hour fire resistance rating where the exit connects four or more stories, unless one of the following conditions exists:
 - (a) In existing non-high-rise buildings, existing exit stair enclosures shall have not less than a 1-hour fire resistance rating.
 - (b) In existing buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, existing exit stair enclosures shall have not less than a 1-hour fire resistance rating.
 - (c) One-hour enclosures in accordance with 28.2.2.1.2, 29.2.2.1.2, 30.2.2.1.2, and 31.2.2.1.2 shall be permitted as an alternative to the requirement of 7.1.3.2.1(2).
- (3) The 2-hour fire resistance-rated separation required by 7.1.3.2.1(2) above shall be constructed of an assembly of noncombustible or limited-combustible materials and shall be supported by construction having not less than a 2-hour fire resistance rating.
- (4) Openings in the separation shall be protected by fire door assemblies equipped with door closers complying with 7.2.1.8.
- (5)*Openings in exit enclosures shall be limited to doors from normally occupied spaces and corridors and doors for egress from the enclosure, unless one of the following conditions exists:
 - (a) Openings in exit passageways in mall buildings as provided in Chapter 36 and Chapter 37 shall be permitted.
 - (b) In buildings of Type I or Type II construction, existing fire protection-rated doors to interstitial spaces shall be permitted, provided that such spaces meet all of the following criteria:
 - i. The space is used solely for distribution of pipes, ducts, and conduits.
 - ii. The space contains no storage.
 - iii. The space is separated from the exit enclosure in accordance with Section 8.3.
 - (c) Existing openings to mechanical equipment spaces protected by approved existing fire protection-rated doors shall be permitted, provided that the following criteria are met:
 - i. The space is used solely for non-fuel-fired mechanical equipment.
 - ii. The space contains no storage of combustible materials.
 - iii. The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (6) Penetrations into, and openings through, an exit enclosure assembly shall be limited to the following:
 - (a) Doors permitted by 7.1.3.2.1(5)
 - (b) Electrical conduit serving the stairway
 - (c) Required exit doors

- (d) Ductwork and equipment necessary for independent stair pressurization
 - (e) Water or steam piping necessary for the heating or cooling of the exit enclosure
 - (f) Sprinkler piping
 - (g) Standpipes
 - (h) Existing penetrations protected in accordance with 8.3.5
 - (i) Penetrations for fire alarm circuits where the circuits are installed in metal conduit and the penetrations are protected in accordance with 8.3.5.
- (7) Penetrations or communicating openings shall be prohibited between adjacent exit enclosures.

7.1.3.2.2 An exit enclosure shall provide a continuous protected path of travel to an exit discharge.

7.1.3.2.3* An exit enclosure shall not be used for any purpose that has the potential to interfere with its use as an exit and, if so designated, as an area of refuge. (*See also 7.2.2.5.3.*)

7.1.4 Interior Finish in Exit Enclosures.

7.1.4.1* Interior Wall and Ceiling Finish in Exit Enclosures. Interior wall and ceiling finish shall be in accordance with Section 10.2. In exit enclosures, interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B.

7.1.4.2* Interior Floor Finish in Exit Enclosures. New interior floor finish in exit enclosures, including stair treads and risers, shall be not less than Class II in accordance with Chapter 10.

7.1.5* Headroom.

7.1.5.1 Means of egress shall be designed and maintained to provide headroom in accordance with other sections of this *Code*, and such headroom shall be not less than 2285 mm (90 in.), with projections from the ceiling not less than 2030 mm (80 in.) nominal above the finished floor, unless otherwise specified in 7.1.5.1.1 and 7.1.5.1.2.

7.1.5.1.1 In existing buildings, the ceiling height shall be not less than 2135 mm (84 in.) from the floor, with projections from the ceiling not less than 2030 mm (80 in.) nominal above the floor.

7.1.5.1.2 Headroom in industrial equipment access areas as provided in 40.2.5.2 shall be permitted.

7.1.5.2 The minimum ceiling height shall be maintained for not less than two-thirds of the ceiling area of any room or space, provided that the ceiling height of remaining ceiling area is not less than 2030 mm (80 in.).

7.1.5.3 Headroom on stairs shall be not less than 2030 mm (80 in.) and shall be measured vertically above a plane parallel to and tangent with the most forward projection of the stair tread.

7.1.6 Walking Surfaces in the Means of Egress.

7.1.6.1 General.

7.1.6.1.1 Walking surfaces in the means of egress shall comply with 7.1.6.2 through 7.1.6.4.

7.1.6.1.2 Approved, existing walking surfaces shall be permitted.

7.1.6.2 Changes in Elevation. Abrupt changes in elevation of walking surfaces shall not exceed 6.3 mm ($\frac{1}{4}$ in.). Changes in elevation exceeding 6.3 mm ($\frac{1}{4}$ in.), but not exceeding 13 mm ($\frac{1}{2}$ in.), shall be beveled 1 to 2. Changes in elevation

exceeding 13 mm ($\frac{1}{2}$ in.) shall be considered a change in level and shall be subject to the requirements of 7.1.7.

7.1.6.3 Level. Walking surfaces shall be nominally level. The slope of a walking surface in the direction of travel shall not exceed 1 in 20 unless the ramp requirements of 7.2.5 are met. The slope perpendicular to the direction of travel shall not exceed 1 in 48.

7.1.6.4* Slip Resistance. Walking surfaces shall be slip resistant under foreseeable conditions. The walking surface of each element in the means of egress shall be uniformly slip resistant along the natural path of travel.

7.1.7 Changes in Level in Means of Egress.

7.1.7.1 Changes in level in means of egress shall be achieved by an approved means of egress where the elevation difference exceeds 535 mm (21 in.).

7.1.7.2* Changes in level in means of egress not in excess of 535 mm (21 in.) shall be achieved either by a ramp complying with the requirements of 7.2.5 or by a stair complying with the requirements of 7.2.2.

7.1.7.2.1 Where a ramp is used, the presence and location of ramped portions of walkways shall be readily apparent.

7.1.7.2.2 Where a stair is used, the tread depth of such stair shall be not less than 330 mm (13 in.).

7.1.7.2.3 Tread depth in industrial equipment access areas as provided in 40.2.5.2 shall be permitted.

7.1.7.2.4 The presence and location of each step shall be readily apparent.

7.1.8* Guards. Guards in accordance with 7.2.2.4 shall be provided at the open sides of means of egress that exceed 760 mm (30 in.) above the floor or grade below.

7.1.9 Impediments to Egress. Any device or alarm installed to restrict the improper use of a means of egress shall be designed and installed so that it cannot, even in case of failure, impede or prevent emergency use of such means of egress unless otherwise provided in 7.2.1.6 and Chapter 18, Chapter 19, Chapter 22, and Chapter 23.

7.1.10 Means of Egress Reliability.

7.1.10.1* Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency.

7.1.10.2 Furnishings and Decorations in Means of Egress.

7.1.10.2.1 No furnishings, decorations, or other objects shall obstruct exits, access thereto, egress therefrom, or visibility thereof.

7.1.10.2.2 No obstruction by railings, barriers, or gates shall divide the means of egress into sections appurtenant to individual rooms, apartments, or other occupied spaces. Where the authority having jurisdiction finds the required path of travel to be obstructed by furniture or other movable objects, the authority shall be permitted to require that such objects be secured out of the way or shall be permitted to require that railings or other permanent barriers be installed to protect the path of travel against encroachment.

7.1.10.2.3 Mirrors shall not be placed on exit doors. Mirrors shall not be placed in or adjacent to any exit in such a manner as to confuse the direction of egress.

7.1.11 Sprinkler System Installation. Where another provision of this chapter requires an automatic sprinkler system, the sprinkler system shall be installed in accordance with the subparts of 9.7.1.1 permitted by the applicable occupancy chapters.

7.2 Means of Egress Components.

7.2.1 Doors.

7.2.1.1 General.

7.2.1.1.1 A door assembly in a means of egress shall conform to the general requirements of Section 7.1 and to the special requirements of 7.2.1. Such an assembly shall be designated as a door.

7.2.1.1.2 Every door and every principal entrance that is required to serve as an exit shall be designed and constructed so that the path of egress travel is obvious and direct. Windows that, because of their physical configuration or design and the materials used in their construction, have the potential to be mistaken for doors shall be made inaccessible to the occupants by barriers or railings.

7.2.1.1.3* For the purposes of Section 7.2, a building shall be considered to be occupied at any time it is open for general occupancy, any time it is open to the public, or at any other time it is occupied by more than 10 persons.

7.2.1.2 Width.

7.2.1.2.1* Egress Capacity Width. For purposes of calculating capacity, the width of doors shall be measured as follows:

- (1) For new swinging doors, only the width of the doorway when the door is open 90 degrees, as measured in accordance with 7.2.1.2.1(4) and 7.2.1.2.1(5), shall be included.
- (2) For other types of new doors, only the width of the doorway when the door is in the fully open position, as measured in accordance with 7.2.1.2.1(4) and 7.2.1.2.1(5), shall be included.
- (3) For any existing door installation, only the width of the doorway when the door is in the fully open position, as measured in accordance with 7.2.1.2.1(4) and 7.2.1.2.1(5), shall be included.
- (4) For all doors, projections not more than 90 mm (3½ in.) at each side of the doorway at a height of not more than 965 mm (38 in.) shall not be considered a reduction in egress capacity width.
- (5) For swinging doors, egress capacity width shall be measured between the face of the door and the stop.

7.2.1.2.2 Clear Width. Clear width shall be measured as follows:

- (1) At the narrowest point in the door opening
- (2) For swinging doors, between the face of the door and the stop
- (3) Without subtracting for the obstructions permitted by 7.2.1.2.3.2 and 7.2.1.2.3.3

7.2.1.2.3* Measurement.

7.2.1.2.3.1 For purposes of determining minimum door width, the clear width shall be used unless door leaf width is specified.

7.2.1.2.3.2 For swinging doors, projections of not more than 100 mm (4 in.) into the doorway width on the hinge side shall not be considered reductions in width, provided that such projections are for purposes of accommodating panic hardware or fire exit hardware and are located not less than 865 mm (34 in.) above the floor.

7.2.1.2.3.3 Projections exceeding 2030 mm (80 in.) above the floor shall not be considered reductions in width.

7.2.1.2.4 Minimum Door Width. Door openings in means of egress shall be not less than 810 mm (32 in.) in clear width, unless one of the following conditions exists:

- (1) Where a pair of doors is provided, not less than one of the doors shall provide not less than an 810-mm (32-in.) clear width opening.
- (2) Exit access doors serving a room not exceeding 70 ft² (6.5 m²) and not required to be accessible to persons with severe mobility impairments shall be not less than 610 mm (24 in.) in door leaf width.
- (3) Doors serving a building or portion thereof not required to be accessible to persons with severe mobility impairments shall be permitted to be 710 mm (28 in.) in door leaf width.
- (4) In existing buildings, the existing door leaf width shall be not less than 710 mm (28 in.).
- (5) Doors in detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23 shall not be required to comply with 7.2.1.2.4.
- (6) Interior doors in dwelling units as otherwise provided in Chapter 24 shall not be required to comply with 7.2.1.2.4.
- (7) A power-operated door leaf located within a two-leaf opening shall be exempt from the minimum 810-mm (32-in.) single-leaf requirement in accordance with 7.2.1.9.1.5.
- (8) Revolving doors as provided in 7.2.1.10 shall be exempt from the minimum 810-mm (32-in.) width requirement.

7.2.1.3 Floor Level.

7.2.1.3.1 The elevation of the floor surfaces on both sides of a door shall not vary by more than 13 mm (½ in.).

7.2.1.3.2 The elevation of the floor surfaces required by 7.2.1.3.1 shall be maintained on both sides of the doorway for a distance not less than the width of the widest leaf.

7.2.1.3.3 Thresholds at doorways shall not exceed 13 mm (½ in.) in height.

7.2.1.3.4 Raised thresholds and floor level changes in excess of 6.3 mm (¼ in.) at doorways shall be beveled with a slope not steeper than 1 in 2.

7.2.1.3.5 In existing buildings where the door discharges to the outside or to an exterior balcony or exterior exit access, the floor level outside the door shall be permitted to be one step lower than that of the inside, but shall be not more than 205 mm (8 in.) lower.

7.2.1.3.6 In existing buildings, a door at the top of a stair shall be permitted to open directly at a stair, provided that the door does not swing over the stair and that the door serves an area with an occupant load of fewer than 50 persons.

7.2.1.4 Swing and Force to Open.

7.2.1.4.1* Any door in a means of egress shall be of the side-hinged or pivoted-swinging type, and shall be installed to be capable of swinging from any position to the full required width of the opening in which it is installed, unless otherwise specified in 7.2.1.4.1.1 through 7.2.1.4.1.8.

7.2.1.4.1.1 Sliding doors in detention and correctional occupancies as provided in Chapter 22 and Chapter 23, shall be permitted.

7.2.1.4.1.2 Doors in dwelling units as provided in Chapter 24 shall be permitted.

7.2.1.4.1.3 Doors in residential board and care occupancies as provided in Chapter 32 and Chapter 33 shall be permitted.

7.2.1.4.1.4 Where permitted in Chapter 12 through Chapter 42, horizontal-sliding or vertical-rolling security grilles or doors that are part of the required means of egress shall be permitted, provided that they meet the following criteria:

- (1) Such grilles or doors shall remain secured in the fully open position during the period of occupancy by the general public.
- (2) On or adjacent to the grille or door, there shall be a readily visible, durable sign in letters not less than 25 mm (1 in.) high on a contrasting background that reads as follows: **THIS DOOR TO REMAIN OPEN WHEN THE BUILDING IS OCCUPIED.**
- (3) Doors or grilles shall not be brought to the closed position when the space is occupied.
- (4) Doors or grilles shall be operable from within the space without the use of any special knowledge or effort.
- (5) Where two or more means of egress are required, not more than half of the means of egress shall be equipped with horizontal-sliding or vertical-rolling grilles or doors.

7.2.1.4.1.5 Horizontal-sliding doors complying with 7.2.1.14 shall be permitted.

7.2.1.4.1.6 Where private garages, business areas, industrial areas, and storage areas with an occupant load not exceeding 10 contain only low or ordinary hazard contents, doors to such areas shall be exempt from the requirement of 7.2.1.4.1.

7.2.1.4.1.7 Revolving doors complying with 7.2.1.10 shall be permitted.

7.2.1.4.1.8 Existing fusible link-operated horizontal-sliding or vertical-rolling fire doors shall be permitted to be used as provided in Chapter 12 through Chapter 42.

7.2.1.4.2 Doors required to be of the side-hinged or pivoted-swinging type shall swing in the direction of egress travel where serving a room or area with an occupant load of 50 or more, except under the following conditions:

- (1) Doors in horizontal exits shall not be required to swing in the direction of egress travel where permitted by 7.2.4.3.7.1 or 7.2.4.3.7.2.
- (2) Smoke barrier doors shall not be required to swing in the direction of egress travel in existing health care occupancies as provided in Chapter 19.

7.2.1.4.3 A door shall swing in the direction of egress travel under either of the following conditions:

- (1) Where the door is used in an exit enclosure, unless the door is the door of an individual living unit that opens directly into an exit enclosure
- (2) Where the door serves a high hazard contents area

7.2.1.4.4* During its swing, any door in a means of egress shall leave not less than one-half of the required width of an aisle, a corridor, a passageway, or a landing unobstructed and shall project not more than 180 mm (7 in.) into the required width of an aisle, a corridor, a passageway, or a landing, when fully open, unless both of the following conditions are met:

- (1) The door provides access to a stair in an existing building.

- (2) The door meets the requirement that limits projection to not more than 180 mm (7 in.) into the required width of a stair or landing when the door is fully open.

7.2.1.4.5 The forces required to fully open any door manually in a means of egress shall not exceed 67 N (15 lbf) to release the latch, 133 N (30 lbf) to set the door in motion, and 67 N (15 lbf) to open the door to the minimum required width, unless otherwise specified in 7.2.1.4.5.2 through 7.2.1.4.5.5.

7.2.1.4.5.1 The forces specified in 7.2.1.4.5 shall be applied to the latch stile.

7.2.1.4.5.2 Opening forces for interior side-hinged or pivoted-swinging doors without closers shall not exceed 22 N (5 lbf).

7.2.1.4.5.3 The opening force for existing doors in existing buildings shall not exceed 222 N (50 lbf) applied to the latch stile.

7.2.1.4.5.4 The opening forces for horizontal sliding doors in detention and correctional occupancies shall be as provided in Chapter 22 and Chapter 23.

7.2.1.4.5.5 The opening forces for power-operated doors shall be as provided in 7.2.1.9.

7.2.1.4.6 Screen doors and storm doors used in a means of egress shall be subject to the requirements for direction of swing that are applicable to other doors used in a means of egress.

7.2.1.5 Locks, Latches, and Alarm Devices.

7.2.1.5.1 Doors shall be arranged to be opened readily from the egress side whenever the building is occupied.

7.2.1.5.2 Locks, if provided, shall not require the use of a key, a tool, or special knowledge or effort for operation from the egress side.

7.2.1.5.3 The requirements of 7.2.1.5.1 and 7.2.1.5.2 shall not apply where otherwise provided in Chapter 18 through Chapter 23.

7.2.1.5.4 Exterior doors shall be permitted to have key-operated locks from the egress side, provided that the following criteria are met:

- (1) This alternative is permitted in Chapter 12 through Chapter 42 for the specific occupancy.
- (2) A readily visible, durable sign in letters not less than 25 mm (1 in.) high on a contrasting background that reads as follows is located on or adjacent to the door: **THIS DOOR TO REMAIN UNLOCKED WHEN THE BUILDING IS OCCUPIED.**
- (3) The locking device is of a type that is readily distinguishable as locked.
- (4) A key is immediately available to any occupant inside the building when it is locked.

7.2.1.5.5 The alternative provisions of 7.2.1.5.4 shall be permitted to be revoked by the authority having jurisdiction for cause.

7.2.1.5.6 Where permitted in Chapter 12 through Chapter 42, key operation shall be permitted, provided that the key cannot be removed when the door is locked from the side from which egress is to be made.

7.2.1.5.7* Every door in a stair enclosure serving more than four stories, unless permitted by 7.2.1.5.7.2, shall meet one of the following:

- (1) Re-entry from the stair enclosure to the interior of the building shall be provided.
- (2) An automatic release that is actuated with the initiation of the building fire alarm system shall be provided to unlock all stair enclosure doors to allow re-entry.
- (3) Selected re-entry shall be provided in accordance with 7.2.1.5.7.1.

7.2.1.5.7.1 Doors on stair enclosures shall be permitted to be equipped with hardware that prevents re-entry into the interior of the building, provided that the following criteria are met:

- (1) There shall be not less than two levels where it is possible to leave the stair enclosure to access another exit.
- (2) There shall be not more than four stories intervening between stories where it is possible to leave the stair enclosure to access another exit.
- (3) Re-entry shall be possible on the top story or next-to-top story that allows access to another exit.
- (4) Doors allowing re-entry shall be identified as such on the stair side of the door.
- (5) Doors not allowing re-entry shall be provided with a sign on the stair side indicating the location of the nearest door, in each direction of travel, that allows re-entry or exit.

7.2.1.5.7.2 The requirement of 7.2.1.5.7 shall not apply to the following:

- (1) Existing installations as permitted in Chapter 12 through Chapter 42
- (2) Stair enclosures serving a building permitted to have a single exit in accordance with Chapter 11 through Chapter 42
- (3) Stair enclosures in health care occupancies where otherwise provided in Chapter 18
- (4) Stair enclosures in detention and correctional occupancies where otherwise provided in Chapter 22

7.2.1.5.8 If a stair enclosure allows access to the roof of the building, the door to the roof either shall be kept locked or shall allow re-entry from the roof.

7.2.1.5.9* A latch or other fastening device on a door shall be provided with a releasing device that has an obvious method of operation and that is readily operated under all lighting conditions.

7.2.1.5.9.1 The releasing mechanism for any latch other than existing installations shall be located not less than 865 mm (34 in.), and not more than 1220 mm (48 in.), above the finished floor.

7.2.1.5.9.2 The releasing mechanism shall open the door with not more than one releasing operation, unless otherwise specified in 7.2.1.5.9.3 and 7.2.1.5.9.4.

7.2.1.5.9.3* Egress doors from individual living units and guest rooms of residential occupancies shall be permitted to be provided with devices, including automatic latching devices, that require not more than one additional releasing operation, provided that such device is operable from the inside without the use of a key or tool and is mounted at a height not exceeding 1220 mm (48 in.) above the finished floor.

7.2.1.5.9.4 Existing security devices permitted by 7.2.1.5.9.3 shall be permitted to have two additional releasing operations.

7.2.1.5.9.5 Existing security devices permitted by 7.2.1.5.9.3, other than automatic latching devices, shall be located not more than 1525 mm (60 in.) above the finished floor.

7.2.1.5.10 Where pairs of doors are required in a means of egress, one of the following criteria shall be met:

- (1) Each leaf of the pair shall be provided with a releasing device that does not depend on the release of one door before the other.
- (2) Approved automatic flush bolts shall be used and arranged such that the following criteria are met:
 - (a) The door leaf equipped with the automatic flush bolts shall have no doorknob or surface-mounted hardware.
 - (b) Unlatching of any leaf shall not require more than one operation.

7.2.1.5.11* Devices shall not be installed in connection with any door on which panic hardware or fire exit hardware is required where such devices prevent or are intended to prevent the free use of the door for purposes of egress, unless otherwise provided in 7.2.1.6.

7.2.1.6 Special Locking Arrangements.

7.2.1.6.1 Delayed-Egress Locks. Approved, listed, delayed-egress locks shall be permitted to be installed on doors serving low and ordinary hazard contents in buildings protected throughout by an approved, supervised automatic fire detection system in accordance with Section 9.6 or an approved, supervised automatic sprinkler system in accordance with Section 9.7, and where permitted in Chapter 12 through Chapter 42, provided that the following criteria are met:

- (1) The doors shall unlock upon actuation of one of the following:
 - (a) An approved, supervised automatic sprinkler system in accordance with Section 9.7
 - (b) Any heat detector
 - (c) Not more than two smoke detectors of an approved, supervised automatic fire detection system in accordance with Section 9.6
- (2) The doors shall unlock upon loss of power controlling the lock or locking mechanism.
- (3)*An irreversible process shall release the lock within 15 seconds, or 30 seconds where approved by the authority having jurisdiction, upon application of a force to the release device required in 7.2.1.5.9 under the following conditions:
 - (a) The force shall not be required to exceed 67 N (15 lbf).
 - (b) The force shall not be required to be continuously applied for more than 3 seconds.
 - (c) The initiation of the release process shall activate an audible signal in the vicinity of the door.
 - (d) Once the door lock has been released by the application of force to the releasing device, relocking shall be by manual means only.
- (4)*A readily visible, durable sign in letters not less than 25 mm (1 in.) high and not less than 3.2 mm (1/8 in.) in stroke width on a contrasting background that reads as follows shall be located on the door adjacent to the release device:

PUSH UNTIL ALARM SOUNDS

DOOR CAN BE OPENED IN 15 SECONDS

7.2.1.6.2 Access-Controlled Egress Doors. Where permitted in Chapter 11 through Chapter 42, doors in the means of egress shall be permitted to be equipped with an approved

entrance and egress access control system, provided that the following criteria are met:

- (1) One of the following shall be provided:
 - (a) A sensor on the egress side, arranged to detect an occupant approaching doors that are arranged to unlock in the direction of egress upon detection of an approaching occupant or loss of power to the sensor
 - (b) Listed panic hardware or fire exit hardware that, when operated, unlocks the door
- (2) Loss of power to the part of the access control system that locks the doors shall automatically unlock the doors in the direction of egress.
- (3) The doors shall be arranged to unlock in the direction of egress from a manual release device located 1015 mm to 1220 mm (40 in. to 48 in.) vertically above the floor and within 1525 mm (60 in.) of the secured doors.
- (4) The manual release device specified in 7.2.1.6.2(3) shall be readily accessible and clearly identified by a sign that reads as follows: PUSH TO EXIT.
- (5) When operated, the manual release device shall result in direct interruption of power to the lock — independent of the access control system electronics — and the doors shall remain unlocked for not less than 30 seconds.
- (6) Activation of the building fire-protective signaling system, if provided, shall automatically unlock the doors in the direction of egress, and the doors shall remain unlocked until the fire-protective signaling system has been manually reset.
- (7) Activation of the building automatic sprinkler or fire detection system, if provided, shall automatically unlock the doors in the direction of egress, and the doors shall remain unlocked until the fire-protective signaling system has been manually reset.

7.2.1.7 Panic Hardware and Fire Exit Hardware.

7.2.1.7.1 Where a door is required to be equipped with panic or fire exit hardware, such hardware shall meet the following criteria:

- (1) It shall consist of a cross bar or a push pad, the actuating portion of which extends across not less than one-half of the width of the door leaf.
- (2) It shall be mounted as follows:
 - (a) New installations shall be not less than 865 mm (34 in.), nor more than 1220 mm (48 in.), above the floor.
 - (b) Existing installations shall be not less than 760 mm (30 in.), nor more than 1220 mm (48 in.), above the floor.
- (3) It shall be constructed so that a horizontal force not to exceed 66 N (15 lbf) actuates the cross bar or push pad and latches.

7.2.1.7.2 Only approved panic hardware shall be used on doors that are not fire doors. Only approved fire exit hardware shall be used on fire doors.

7.2.1.7.3 Required panic hardware and fire exit hardware, in other than detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23, shall not be equipped with any locking device, set screw, or other arrangement that prevents the release of the latch when pressure is applied to the releasing device.

7.2.1.7.4 Devices that hold the latch in the retracted position shall be prohibited on fire exit hardware, unless such devices are listed and approved for such purposes.

7.2.1.8 Self-Closing Devices.

7.2.1.8.1* A door normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2.

7.2.1.8.2 In any building of low or ordinary hazard contents, as defined in 6.2.2.2 and 6.2.2.3, or where approved by the authority having jurisdiction, doors shall be permitted to be automatic-closing, provided that the following criteria are met:

- (1) Upon release of the hold-open mechanism, the door becomes self-closing.
- (2) The release device is designed so that the door instantly releases manually and, upon release, becomes self-closing, or the door can be readily closed.
- (3) The automatic releasing mechanism or medium is activated by the operation of approved smoke detectors installed in accordance with the requirements for smoke detectors for door release service in *NFPA 72®*, *National Fire Alarm Code®*.
- (4) Upon loss of power to the hold-open device, the hold-open mechanism is released and the door becomes self-closing.
- (5) The release by means of smoke detection of one door in a stair enclosure results in closing all doors serving that stair.

7.2.1.9* Powered Doors.

7.2.1.9.1* **General.** Where means of egress doors are operated by power upon the approach of a person or are provided with power-assisted manual operation, the design shall be such that, in the event of power failure, the doors open manually to allow egress travel or close when necessary to safeguard the means of egress.

7.2.1.9.1.1 The forces required to manually open the doors specified in 7.2.1.9.1 shall not exceed those required in 7.2.1.4.5, except that the force required to set the door in motion shall not exceed 222 N (50 lbf).

7.2.1.9.1.2 The door shall be designed and installed so that, when a force is applied to the door on the side from which egress is made, it shall be capable of swinging from any position to provide full use of the required width of the opening in which it is installed (*see* 7.2.1.4).

7.2.1.9.1.3 A readily visible, durable sign in letters not less than 25 mm (1 in.) high on a contrasting background that reads as follows shall be located on the egress side of each door:

IN EMERGENCY, PUSH TO OPEN

7.2.1.9.1.4 Sliding, power-operated doors in exit access serving an occupant load of fewer than 50 that manually open in the direction of door travel with forces not exceeding those required in 7.2.1.4.5 shall not be required to have the swing-out feature required by 7.2.1.9.1.2. The required sign shall be in letters not less than 25 mm (1 in.) high on a contrasting background and shall read as follows:

IN EMERGENCY, SLIDE TO OPEN

7.2.1.9.1.5* In the emergency breakout mode, a door leaf located within a two-leaf opening shall be exempt from the minimum 810-mm (32-in.) single-leaf requirement of 7.2.1.2.4, provided that the clear width of the single leaf is not less than 760 mm (30 in.).

7.2.1.9.1.6 For a biparting sliding door in the emergency breakout mode, a door leaf located within a multiple-leaf opening shall be exempt from the minimum 810-mm (32-in.) single-leaf requirement of 7.2.1.2.4 if a clear opening of not less than 810 mm (32 in.) is provided by all leaves broken out.

7.2.1.9.1.7 Doors complying with 7.2.1.14 shall be permitted to be used.

7.2.1.9.1.8 The requirements of 7.2.1.9.1 through 7.2.1.9.1.7 shall not apply in detention and correctional occupancies where otherwise provided in Chapter 22 and Chapter 23.

7.2.1.9.2 Doors Required to Be Self-Closing. Where doors are required to be self-closing and are operated by power upon the approach of a person, or are provided with power-assisted manual operation, they shall be permitted in the means of egress where they meet the following criteria:

- (1) The doors can be opened manually in accordance with 7.2.1.9.1 to allow egress travel in the event of power failure.
- (2) New doors remain in the closed position unless actuated or opened manually.
- (3) When actuated, new doors remain open for not more than 30 seconds.
- (4) Doors held open for any period of time close — and the power-assist mechanism ceases to function — upon operation of approved smoke detectors installed in such a way as to detect smoke on either side of the door opening in accordance with the provisions of *NFPA 72*[®], *National Fire Alarm Code*[®].
- (5) Doors required to be self-latching are either self-latching or become self-latching upon operation of approved smoke detectors per 7.2.1.9.2(4).
- (6) New power-assisted swinging doors comply with BHMA/ANSI A156.19, *American National Standard for Power Assist and Low Energy Power Operated Doors*.

7.2.1.10 Revolving Doors.

7.2.1.10.1 Revolving doors, whether used or not used in the means of egress, shall comply with the following:

- (1) Revolving doors shall be capable of being collapsed into a book-fold position, unless they are existing revolving doors approved by the authority having jurisdiction.
- (2) When revolving doors are collapsed into the book-fold position, the parallel egress paths formed shall provide an aggregate width of 915 mm (36 in.), unless they are approved, existing revolving doors.
- (3) Revolving doors shall not be used within 3050 mm (120 in.) of the foot or the top of stairs or escalators.
- (4) A dispersal area acceptable to the authority having jurisdiction shall be located between stairs or escalators and the revolving door.
- (5) The revolutions per minute (rpm) of revolving doors shall not exceed the values in Table 7.2.1.10.1.
- (6) Each revolving door shall have a conforming side-hinged swinging door in the same wall as the revolving door and within 3050 mm (120 in.) of the revolving door, unless one of the following conditions applies:

- (a) Revolving doors shall be permitted without adjacent swinging doors, as required by 7.2.1.10.1(6), in street floor elevator lobbies, provided that no stairways or doors from other parts of the building discharge through the lobby and the lobby has no occupancy other than as a means of travel between the elevators and street.
- (b) The requirement of 7.2.1.10.1(6) shall not apply to existing revolving doors where the number of revolving doors does not exceed the number of swinging doors within 6100 mm (240 in.) of the revolving door.

Table 7.2.1.10.1 Revolving Door Maximum Speed

Inside Diameter		Power-Driven Speed Control (rpm)	Manual Speed Control (rpm)
mm	in.		
1980	78	11	12
2135	84	10	11
2285	90	9	11
2440	96	9	10
2590	102	8	9
2745	108	8	9
2895	114	7	8
3050	120	7	8

7.2.1.10.2 Where permitted in Chapter 12 through Chapter 42, revolving doors shall be permitted as a component in a means of egress, provided that the following criteria are met:

- (1) Revolving doors shall not be given credit for more than 50 percent of the required egress capacity.
- (2) Each revolving door shall not be credited with more than a 50-person capacity or, if of not less than a 2745-mm (108-in.) diameter, a revolving door shall be permitted egress capacity based on the clear opening width provided when collapsed into a book-fold position.
- (3) Revolving doors shall be capable of being collapsed into a book-fold position when a force not exceeding 580 N (130 lbf) is applied to the wings within 75 mm (3 in.) of the outer edge.

7.2.1.10.3 Revolving doors not used as a component of a means of egress shall have a collapsing force not exceeding 800 N (180 lbf).

7.2.1.10.4 The requirement of 7.2.1.10.3 shall not apply to revolving doors, provided that the collapsing force is reduced to a force not to exceed 580 N (130 lbf) under the following conditions:

- (1) Power failure, or removal of power to the device holding the wings in position
- (2) Actuation of the automatic sprinkler system, where such a system is provided
- (3) Actuation of a smoke detection system that is installed to provide coverage in all areas within the building that are within 23 m (75 ft) of the revolving doors
- (4) Actuation of a clearly identified manual control switch in an approved location that reduces the holding force to a force not to exceed 580 N (130 lbf)

7.2.1.11 Turnstiles.

7.2.1.11.1 Turnstiles or similar devices that restrict travel to one direction or are used to collect fares or admission charges shall not be placed so as to obstruct any required means of egress, unless otherwise specified in 7.2.1.11.1.1 and 7.2.1.11.1.2

7.2.1.11.1.1 Approved turnstiles not exceeding 990 mm (39 in.) in height that turn freely in the direction of egress travel shall be permitted where revolving doors are permitted in Chapter 12 through Chapter 42.

7.2.1.11.1.2 Where turnstiles are approved by the authority having jurisdiction and permitted in Chapter 12 through Chapter 42, each turnstile shall be credited for a capacity of 50 persons, provided that such turnstiles meet the following criteria:

- (1) They freewheel in the egress direction when primary power is lost, and freewheel in the direction of egress travel upon manual release by an employee assigned in the area.
- (2) They are not given credit for more than 50 percent of the required egress width.
- (3) They are not in excess of 990 mm (39 in.) in height and have a clear width of not less than 420 mm (16½ in.).

7.2.1.11.2 Turnstiles exceeding 990 mm (39 in.) in height shall meet the requirements for revolving doors in 7.2.1.10.

7.2.1.11.3 Turnstiles located in, or furnishing access to, required exits shall provide not less than 420 mm (16½ in.) clear width at and below a height of 990 mm (39 in.) and at least 560 mm (22 in.) clear width at heights above 990 mm (39 in.).

7.2.1.12 Doors in Folding Partitions. Where permanently mounted folding or movable partitions divide a room into smaller spaces, a swinging door or open doorway shall be provided as an exit access from each such space, unless otherwise specified in 7.2.1.12.1 and 7.2.1.12.2.

7.2.1.12.1 A door or opening in the folding partition shall not be required, provided that all of the following criteria are met:

- (1) The subdivided space is not used by more than 20 persons at any time.
- (2) The use of the space is under adult supervision.
- (3) The partitions are arranged so that they do not extend across any aisle or corridor used as an exit access to the required exits from the story.
- (4) The partitions conform to the interior finish and other requirements of this *Code*.
- (5) The partitions are of an approved type, have a simple method of release, and are capable of being opened quickly and easily by experienced persons in case of emergency.

7.2.1.12.2 Where a subdivided space is provided with not less than two means of egress, the swinging door in the folding partition specified in 7.2.1.12 shall not be required, and one such means of egress shall be permitted to be equipped with a horizontal-sliding door complying with 7.2.1.14.

7.2.1.13 Balanced Doors. If panic hardware is installed on balanced doors, the panic hardware shall be of the push-pad type, and the pad shall not extend more than approximately one-half the width of the door, measured from the latch side. [See 7.2.1.7.1(1).]

7.2.1.14 Horizontal-Sliding Doors. Horizontal-sliding doors shall be permitted in means of egress, provided that the following criteria are met:

- (1) The door is readily operable from either side without special knowledge or effort.
- (2) The force that, when applied to the operating device in the direction of egress, is required to operate the door is not more than 67 N (15 lbf).
- (3) The force required to operate the door in the direction of door travel is not more than 133 N (30 lbf) to set the door in motion and is not more than 67 N (15 lbf) to close the door or open it to the minimum required width.
- (4) The door is operable using a force of not more than 222 N (50 lbf) when a force of 1100 N (250 lbf) is applied perpendicularly to the door adjacent to the operating device, unless the door is an existing horizontal-sliding exit access door serving an area with an occupant load of fewer than 50.
- (5) The door assembly complies with the fire protection rating, if required, and, where rated, is self-closing or automatic-closing by means of smoke detection in accordance with 7.2.1.8 and is installed in accordance with NFPA 80, *Standard for Fire Doors and Fire Windows*.

7.2.2 Stairs.**7.2.2.1 General.**

7.2.2.1.1 Stairs used as a component in the means of egress shall conform to the general requirements of Section 7.1 and to the special requirements of this 7.2.2 unless otherwise specified in 7.2.2.1.2.

7.2.2.1.2 The requirement of 7.2.2.1.1 shall not apply to the following:

- (1) Aisle stairs in assembly occupancies as provided in Chapter 12 and Chapter 13
- (2) Approved, existing noncomplying stairs

7.2.2.2 Dimensional Criteria.

7.2.2.2.1 Standard Stairs. Stairs shall meet the following criteria:

- (1) New stairs shall be in accordance with Table 7.2.2.2.1(a).
- (2)*Existing stairs shall be permitted to remain in use, provided that they meet the requirements for existing stairs shown in Table 7.2.2.2.1(b).
- (3) Approved existing stairs shall be permitted to be rebuilt in accordance with the following:
 - (a) Dimensional criteria of Table 7.2.2.2.1(b)
 - (b) Other stair requirements of 7.2.2
- (4) The requirements for new and existing stairs shall not apply to stairs located in industrial equipment access areas where otherwise provided in 40.2.5.2.

7.2.2.2.2 Curved Stairs.

7.2.2.2.2.1 New curved stairs shall be permitted as a component in a means of egress, provided that the depth of tread is not less than 280 mm (11 in.) at a point 305 mm (12 in.) from the narrower end of the tread and the smallest radius is not less than twice the stair width.

7.2.2.2.2.2 Existing curved stairs shall be permitted as a component in a means of egress, provided that the depth of tread is not less than 255 mm (10 in.) at a point 305 mm (12 in.) from the narrower end of the tread and the smallest radius is not less than twice the stair width.

7.2.2.2.3 Spiral Stairs.

Table 7.2.2.2.1(a) New Stairs

Feature	Dimensional Criteria
Minimum width clear of all obstructions, except projections not more than 114 mm (4½ in.) at or below handrail height on each side	1120 mm (44 in.); 915 mm (36 in.) where total occupant load of all stories served by stairways is fewer than 50
Maximum height of risers	180 mm (7 in.)
Minimum height of risers	100 mm (4 in.)
Minimum tread depth	280 mm (11 in.)
Minimum headroom	2030 mm (80 in.)
Maximum height between landings	3660 mm (144 in.)
Landing	See 7.2.1.3 and 7.2.1.4.4

Table 7.2.2.2.1(b) Existing Stairs

Feature	Dimensional Criteria	
	Class A	Class B
Minimum width clear of all obstructions, except projections not more than 114 mm (4½ in.) at or below handrail height on each side	915 mm (36 in.)	915 mm (36 in.)
Maximum height of risers	190 mm (7½ in.)	205 mm (8 in.)
Minimum tread depth	255 mm (10 in.)	230 mm (9 in.)
Minimum headroom	2030 mm (80 in.)	2030 mm (80 in.)
Maximum height between landings	3660 mm (144 in.)	3660 mm (144 in.)
Landing	See 7.2.1.3 and 7.2.1.4.4	

7.2.2.2.3.1 Where specifically permitted for individual occupancies by Chapter 12 through Chapter 42, spiral stairs shall be permitted as a component in a means of egress in accordance with 7.2.2.2.3.2 through 7.2.2.2.3.4.

7.2.2.2.3.2 Spiral stairs shall be permitted, provided that the following criteria are met:

- (1) Riser heights shall not exceed 180 mm (7 in.).
- (2) The stairway shall have a tread depth of not less than 280 mm (11 in.) for a portion of the stairway width sufficient to provide egress capacity for the occupant load served in accordance with 7.3.3.1.
- (3) At the outer side of the stairway, an additional 265 mm (10½ in.) of width shall be provided clear to the other handrail, and this width shall not be included as part of the required egress capacity.
- (4) Handrails complying with 7.2.2.4 shall be provided on both sides of the spiral stairway.

- (5) The inner handrail shall be located within 610 mm (24 in.), measured horizontally, of the point where a tread depth of not less than 280 mm (11 in.) is provided.
- (6) The turn of the stairway shall be such that the outer handrail is at the right side of descending users.

7.2.2.2.3.3 Where the occupant load served does not exceed three, spiral stairs shall be permitted, provided that the following criteria are met:

- (1) The clear width of the stairs shall be not less than 660 mm (26 in.).
- (2) The height of risers shall not exceed 240 mm (9½ in.).
- (3) The headroom shall be not less than 1980 mm (78 in.).
- (4) Treads shall have a depth not less than 190 mm (7½ in.) at a point 305 mm (12 in.) from the narrower edge.
- (5) All treads shall be identical.
- (6) Handrails shall be provided on both sides of the stairway.

7.2.2.2.3.4 Where the occupant load served does not exceed five, existing spiral stairs shall be permitted, provided the requirements of 7.2.2.2.3.3(1) through 7.2.2.2.3.3(5) are met.

7.2.2.2.4* Winders.

7.2.2.2.4.1 Where specified in Chapter 12 through Chapter 42, winders shall be permitted in stairs, provided that they meet the requirements of 7.2.2.2.4.2 and 7.2.2.2.4.3.

7.2.2.2.4.2 New winders shall have a tread depth of not less than 150 mm (6 in.) and a tread depth of not less than 280 mm (11 in.) at a point 305 mm (12 in.) from the narrowest edge.

7.2.2.2.4.3 Existing winders shall be permitted to be continued in use, provided that they have a tread depth of not less than 150 mm (6 in.) and a tread depth of not less than 230 mm (9 in.) at a point 305 mm (12 in.) from the narrowest edge.

7.2.2.3 Stair Details.

7.2.2.3.1 Construction.

7.2.2.3.1.1 All stairs serving as required means of egress shall be of permanent fixed construction, unless they are stairs serving seating that is designed to be repositioned in accordance with Chapter 12 and Chapter 13.

7.2.2.3.1.2 Each stair, platform, and landing, not including handrails and existing stairs, in buildings required in this Code to be of Type I or Type II construction shall be of noncombustible material throughout.

7.2.2.3.2 Landings.

7.2.2.3.2.1 Stairs shall have landings at door openings, except as permitted in 7.2.2.3.2.5.

7.2.2.3.2.2 Stairs and intermediate landings shall continue with no decrease in width along the direction of egress travel.

7.2.2.3.2.3 In new buildings, every landing shall have a dimension, measured in the direction of travel, that is not less than the width of the stair.

7.2.2.3.2.4 Landings shall not be required to exceed 1220 mm (48 in.) in the direction of travel, provided that the stair has a straight run.

7.2.2.3.2.5 In one- and two-family dwellings and existing buildings, a door at the top of a stair shall be permitted to open directly to the stair, provided that the door does not swing over the stair and the door serves an area with an occupant load of fewer than 50 persons.

7.2.2.3.3 Tread and Landing Surfaces.

7.2.2.3.3.1 Stair treads and landings shall be solid, without perforations, unless otherwise permitted in 7.2.2.3.3.4.

7.2.2.3.3.2* Stair treads and landings shall be free of projections or lips that could trip stair users.

7.2.2.3.3.3 If not vertical, risers on other than existing stairs shall be permitted to slope under the tread at an angle not to exceed 30 degrees from vertical, provided that the projection of the nosing does not exceed 38 mm (1½ in.).

7.2.2.3.3.4 The requirement of 7.2.2.3.3.1 shall not apply to noncombustible grated stair treads and landings in the following occupancies:

- (1) Assembly occupancies as otherwise provided in Chapter 12 and Chapter 13
- (2) Detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23
- (3) Industrial occupancies as otherwise provided in Chapter 40

7.2.2.3.4* Tread Slope. Tread slope shall not exceed 21 mm/m (¼ in./ft) (a slope of 1 in 48).

7.2.2.3.5* Riser Height and Tread Depth. Riser height shall be measured as the vertical distance between tread nosings. Tread depth shall be measured horizontally between the vertical planes of the foremost projection of adjacent treads and at a right angle to the tread's leading edge but shall not include bevelled or rounded tread surfaces that slope more than 20 degrees (a slope of 1 in 2.75). At tread nosings, such beveling or rounding shall not exceed 13 mm (½ in.) in horizontal dimension.

7.2.2.3.6 Dimensional Uniformity.

7.2.2.3.6.1 Variation in excess of 4.8 mm (⅜ in.) in the depth of adjacent treads or in the height of adjacent risers shall be prohibited unless otherwise permitted in 7.2.2.3.6.3.

7.2.2.3.6.2 The tolerance between the largest and smallest riser or between the largest and smallest tread shall not exceed 9.5 mm (⅜ in.) in any flight.

7.2.2.3.6.3 Where the bottom riser adjoins a sloping public way, walk, or driveway having an established grade and serving as a landing, the bottom riser shall be permitted to have a variation in height of not more than 25 mm in every 300 mm (1 in. in every 12 in.) of stairway width.

7.2.2.4 Guards and Handrails.**7.2.2.4.1 Handrails.**

7.2.2.4.1.1 Stairs and ramps shall have handrails on both sides, unless otherwise permitted in 7.2.2.4.1.5 or 7.2.2.4.1.6.

7.2.2.4.1.2 In addition to the handrails required at the sides of stairs by 7.2.2.4.1.1, the following provisions shall apply:

- (1) For new stairs exceeding 1905 mm (75 in.) in width, handrails shall be provided within 760 mm (30 in.) of all portions of the required egress width.
- (2) For existing stairs, handrails shall be provided within 1120 mm (44 in.) of all portions of the required egress width.

7.2.2.4.1.3 Where new intermediate handrails are provided in accordance with 7.2.2.4.1.2, the minimum clear width between handrails shall be 510 mm (20 in.).

7.2.2.4.1.4* The required egress width shall be provided along the natural path of travel.

7.2.2.4.1.5 If a single step or a ramp is part of a curb that separates a sidewalk from a vehicular way, it shall not be required to have a handrail.

7.2.2.4.1.6 Existing stairs, existing ramps, stairs within dwelling units and within guest rooms, and ramps within dwelling units and guest rooms shall be permitted to have a handrail on one side only.

7.2.2.4.2 Continuity. Required guards and handrails shall continue for the full length of each flight of stairs. At turns of new stairs, inside handrails shall be continuous between flights at landings.

7.2.2.4.3 Projections. The design of guards and handrails and the hardware for attaching handrails to guards, balusters, or walls shall be such that there are no projections that might engage loose clothing. Openings in guards shall be designed to prevent loose clothing from becoming wedged in such openings.

7.2.2.4.4* Handrail Details.

7.2.2.4.4.1 New handrails on stairs shall be not less than 865 mm (34 in.) and not more than 965 mm (38 in.) above the surface of the tread, measured vertically to the top of the rail from the leading edge of the tread.

7.2.2.4.4.2 Existing required handrails shall be not less than 760 mm (30 in.) and not more than 965 mm (38 in.) above the surface of the tread, measured vertically to the top of the rail from the leading edge of the tread.

7.2.2.4.4.3 The height of required handrails that form part of a guard shall be permitted to exceed 965 mm (38 in.), but shall not exceed 1065 mm (42 in.), measured vertically to the top of the rail from the leading edge of the tread.

7.2.2.4.4.4* Additional handrails that are lower or higher than the main handrail shall be permitted.

7.2.2.4.4.5* New handrails shall be installed to provide a clearance of not less than 57 mm (2¼ in.) between the handrail and the wall to which it is fastened.

7.2.2.4.4.6 Handrails shall include one of the following features:

- (1) A circular cross section with an outside diameter of not less than 32 mm (1¼ in.) and not more than 51 mm (2 in.)
- (2)*A shape that is other than circular with a perimeter dimension of not less than 100 mm (4 in.), but not more than 160 mm (6¼ in.), and with the largest cross-sectional dimension not more than 57 mm (2¼ in.), provided that graspable edges are rounded so as to provide a radius of not less than 3.2 mm (⅛ in.)

7.2.2.4.4.7 New handrails shall be continuously graspable along their entire length.

7.2.2.4.4.8 Handrail brackets or balusters attached to the bottom surface of the handrail shall not be considered to be obstructions to graspability, provided that the following criteria are met:

- (1) They do not project horizontally beyond the sides of the handrail within 38 mm (1½ in.) of the bottom of the handrail and provided that, for each additional 13 mm (½ in.) of handrail perimeter dimension greater than 100 mm (4 in.), the vertical clearance dimension of 38 mm (1½ in.) is reduced by 3.2 mm (⅛ in.).

- (2) They have edges with a radius of not less than 0.25 mm (0.01 in.).

7.2.2.4.4.9 New handrail ends shall be returned to the wall or floor or shall terminate at newel posts.

7.2.2.4.4.10 In other than dwelling units, new handrails that are not continuous between flights shall extend horizontally, at the required height, not less than 305 mm (12 in.) beyond the top riser and continue to slope for a depth of one tread beyond the bottom riser.

7.2.2.4.4.11 Within dwelling units, handrails shall extend, at the required height, to at least those points that are directly above the top and bottom risers.

7.2.2.4.5 Guard Details.

7.2.2.4.5.1 The height of guards required in 7.1.8 shall be measured vertically to the top of the guard from the surface adjacent thereto.

7.2.2.4.5.2 Guards shall be not less than 1065 mm (42 in.) high, except as permitted by one of the following:

- (1) Existing guards within dwelling units shall be permitted to be not less than 915 mm (36 in.) high.
- (2) The requirement of 7.2.2.4.5.2 shall not apply in assembly occupancies where otherwise provided in Chapter 12 and Chapter 13.
- (3)*Existing guards on existing stairs shall be permitted to be not less than 760 mm (30 in.) high.

7.2.2.4.5.3* Open guards, other than approved, existing open guards, shall have intermediate rails or an ornamental pattern such that a sphere 100 mm (4 in.) in diameter is not able to pass through any opening up to a height of 865 mm (34 in.), and the following also shall apply:

- (1) The triangular openings formed by the riser, tread, and bottom element of a guardrail at the open side of a stair shall be of such size that a sphere 150 mm (6 in.) in diameter is not able to pass through the triangular opening.
- (2) In detention and correctional occupancies, in industrial occupancies, and in storage occupancies, the clear distance between intermediate rails, measured at right angles to the rails, shall not exceed 535 mm (21 in.).

7.2.2.5 Enclosure and Protection of Stairs.

7.2.2.5.1 Enclosures.

7.2.2.5.1.1 All inside stairs serving as an exit or exit component shall be enclosed in accordance with 7.1.3.2.

7.2.2.5.1.2 Inside stairs, other than those serving as an exit or exit component, shall be protected in accordance with Section 8.6.

7.2.2.5.1.3 In existing buildings, where a two-story exit enclosure connects the story of exit discharge with an adjacent story, the exit shall be permitted to be enclosed only on the story of exit discharge, provided that not less than 50 percent of the number and capacity of exits on the story of exit discharge are independent of such enclosures.

7.2.2.5.2* Exposures.

7.2.2.5.2.1 Where nonrated walls or unprotected openings enclose the exterior of a stairway, other than an existing stairway, and the walls or openings are exposed by other parts of the building at an angle of less than 180 degrees, the building enclosure walls within 3050 mm (120 in.) horizontally of the

nonrated wall or unprotected opening shall be constructed as required for stairway enclosures, including opening protectives.

7.2.2.5.2.2 Construction shall extend vertically from the ground to a point 3050 mm (120 in.) above the topmost landing of the stairs or to the roofline, whichever is lower.

7.2.2.5.2.3 The fire resistance rating of the separation extending 3050 mm (120 in.) from the stairs shall not be required to exceed 1 hour where openings have not less than a ¾-hour fire protection rating.

7.2.2.5.3* Usable Space. Enclosed, usable spaces within exit enclosures shall be prohibited, including under stairs, unless otherwise permitted by 7.2.2.5.3.2.

7.2.2.5.3.1 Open space within the exit enclosure shall not be used for any purpose that has the potential to interfere with egress.

7.2.2.5.3.2 Enclosed, usable space shall be permitted under stairs, provided that the following criteria are met:

- (1) The space is separated from the stair enclosure by the same fire resistance as the exit enclosure.
- (2) Entrance to the enclosed, usable space shall not be from within the stair enclosure. (See also 7.1.3.2.3.)

7.2.2.5.4* Stairway Marking.

7.2.2.5.4.1 Stairs serving five or more stories shall be provided with special signage within the enclosure at each floor landing. The signage shall indicate the floor level, the terminus of the top and bottom of the stair enclosure, and the identification of the stair enclosure. The signage also shall state the floor level of, and the direction to, exit discharge. The signage shall be located inside the enclosure approximately 1525 mm (60 in.) above the floor landing in a position that is visible when the door is in the open or closed position. The signage shall comply with 7.10.8.1 and 7.10.8.2. The floor level designation shall also be tactile in accordance with ICC/ANSI A117.1 *American National Standard for Accessible and Usable Buildings and Facilities*.

7.2.2.5.4.2 Wherever an enclosed stair requires travel in an upward direction to reach the level of exit discharge, special signs with directional indicators showing the direction to the level of exit discharge shall be provided at each floor level landing from which upward direction of travel is required, unless otherwise provided in 7.2.2.5.4.2(A) and 7.2.2.5.4.2(B), and the following also shall apply:

- (1) Such signage shall comply with 7.10.8.1 and 7.10.8.2.
- (2) Such signage shall be visible when the door is in the open or closed position.

(A) The requirement of 7.2.2.5.4.2 shall not apply where signs required by 7.2.2.5.4.1 are provided.

(B) The requirement of 7.2.2.5.4.2 shall not apply to stairs extending not more than one story below the level of exit discharge where the exit discharge is clearly obvious.

7.2.2.5.4.3 The sign shall be painted or stenciled on the wall or on a separate sign securely attached to the wall.

7.2.2.5.4.4 The stairway identification letter shall be located at the top of the sign in minimum 25-mm (1-in.) high lettering and shall be in accordance with 7.10.8.2.

7.2.2.5.4.5 Roof access or the lack thereof shall be designated by a sign that reads ROOF ACCESS or NO ROOF ACCESS and located under the stairway identification letter. Lettering shall be a minimum of 25 mm (1 in.) high and shall be in accordance with 7.10.8.2.

7.2.2.5.4.6 The floor level number shall be located in the middle of the sign in minimum 125-mm (5-in.) high numbers and shall be in accordance with 7.10.8.2. Mezzanine levels shall have the letter "M" or other appropriate identification letter preceding the floor number, while basement levels shall have the letter "B" or other appropriate identification letter preceding the floor level number.

7.2.2.5.4.7 Identification of the lower and upper terminus of the stairway shall be located at the bottom of the sign in minimum 25-mm (1-in.) high letters or numbers and shall be in accordance with 7.10.8.2.

7.2.2.6 Special Provisions for Outside Stairs.

7.2.2.6.1 Access. Where approved by the authority having jurisdiction, outside stairs shall be permitted to lead to roofs of other sections of a building or an adjoining building where the construction is fire resistive and there is a continuous and safe means of egress from the roof. (See also 7.7.6.)

7.2.2.6.2* Visual Protection. Outside stairs shall be arranged to avoid any impediments to the use of the stairs by persons having a fear of high places. For stairs more than three stories in height, any arrangement intended to meet this requirement shall be not less than 1220 mm (48 in.) in height.

7.2.2.6.3 Separation and Protection of Outside Stairs.

7.2.2.6.3.1 Outside stairs shall be separated from the interior of the building by construction with the fire resistance rating required for enclosed stairs with fixed or self-closing opening protectives, except as follows:

- (1) Outside stairs serving an exterior exit access balcony that has two remote outside stairways or ramps shall be permitted to be unprotected.
- (2) Outside stairs serving not in excess of two adjacent stories, including the story of exit discharge, shall be permitted to be unprotected where there is a remotely located second exit.
- (3) In existing buildings, existing outside stairs serving not in excess of three adjacent stories, including the story of exit discharge, shall be permitted to be unprotected where there is a remotely located second exit.
- (4) The fire resistance rating of a separation extending 3050 mm (120 in.) from the stairs shall not be required to exceed 1 hour where openings have not less than a ¾-hour fire protection rating.
- (5) Outside stairs in existing buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7 shall be permitted to be unprotected.

7.2.2.6.3.2 Wall construction required by 7.2.2.6.3.1 shall extend as follows:

- (1) Vertically from the ground to a point 3050 mm (120 in.) above the topmost landing of the stairs or to the roofline, whichever is lower
- (2) Horizontally for not less than 3050 mm (120 in.)

7.2.2.6.3.3 Roof construction required by 7.2.2.6.3.1 shall meet the following criteria:

- (1) It shall provide protection beneath the stairs.
- (2) It shall extend horizontally to each side of the stair for not less than 3050 mm (120 in.).

7.2.2.6.4 Protection of Openings. All openings below an outside stair shall be protected with an assembly having not less than a ¾-hour fire protection rating as follows:

- (1) Where located in a court, the smallest dimension of which does not exceed one-third its height
- (2) Where located in an alcove having a width that does not exceed one-third its height and a depth that does not exceed one-fourth its height

7.2.2.6.5* Water Accumulation. Outside stairs and landings, other than existing outside stairs and landings, shall be designed to minimize water accumulation on their surfaces.

7.2.2.6.6 Openness. Outside stairs, other than existing outside stairs, shall be not less than 50 percent open on one side. Outside stairs shall be arranged to restrict the accumulation of smoke.

7.2.3 Smokeproof Enclosures.

7.2.3.1 General. Where smokeproof enclosures are required in other sections of this Code, they shall comply with 7.2.3, unless they are approved, existing smokeproof enclosures.

7.2.3.2 Performance Design. An appropriate design method shall be used to provide a system that meets the definition of smokeproof enclosure. The smokeproof enclosure shall be permitted to be created by using natural ventilation, by using mechanical ventilation incorporating a vestibule, or by pressurizing the stair enclosure.

7.2.3.3 Enclosure. A smokeproof enclosure shall be enclosed from the highest point to the lowest point by barriers having 2-hour fire resistance ratings. Where a vestibule is used, it shall be within the 2-hour-rated enclosure and shall be considered part of the smokeproof enclosure.

7.2.3.4 Vestibule. Where a vestibule is provided, the doorway into the vestibule shall be protected with an approved fire door assembly having a 1½-hour fire protection rating, and the fire door assembly from the vestibule to the smokeproof enclosure shall have not less than a 20-minute fire protection rating. Doors shall be designed to minimize air leakage and shall be self-closing or shall be automatic-closing by actuation of a smoke detector within 3050 mm (120 in.) of the vestibule door.

7.2.3.5 Discharge. Every smokeproof enclosure shall discharge into a public way, into a yard or court having direct access to a public way, or into an exit passageway. Such exit passageways shall be without openings, other than the entrance to the smokeproof enclosure and the door to the outside yard, court, or public way. The exit passageway shall be separated from the remainder of the building by a 2-hour fire resistance rating.

7.2.3.6 Access. For smokeproof enclosures other than those consisting of a pressurized stair enclosure complying with 7.2.3.9, access to the smokeproof enclosure stair shall be by way of a vestibule or by way of an exterior balcony.

7.2.3.7 Natural Ventilation. Smokeproof enclosures using natural ventilation shall comply with 7.2.3.3 and the following:

- (1) Where access to the stair is by means of an open exterior balcony, the door assembly to the stair shall have a 1½-hour fire protection rating and shall be self-closing or shall be automatic-closing by actuation of a smoke detector.
- (2) Openings adjacent to the exterior balcony specified in 7.2.3.7(1) shall be protected in accordance with 7.2.2.6.4.

- (3) Every vestibule shall have a net area of not less than 1.5 m² (16 ft²) of opening in an exterior wall facing an exterior court, yard, or public space not less than 6100 mm (240 in.) in width.
- (4) Every vestibule shall have a minimum dimension of not less than the required width of the corridor leading to it and a dimension of not less than 1830 mm (72 in.) in the direction of travel.

7.2.3.8 Mechanical Ventilation. Smokeproof enclosures using mechanical ventilation shall comply with 7.2.3.3 and the requirements of 7.2.3.8(A) through 7.2.3.8(D).

(A) Vestibules shall have a dimension of not less than 1120 mm (44 in.) in width and not less than 1830 mm (72 in.) in direction of travel.

(B) The vestibule shall be provided with not less than one air change per minute, and the exhaust shall be 150 percent of the supply. Supply air shall enter and exhaust air shall discharge from the vestibule through separate tightly constructed ducts used only for such purposes. Supply air shall enter the vestibule within 150 mm (6 in.) of the floor level. The top of the exhaust register shall be located not more than 150 mm (6 in.) below the top of the trap and shall be entirely within the smoke trap area. Doors, when in the open position, shall not obstruct duct openings. Controlling dampers shall be permitted in duct openings if needed to meet the design requirements.

(C) To serve as a smoke and heat trap and to provide an upward-moving air column, the vestibule ceiling shall be not less than 510 mm (20 in.) higher than the door opening into the vestibule. The height shall be permitted to be decreased where justified by engineering design and field testing.

(D) The stair shall be provided with a dampered relief opening at the top and supplied mechanically with sufficient air to discharge at least 70.8 m³/min (2500 ft³/min) through the relief opening while maintaining a positive pressure of not less than 25 N/m² (0.10 in. water column) in the stair, relative to the vestibule with all doors closed.

7.2.3.9 Stair Pressurization.

7.2.3.9.1* Smokeproof enclosures using stair pressurization shall use an approved engineered system with a design pressure difference across the barrier of not less than 12.5 N/m² (0.05 in. water column) in sprinklered buildings, or 25 N/m² (0.10 in. water column) in nonsprinklered buildings, and shall be capable of maintaining these pressure differences under likely conditions of stack effect or wind. The pressure difference across doors shall not exceed that which allows the door to begin to be opened by a force of 133 N (30 lbf) in accordance with 7.2.1.4.5.

7.2.3.9.2 Equipment and ductwork for stair pressurization shall be located in accordance with one of the following specifications:

- (1) Exterior to the building and directly connected to the stairway by ductwork enclosed in noncombustible construction
- (2) Within the stair enclosure with intake and exhaust air vented directly to the outside or through ductwork enclosed by a 2-hour fire-resistive rating
- (3) Within the building under the following conditions:
 - (a) Where the equipment and ductwork are separated from the remainder of the building, including other mechanical equipment, by a 2-hour fire-resistive rating

- (b) Where the building, including the stairway enclosure, is protected throughout by an approved, supervised automatic sprinkler system installed in accordance with Section 9.7, and the equipment and ductwork are separated from the remainder of the building, including other mechanical equipment, by not less than a 1-hour fire-resistive rating

7.2.3.9.3 In all cases specified by 7.2.3.9.2(1) through 7.2.3.9.2(3), openings into the required fire resistance-rated construction shall be limited to those needed for maintenance and operation and shall be protected by self-closing fire protection-rated devices in accordance with 8.3.4.

7.2.3.10 Activation of Mechanical Ventilation and Pressurized Stair Systems.

7.2.3.10.1 For both mechanical ventilation and pressurized stair enclosure systems, the activation of the systems shall be initiated by a smoke detector installed in an approved location within 3050 mm (120 in.) of the entrance to the smokeproof enclosure.

7.2.3.10.2 The required mechanical system shall operate upon the activation of the smoke detectors specified in 7.2.3.10.1 and by manual controls accessible to the fire department. The required system also shall be initiated by the following, if provided:

- (1) Waterflow signal from a complete automatic sprinkler system
- (2) General evacuation alarm signal (*see* 9.6.3.6)

7.2.3.11 Door Closers. The activation of an automatic-closing device on any door in the smokeproof enclosure shall activate all other automatic-closing devices on doors in the smokeproof enclosure.

7.2.3.12 Standby Power. Standby power for mechanical ventilation equipment shall be provided by an approved, self-contained generator that is set to operate whenever there is a loss of power in the normal house current. The generator shall be located in a room having a minimum 1-hour fire resistance-rated separation from the remainder of the building. The generator shall have a fuel supply not less than that which is adequate to operate the equipment for 2 hours.

7.2.3.13 Testing. Before the mechanical equipment is accepted by the authority having jurisdiction, it shall be tested to confirm that it is operating in compliance with the requirements of 7.2.3. All operating parts of the system shall be tested semiannually by approved personnel, and a log shall be kept of the results.

7.2.4 Horizontal Exits.

7.2.4.1 General.

7.2.4.1.1 Where horizontal exits are used in the means of egress, they shall conform to the general requirements of Section 7.1 and the special requirements of 7.2.4.

7.2.4.1.2* Horizontal exits shall be permitted to be substituted for other exits where the total egress capacity of the other exits (stairs, ramps, doors leading outside the building) is not less than half that required for the entire area of the building or connected buildings and provided that none of the other exits, is a horizontal exit, unless otherwise provided in 7.2.4.1.3.

7.2.4.1.3 The requirement of 7.2.4.1.2 shall not apply to the following:

- (1) Health care occupancies as otherwise provided in Chapter 18 and Chapter 19
- (2) Detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23

7.2.4.2 Fire Compartments.

7.2.4.2.1 Every fire compartment for which credit is permitted in connection with a horizontal exit(s) also shall have at least one additional exit, but not less than 50 percent of the required number and capacity of exits, that is not a horizontal exit, unless otherwise provided in 7.2.4.2.1.2.

7.2.4.2.1.1 Any fire compartment not having an exit leading outside shall be considered as part of an adjoining compartment with an exit leading to the outside.

7.2.4.2.1.2 The requirement of 7.2.4.2.1 shall not apply to the following:

- (1) Health care occupancies as otherwise provided in Chapter 18 and Chapter 19
- (2) Detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23

7.2.4.2.2 Every horizontal exit for which credit is permitted shall be arranged so that there are continuously available paths of travel leading from each side of the exit to stairways or other means of egress leading to outside the building.

7.2.4.2.3 Wherever either side of a horizontal exit is occupied, the doors used in connection with the horizontal exit shall be unlocked from the egress side, unless otherwise permitted for the following:

- (1) Health care occupancies as otherwise provided in Chapter 18 and Chapter 19
- (2) Detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23

7.2.4.2.4 The floor area on either side of a horizontal exit shall be sufficient to hold the occupants of both floor areas and shall provide at least 0.28 m² (3 ft²) clear floor area per person, unless otherwise permitted for the following:

- (1) Health care occupancies as otherwise provided in Chapter 18 and Chapter 19
- (2) In detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23

7.2.4.3 Fire Barriers.

7.2.4.3.1 Fire barriers separating building areas between which there are horizontal exits shall have a 2-hour fire resistance rating and shall provide a separation that is continuous to ground. (See also Section 8.3.)

7.2.4.3.2 Where a fire barrier provides a horizontal exit in any story of a building, such fire barrier shall not be required on other stories, provided that the following criteria are met:

- (1) The stories on which the fire barrier is omitted are separated from the story with the horizontal exit by construction having a fire resistance rating at least equal to that of the horizontal exit fire barrier.
- (2) Vertical openings between the story with the horizontal exit and the open fire area story are enclosed with construction having a fire resistance rating at least equal to that of the horizontal exit fire barrier.

(3) All required exits, other than horizontal exits, discharge directly to the outside.

7.2.4.3.3 Where fire barriers serving horizontal exits, other than existing horizontal exits, terminate at outside walls, and the outside walls are at an angle of less than 180 degrees for a distance of 3050 mm (120 in.) on each side of the horizontal exit, the outside walls shall have not less than a 1-hour fire resistance rating, with opening protectives of not less than a ¾-hour fire protection rating, for a distance of 3050 mm (120 in.) on each side of the horizontal exit.

7.2.4.3.4 Fire barriers forming horizontal exits shall not be penetrated by ducts, unless one of the following criteria is met:

- (1) The ducts are existing penetrations protected by approved and listed fire dampers.
- (2) The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (3) The duct penetrations are those permitted in detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23 and are protected by combination fire dampers/smoke leakage-rated dampers that meet the smoke damper actuation requirements of 8.5.4.

7.2.4.3.5 Any opening in the fire barriers specified in 7.2.4.3.4 shall be protected as provided in 8.3.4.

7.2.4.3.6 Doors in horizontal exits shall comply with 7.2.1.4, unless they are sliding doors in industrial or storage occupancies as otherwise provided in Chapter 40 and Chapter 42.

7.2.4.3.7 Unless otherwise specified in 7.2.4.3.7.1 and 7.2.4.3.7.2, swinging fire doors shall be permitted in horizontal exits, provided that the criteria of both 7.2.4.3.7(1) and 7.2.4.3.7(2), or the criteria of both 7.2.4.3.7(1) and 7.2.4.3.7(3), are met as follows:

- (1) The doors shall swing in the direction of egress travel.
- (2) In other than sleeping room areas in detention and correctional occupancies, where a horizontal exit serves areas on both sides of a fire barrier, adjacent openings with swinging doors that open in opposite directions shall be provided, with signs on each side of the fire barrier identifying the door that swings with the travel from that side.
- (3) The doors shall be of any other approved arrangement, provided that the doors always swing with any possible egress travel.

7.2.4.3.7.1 The requirements of 7.2.4.3.7 shall not apply to horizontal exit door swing as provided in Chapter 19 and Chapter 23.

7.2.4.3.7.2 The requirements of 7.2.4.3.7 shall not apply to horizontal exit doors in corridors not more than 1830 (72 in.) wide in existing buildings.

7.2.4.3.8* Doors in horizontal exits shall be designed and installed to minimize air leakage.

7.2.4.3.9* All fire doors in horizontal exits shall be self-closing or automatic-closing in accordance with 7.2.1.8.

7.2.4.3.10 Horizontal exit doors located across a corridor, other than approved existing doors, shall be automatic-closing in accordance with 7.2.1.8.2.

7.2.4.4 Bridges and Balconies.

7.2.4.4.1 Each bridge or balcony used in conjunction with horizontal exits shall have guards and handrails in conformity with the requirements of 7.2.2.4.

7.2.4.4.2 Every bridge or balcony shall be not less than the width of the door to which it leads and shall be not less than 1120 mm (44 in.) wide for new construction.

7.2.4.4.3 Where the bridge or balcony serves as a horizontal exit in one direction, the horizontal exit door shall be required to swing only in the direction of egress travel, unless the door complies with the swing requirements for the following:

- (1) Existing health care occupancies in Chapter 19
- (2) Existing detention and correctional occupancies in Chapter 23

7.2.4.4.4 Where the bridge or balcony serves as a horizontal exit in both directions, doors shall be provided in pairs that swing in opposite directions, with only the door swinging in the direction of egress travel included when determining egress capacity, unless otherwise provided in 7.2.4.4.4.1 through 7.2.4.4.4.3.

7.2.4.4.4.1 Approved existing doors on both ends of the bridge or balcony shall be permitted to swing out from the building.

7.2.4.4.4.2 The requirement of 7.2.4.4.4 shall not apply if the bridge or balcony has sufficient floor area to accommodate the occupant load of either connected building or fire area based on 0.28 m² (3 ft²) per person.

7.2.4.4.4.3 The requirement of 7.2.4.4.4 shall not apply to horizontal exit door swing as provided for the following:

- (1) Existing health care occupancies in Chapter 19
- (2) Existing detention and correctional occupancies in Chapter 23

7.2.4.4.5 In climates subject to the accumulation of snow and ice, the bridge or balcony floor shall be protected to prevent the accumulation of snow and ice.

7.2.4.4.6 In existing buildings, one step not exceeding 205 mm (8 in.) shall be permitted below the level of the inside floor.

7.2.4.4.7 In both of the connected buildings or fire areas, any part of any wall opening that is within 3050 mm (120 in.) of any bridge or balcony, as measured horizontally or below, shall be protected with fire door assemblies or fixed fire window assemblies having a ¾-hour fire protection rating, unless otherwise provided in 7.2.4.4.8.

7.2.4.4.8 The requirement of 7.2.4.4.7 shall not apply to approved existing bridges and balconies.

7.2.5 Ramps.

7.2.5.1 General. Every ramp used as a component in a means of egress shall conform to the general requirements of Section 7.1 and to the special requirements of 7.2.5.

7.2.5.2 Dimensional Criteria. The following dimensional criteria shall apply to ramps:

- (1) New ramps shall be in accordance with Table 7.2.5.2(a), unless otherwise permitted by the following:
 - (a) Table 7.2.5.2(a) shall not apply to industrial equipment access areas as otherwise provided in 40.2.5.2
 - (b) The maximum slope requirement shall not apply to ramps in assembly occupancies as otherwise provided in Chapter 12.
 - (c) The maximum slope or maximum rise for a single ramp run shall not apply to ramps providing access to vehicles, vessels, mobile structures, and aircraft.
- (2) Existing ramps shall be permitted to remain in use or be rebuilt, provided that they meet the requirements shown in Table 7.2.5.2(b), unless otherwise permitted by the following:

- (a) The requirements of Table 7.2.5.2(b) shall not apply to industrial equipment access areas as otherwise provided in 40.2.5.2.
- (b) The maximum slope or maximum height between landings for a single ramp run shall not apply to ramps providing access to vehicles, vessels, mobile structures, and aircraft.
- (c) Approved existing ramps with slopes not steeper than 1 in 6 shall be permitted to remain in use.
- (d) Existing ramps with slopes not steeper than 1 in 10 shall not be required to be provided with landings.

Table 7.2.5.2(a) New Ramps

Feature	Dimensional Criteria
Minimum width clear of all obstructions, except projections not more than 114 mm (4½ in.) at or below handrail height on each side	1120 mm (44 in.)
Maximum slope	1 in 12
Maximum cross slope	1 in 48
Maximum rise for a single ramp run	760 mm (30 in.)

Table 7.2.5.2(b) Existing Ramps

Feature	Dimensional Criteria
Minimum width	760 mm (30 in.)
Maximum slope	1 in 8
Maximum height between landings	3660 mm (144 in.)

7.2.5.3 Ramp Details.

7.2.5.3.1 Construction. Ramp construction shall be as follows:

- (1) All ramps serving as required means of egress shall be of permanent fixed construction.
- (2) Each ramp in buildings required by this *Code* to be of Type I or Type II construction shall be noncombustible or limited-combustible throughout.
- (3) The ramp floor and landings shall be solid and without perforations.

7.2.5.3.2 Landings. Ramp landings shall be as follows:

- (1) Ramps shall have landings located at the top, at the bottom, and at doors opening onto the ramp.
- (2) The slope of the landing shall not be steeper than 1 in 48.
- (3) Every landing shall have a width not less than the width of the ramp.
- (4) Every landing shall be not less than 1525 mm (60 in.) long in the direction of travel, unless the landing is an approved existing landing.
- (5) Any changes in travel direction shall be made only at landings, unless the ramp is an existing ramp.
- (6) Ramps and intermediate landings shall continue with no decrease in width along the direction of egress travel.

7.2.5.3.3 Drop-Offs. Ramps and landings with drop-offs shall have curbs, walls, railings, or projecting surfaces that prevent people from traveling off the edge of the ramp. Curbs or barriers shall be not less than 100 mm (4 in.) in height.

7.2.5.4 Guards and Handrails.

7.2.5.4.1 Guards complying with 7.2.2.4 shall be provided for ramps, unless otherwise provided in 7.2.5.4.4.

7.2.5.4.2 Handrails complying with 7.2.2.4 shall be provided along both sides of a ramp run with a rise greater than 150 mm (6 in.), unless otherwise provided in 7.2.5.4.4.

7.2.5.4.3 The height of handrails and guards shall be measured vertically to the top of the guard or rail from the walking surface adjacent thereto.

7.2.5.4.4 The requirements of 7.2.5.4.1 and 7.2.5.4.2 shall not apply to guards and handrails provided for ramped aisles in assembly occupancies as otherwise provided in Chapter 12 and Chapter 13.

7.2.5.5 Enclosure and Protection of Ramps. Ramps in a required means of egress shall be enclosed or protected as a stair in accordance with 7.2.2.5 and 7.2.2.6.

7.2.5.6 Special Provisions for Outside Ramps.

7.2.5.6.1* Visual Protection. Outside ramps shall be arranged to avoid any impediments to their use by persons having a fear of high places. For ramps more than three stories in height, any arrangement intended to meet this requirement shall be at least 1220 mm (48 in.) in height.

7.2.5.6.2* Water Accumulation. Outside ramps and landings shall be designed to minimize water accumulation on their surfaces.

7.2.6* Exit Passageways.

7.2.6.1* General. Exit passageways used as exit components shall conform to the general requirements of Section 7.1 and to the special requirements of 7.2.6.

7.2.6.2 Enclosure. An exit passageway shall be separated from other parts of the building as specified in 7.1.3.2, and the following alternatives shall be permitted:

- (1) Fire windows in accordance with 8.3.3 shall be permitted to be installed in the separation in a building protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (2) Existing fixed wired glass panels in steel sash shall be permitted to be continued in use in the separation in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

7.2.6.3 Stair Discharge. An exit passageway that serves as a discharge from a stair enclosure shall have not less than the same fire resistance rating and opening protective fire protection rating as those required for the stair enclosure.

7.2.6.4 Width. The width of an exit passageway shall be adequate to accommodate the aggregate required capacity of all exits that discharge through it, unless one of the following conditions applies:

- (1)*Where an exit passageway serves occupants of the level of exit discharge as well as other stories, the capacity shall not be required to be aggregated.
- (2) As provided in Chapter 36 and Chapter 37, an exit passageway in a mall building shall be permitted to accommodate occupant loads independently from the mall and the tenant spaces. (See 36.2.2.7.2 and 37.2.2.7.2.)

7.2.6.5 Floor. The floor shall be solid and without perforations.

7.2.7 Escalators and Moving Walks. Escalators and moving walks shall not constitute a part of the required means of egress, unless they are previously approved existing escalators and moving walks.

7.2.8 Fire Escape Stairs.

7.2.8.1 General.

7.2.8.1.1 Fire escape stairs shall comply with the provisions of 7.2.8, unless they are approved, existing fire escape stairs.

7.2.8.1.2 Fire escape stairs shall not constitute any of the required means of egress, unless otherwise provided in 7.2.8.1.2.1 and 7.2.8.1.2.2.

7.2.8.1.2.1 Fire escape stairs shall be permitted on existing buildings as provided in Chapter 11 through Chapter 42 but shall not constitute more than 50 percent of the required means of egress.

7.2.8.1.2.2 New fire escape stairs shall be permitted to be erected on existing buildings only where the authority having jurisdiction has determined that outside stairs are impractical. (See 7.2.2.)

7.2.8.1.2.3 New fire escape stairs permitted by 7.2.8.1.2.2 shall not incorporate ladders or access windows, regardless of occupancy classification or occupant load served.

7.2.8.1.3 Fire escape stairs of the return-platform type with superimposed runs, or of the straight-run type with a platform that continues in the same direction, shall be permitted. Either type shall be permitted to be parallel to, or at right angles to, buildings. Either type shall be permitted to be attached to buildings or erected independently of buildings and connected by walkways.

7.2.8.2 Protection of Openings. Fire escape stairs shall be exposed to the smallest possible number of window and door openings, and each opening shall be protected with approved fire door or fire window assemblies where the opening or any portion of the opening is located as follows:

- (1) Horizontally, within 4570 mm (180 in.) of any balcony, platform, or stairway constituting a component of the fire escape stair
- (2) Below, within three stories or 10.7 m (35 ft) of any balcony, platform, walkway, or stairway constituting a component of the fire escape stair, or within two stories or 6100 mm (240 in.) of a platform or walkway leading from any story to the fire escape stair
- (3) Above, within 3050 mm (120 in.) of any balcony, platform, or walkway, as measured vertically, or within 3050 mm (120 in.) of any stair tread surface, as measured vertically
- (4) Facing a court served by a fire escape stair where the least dimension of the court does not exceed one-third of the height to the uppermost platform of the fire escape stair, measured from the ground
- (5) Facing an alcove served by a fire escape stair where the width of the alcove does not exceed one-third, or the depth of the alcove does not exceed one-fourth, of the height to the uppermost platform of the fire escape stair, measured from the ground

7.2.8.2.1 The requirements of 7.2.8.2 shall not apply to openings located on the top story where stairs do not lead to the roof.

7.2.8.2.2 The requirements of 7.2.8.2 shall be permitted to be modified by the authority having jurisdiction where automatic sprinkler protection is provided, where the occupancies is limited to low hazard contents, or where other special conditions exist.

7.2.8.2.3 The requirements of 7.2.8.2 for the protection of window openings shall not apply where such window openings are necessary for access to existing fire escape stairs.

7.2.8.3 Access.

7.2.8.3.1 Access to fire escape stairs shall be in accordance with 7.2.8.4 and 7.5.1.1.1 through 7.5.1.1.3.

7.2.8.3.2 Where access is permitted by way of windows, the windows shall be arranged and maintained so as to be easily opened. Screening or storm windows that restrict free access to the fire escape stair shall be prohibited.

7.2.8.3.3 Fire escape stairs shall extend to the roof in all cases where the roof is subject to occupancy or provides an area of safe refuge, unless otherwise provided in 7.2.8.3.4.

7.2.8.3.4 If the roof has a pitch that does not exceed 1 to 6, fire escape ladders in accordance with 7.2.9 or alternating tread devices in accordance with 7.2.11 shall be provided for access to the roof.

7.2.8.3.5 Access to a fire escape stair shall be directly to a balcony, landing, or platform; shall not exceed the floor or window-sill level; and shall not be more than 205 mm (8 in.) below the floor level or 455 mm (18 in.) below the windowsill level.

7.2.8.4 Stair Details.

7.2.8.4.1 General. Fire escape stairs shall comply with the requirements of Table 7.2.8.4.1(a). Replacement of fire escape stairs shall comply with the requirements of Table 7.2.8.4.1(b).

7.2.8.4.2 Slip Resistance. Stair treads and landings of new or replacement fire escape stairs shall have slip-resistant surfaces.

7.2.8.5 Guards, Handrails, and Visual Enclosures.

7.2.8.5.1 All fire escape stairs shall have walls or guards and handrails on both sides in accordance with 7.2.2.4.

7.2.8.5.2 Replacement fire escape stairs in occupancies serving more than 10 occupants shall have visual enclosures to avoid any impediments to stair use by persons having a fear of high places. For stairs more than three stories in height, any arrangement intended to meet this requirement shall be at least 1065 mm (42 in.) in height.

7.2.8.6 Materials and Strength.

7.2.8.6.1 Noncombustible materials shall be used for the construction of all components of fire escape stairs.

7.2.8.6.2 The authority having jurisdiction shall be permitted to approve any existing fire escape stair that has been shown by load test or other satisfactory evidence to have adequate strength.

7.2.8.7* Swinging Stairs.

7.2.8.7.1 A single swinging stair section shall be permitted to terminate fire escape stairs over sidewalks, alleys, or driveways where it is impractical to make the termination with fire escape stairs.

7.2.8.7.2 Swinging stair sections shall not be located over doors, over the path of travel from any other exit, or in any locations where there are likely to be obstructions.

7.2.8.7.3 The width of swinging stair sections shall be at least that of the fire escape stairs above.

7.2.8.7.4 The pitch of swinging stair sections shall not exceed the pitch of the fire escape stairs above.

7.2.8.7.5 Guards and handrails shall be provided in accordance with 7.2.2.4 and shall be similar in height and construction to those used with the fire escape stairs above. Guards and handrails shall be designed to prevent any possibility of injury to persons where stairs swing downward. The clearance between moving sections and any other portion of the stair system where hands have the potential to be caught shall be not less than 100 mm (4 in.).

7.2.8.7.6 If the distance from the lowest platform to ground is not less than 3660 mm (144 in.), an intermediate balcony not more than 3660 mm (144 in.) from the ground and not less than 2135 mm (84 in.) in the clear underneath shall be provided, with width not less than that of the stairs and length not less than 1220 mm (48 in.).

7.2.8.7.7 Swinging stairs shall be counterbalanced about a pivot, and cables shall not be used. A weight of 68 kg (150 lb) located one step from the pivot shall not cause the stairs to swing downward, and a weight of 68 kg (150 lb) located one-quarter of the length of the swinging stairs from the pivot shall cause the stairs to swing down.

7.2.8.7.8 The pivot for swinging stairs shall be of a corrosion-resistant assembly or shall have clearances to prevent sticking due to corrosion.

7.2.8.7.9* Devices shall not be installed to lock a swinging stair section in the up position.

7.2.8.8 Intervening Spaces.

7.2.8.8.1 Where approved by the authority having jurisdiction, fire escape stairs shall be permitted to lead to an adjoining roof that is crossed before continuing downward travel. The direction of travel shall be clearly marked, and walkways with guards and handrails complying with 7.2.2.4 shall be provided.

7.2.8.8.2 Where approved by the authority having jurisdiction, fire escape stairs shall be permitted to be used in combination with inside or outside stairs complying with 7.2.2, provided that a continuous safe path of travel is maintained.

7.2.9 Fire Escape Ladders.

7.2.9.1 General. Fire escape ladders complying with 7.2.9.2 and 7.2.9.3 shall be permitted in the means of egress only where providing one of the following:

- (1) Access to unoccupied roof spaces as permitted in 7.2.8.3.4
- (2) A second means of egress from storage elevators as permitted in Chapter 42
- (3) A means of egress from towers and elevated platforms around machinery or similar spaces subject to occupancy not to exceed three persons who are all capable of using the ladder
- (4) A secondary means of egress from boiler rooms or similar spaces subject to occupancy not to exceed three persons who are all capable of using the ladder
- (5) Access to the ground from the lowest balcony or landing of a fire escape stair for small buildings as permitted in 7.2.8.4 where approved by the authority having jurisdiction

Table 7.2.8.4.1(a) Fire Escape Stairs

Feature	Serving More than 10 Occupants	Serving 10 or Fewer Occupants
Minimum widths	560 mm (22 in.) clear between rails	455 mm (18 in.) clear between rails
Minimum horizontal dimension of any landing or platform	560 mm (22 in.) clear	455 mm (18 in.) clear
Maximum riser height	230 mm (9 in.)	305 mm (12 in.)
Minimum tread, exclusive of nosing	230 mm (9 in.)	150 mm (6 in.)
Minimum nosing or projection	25 mm (1 in.)	No requirement
Tread construction	Solid 13-mm (½-in.) diameter perforations permitted	Flat metal bars on edge or square bars secured against turning, spaced 32 mm (1¼ in.) maximum on centers
Winders	None	Permitted subject to capacity penalty
Risers	None	No requirement
Spiral	None	Permitted subject to capacity penalty
Maximum height between landings	3660 mm (144 in.)	No requirement
Headroom, minimum	2030 mm (80 in.)	2030 mm (80 in.)
Access to escape	Door or casement windows, 610 mm × 1980 mm (24 in. × 78 in.); or double-hung windows, 760 mm × 915 mm (30 in. × 36 in.) clear opening	Windows providing a clear opening of at least 510 mm (20 in.) in width, 610 mm (24 in.) in height, and 0.53 m ² (5.7 ft ²) in area
Level of access opening	Not over 305 mm (12 in.) above floor; steps if higher	Not over 305 mm (12 in.) above floor; steps if higher
Discharge to ground	Swinging stair section permitted if approved by authority having jurisdiction	Swinging stair, or ladder if approved by authority having jurisdiction
Capacity	13 mm (0.5 in.) per person, if access by door; 25 mm (1 in.) per person, if access by climbing over windowsill	10 persons; if winders or ladder from bottom balcony, 5 persons; if both, 1 person

Table 7.2.8.4.1(b) Replacement Fire Escape Stairs

Feature	Serving More than 10 Occupants	Serving 10 or Fewer Occupants
Minimum widths	560 mm (22 in.) clear between rails	560 mm (22 in.) clear between rails
Minimum horizontal dimension of any landing or platform	560 mm (22 in.)	560 mm (22 in.)
Maximum riser height	230 mm (9 in.)	230 mm (9 in.)
Minimum tread, exclusive of nosing	255 mm (10 in.)	255 mm (10 in.)
Tread construction	Solid, 13-mm (½-in.) diameter perforations permitted	Solid, 13-mm (½-in.) diameter perforations permitted
Winders	None	Permitted subject to 7.2.2.2.4
Spiral	None	Permitted subject to 7.2.2.2.3
Risers	None	None
Maximum height between landings	3660 mm (144 in.)	3660 mm (144 in.)
Headroom, minimum	2030 mm (80 in.)	2030 mm (80 in.)
Access to escape	Door or casement windows, 610 mm × 1980 mm (24 in. × 78 in.); or double-hung windows, 760 mm × 915 mm (30 in. × 36 in.) clear opening	Windows providing a clear opening of at least 510 mm (20 in.) in width, 610 mm (24 in.) in height, and 0.53 m ² (5.7 ft ²) in area
Level of access opening	Not over 305 mm (12 in.) above floor; steps if higher	Not over 305 mm (12 in.) above floor; steps if higher
Discharge to ground	Swinging stair section permitted if approved by authority having jurisdiction	Swinging stair section permitted if approved by authority having jurisdiction
Capacity	13 mm (0.5 in.) per person, if access by door; 25 mm (1 in.) per person, if access by climbing over windowsill	10 persons

7.2.9.2 Construction and Installation.

7.2.9.2.1 Fire escape ladders shall comply with ANSI A14.3, *Safety Code for Fixed Ladders*, unless one of the following criteria is met:

- (1) Approved existing ladders complying with the edition of this *Code* that was in effect when the ladders were installed shall be permitted.
- (2) Industrial stairs complying with the minimum requirements for fixed stairs of ANSI A1264.1, *Safety Requirements for Workplace Floor and Wall Openings, Stairs and Railing Systems*, shall be permitted where fire escape ladders are permitted in accordance with Chapter 40.

7.2.9.2.2 Ladders shall be installed with a pitch that exceeds 75 degrees.

7.2.9.3 Access. The lowest rung of any ladder shall not be more than 305 mm (12 in.) above the level of the surface beneath it.

7.2.10 Slide Escapes.**7.2.10.1 General.**

7.2.10.1.1 A slide escape shall be permitted as a component in a means of egress where permitted in Chapter 12 through Chapter 42.

7.2.10.1.2 Each slide escape shall be of an approved type.

7.2.10.2 Capacity.

7.2.10.2.1 Slide escapes, where permitted as a required means of egress, shall have a capacity of 60 persons.

7.2.10.2.2 Slide escapes shall not constitute more than 25 percent of the required egress capacity from any building or structure or any individual story thereof, unless otherwise provided for industrial occupancies in Chapter 40.

7.2.11* Alternating Tread Devices.

7.2.11.1 Alternating tread devices complying with 7.2.11.2 shall be permitted in the means of egress only where providing one of the following:

- (1) Access to unoccupied roof spaces as permitted in 7.2.8.3.4
- (2) A second means of egress from storage elevators as permitted in Chapter 42
- (3) A means of egress from towers and elevated platforms around machinery or similar spaces subject to occupancy not to exceed three persons who are all capable of using the alternating tread device
- (4) A secondary means of egress from boiler rooms or similar spaces subject to occupancy not to exceed three persons who are all capable of using the alternating tread device

7.2.11.2 Alternating tread devices shall comply with the following:

- (1) Handrails shall be provided on both sides of alternating tread devices in accordance with 7.2.2.4.4.
- (2) The clear width between handrails shall be not less than 430 mm (17 in.) and not more than 610 mm (24 in.).
- (3) Headroom shall be not less than 2030 mm (80 in.).
- (4) The angle of the device shall be between 50 degrees and 68 degrees to horizontal.
- (5) The height of the riser shall not exceed 240 mm (9.5 in.).

- (6) Treads shall have a projected tread depth of not less than 145 mm (5.8 in.), measured in accordance with 7.2.2, with each tread providing 240 mm (9.5 in.) of depth, including tread overlap.
- (7) A distance of not less than 150 mm (6 in.) shall be provided between the stair handrail and any other object.
- (8) The initial tread of the stair shall begin at the same elevation as the platform, landing, or floor surface.
- (9) The alternating treads shall not be laterally separated by a distance of more than 51 mm (2 in.).
- (10) The occupant load served shall not exceed three.

7.2.12 Areas of Refuge.**7.2.12.1 General.**

7.2.12.1.1 Unless otherwise provided in 7.2.12.1.2, an area of refuge used as part of a required accessible means of egress in accordance with 7.5.4, or used as a part of any required means of egress, shall conform to the following:

- (1) General requirements of Section 7.1
- (2) Requirements of 7.2.12.2 and 7.2.12.3

7.2.12.1.2 The requirements of 7.2.12.1.1(2) shall not apply to areas of refuge consisting of stories of buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

7.2.12.2 Accessibility.

7.2.12.2.1 Required portions of an area of refuge shall be accessible from the space they serve by an accessible means of egress.

7.2.12.2.2 Required portions of an area of refuge shall have access to a public way via an exit or an elevator without requiring return to the building spaces through which travel to the area of refuge occurred.

7.2.12.2.3* Where the exit providing egress from an area of refuge to a public way that is in accordance with 7.2.12.2.2 includes stairs, the clear width of landings and stair flights, measured between handrails and at all points below handrail height, shall be not less than 1220 mm (48 in.), unless otherwise permitted by the following:

- (1) The minimum 1220-mm (48-in.) clear width shall not be required where the area of refuge is separated from the remainder of the story by a horizontal exit meeting the requirements of 7.2.4. (See also 7.2.12.3.4.)
- (2) For stairs where egress is in the descending direction, a clear width of not less than 940 mm (37 in.), measured at and below handrail height, shall be permitted if approved alternative measures are provided that do not necessitate carrying occupied wheelchairs on the stairs.
- (3) Existing stairs and landings that provide a clear width of not less than 940 mm (37 in.), measured at and below handrail height, shall be permitted.

7.2.12.2.4* Where an elevator provides access from an area of refuge to a public way that is in accordance with 7.2.12.2.2, the following criteria shall be met:

- (1) The elevator shall be approved for fire fighter service as provided in ASME A17.1, *Safety Code for Elevators and Escalators*.
- (2) The power supply shall be protected against interruption from fire occurring within the building but outside the area of refuge.

- (3) The elevator shall be located in a shaft system meeting the requirements for smokeproof enclosures in accordance with 7.2.3, unless otherwise provided in 7.2.12.2.4.1 and 7.2.12.2.4.2.

7.2.12.2.4.1 The smokeproof enclosure specified in 7.2.12.2.4(3) shall not be required for areas of refuge that are more than 93 m² (1000 ft²) and that are created by a horizontal exit meeting the requirements of 7.2.4.

7.2.12.2.4.2 The smokeproof enclosure specified in 7.2.12.2.4(3) shall not be required for elevators complying with 7.2.13.

7.2.12.2.5 The area of refuge shall be provided with a two-way communication system for communication between the area of refuge and a central control point. The door to the stair enclosure or the elevator door and the associated portion of the area of refuge that the stair enclosure door or elevator door serves shall be identified by signage. (See 7.2.12.3.5.)

7.2.12.2.6* Instructions for summoning assistance, via the two-way communication system, and written identification of the area of refuge location shall be posted adjacent to the two-way communication system.

7.2.12.3 Details.

7.2.12.3.1* Each area of refuge shall be sized to accommodate one wheelchair space of 760 mm × 1220 mm (30 in. × 48 in.) for every 200 occupants, or portion thereof, based on the occupant load served by the area of refuge. Such wheelchair spaces shall maintain the width of a means of egress to not less than that required for the occupant load served and to not less than 915 mm (36 in.).

7.2.12.3.2* For any area of refuge that does not exceed 93 m² (1000 ft²), it shall be demonstrated by calculation or test that tenable conditions are maintained within the area of refuge for a period of 15 minutes when the exposing space on the other side of the separation creating the area of refuge is subjected to the maximum expected fire conditions.

7.2.12.3.3 Access to any designated wheelchair space in an area of refuge shall not pass through more than one adjoining wheelchair space.

7.2.12.3.4* Each area of refuge shall be separated from the remainder of the story by a barrier with not less than a 1-hour fire resistance rating, unless one of the following criteria applies:

- (1) A greater rating is required in other provisions of this Code.
- (2) The barrier is an existing barrier with a minimum 30-minute fire resistance rating.

7.2.12.3.4.1 New fire door assemblies serving an area of refuge shall be positive-pressure rated in accordance with 8.2.2.4.

7.2.12.3.4.2 The barriers specified in 7.2.12.3.4, and any openings in them, shall minimize air leakage and retard the passage of smoke.

7.2.12.3.4.3 Doors in the barriers specified in 7.2.12.3.4 shall have not less than a 20-minute fire protection rating, unless a greater rating is required in other provisions of this Code, and shall be either self-closing or automatic-closing in accordance with 7.2.1.8.

7.2.12.3.4.4 Ducts shall be permitted to penetrate the barrier specified in 7.2.12.3.4, unless prohibited in other provisions of this Code, and shall be provided with smoke-actuated dampers

or other approved means to resist the transfer of smoke into the area of refuge.

7.2.12.3.5 Each area of refuge shall be identified by a sign that reads as the follows:

AREA OF REFUGE

7.2.12.3.5.1 The sign required by 7.2.12.3.5 shall conform to the requirements of ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*, for such signage and shall display the international symbol of accessibility. Signs also shall be located as follows:

- (1) At each door providing access to the area of refuge
- (2) At all exits not providing an accessible means of egress, as defined in 3.3.136.1
- (3) Where necessary to indicate clearly the direction to an area of refuge

7.2.12.3.5.2 Signs required by 7.2.12.3.5 shall be illuminated as required for exit signs where exit sign illumination is required.

7.2.12.3.6 Tactile signage complying with ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*, shall be located at each door to an area of refuge.

7.2.13 Elevators.

7.2.13.1* General. An elevator complying with the requirements of Section 9.4 and 7.2.13 shall be permitted to be used as a second means of egress from towers, as defined in 3.3.224, provided that the following criteria are met:

- (1) The tower and any attached structure shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (2) The tower shall be subject to occupancy not to exceed 90 persons.
- (3) Primary egress discharges shall be directly to the outside.
- (4) No high hazard content areas shall exist in the tower or attached structure.
- (5) One hundred percent of the egress capacity shall be provided independent of the elevators.
- (6) An evacuation plan that specifically includes the elevator shall be implemented and staff personnel shall be trained in operations and procedures for elevator emergency use in normal operating mode prior to fire fighter recall.
- (7) The tower shall not be used by the general public.

7.2.13.2 Elevator Evacuation System Capacity.

7.2.13.2.1 The elevator car shall have a capacity of not less than eight persons.

7.2.13.2.2 The elevator lobby shall have a capacity of not less than 50 percent of the occupant load of the area served by the lobby. The capacity shall be calculated based on 0.28 m² (3 ft²) per person and shall also include one wheelchair space of 760 mm × 1220 mm (30 in. × 48 in.) for every 50 persons, or portion thereof, of the total occupant load served by that lobby.

7.2.13.3 Elevator Lobby. Every floor served by the elevator shall have an elevator lobby. Barriers forming the elevator lobby shall have a fire resistance rating of not less than 1 hour and shall be arranged as a smoke barrier in accordance with Section 8.5.

7.2.13.4 Elevator Lobby Doors. Elevator lobby doors shall have a fire protection rating of at least 1 hour. The transmitted temperature end point shall not exceed 250°C Δ (450°F Δ)

above ambient at the end of 30 minutes of the fire exposure specified in the test method referenced in 8.3.3.2. Elevator lobby doors shall be self-closing or automatic-closing in accordance with 7.2.1.8.

7.2.13.5 Door Activation. The elevator lobby doors shall close in response to a signal from a smoke detector located directly outside the elevator lobby adjacent to or on each door opening. Elevator lobby doors shall be permitted to close in response to a signal from the building fire alarm system. Where one elevator lobby door closes by means of a smoke detector or a signal from the building fire alarm system, all elevator lobby doors serving that elevator evacuation system shall close.

7.2.13.6* Water Protection. Building elements shall be used to restrict water exposure of elevator equipment.

7.2.13.7* Power and Control Wiring. Elevator equipment, elevator communications, elevator machine room cooling, and elevator controller cooling shall be supplied by both normal and standby power. Wiring for power and control shall be located and properly protected to ensure at least 1 hour of operation in the event of a fire.

7.2.13.8* Communications. Two-way communication systems shall be provided between elevator lobbies and a central control point and between elevator cars and a central control point. Communications wiring shall be protected to ensure at least 1 hour of operation in the event of fire.

7.2.13.9* Elevator Operation. Elevators shall be provided with fire fighter service in accordance with ASME A17.1, *Safety Code for Elevators and Escalators*.

7.2.13.10 Maintenance. Where an elevator lobby is served by only one elevator car, the elevator evacuation system shall have a program of scheduled maintenance during times of building shutdown or low building activity. Repairs shall be performed within 24 hours of breakdown.

7.2.13.11 Earthquake Protection. Elevators shall have the capability of orderly shutdowns during earthquakes at locations where such shutdowns are an option of ASME A17.1, *Safety Code for Elevators and Escalators*.

7.2.13.12 Signage. Signage shall comply with 7.10.8.2.

7.3 Capacity of Means of Egress.

7.3.1 Occupant Load.

7.3.1.1 Sufficient Capacity for Occupant Load. The total capacity of the means of egress for any story, balcony, tier, or other occupied space shall be sufficient for the occupant load thereof.

7.3.1.2* Occupant Load Factor. The occupant load in any building or portion thereof shall be not less than the number of persons determined by dividing the floor area assigned to that use by the occupant load factor for that use as specified in Table 7.3.1.2, Figure 7.3.1.2(a), and Figure 7.3.1.2(b). Where both gross and net area figures are given for the same occupancy, calculations shall be made by applying the gross area figure to the gross area of the portion of the building devoted to the use for which the gross area figure is specified and by applying the net area figure to the net area of the portion of the building devoted to the use for which the net area figure is specified.

Table 7.3.1.2 Occupant Load Factor

Use	m ² (per person) ¹	ft ² (per person) ¹
Assembly Use		
Concentrated use, without fixed seating	0.65 net	7 net
Less concentrated use, without fixed seating	1.4 net	15 net
Bench-type seating	1 person/455 linear mm	1 person/18 linear in.
Fixed seating	Number of fixed seats	Number of fixed seats
Waiting spaces	See 12.1.7.2 and 13.1.7.2	See 12.1.7.2 and 13.1.7.2
Kitchens	9.3	100
Library stack areas	9.3	100
Library reading rooms	4.6 net	50 net
Swimming pools	4.6 (water surface)	50 (water surface)
Swimming pool decks	2.8	30
Exercise rooms with equipment	4.6	50
Exercise rooms without equipment	1.4	15
Stages	1.4 net	15 net
Lighting and access catwalks, galleries, gridirons	9.3 net	100 net
Casinos and similar gaming areas	1	11
Skating rinks	4.6	50
Educational Use		
Classrooms	1.9 net	20 net
Shops, laboratories, vocational rooms	4.6 net	50 net
Day-Care Use	3.3 net	35 net
Health Care Use		
Inpatient treatment departments	22.3	240
Sleeping departments	11.1	120
Detention and Correctional Use	11.1	120
Residential Use		
Hotels and dormitories	18.6	200
Apartment buildings	18.6	200
Board and care, large	18.6	200
Industrial Use		
General and high hazard industrial	9.3	100
Special purpose industrial	NA	NA
Business Use	9.3	100
Storage Use (other than mercantile storerooms)	NA	NA

(continues)

Table 7.3.1.2 *Continued*

Use	m ² (per person) ¹	ft ² (per person) ¹
Mercantile Use		
Sales area on street floor ^{2,3}	2.8	30
Sales area on two or more street floors ³	3.7	40
Sales area on floor below street floor ³	2.8	30
Sales area on floors above street floor ³	5.6	60
Floors or portions of floors used only for offices	See business use	See business use
Floors or portions of floors used only for storage, receiving, and shipping, and not open to general public	27.9	300
Mall buildings ⁴	Per factors applicable to use of space ⁵	Per factors applicable to use of space ⁵

Note: NA = not applicable. The occupant load is the maximum probable number of occupants present at any time.

¹All factors are expressed in gross area unless marked "net."

²For the purpose of determining occupant load in mercantile occupancies where, due to differences in grade of streets on different sides, two or more floors directly accessible from streets (not including alleys or similar back streets) exist, each such floor is permitted to be considered a street floor. The occupant load factor is one person for each 3.7 m² (40 ft²) of gross floor area of sales space.

³For the purpose of determining occupant load in mercantile occupancies with no street floor, as defined in 3.3.216, but with access directly from the street by stairs or escalators, the floor at the point of entrance to the mercantile occupancy is considered the street floor.

⁴For any food court or other assembly use areas located in the mall that are not included as a portion of the gross leasable area of the mall building, the occupant load is calculated based on the occupant load factor for that use as specified in Table 7.3.1.2. The remaining mall area is not required to be assigned an occupant load.

⁵The portions of the mall that are considered a pedestrian way and not used as gross leasable area are not required to be assessed an occupant load based on Table 7.3.1.2. However, means of egress from a mall pedestrian way are required to be provided for an occupant load determined by dividing the gross leasable area of the mall building (not including anchor stores) by the appropriate lowest whole number occupant load factor from Figure 7.3.1.2(a) or Figure 7.3.1.2(b).

Each individual tenant space is required to have means of egress to the outside or to the mall based on occupant loads calculated by using the appropriate occupant load factor from Table 7.3.1.2.

Each individual anchor store is required to have means of egress independent of the mall.




FIGURE 7.3.1.2(a) Mall Building Occupant Load Factors.




FIGURE 7.3.1.2(b) Mall Building Occupant Load Factors.

7.3.1.3 Occupant Load Increases.

7.3.1.3.1 The occupant load in any building or portion thereof shall be permitted to be increased from the occupant load established for the given use in accordance with 7.3.1.2 where all other requirements of this Code are also met, based on such increased occupant load.

7.3.1.3.2 The authority having jurisdiction shall be permitted to require an approved aisle, seating, or fixed equipment diagram to substantiate any increase in occupant load and shall be permitted to require that such a diagram be posted in an approved location.

7.3.1.4 Exits Serving More than One Story. Where an exit serves more than one story, only the occupant load of each story considered individually shall be used in computing the required capacity of the exit at that story, provided that the required egress capacity of the exit is not decreased in the direction of egress travel.

7.3.1.5 Capacity from a Point of Convergence. Where means of egress from a story above and a story below converge at an intermediate story, the capacity of the means of egress from the point of convergence shall be not less than the sum of the capacity of the two means of egress.

7.3.1.6 Egress Capacity from Balconies and Mezzanines. Where any required egress capacity from a balcony or mezzanine passes through the room below, that required capacity shall be added to the required egress capacity of the room below.

7.3.2 Measurement of Means of Egress.

7.3.2.1 The width of means of egress shall be measured in the clear at the narrowest point of the exit component under consideration, unless otherwise provided in 7.3.2.2.

7.3.2.2 Projections within the means of egress of not more than 114 mm (4½ in.) on each side shall be permitted at a height of 965 mm (38 in.) and below.

7.3.3 Egress Capacity.

7.3.3.1 Egress capacity for approved components of means of egress shall be based on the capacity factors shown in Table 7.3.3.1.

Table 7.3.3.1 Capacity Factors

Area	Stairways (width per person)		Level Components and Ramps (width per person)	
	mm	in.	mm	in.
Board and care	10	0.4	5	0.2
Health care, sprinklered	7.6	0.3	5	0.2
Health care, nonsprinklered	15	0.6	13	0.5
High hazard contents	18	0.7	10	0.4
All others	7.6	0.3	5	0.2

7.3.3.2 The required capacity of a corridor shall be the occupant load that utilizes the corridor for exit access divided by the required number of exits to which the corridor connects, but the corridor capacity shall be not less than the required capacity of the exit to which the corridor leads.

7.3.4 Minimum Width.

7.3.4.1 The width of any means of egress, unless otherwise provided in 7.3.4.1.1 through 7.3.4.1.3, shall be as follows:

- (1) Not less than that required for a given egress component in this chapter or Chapter 12 through Chapter 42
- (2) Not less than 915 mm (36 in.)

7.3.4.1.1* The width of exit access that is formed by furniture and movable partitions, that serves not more than six people, and that has a length not exceeding 15 m (50 ft) shall meet both of the following criteria:

- (1) The width shall be not less than 455 mm (18 in.) at and below a height of 965 mm (38 in.), and not less than 710 mm (28 in.) above a height of 965 mm (38 in.).
- (2) A width of not less than 915 mm (36 in.) for new exit access, and not less than 710 mm (28 in.) for existing exit access, shall be capable of being provided without moving permanent walls.

7.3.4.1.2 In existing buildings, the width of exit access shall be permitted to be not less than 710 mm (28 in.).

7.3.4.1.3 The requirement of 7.3.4.1 shall not apply to the following:

- (1) Doors as otherwise provided for in 7.2.1.2
- (2) Aisles and aisle accessways in assembly occupancies as otherwise provided in Chapter 12 and Chapter 13
- (3) Industrial equipment access as otherwise provided in 40.2.5.2

7.3.4.2 Where a single exit access leads to an exit, its capacity in terms of width shall be not less than the required capacity of the exit to which it leads.

7.3.4.3 Where more than one exit access leads to an exit, each shall have a width adequate for the number of persons it accommodates.

7.4 Number of Means of Egress.

7.4.1 General.

7.4.1.1 The number of means of egress from any balcony, mezzanine, story, or portion thereof shall be not less than two, except under one of the following conditions:

- (1) Where a single means of egress is permitted in Chapter 11 through Chapter 42.
- (2) Where a single means of egress is permitted for a mezzanine or balcony and the common path of travel limitations of Chapter 12 through Chapter 42 are met

7.4.1.2 The number of means of egress from any story or portion thereof, other than for existing buildings as permitted in Chapter 12 through Chapter 42, shall be as follows:

- (1) Occupant load more than 500 but not more than 1000 — not less than 3
- (2) Occupant load more than 1000 — not less than 4

7.4.1.3 Accessible means of egress in accordance with 7.5.4 that do not utilize elevators shall be permitted to serve as any or all of the required minimum number of means of egress.

7.4.1.4 The occupant load of each story considered individually shall be required to be used in computing the number of means of egress at each story, provided that the required number of means of egress is not decreased in the direction of egress travel.

7.4.1.5 Doors other than the hoistway door; the elevator car door; and doors that are readily openable from the car side without a key, a tool, special knowledge, or special effort shall be prohibited at the point of access to an elevator car.

7.4.1.6 Elevator lobbies shall have access to at least one exit. Such exit access shall not require the use of a key, a tool, special knowledge, or special effort.

7.5 Arrangement of Means of Egress.

7.5.1 General.

7.5.1.1 Exits shall be located and exit access shall be arranged so that exits are readily accessible at all times.

7.5.1.1.1* Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4.

7.5.1.1.2 Exit access corridors shall provide access to not less than two approved exits, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4.

7.5.1.1.3 The requirements of 7.5.1.1.1 and 7.5.1.1.2 shall not apply where a single exit is permitted in Chapter 12 through Chapter 42.

7.5.1.1.4 Where common paths of travel are permitted for an occupancy in Chapter 12 through Chapter 42, such common paths of travel shall be permitted but shall not exceed the limit specified.

7.5.1.2 Corridors shall provide exit access without passing through any intervening rooms other than corridors, lobbies, and other spaces permitted to be open to the corridor, unless otherwise provided in 7.5.1.2.1 and 7.5.1.2.2.

7.5.1.2.1 Approved existing corridors that require passage through a room to access an exit shall be permitted to continue to be used, provided that the following criteria are met:

- (1) The path of travel is marked in accordance with Section 7.10.
- (2) Doors to such rooms comply with 7.2.1.
- (3) Such arrangement is not prohibited by the applicable occupancy chapter.

7.5.1.2.2 Corridors that are not required to be fire resistance rated shall be permitted to discharge into open floor plan areas.

7.5.1.3 Remoteness shall be provided in accordance with 7.5.1.3.1 through 7.5.1.3.7.

7.5.1.3.1 Where more than one exit is required from a building or portion thereof, such exits shall be remotely located from each other and shall be arranged and constructed to minimize the possibility that more than one has the potential to be blocked by any one fire or other emergency condition.

7.5.1.3.2* Where two exits or exit access doors are required, they shall be located at a distance from one another not less than one-half the length of the maximum overall diagonal dimension of the building or area to be served, measured in a straight line between the nearest edge of the exit doors or exit access doors, unless otherwise provided in 7.5.1.3.3 through 7.5.1.3.5.

7.5.1.3.3 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, the minimum separation distance between two exits or exit access doors measured in accordance with 7.5.1.3.2 shall be not less than one-third the length of the maximum overall diagonal dimension of the building or area to be served.

7.5.1.3.4 Where exit enclosures are provided as the required exits specified in 7.5.1.3.2 and are interconnected by not less than a 1-hour fire resistance-rated corridor, exit separation shall be permitted to be measured along the line of travel within the corridor.

7.5.1.3.5 In existing buildings, where more than one exit or exit access door is required, such exits or exit access doors shall be permitted to be remotely located in accordance with 7.5.1.3.1.

7.5.1.3.6 Where more than two exits or exit access doors are required, at least two of the required exits or exit access doors shall be arranged to comply with the minimum separation distance requirement.

7.5.1.3.7 The balance of the exits or exit access doors specified in 7.5.1.3.6 shall be located so that, if one becomes blocked, the others shall be available.

7.5.1.4 Interlocking or scissor stairs shall comply with the 7.5.1.4.1 and 7.5.1.4.2.

7.5.1.4.1 New interlocking or scissor stairs shall be permitted to be considered only as a single exit.

7.5.1.4.2* Existing interlocking or scissor stairs shall be permitted to be considered separate exits if they meet the following criteria:

- (1) They are enclosed in accordance with 7.1.3.2.
- (2) They are separated from each other by 2-hour fire resistance-rated noncombustible construction.
- (3) No protected or unprotected penetrations or communicating openings exist between the stair enclosures.

7.5.1.5* Exit access shall be arranged so that there are no dead ends in corridors, unless permitted by, and limited to the lengths specified in, Chapter 12 through Chapter 42.

7.5.1.6 Exit access from rooms or spaces shall be permitted to be through adjoining or intervening rooms or areas, provided that such rooms or areas are accessory to the area served. Foyers, lobbies, and reception rooms constructed as required for corridors shall not be construed as intervening rooms. Exit access shall be arranged so that it is not necessary to pass through any area identified under Protection from Hazards in Chapter 11 through Chapter 42.

7.5.2 Impediments to Egress. See also 7.1.9 and 7.2.1.5.

7.5.2.1 Access to an exit shall not be through kitchens, store-rooms other than as provided in Chapter 36 and Chapter 37, restrooms, workrooms, closets, bedrooms or similar spaces, or other rooms or spaces subject to locking, unless passage through such rooms or spaces is permitted for the occupancy by Chapter 18, Chapter 19, Chapter 22, and Chapter 23.

7.5.2.2* Exit access and exit doors shall be designed and arranged to be clearly recognizable.

7.5.2.2.1 Hangings or draperies shall not be placed over exit doors or located so that they conceal or obscure any exit, unless otherwise provided in 7.5.2.2.2.

7.5.2.2.2 Curtains shall be permitted across means of egress openings in tent walls if the following criteria are met:

- (1) They are distinctly marked in contrast to the tent wall so as to be recognizable as means of egress.
- (2) They are installed across an opening that is at least 1830 mm (72 in.) in width.
- (3) They are hung from slide rings or equivalent hardware so as to be readily moved to the side to create an unobstructed opening in the tent wall that is of the minimum width required for door openings.

7.5.2.2.3 Mirrors shall not be placed on exit doors.

7.5.2.2.4 Mirrors shall not be placed in or adjacent to any exit in such a manner as to confuse the direction of exit.

7.5.3 Exterior Ways of Exit Access.

7.5.3.1 Exit access shall be permitted to be by means of any exterior balcony, porch, gallery, or roof that conforms to the requirements of this chapter.

7.5.3.2 The long side of the balcony, porch, gallery, or similar space shall be at least 50 percent open and shall be arranged to restrict the accumulation of smoke.

7.5.3.3 Exterior exit access balconies shall be separated from the interior of the building by walls and opening protectives as required for corridors, unless the exterior exit access balcony is served by at least two remote stairs that can be accessed without any occupant traveling past an unprotected opening to reach one of the stairs, or where dead ends on the exterior exit access do not exceed 6100 mm (240 in.).

7.5.3.4 Exterior exit access shall be arranged so that there are no dead ends in excess of those permitted for dead-end corridors in Chapter 11 through Chapter 42.

7.5.4 Accessible Means of Egress.

7.5.4.1* Areas accessible to people with severe mobility impairment, other than in existing buildings, shall have not less than two accessible means of egress, unless otherwise provided in 7.5.4.1.2 through 7.5.4.1.4.

7.5.4.1.1 Access within the allowable travel distance shall be provided to not less than one accessible area of refuge or one accessible exit providing an accessible route to an exit discharge.

7.5.4.1.2 A single accessible means of egress shall be permitted from buildings or areas of buildings permitted to have a single exit.

7.5.4.1.3 Accessible means of egress shall not be required in health care occupancies protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

7.5.4.1.4 Exit access travel along the accessible means of egress shall be permitted to be common for the distances permitted as common paths of travel.

7.5.4.2 Where two accessible means of egress are required, the exits serving such means of egress shall be located at a distance from one another not less than one-half the length of the maximum overall diagonal dimension of the building or area to be served, measured in a straight line between the nearest edge of the exit doors or exit access doors, unless otherwise provided in 7.5.4.2.1 through 7.5.4.2.3.

7.5.4.2.1 Where exit enclosures are provided as the required exits specified in 7.5.4.2 and are interconnected by not less than a 1-hour fire resistance-rated corridor, exit separation shall be permitted to be measured along the line of travel within the corridor.

7.5.4.2.2 The requirement of 7.5.4.2 shall not apply to buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

7.5.4.2.3 The requirement of 7.5.4.2 shall not apply where the physical arrangement of means of egress prevents the possibility that access to both accessible means of egress will be blocked by any one fire or other emergency condition as approved by the authority having jurisdiction.

7.5.4.3 Each required accessible means of egress shall be continuous from each accessible occupied area to a public way or area of refuge in accordance with 7.2.12.2.2.

7.5.4.4 Where an exit stair is used in an accessible means of egress, it shall comply with 7.2.12.2.3 and shall either incorporate an area of refuge within an enlarged story-level landing or shall be accessed from an area of refuge.

7.5.4.5 To be considered part of an accessible means of egress, an elevator shall be in accordance with 7.2.12.2.4.

7.5.4.6 To be considered part of an accessible means of egress, a smoke barrier in accordance with Section 8.5 with not less than a 1-hour fire resistance rating, or a horizontal exit in accordance with 7.2.4, shall discharge to an area of refuge in accordance with 7.2.12.

7.5.4.7 Accessible stories that are four or more stories above or below a story of exit discharge shall have not less than one elevator complying with 7.5.4.5.

7.6* Measurement of Travel Distance to Exits.

7.6.1* The travel distance to an exit shall be measured on the floor or other walking surface as follows:

- (1) Along the centerline of the natural path of travel, starting from the most remote point subject to occupancy
- (2) Curving around any corners or obstructions with a 305-mm (12-in.) clearance therefrom
- (3) Terminating at one of the following:
 - (a) Center of the doorway
 - (b) Other point at which the exit begins
 - (c) Smoke barrier in an existing detention and correctional occupancy as provided in Chapter 23.

7.6.2* Where open stairways or ramps are permitted as a path of travel to required exits, the distance shall include the travel on the stairway or ramp and the travel from the end of the stairway or ramp to an outside door or other exit in addition to the distance traveled to reach the stairway or ramp.

7.6.3 Where any part of an exterior exit is within 3050 mm (120 in.) of horizontal distance of any unprotected building opening, as permitted by 7.2.2.6.3 for outside stairs, the travel distance to the exit shall include the length of travel to ground level.

7.6.4 Where measurement includes stairs, the measurement shall be taken in the plane of the tread nosing.

7.6.5 The travel distance in any occupied space to not less than one exit, measured in accordance with 7.6.1 through 7.6.4, shall not exceed the limits specified in this *Code*. (See 7.6.6.)

7.6.6 Travel distance limitations shall be as provided in Chapter 11 through Chapter 42 and, for high hazard areas, shall be in accordance with Section 7.11.

7.7 Discharge from Exits.

7.7.1* Exit Termination. Exits shall terminate directly, at a public way or at an exterior exit discharge, unless otherwise provided in 7.7.1.2 through 7.7.1.4.

7.7.1.1 Yards, courts, open spaces, or other portions of the exit discharge shall be of required width and size to provide all occupants with a safe access to a public way.

7.7.1.2 The requirement of 7.7.1 shall not apply to interior exit discharge as otherwise provided in 7.7.2.

7.7.1.3 The requirement of 7.7.1 shall not apply to rooftop exit discharge as otherwise provided in 7.7.6.

7.7.1.4 Means of egress shall be permitted to terminate in an exterior area of refuge for detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23.

7.7.2 Discharge through Areas on Level of Exit Discharge. Not more than 50 percent of the required number of exits, and not more than 50 percent of the required egress capacity, shall be permitted to discharge through areas on the

level of exit discharge, unless otherwise permitted in 7.7.2.1 and 7.7.2.2, provided that the criteria of 7.7.2.3 through 7.7.2.7 are met.

7.7.2.1 One hundred percent of the exits shall be permitted to discharge through areas on the level of exit discharge in detention and correctional occupancies as otherwise provided in Chapter 22 and Chapter 23.

7.7.2.2 In existing buildings, the 50 percent limit on egress capacity shall not apply if the 50 percent limit on the required number of exits is met.

7.7.2.3 The discharge specified in 7.7.2 shall lead to a free and unobstructed way to the exterior of the building, and such way shall be readily visible and identifiable from the point of discharge from the exit.

7.7.2.4 The level of discharge shall be protected throughout by an approved, automatic sprinkler system in accordance with Section 9.7, or the portion of the level of discharge used for discharge shall be protected by an approved, automatic sprinkler system in accordance with Section 9.7 and shall be separated from the nonsprinklered portion of the floor by a fire resistance rating meeting the requirements for the enclosure of exits. (See 7.1.3.2.1.)

7.7.2.5 The requirement of 7.7.2.4 shall not apply where the discharge area is a vestibule or foyer that meets all of the following criteria:

- (1) The depth from the exterior of the building shall be not more than 3050 mm (120 in.), and the length shall be not more than 9140 mm (360 in.).
- (2) The foyer shall be separated from the remainder of the level of discharge by construction providing protection not less than the equivalent of wired glass in steel frames.
- (3) The foyer shall serve only as means of egress and shall include an exit directly to the outside.

7.7.2.6 The entire area on the level of discharge shall be separated from areas below by construction having a fire resistance rating not less than that required for the exit enclosure, unless otherwise provided in 7.7.2.7.

7.7.2.7 Levels below the level of discharge in an atrium shall be permitted to be open to the level of discharge where such level of discharge is protected in accordance with 8.6.7.

7.7.3 Arrangement and Marking of Exit Discharge. The exit discharge shall be arranged and marked to make clear the direction of egress to a public way. Stairs shall be arranged so as to make clear the direction of egress to a public way. Stairs that continue more than one-half story beyond the level of exit discharge shall be interrupted at the level of exit discharge by partitions, doors, or other effective means.

7.7.4 Components of Exit Discharge. Doors, stairs, ramps, corridors, exit passageways, bridges, balconies, escalators, moving walks, and other components of an exit discharge shall comply with the detailed requirements of this chapter for such components.

7.7.5 Signs. See 7.2.2.5.4.

7.7.6 Discharge to Roofs. Where approved by the authority having jurisdiction, exits shall be permitted to discharge to roofs or other sections of the building or an adjoining building where the following criteria are met:

- (1) The roof/ceiling assembly construction has a fire resistance rating not less than that required for the exit enclosure.
- (2) A continuous and safe means of egress from the roof is available.

7.8 Illumination of Means of Egress.

7.8.1 General.

7.8.1.1* Illumination of means of egress shall be provided in accordance with Section 7.8 for every building and structure where required in Chapter 11 through Chapter 42. For the purposes of this requirement, exit access shall include only designated stairs, aisles, corridors, ramps, escalators, and passageways leading to an exit. For the purposes of this requirement, exit discharge shall include only designated stairs, aisles, corridors, ramps, escalators, walkways, and exit passageways leading to a public way.

7.8.1.2 Illumination of means of egress shall be continuous during the time that the conditions of occupancy require that the means of egress be available for use, unless otherwise provided in 7.8.1.2.2.

7.8.1.2.1 Artificial lighting shall be employed at such locations and for such periods of time as are necessary to maintain the illumination to the minimum criteria values herein specified.

7.8.1.2.2 Automatic, motion sensor-type lighting switches shall be permitted within the means of egress, provided that the switch controllers are equipped for fail-safe operation, the illumination timers are set for a minimum 15-minute duration, and the motion sensor is activated by any occupant movement in the area served by the lighting units.

7.8.1.3* The floors and other walking surfaces within an exit and within the portions of the exit access and exit discharge designated in 7.8.1.1 shall be illuminated as follows:

- (1) During conditions of stair use, the minimum illumination for new stairs shall be at least 108 lux (10 ft-candle), measured at the walking surfaces.
- (2) The minimum illumination for floors and walking surfaces, other than new stairs, shall be to values of at least 10.8 lux (1 ft-candle), measured at the floor.
- (3) In assembly occupancies, the illumination of the floors of exit access shall be at least 2.2 lux (0.2 ft-candle) during periods of performances or projections involving directed light.
- (4)*The minimum illumination requirements shall not apply where operations or processes require low lighting levels.

7.8.1.4* Required illumination shall be arranged so that the failure of any single lighting unit does not result in an illumination level of less than 2.2 lux (0.2 ft-candle) in any designated area.

7.8.1.5 The equipment or units installed to meet the requirements of Section 7.10 also shall be permitted to serve the function of illumination of means of egress, provided that all requirements of Section 7.8 for such illumination are met.

7.8.2 Sources of Illumination.

7.8.2.1* Illumination of means of egress shall be from a source considered reliable by the authority having jurisdiction.

7.8.2.2 Battery-operated electric lights and other types of portable lamps or lanterns shall not be used for primary illumination of means of egress. Battery-operated electric lights shall

be permitted to be used as an emergency source to the extent permitted under Section 7.9.

7.9 Emergency Lighting.

7.9.1 General.

7.9.1.1* Emergency lighting facilities for means of egress shall be provided in accordance with Section 7.9 for the following:

- (1) Buildings or structures where required in Chapter 11 through Chapter 42
- (2) Underground and limited access structures as addressed in Section 11.7
- (3) High-rise buildings as required by other sections of this *Code*
- (4) Doors equipped with delayed-egress locks
- (5) Stair shaft and vestibule of smokeproof enclosures, for which the following also apply:
 - (a) The stair shaft and vestibule shall be permitted to include a standby generator that is installed for the smokeproof enclosure mechanical ventilation equipment.
 - (b) The standby generator shall be permitted to be used for the stair shaft and vestibule emergency lighting power supply.

7.9.1.2 For the purposes of 7.9.1.1, exit access shall include only designated stairs, aisles, corridors, ramps, escalators, and passageways leading to an exit. For the purposes of 7.9.1.1, exit discharge shall include only designated stairs, ramps, aisles, walkways, and escalators leading to a public way.

7.9.1.3 Where maintenance of illumination depends on changing from one energy source to another, a delay of not more than 10 seconds shall be permitted.

7.9.2 Performance of System.

7.9.2.1* Emergency illumination shall be provided for not less than 1½ hours in the event of failure of normal lighting. Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 10.8 lux (1 ft-candle) and, at any point, not less than 1.1 lux (0.1 ft-candle), measured along the path of egress at floor level. Illumination levels shall be permitted to decline to not less than an average of 6.5 lux (0.6 ft-candle) and, at any point, not less than 6.5 lux (0.06 ft-candle) at the end of the 1½ hours. A maximum-to-minimum illumination uniformity ratio of 40 to 1 shall not be exceeded.

7.9.2.2* The emergency lighting system shall be arranged to provide the required illumination automatically in the event of any interruption of normal lighting due to any of the following:

- (1) Failure of a public utility or other outside electrical power supply
- (2) Opening of a circuit breaker or fuse
- (3) Manual act(s), including accidental opening of a switch controlling normal lighting facilities

7.9.2.3 Emergency generators providing power to emergency lighting systems shall be installed, tested, and maintained in accordance with NFPA 110, *Standard for Emergency and Standby Power Systems*. Stored electrical energy systems, where required in this *Code*, shall be installed and tested in accordance with NFPA 111, *Standard on Stored Electrical Energy Emergency and Standby Power Systems*.

7.9.2.4* Battery-operated emergency lights shall use only reliable types of rechargeable batteries provided with suitable facilities for maintaining them in properly charged condition.

Batteries used in such lights or units shall be approved for their intended use and shall comply with NFPA 70, *National Electrical Code*®.

7.9.2.5 The emergency lighting system shall be either continuously in operation or shall be capable of repeated automatic operation without manual intervention.

7.9.3 Periodic Testing of Emergency Lighting Equipment.

7.9.3.1 Required emergency lighting systems shall be tested in accordance with one of the three options offered by 7.9.3.1.1, 7.9.3.1.2, or 7.9.3.1.3.

7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows:

- (1) Functional testing shall be conducted at 30-day intervals for not less than 30 seconds.
- (2) Functional testing shall be conducted annually for not less than 1½ hours if the emergency lighting system is battery powered.
- (3) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and 7.9.3.1.1(2).
- (4) Written records of visual inspections and tests shall be kept by the owner for inspection by the authority having jurisdiction.

7.9.3.1.2 Testing of required emergency lighting systems shall be permitted to be conducted as follows:

- (1) Self-testing/self-diagnostic battery-operated emergency lighting equipment shall be provided.
- (2) Self-testing/self-diagnostic battery-operated emergency lighting equipment shall automatically perform not less than once every 30 days a test for not less than 30 seconds and a diagnostic routine.
- (3) Self-testing/self-diagnostic battery-operated emergency lighting equipment shall indicate failures by a status indicator.
- (4) A visual inspection shall be performed at intervals not exceeding 30 days.
- (5) Functional testing shall be conducted annually for not less than 1½ hours.
- (6) Self-testing/self-diagnostic battery-operated emergency lighting equipment shall be fully operational for the duration of the 1½ hour test.
- (7) Written records of visual inspections and tests shall be kept by the owner for inspection by the authority having jurisdiction.

7.9.3.1.3 Testing of required emergency lighting systems shall be permitted to be conducted as follows:

- (1) Computer-based, self-testing/self-diagnostic battery-operated emergency lighting equipment shall be provided.
- (2) The emergency lighting equipment shall automatically perform not less than once every 30 days a test for not less than 30 seconds and a diagnostic routine.
- (3) The emergency lighting equipment shall automatically perform annually a test for not less than 1½ hours.
- (4) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.3(2) and 7.9.3.1.3(3).
- (5) The computer-based system shall be capable of providing a report of the history of tests and failures at all times.

7.10 Marking of Means of Egress.

7.10.1 General.

7.10.1.1 Where Required. Means of egress shall be marked in accordance with Section 7.10 where required in Chapter 11 through Chapter 42.

7.10.1.2* Exits. Exits, other than main exterior exit doors that obviously and clearly are identifiable as exits, shall be marked by an approved sign that is readily visible from any direction of exit access.

7.10.1.3 Exit Stair Door Tactile Signage. Tactile signage shall be provided to meet the following criteria, unless otherwise provided in 7.10.1.4:

- (1) Tactile signage shall be located at each exit door requiring an exit sign.
- (2) Tactile signage shall read as follows: EXIT
- (3) Tactile signage shall comply with ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*.

7.10.1.4 Existing Exemption. The requirements of 7.10.1.3 shall not apply to existing buildings, provided that the occupancy classification does not change.

7.10.1.5 Exit Access.

7.10.1.5.1 Access to exits shall be marked by approved, readily visible signs in all cases where the exit or way to reach the exit is not readily apparent to the occupants.

7.10.1.5.2* New sign placement shall be such that no point in an exit access corridor is in excess of the rated viewing distance or 30 m (100 ft), whichever is less, from the nearest sign.

7.10.1.6* Floor Proximity Exit Signs. Where floor proximity exit signs are required in Chapter 11 through Chapter 42, such signs shall be located near the floor level in addition to those signs required for doors or corridors. The signs shall be illuminated in accordance with 7.10.5. Externally illuminated signs shall be sized in accordance with 7.10.6.1. The bottom of the sign shall be not less than 150 mm (6 in.) but not more than 455 mm (18 in.) above the floor. For exit doors, the sign shall be mounted on the door or adjacent to the door, with the nearest edge of the sign within 100 mm (4 in.) of the door frame.

7.10.1.7* Floor Proximity Egress Path Marking. Where floor proximity egress path marking is required in Chapter 11 through Chapter 42, a listed and approved floor proximity egress path marking system that is internally illuminated shall be installed within 455 mm (18 in.) of the floor. The system shall provide a visible delineation of the path of travel along the designated exit access and shall be essentially continuous, except as interrupted by doorways, hallways, corridors, or other such architectural features. The system shall operate continuously or at any time the building fire alarm system is activated. The activation, duration, and continuity of operation of the system shall be in accordance with 7.9.2.

7.10.1.8* Visibility. Every sign required in Section 7.10 shall be located and of such size, distinctive color, and design that it is readily visible and shall provide contrast with decorations, interior finish, or other signs. No decorations, furnishings, or equipment that impairs visibility of a sign shall be permitted. No brightly illuminated sign (for other than exit purposes), display, or object in or near the line of vision of the required exit sign that could detract attention from the exit sign shall be permitted.

7.10.1.9 Mounting Location. The bottom of new egress markings shall be located at a vertical distance of not more than 2030 mm (80 in.) above the top edge of the egress opening intended for designation by that marking. Egress markings shall be located at a horizontal distance of not more than the required width of the egress opening, as measured from the edge of the egress opening intended for designation by that marking to the nearest edge of the marking.

7.10.2* Directional Signs. A sign complying with 7.10.3 with a directional indicator showing the direction of travel shall be placed in every location where the direction of travel to reach the nearest exit is not apparent.

7.10.3* Sign Legend.

7.10.3.1 Signs required by 7.10.1 and 7.10.2 shall read as follows in plainly legible letters, or other appropriate wording shall be used:

EXIT

7.10.3.2* Where approved by the authority having jurisdiction, pictograms shall be permitted.

7.10.4* Power Source. Where emergency lighting facilities are required by the applicable provisions of Chapter 11 through Chapter 42 for individual occupancies, the signs, other than approved self-luminous signs, shall be illuminated by the emergency lighting facilities. The level of illumination of the signs shall be in accordance with 7.10.6.3 or 7.10.7 for the required emergency lighting duration as specified in 7.9.2.1. However, the level of illumination shall be permitted to decline to 60 percent at the end of the emergency lighting duration.

7.10.5 Illumination of Signs.

7.10.5.1* General. Every sign required by 7.10.1.2 or 7.10.1.5, other than where operations or processes require low lighting levels, shall be suitably illuminated by a reliable light source. Externally and internally illuminated signs shall be legible in both the normal and emergency lighting mode.

7.10.5.2* Continuous Illumination.

7.10.5.2.1 Every sign required to be illuminated by 7.10.6.3 and 7.10.7 shall be continuously illuminated as required under the provisions of Section 7.8 unless otherwise provided in 7.10.5.2.2.

7.10.5.2.2* Illumination for signs shall be permitted to flash on and off upon activation of the fire alarm system.

7.10.6 Externally Illuminated Signs.

7.10.6.1* Size of Signs.

7.10.6.1.1 Externally illuminated signs required by 7.10.1 and 7.10.2, other than approved existing signs, unless otherwise provided in 7.10.6.1.2, shall read EXIT, or other appropriate wording shall be used, in plainly legible letters sized as follows:

- (1) For new signs, the letters shall be not less than 150 mm (6 in.) high, with the principal strokes of letters not less than 19 mm (¾ in.) wide.
- (2) For existing signs, the required wording shall be permitted to be in plainly legible letters not less than 100 mm (4 in.) high.
- (3) The word EXIT shall be in letters of a width not less than 51 mm (2 in.), except the letter I, and the minimum spacing between letters shall be not less than 9.5 mm (⅜ in.).

- (4) Sign legend elements larger than the minimum established in 7.10.6.1.1(1) through 7.10.6.1.1(3) shall use letter widths, strokes, and spacing in proportion to their height.

7.10.6.1.2 The requirements of 7.10.6.1.1 shall not apply to marking required by 7.10.1.3 and 7.10.1.6.

7.10.6.2* Size and Location of Directional Indicator.

7.10.6.2.1 Directional indicators, unless otherwise provided in 7.10.6.2.2, shall comply with the following:

- (1) The directional indicator shall be located outside of the EXIT legend, not less than 9.5 mm ($\frac{3}{8}$ in.) from any letter.
- (2) The directional indicator shall be of a chevron type, as shown in Figure 7.10.6.2.1.
- (3) The directional indicator shall be identifiable as a directional indicator at a distance of 12 m (40 ft).
- (4) A directional indicator larger than the minimum established for compliance with 7.10.6.2.1(3) shall be proportionately increased in height, width and stroke.
- (5) The directional indicator shall be located at the end of the sign for the direction indicated.




FIGURE 7.10.6.2.1 Chevron-Type Indicator.

7.10.6.2.2 The requirements of 7.10.6.2.1 shall not apply to approved existing signs.

7.10.6.3* Level of Illumination. Externally illuminated signs shall be illuminated by not less than 54 lux (5 ft-candles) at the illuminated surface and shall have a contrast ratio of not less than 0.5.

7.10.7 Internally Illuminated Signs.

7.10.7.1 Listing. Internally illuminated signs shall be listed in accordance with UL 924, *Standard for Safety Emergency Lighting and Power Equipment*, unless they meet one of the following criteria:

- (1) They are approved existing signs.
- (2) They are existing signs having the required wording in legible letters not less than 100 mm (4 in.) high.
- (3) They are signs that are in accordance with 7.10.1.3 and 7.10.1.6.

7.10.7.2* Photoluminescent Signs. The face of a photoluminescent sign shall be continually illuminated while the building is occupied. The illumination levels on the face of the photoluminescent sign shall be in accordance with its listing. The charging illumination shall be a reliable light source as determined by the authority having jurisdiction. The charging light source shall be of a type specified in the product markings.

7.10.8 Special Signs.

7.10.8.1 Sign Illumination.

7.10.8.1.1 Where required by other provisions of this *Code*, special signs shall be illuminated.

7.10.8.1.2 Where emergency lighting facilities are required by the applicable provisions of Chapter 12 through Chapter 42, the required illumination of special signs shall additionally be provided under emergency lighting conditions.

7.10.8.2 Characters. Special signs, where required by other provisions of this *Code*, shall comply with the visual character requirements of ICC/ANSI A117.1 *American National Standard for Accessible and Usable Buildings and Facilities*.

7.10.8.3* No Exit.

7.10.8.3.1 Any door, passage, or stairway that is neither an exit nor a way of exit access and that is located or arranged so that it is likely to be mistaken for an exit shall be identified by a sign that reads as follows:

NO
EXIT

7.10.8.3.2 The NO EXIT sign shall have the word NO in letters 51 mm (2 in.) high, with a stroke width of 9.5 mm ($\frac{3}{8}$ in.), and the word EXIT in letters 25 mm (1 in.) high, with the word EXIT below the word NO, unless such sign is an approved existing sign.

7.10.8.4 Elevator Signs. Elevators that are a part of a means of egress (see 7.2.13.1) shall have signs with a minimum letter height of 16 mm ($\frac{5}{8}$ in.) posted in every elevator lobby as follows:

- (1)*Signs that indicate that the elevator can be used for egress, including any restrictions on use
- (2)*Signs that indicate the operational status of elevators

7.10.9 Testing and Maintenance.

7.10.9.1 Inspection. Exit signs shall be visually inspected for operation of the illumination sources at intervals not to exceed 30 days, or shall be periodically monitored in accordance with 7.9.3.1.3.

7.10.9.2 Testing. Exit signs connected to or provided with a battery-operated emergency illumination source, where required in 7.10.4, shall be tested and maintained in accordance with 7.9.3.

7.11 Special Provisions for Occupancies with High Hazard Contents. See Section 6.2.

7.11.1* Where the contents are classified as high hazard, exits shall be provided and arranged to allow all occupants to escape from the building or structure or from the hazardous area thereof to the outside or to a place of safety with a travel distance of not more than 23 m (75 ft), measured as required in 7.6.1, unless otherwise provided in 7.11.2.

7.11.2 The requirement of 7.11.1 shall not apply to storage occupancies as otherwise provided in Chapter 42.

7.11.3 Egress capacity for high hazard contents areas shall be based on 18 mm/person (0.7 in./person) for stairs or 10 mm/person (0.4 in./person) for level components and ramps in accordance with 7.3.3.1.

7.11.4 Not less than two means of egress shall be provided from each building or hazardous area thereof, unless all of the following criteria are met:

- (1) Rooms or spaces do not exceed 18.6 m^2 (200 ft^2).
- (2) Rooms or spaces have an occupant load not exceeding three persons.
- (3) Rooms or spaces have a travel distance to the room door not exceeding 7620 mm (300 in.).

7.11.5 Means of egress, for rooms or spaces other than those that meet the criteria of 7.11.4(1) through 7.11.4(3), shall be arranged so that there are no dead ends in corridors.

7.11.6 Doors serving high hazard contents areas with occupant loads in excess of five shall be permitted to be provided with a latch or lock only if the latch or lock is panic hardware or fire exit hardware complying with 7.2.1.7.

7.12 Mechanical Equipment Rooms, Boiler Rooms, and Furnace Rooms.

7.12.1 Mechanical equipment rooms, boiler rooms, furnace rooms, and similar spaces shall be arranged to limit common path of travel to a distance not exceeding 15 m (50 ft), unless otherwise permitted by the following:

- (1) A common path of travel not exceeding 30 m (100 ft) shall be permitted in the following locations:
 - (a) In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7
 - (b) In mechanical equipment rooms with no fuel-fired equipment
 - (c) In existing buildings
- (2) In an existing building, a common path of travel not exceeding 46 m (150 ft) shall be permitted if all of the following criteria are met:
 - (a) The building is protected throughout by an approved, supervised automatic sprinkler system installed in accordance with Section 9.7
 - (b) No fuel-fired equipment is within the space.
 - (c) The egress path is readily identifiable.
- (3) The requirement of 7.12.1 shall not apply to rooms or spaces in existing health care occupancies complying with the arrangement of means of egress provisions of 19.2.5 and the travel distance limits of 19.2.6.

7.12.2 Stories used exclusively for mechanical equipment, furnaces, or boilers shall be permitted to have a single means of egress where the travel distance to an exit on that story is not in excess of the common path of travel limitations of 7.12.1.

Chapter 8 Features of Fire Protection

8.1 General.

8.1.1 Application. The features of fire protection set forth in this chapter shall apply to both new construction and existing buildings.

8.1.2 Automatic Sprinkler Systems. Where another provision of this chapter requires an automatic sprinkler system, the automatic sprinkler system shall be installed in accordance with the subparts of 9.7.1.1 as permitted by the applicable occupancy chapter.

8.2 Construction and Compartmentation.

8.2.1 Construction.

8.2.1.1 Buildings or structures occupied or used in accordance with the individual occupancy chapters, Chapter 12 through Chapter 42, shall meet the minimum construction requirements of those chapters.

8.2.1.2* NFPA 220, *Standard on Types of Building Construction*, shall be used to determine the requirements for the construction classification.

8.2.1.3 Where the building or facility includes additions or connected structures of different construction types, the rating and classification of the structure shall be based on one of the following:

- (1) Separate buildings, if a 2-hour or greater vertically aligned fire barrier wall in accordance with NFPA 221, *Standard for Fire Walls and Fire Barrier Walls*, exists between the portions of the building
- (2) Separate buildings, if provided with previously approved separations
- (3) The least fire-resistive type of construction of the connected portions, if separation as specified in 8.2.1.3(1) or 8.2.1.3(2) is not provided

8.2.2 General.

8.2.2.1 Where required by other chapters of this *Code*, every building shall be divided into compartments to limit the spread of fire and restrict the movement of smoke.

8.2.2.2 Fire compartments shall be formed with fire barriers that comply with Section 8.3.

8.2.2.3* Fire compartments shall be formed by fire barriers complying with one of the following:

- (1) The fire barriers are continuous from outside wall to outside wall or from one fire barrier to another, or a combination thereof, including continuity through all concealed spaces, such as those found above a ceiling, including interstitial spaces.
- (2) The fire barriers are continuous from outside wall to outside wall or from one fire barrier to another, or from the floor to the bottom of the interstitial space, provided that the construction assembly forming the bottom of the interstitial space has a fire resistance rating not less than that of the fire barrier.

8.2.2.4 Where required elsewhere in this *Code* to comply with 8.2.2.4, door assemblies also shall comply with the following:

- (1) They shall be tested in accordance with UL 1784, *Standard for Air Leakage Tests for Door Assemblies*.
- (2) The maximum air leakage rate of the door assembly shall be $0.9 \text{ m}^3/\text{min}/\text{m}^2$ ($3.0 \text{ ft}^3/\text{min}/\text{ft}^2$) of door opening at $25 \text{ N}/\text{m}^2$ (0.10 in. water column) for both the ambient and elevated temperature tests.

8.2.3 Fire Resistive-Rated Construction.

8.2.3.1* The fire resistance of structural elements and building assemblies shall be determined in accordance with test procedures set forth in NFPA 251, or other approved test methods, or analytical methods approved by the authority having jurisdiction. Materials used to construct fire resistance-rated elements and assemblies shall be limited to those permitted in this *Code*.

8.2.3.2 Fire resistance-rated floor and roof assemblies shall be classified as restrained or unrestrained in accordance with NFPA 251 or other approved test methods. The construction shall be considered restrained only where a registered design professional has furnished the authority having jurisdiction with satisfactory documentation verifying that the construction is restrained. The classification of fire resistance-rated floor and roof construction shall be identified on the plans as restrained or unrestrained.

8.2.3.3 Structural elements that support fire barriers shall be permitted to have only the fire resistance rating required for the construction classification of the building, provided that both of the following criteria are met:

- (1) Such structural elements support nonbearing wall or partition assemblies have a required fire resistance rating of 1 hour or less.
- (2) Such structural elements do not serve as exit enclosures or protection for vertical openings.

8.2.3.4 The requirement of 8.2.3.3 shall not apply to health care occupancy structural elements supporting floor assemblies in accordance with the provisions of 18.1.6 and 19.1.6.

8.2.4 Analytical Methods.

8.2.4.1 Analytical methods utilized to determine the fire resistance of building assemblies shall comply with 8.2.4.2 or 8.2.4.3.

8.2.4.2* Where calculations are used to establish the fire resistance rating of structural elements or assemblies, they shall be permitted to be performed in accordance with ASCE/SFPE 29, *Standard Calculation Methods for Structural Fire Protection*. Where calculations are used to establish the fire resistance rating of concrete or masonry elements or assemblies, the provisions of ACI 216.1/TMS 0216.1, *Standard Method for Determining Fire Resistance of Concrete and Masonry Assemblies*, shall be permitted to be used.

8.2.4.3 Except for the method specified in 8.2.4.2, analytical methods used to calculate the fire resistance of building assemblies or structural elements shall be approved. Where an approved analytical method is utilized to establish the fire resistance rating of a structural element or building assembly, the calculations shall be based upon the fire exposure and acceptance criteria specified in NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*.

8.3 Fire Barriers.

8.3.1 General. Fire barriers used to provide enclosure, subdivision, or protection under this *Code* shall be classified in accordance with one of the following fire resistance ratings:

- (1) 2-hour fire resistance rating
- (2) 1-hour fire resistance rating
- (3) *½-hour fire resistance rating

8.3.2 Walls.

8.3.2.1 The fire-resistive materials, assemblies, and systems used shall be limited to those permitted in this *Code* and this chapter.

8.3.2.2 The construction materials and details for fire-resistive assemblies and systems for walls described shall comply with all other provisions of this *Code*, except as modified herein.

8.3.2.3 Interior walls and partitions of nonsymmetrical construction shall be evaluated from both directions and assigned a fire resistance rating based on the shorter duration obtained

in accordance with NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*. When the wall is tested with the least fire-resistive side exposed to the furnace, the wall shall not be required to be subjected to tests from the opposite side.

8.3.3 Fire Doors and Windows.

8.3.3.1 Wall openings required to have a fire protection rating by Table 8.3.4.2 shall be protected by approved, listed, labeled fire door assemblies and fire window assemblies and their accompanying hardware, including all frames, closing devices, anchorage, and sills in accordance with the requirements of NFPA 80, *Standard for Fire Doors and Fire Windows*, except as otherwise specified in this *Code*.

8.3.3.2* Fire protection ratings for products required to comply with 8.3.3 shall be as determined and reported by a nationally recognized testing agency in accordance with NFPA 252, *Standard Methods of Fire Tests of Door Assemblies*, or NFPA 257, *Standard on Fire Test for Window and Glass Block Assemblies*.

(A) Fire protection-rated glazing shall be evaluated under positive pressure in accordance with NFPA 257.

(B) All products required to comply with 8.3.3.2 shall bear an approved label.

8.3.3.3 Unless otherwise specified, fire doors shall be self-closing or automatic-closing in accordance with 7.2.1.8.

8.3.3.4 Floor fire door assemblies shall be tested in accordance with NFPA 288, *Standard Methods of Fire Tests of Floor Fire Door Assemblies Installed Horizontally in Fire Resistance-Rated Floor Systems*, and shall achieve a fire resistance rating not less than the assembly being penetrated. Floor fire doors assemblies shall be listed and labeled.

8.3.3.5 Fire protection-rated glazing shall be permitted in fire barriers having a required fire resistance rating of 1 hour or less and shall be of an approved type with the appropriate fire protection rating for the location in which the barriers are installed.

8.3.3.6* Glazing in fire window assemblies, other than in existing fire window installations of wired glass and other fire-rated glazing material, shall be of a design that has been tested to meet the conditions of acceptance of NFPA 257, *Standard on Fire Test for Window and Glass Block Assemblies*. Fire protection-rated glazing in fire door assemblies, other than in existing fire-rated door assemblies, shall be of a design that has been tested to meet the conditions of acceptance of NFPA 252, *Standard Methods of Fire Tests of Door Assemblies*.

8.3.3.7 Wired glass of 6 mm (¼ in.) in thickness and labeled for fire protection purposes shall be permitted to be used in approved opening protectives provided the maximum size specified by the listing is not exceeded. Other glazing materials that have been tested and labeled to indicate the type of opening to be protected for fire protection purposes shall be permitted to be used in approved opening protectives in accordance with their listing, with the maximum sizes tested.

8.3.3.8 Nonsymmetrical fire protection-rated glazing systems shall be tested with each face exposed to the furnace, and the assigned fire protection rating shall be that of the shortest duration obtained from the two tests conducted in compliance with NFPA 257, *Standard on Fire Test for Window and Glass Block Assemblies*.

8.3.3.9 The total combined area of glazing in fire-rated window assemblies and fire-rated door assemblies used in fire barriers shall not exceed 25 percent of the area of the fire barrier that is common with any room, unless the installation meets one of the following criteria:

- (1) The installation is an existing fire window installation of wired glass and other fire-rated glazing material in approved metal frames;
- (2) The installation is an existing fire window installations of wired glass and other fire-rated glazing materials in approved frames.
- (3) The fire protection-rated glazing material is installed in approved existing frames.

8.3.4 Opening Protectives.

8.3.4.1 Every opening in a fire barrier shall be protected to limit the spread of fire and restrict the movement of smoke from one side of the fire barrier to the other.

8.3.4.2* The fire protection rating for opening protectives in fire barriers, fire-rated smoke barriers, and fire-rated smoke partitions shall be in accordance with Table 8.3.4.2.

Table 8.3.4.2 Minimum Fire Protection Ratings for Opening Protectives in Fire Resistance-Rated Assemblies

Component	Walls and Partitions (hr)	Fire Door Assemblies (hr)	Fire Window Assemblies (hr)
Elevator hoistways	2	1½	NP
Vertical shafts (including stairways, exits, and refuse chutes)	1	1	NP
Fire barriers	2	1½	NP
Horizontal exits	1	¾	¾
Exit access corridors ¹	2	1½	NP
Smoke barriers ¹	1	1½	NP
Smoke partitions ^{1,2}	½	⅓	⅓

Note: NP = not permitted.

¹ Fire doors are not required to have a hose stream test per NFPA 252.

² For residential board and care, see 32.2.3.1.1 and 33.2.3.1.1.

8.3.4.3 Existing fire door assemblies having a ¾-hour fire protection rating shall be permitted to continue to be used in vertical openings and in exit enclosures in lieu of the 1-hour rating required by Table 8.3.4.2.

8.3.4.4 Where a 20-minute fire protection-rated door is required in existing buildings, an existing 44-mm (1¾-in.) solid-bonded wood-core door, an existing steel-clad (tin-clad) wood door, or an existing solid-core steel door with positive latch and closer shall be permitted, unless otherwise specified by Chapter 11 through Chapter 42.

8.3.5 Penetrations. The provisions of 8.3.5 shall govern the materials and methods of construction used to protect through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance-rated horizontal assemblies. The provisions of 8.3.5 shall not apply to approved existing materials and methods of construction used to protect existing through-penetrations and existing membrane penetrations in fire walls, fire barrier walls, or fire resistance-rated horizontal assemblies, unless otherwise required by Chapter 12 through Chapter 42.

8.3.5.1 Firestop Systems and Devices Required. Penetrations for cables, cable trays, conduits, pipes, tubes, combustion vents and exhaust vents, wires, and similar items to accommodate electrical, mechanical, plumbing, and communications systems that pass through a wall, floor, or floor/ceiling assembly constructed as a fire barrier shall be protected by a firestop system or device. The firestop system or device shall be tested in accordance with ASTM E-814 or ANSI/UL 1479 at a minimum positive pressure differential of 2.5 N/m² (0.01 in. water column) between the exposed and the unexposed surface of the test assembly.

8.3.5.1.1 The requirements of 8.3.5.1 shall not apply where otherwise permitted by any one of the following:

- (1) Where penetrations are tested and installed as part of an assembly tested and rated in accordance with NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*
- (2) Where penetrations through floors are enclosed in a shaft enclosure designed as a fire barrier
- (3) Where concrete, grout, or mortar has been used to fill the annular spaces around cast-iron, copper, or steel piping that penetrates one or more concrete or masonry fire resistance-rated assemblies and both of the following criteria are also met:
 - (a) The nominal diameter of each penetrating item shall not exceed 150 mm (6 in.), and the opening size shall not exceed 0.09 m² (1 ft²).
 - (b) The thickness of the concrete, grout, or mortar shall be the full thickness of the assembly
- (4) Where firestopping materials are used with the penetrating items in 8.3.5.1.1(1) through 8.3.5.1.1(3) and both of the following criteria are also met:
 - (a) The penetration shall be limited to only one floor.
 - (b) The firestopping material shall be capable of preventing the passage of flame and hot gases sufficient to ignite cotton waste when subjected to the time-temperature fire conditions of NFPA 251 under a minimum positive pressure differential of 2.5 N/m² (0.01 in. water column) at the location of the penetration for the time period equivalent to the required fire resistance rating of the assembly penetrated.

8.3.5.1.2 The maximum nominal diameter of the following penetrating items shall be not greater than 100 mm (4 in.), and the aggregate area of all penetrating items shall not exceed 64,520 mm² (100 in.²) in any 9.3 m² (100 ft²) of floor or wall area:

- (1) Steel, ferrous, or copper cables
- (2) Cable or wire with steel jackets
- (3) Cast-iron, steel, or copper pipes
- (4) Steel conduit or tubing

8.3.5.1.3 Firestop systems and devices shall have an F rating of at least 1 hour, but not less than the required fire-resistive rating of the fire barrier penetrated.

8.3.5.1.4 Penetrations in fire-rated horizontal assemblies shall be required to have a T rating of at least 1 hour, but not less than the rating of the horizontal assembly, and shall not be required for the following:

- (1) Floor penetrations contained within the cavity of a wall assembly
- (2) Penetrations through floors or floor assemblies where the penetration is not in direct contact with combustible material

8.3.5.2 Sleeves. Where the penetrating item uses a sleeve to penetrate the wall or floor, the sleeve shall be securely set in the wall or floor, and the space between the item and the sleeve shall be filled with a material that complies with 8.3.5.1.

8.3.5.3 Insulation and Coverings. Insulation and coverings for penetrating items shall not pass through the wall or floor unless the insulation or covering has been tested as part of the firestop system or device.

8.3.5.4 Transmission of Vibrations. Where designs take transmission of vibrations into consideration, any vibration isolation shall meet one of the following conditions:

- (1) It shall be provided on either side of the wall or floor.
- (2) It shall be designed for the specific purpose.

8.3.5.5 Transitions.

8.3.5.5.1 Where piping penetrates a fire resistance-rated wall or floor assembly, combustible piping shall not connect to noncombustible piping within 915 mm (36 in.) of the firestop system or device without demonstration that the transition will not reduce the fire resistance rating, except in the case of previously approved installations.

8.3.5.5.2 Unshielded couplings shall not be used to connect noncombustible piping to combustible piping unless it can be demonstrated that the transition complies with the fire-resistive requirements of 8.3.5.5.

8.3.5.6 Membrane Penetrations.

8.3.5.6.1 Membrane penetrations for cables, cable trays, conduits, pipes, tubes, combustion vents and exhaust vents, wires, and similar items to accommodate electrical, mechanical, plumbing, and communications systems that pass through a membrane of a wall, floor, or floor/ceiling assembly constructed as a fire barrier shall be protected by a firestop system or device and shall comply with 8.3.5.1 through 8.3.5.5.2.

8.3.5.6.2 The firestop system or device shall be tested in accordance with ASTM E-814 or ANSI/UL 1479 at a minimum positive pressure differential of 2.5 N/m² (0.01 in. water column) between the exposed and the unexposed surface of the test assembly, unless one of the following is met:

- (1) Membrane penetrations of ceilings that are not an integral part of a fire resistance-rated floor/ceiling or roof/ceiling assembly shall be permitted.
- (2) Membrane penetrations of steel, ferrous, or copper conduits, pipes, tubes, or combustion vents or exhaust vents shall be permitted where the annular space is protected with an approved material, and the aggregate area of the openings does not exceed 0.06 m² (0.7 ft²) in any 9.3 m² (100 ft²) of ceiling area.

(3) Electrical outlet boxes and fittings shall be permitted, provided that such devices are listed for use in fire resistance-rated assemblies and are installed in accordance with their listing.

(4) The annular space created by the membrane penetration of a fire sprinkler shall be permitted, provided that the space is covered by a metal escutcheon plate.

8.3.5.6.3 Where walls or partitions are required to have a fire resistance rating of not less than 1 hour, recessed fixtures shall be installed in the wall or partition in such a manner that the required fire resistance is not reduced, unless one of the following is met:

(1) Any steel electrical box not exceeding 0.01 m² (0.1 ft²) shall be permitted where the aggregate area of the openings provided for the boxes does not exceed 0.06 m² (0.7 ft²) in any 9.3 m² (100 ft²) of wall area, and, where outlet boxes are installed on opposite sides of the wall, the boxes shall be separated by one of the following:

- (a) Horizontal distance of not less than 610 mm (24 in.)
- (b) Horizontal distance of not less than the depth of the wall cavity, where the wall cavity is filled with cellulose loose-fill, rock wool, or slag wool insulation
- (c) *Solid fireblocking
- (d) Other listed materials and methods

(2) Membrane penetrations for any listed electrical outlet box made of any material shall be permitted, provided that such boxes have been tested for use in fire resistance-rated assemblies and are installed in accordance with the instructions included in the listing.

(3) The annular space created by the membrane penetration of a fire sprinkler shall be permitted, provided that the space is covered by a metal escutcheon plate.

8.3.5.7 Openings for Air-Handling Ductwork. Openings in fire barriers for air-handling ductwork or air movement shall be protected in accordance with 9.2.1.

8.4 Smoke Partitions.

8.4.1* General. Where required elsewhere in this *Code*, smoke partitions shall be provided to limit the transfer of smoke.

8.4.2 Continuity. The following shall apply to smoke partitions:

(1) They shall extend from the floor to the underside of the floor or roof deck above, through any concealed spaces, such as those above suspended ceilings, and through interstitial structural and mechanical spaces.

(2)*They shall be permitted to extend from the floor to the underside of a monolithic or suspended ceiling system where the following conditions are met:

- (a) The ceiling system forms a continuous membrane.
- (b) A smoke-tight joint is provided between the top of the smoke partition and the bottom of the suspended ceiling.
- (c) The space above the ceiling is not used as a plenum.

(3) Smoke partitions enclosing hazardous areas shall be permitted to terminate at the underside of a monolithic or suspended ceiling system where the following conditions are met:

- (a) The ceiling system forms a continuous membrane.
- (b) A smoke-tight joint is provided between the top of the smoke partition and the bottom of the suspended ceiling.
- (c) Where the space above the ceiling is used as a plenum, return grilles from the hazardous area into the plenums are not permitted.

8.4.3 Opening Protectives.

8.4.3.1 Doors in smoke partitions shall comply with 8.4.3.2 through 8.4.3.5.

8.4.3.2 Doors shall comply with the provisions of 7.2.1.

8.4.3.3 Doors shall not include louvers.

8.4.3.4* Door clearances shall be in accordance with NFPA 80, *Standard for Fire Doors and Fire Windows*.

8.4.3.5 Doors shall be self-closing or automatic-closing in accordance with 7.2.1.8.

8.4.4 Penetrations. The provisions of 8.4.4 shall govern the materials and methods of construction used to protect through-penetrations and membrane penetrations of smoke partitions.

8.4.4.1 Penetrations for cables, cable trays, conduits, pipes, tubes, vents, wires, and similar items to accommodate electrical, mechanical, plumbing, and communications systems that pass through a smoke partition shall be protected by a system or material that is capable of limiting the transfer of smoke.

8.4.4.2 Where designs take transmission of vibrations into consideration, any vibration isolation shall meet one of the following conditions:

- (1) It shall be provided on either side of the smoke partition.
- (2) It shall be designed for the specific purpose.

8.4.5 Joints.

8.4.5.1 The provisions of 8.4.5 shall govern the materials and methods of construction used to protect joints in between and at the perimeter of smoke partitions or, where smoke partitions meet other smoke partitions, the floor or roof deck above, or the outside walls. The provisions of 8.4.5 shall not apply to approved existing materials and methods of construction used to protect existing joints in smoke partitions, unless otherwise required by Chapter 12 through Chapter 42.

8.4.5.2 Joints made within or at the perimeter of smoke partitions shall be protected with a joint system that is capable of limiting the transfer of smoke.

8.4.6 Air-Transfer Openings.

8.4.6.1 General. The provisions of 8.4.6 shall govern the materials and methods of construction used to protect air-transfer openings in smoke partitions.

8.4.6.2* Smoke Dampers. Air-transfer openings in smoke partitions shall be provided with approved smoke dampers designed and tested in accordance with the requirements of UL 555S, *Standard for Smoke Dampers*, to limit the transfer of smoke.

8.4.6.3 Smoke Damper Ratings. Smoke damper leakage ratings shall be not less than Class II. Elevated temperature ratings shall be not less than 140°C (250°F).

8.4.6.4 Smoke Detectors. Dampers in air-transfer openings shall close upon detection of smoke by approved smoke detectors installed in accordance with NFPA 72®, *National Fire Alarm Code*®.

8.5 Smoke Barriers.

8.5.1* General. Where required by Chapter 12 through Chapter 42, smoke barriers shall be provided to subdivide building spaces for the purpose of restricting the movement of smoke.

8.5.2* Continuity.

8.5.2.1 Smoke barriers required by this *Code* shall be continuous from an outside wall to an outside wall, from a floor to a floor, or from a smoke barrier to a smoke barrier, or a combination thereof.

8.5.2.2 Smoke barriers shall be continuous through all concealed spaces, such as those found above a ceiling, including interstitial spaces.

8.5.2.3 A smoke barrier required for an occupied space below an interstitial space shall not be required to extend through the interstitial space, provided that the construction assembly forming the bottom of the interstitial space provides resistance to the passage of smoke equal to that provided by the smoke barrier.

8.5.3 Fire Barrier Used as Smoke Barrier. A fire barrier shall be permitted to be used as a smoke barrier, provided that it meets the requirements of 8.5.3 through 8.5.6.

8.5.3.1* Doors in smoke barriers shall close the opening leaving only the minimum clearance necessary for proper operation and shall be without undercuts, louvers, or grilles.

8.5.3.2 Where required by Chapter 12 through Chapter 42, doors in smoke barriers shall comply with the requirements of 8.2.2.4.

8.5.3.3 Latching hardware shall not be required on doors in smoke barriers where permitted by Chapter 12 through Chapter 42.

8.5.3.4* Doors in smoke barriers shall be self-closing or automatic-closing in accordance with 7.2.1.8 and shall comply with the provisions of 7.2.1.

8.5.3.5 Fire window assemblies shall comply with 8.3.3.

8.5.4 Ducts and Air-Transfer Openings.

8.5.4.1 General. The provisions of 8.5.4 shall govern the materials and methods of construction used to protect ducts and air-transfer openings in smoke barriers.

8.5.4.2 Smoke Dampers. Where a smoke barrier is penetrated by a duct or air-transfer opening, a smoke damper designed and tested in accordance with the requirements of UL 555S shall be installed. Where a smoke barrier is also constructed as a fire barrier, a combination fire/smoke damper designed and tested in accordance with the requirements of UL 555, *Standard for Fire Dampers*, and UL 555S shall be installed.

8.5.4.3 Smoke Damper Exemptions. Smoke dampers shall not be required under any of the following conditions:

- (1) Where specifically exempted by provisions in Chapter 12 through Chapter 42
- (2) Where ducts or air-transfer openings are part of an engineered smoke control system
- (3) Where the air in ducts continues to move and the air-handling system installed is arranged to prevent recirculation of exhaust or return air under fire emergency conditions
- (4) Where the air inlet or outlet openings in ducts are limited to a single smoke compartment
- (5) Where ducts penetrate floors that serve as smoke barriers

8.5.4.4 Installation.

8.5.4.4.1 Air-conditioning, heating, ventilating ductwork, and related equipment, including smoke dampers and combination

fire and smoke dampers, shall be installed in accordance with NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*.

8.5.4.4.2 The equipment specified in 8.5.4.4.1 shall be installed in accordance with the requirements of 8.5.4.4, the manufacturer's installation instructions, and the equipment listing.

8.5.4.5 Access and Identification. Access to the dampers shall be provided for inspection, testing, and maintenance. The access openings shall not reduce the fire resistance rating of the fire barrier assembly.

8.5.4.6 Smoke Damper Ratings. Smoke damper leakage ratings shall be not less than Class II. Elevated temperature ratings shall be not less than 140°C (250°F).

8.5.4.7 Smoke Detectors.

8.5.4.7.1 Required smoke dampers in ducts penetrating smoke barriers shall close upon detection of smoke by approved smoke detectors in accordance with *NFPA 72®*, *National Fire Alarm Code®*, unless one of the following conditions exists:

- (1) The ducts penetrate smoke barriers above the smoke barrier doors and the door release detector actuates the damper.
- (2) Approved smoke detector installations are located within the ducts in existing installations.

8.5.4.7.2 Where a duct is provided on one side of the smoke barrier, the smoke detectors on the duct side shall be in accordance with 8.5.4.7.1.

8.5.4.7.3 Required smoke dampers in air-transfer openings shall close upon detection of smoke by approved smoke detectors in accordance with *NFPA 72®*, *National Fire Alarm Code®*.

8.5.5 Penetrations.

8.5.5.1 The provisions of 8.5.5 shall govern the materials and methods of construction used to protect through-penetrations and membrane penetrations of smoke barriers.

8.5.5.2 Penetrations for cables, cable trays, conduits, pipes, tubes, vents, wires, and similar items to accommodate electrical, mechanical, plumbing, and communications systems that pass through a wall, floor, or floor/ceiling assembly constructed as a smoke barrier, or through the ceiling membrane of the roof/ceiling of a smoke barrier assembly, shall be protected by a system or material capable of restricting the transfer of smoke.

8.5.5.3 Where a smoke barrier is also constructed as a fire barrier, the penetrations shall be protected in accordance with the requirements of 8.3.5 to limit the spread of fire for a time period equal to the fire resistance rating of the assembly and 8.5.5 to restrict the transfer of smoke, unless the requirements of 8.5.5.4 are met.

8.5.5.4 Where sprinklers penetrate a single membrane of a fire resistance-rated assembly in buildings equipped throughout with an approved automatic fire sprinkler system, non-combustible escutcheon plates shall be permitted, provided that the space around each sprinkler penetration does not exceed 13 mm (½ in.), measured between the edge of the membrane and the sprinkler.

8.5.5.5 Where the penetrating item uses a sleeve to penetrate the smoke barrier, the sleeve shall be securely set in the smoke barrier, and the space between the item and the sleeve shall be filled with a material capable of restricting the transfer of smoke.

8.5.5.6 Where designs take transmission of vibrations into consideration, any vibration isolation shall meet one of the following conditions:

- (1) It shall be provided on either side of the fire barrier.
- (2) It shall be designed for the specific purpose.

8.5.6 Joints.

8.5.6.1 The provisions of 8.5.6 shall govern the materials and methods of construction used to protect joints in between and at the perimeter of smoke barriers or, where smoke barriers meet other smoke barriers, the floor or roof deck above, or the outside walls. The provisions of 8.5.6 shall not apply to approved existing materials and methods of construction used to protect existing joints in smoke barriers, unless otherwise required by Chapter 12 through Chapter 42.

8.5.6.2 Joints made within or at the perimeter of smoke barriers shall be protected with a joint system that is capable of limiting the transfer of smoke.

8.5.6.3 Joints made within or between smoke barriers shall be protected with a smoke-tight joint system that is capable of limiting the transfer of smoke.

8.5.6.4 Smoke barriers that are also constructed as fire barriers shall be protected with a joint system that is designed and tested to resist the spread of fire for a time period equal to the required fire resistance rating of the assembly and restrict the transfer of smoke.

8.5.6.5 Testing of the joint system in a smoke barrier that also serves as fire barrier shall be representative of the actual installation suitable for the required engineering demand without compromising the fire resistance rating of the assembly or the structural integrity of the assembly.

8.6 Vertical Openings.

8.6.1 Floor Smoke Barriers. Every floor that separates stories in a building shall meet one of the following criteria:

- (1) It shall be constructed as a smoke barrier to form a basic degree of compartmentation. (See 3.3.23.2.)
- (2) It shall have openings as permitted by 8.6.6, 8.6.7, 8.6.8, or Chapter 11 through Chapter 42.

8.6.2* Continuity. Openings through floors shall be enclosed with fire barrier walls, shall be continuous from floor to floor, or floor to roof, and shall be protected as appropriate for the fire resistance rating of the barrier.

8.6.3 Continuity Exemptions. The requirements of 8.6.2 shall not apply where otherwise permitted by the following:

- (1) Where pneumatic tube conveyors are protected in accordance with 8.3.5.1
- (2) Where specified by 8.6.6, 8.6.7, 8.6.8.1, 8.6.8.2, or Chapter 11 through Chapter 42
- (3) Where escalators and moving walks are protected in accordance with 8.6.8.5 or 8.6.8.6
- (4) Where expansion or seismic joints designed to prevent the penetration of fire and shown to have a fire resistance rating of not less than that required for the floor when tested in accordance with ANSI/UL 2079, *Test of Fire Resistance of Building Joint Systems*
- (5) Where existing mail chutes meet one of the following criteria:
 - (a) The cross-sectional area does not exceed 0.01 m² (0.1 ft²).
 - (b) The building is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

8.6.4 Shafts. Shafts that do not extend to the bottom or the top of the building or structure shall comply with either 8.6.4.1 or 8.6.4.2.

8.6.4.1 Shafts shall be enclosed at the lowest or highest level of the shaft, respectively, with construction in accordance with 8.6.5.

8.6.4.2 Shafts shall be permitted to terminate in a room or space having a use related to the purpose of the shaft, provided that the room or space is separated from the remainder of the building by construction having a fire resistance rating and opening protectives in accordance with 8.6.5 and 8.3.4.

8.6.4.3 Shafts that do not extend to the bottom or top of the building or structure shall be permitted to be protected by approved fire dampers installed in accordance with their listing at the lowest or highest floor level, as applicable, within the shaft enclosure.

8.6.5* Required Fire Resistance Rating. The fire resistance rating for the enclosure of floor openings shall be not less than as follows (*see 7.1.3.2.1 for enclosure of exits*):

- (1) Enclosures connecting four stories or more in new construction — 2-hour fire barriers
- (2) Other enclosures in new construction — 1-hour fire barriers
- (3) Existing enclosures in existing buildings — ½-hour fire barriers
- (4) Enclosures for lodging and rooming houses — as specified in Chapter 26
- (5) Enclosures for new hotels — as specified in Chapter 28
- (6) Enclosures for new apartment buildings — as specified in Chapter 30

8.6.6 Communicating Space. Unless prohibited by Chapter 12 through Chapter 42, unenclosed floor openings forming a communicating space between floor levels shall be permitted, provided that the following conditions are met:

- (1) The communicating space does not connect more than three contiguous stories.
- (2) The lowest or next-to-lowest story within the communicating space is a street floor.
- (3) The entire floor area of the communicating space is open and unobstructed, such that a fire in any part of the space will be readily obvious to the occupants of the space prior to the time it becomes an occupant hazard.
- (4) The communicating space is separated from the remainder of the building by fire barriers with not less than a 1-hour fire resistance rating, unless one of the following is met:
 - (a) In buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7, a smoke barrier in accordance with Section 8.5 shall be permitted to serve as the separation required by 8.6.6(4).
 - (b) The requirement of 8.6.6(4) shall not apply to fully sprinklered residential housing units of detention and correctional occupancies in accordance with 22.3.1(2) and 23.3.1.1(2)
- (5) The communicating space has ordinary hazard contents protected throughout by an approved automatic sprinkler system in accordance with Section 9.7 or has only low hazard contents. (*See 6.2.2.*)
- (6) Egress capacity is sufficient to allow all the occupants of all levels within the communicating space to simultaneously egress the communicating space by considering it as single floor area in determining the required egress capacity.

(7)*Each occupant within the communicating space has access to not less than one exit without having to traverse another story within the communicating space.

(8) Each occupant not in the communicating space has access to not less than one exit without having to enter the communicating space.

8.6.7* Atriums. Unless prohibited by Chapter 12 through Chapter 42, an atrium shall be permitted, provided that the following conditions are met:

- (1) The atrium is separated from the adjacent spaces by fire barriers with not less than a 1-hour fire resistance rating with opening protectives for corridor walls, unless one of the following is met:
 - (a) The requirement of 8.6.7(1) shall not apply to existing, previously approved atriums.
 - (b) Any number of levels of the building shall be permitted to open directly to the atrium without enclosure based on the results of the engineering analysis required in 8.6.7(5).
- (c)*Glass walls and inoperable windows shall be permitted in lieu of the fire barriers where all the following are met:
 - i. Automatic sprinklers are spaced along both sides of the glass wall and the inoperable window at intervals not to exceed 1830 mm (72 in.).
 - ii. The automatic sprinklers specified in 8.6.7(1)(c)i are located at a distance from the glass wall not to exceed 305 mm (12 in.) and arranged so that the entire surface of the glass is wet upon operation of the sprinklers.
 - iii. The glass wall is of tempered, wired, or laminated glass held in place by a gasket system that allows the glass framing system to deflect without breaking (loading) the glass before the sprinklers operate.
 - iv. The automatic sprinklers required by 8.6.7(1)(c)i are not required on the atrium side of the glass wall and the inoperable windows where there is no walkway or other floor area on the atrium side above the main floor level.
 - v. Doors in the glass walls shall be glass or other material that resists the passage of smoke.
 - vi. Doors in the glass walls shall be self-closing or automatic-closing upon detection of smoke.
- (2) Access to exits is permitted to be within the atrium, and exit discharge in accordance with 7.7.2 is permitted to be within the atrium.
- (3) The occupancy within the atrium meets the specifications for classification as low or ordinary hazard contents. (*See 6.2.2.*)
- (4) The entire building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (5)*For other than existing, previously approved atriums, an engineering analysis is performed that demonstrates that the building is designed to keep the smoke layer interface above the highest unprotected opening to adjoining spaces, or 1830 mm (72 in.) above the highest floor level of exit access open to the atrium, for a period equal to 1.5 times the calculated egress time or 20 minutes, whichever is greater.

(6)*In other than existing, previously approved atriums, where an engineered smoke control system is installed to meet the requirements of 8.6.7(5), the system is independently activated by each of the following:

- (a) The required automatic sprinkler system
- (b) Manual controls that are readily accessible to the fire department

8.6.8 Convenience Openings.

8.6.8.1 A vertical opening serving as other than an exit enclosure, connecting only two adjacent stories, and piercing only one floor shall be permitted to be open to one of the two stories.

8.6.8.2 Where permitted by Chapter 12 through Chapter 42, unenclosed vertical openings not concealed within the building construction shall be permitted as follows:

- (1) Such openings shall connect not more than two adjacent stories (one floor pierced only).
- (2) Such openings shall be separated from unprotected vertical openings serving other floors by a barrier complying with 8.6.5.
- (3) Such openings shall be separated from corridors.
- (4)*Such openings shall not serve as a required means of egress.

8.6.8.3 For other than existing hoistways in existing buildings, elevator cars located within a building shall be enclosed as follows:

- (1) Where there are three or fewer elevator cars in a building, they shall be permitted to be located within the same hoistway enclosure.
- (2) Where there are four elevator cars in the building, they shall be divided in such a manner that not less than two separate hoistway enclosures are provided.
- (3) Where there are more than four elevator cars in the building, the number of elevator cars located within a single hoistway enclosure shall not exceed four.

8.6.8.4 Service openings for conveyors, elevators, and dumbwaiters, where required to be open on more than one story at the same time for purposes of operation, shall be provided with closing devices in accordance with 7.2.1.8.

8.6.8.5 Any escalators and moving walks serving as a required exit in existing buildings shall be enclosed in the same manner as exit stairways. (See 7.1.3.2.)

8.6.8.6 Any escalators and moving walks not constituting an exit shall have their floor openings enclosed or protected as required for other vertical openings, unless otherwise permitted by the following:

- (1) The requirement of 8.6.8.6 shall not apply to escalators in large open areas, such as atriums and enclosed shopping malls.
- (2)*In buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7, escalator and moving walk openings shall be permitted to be protected in accordance with the method detailed in NFPA 13, *Standard for the Installation of Sprinkler Systems*, or in accordance with a method approved by the authority having jurisdiction.
- (3) In buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7, escalator and moving walk openings shall be permitted to be protected by rolling steel shutters appropriate for the fire resistance rating of the vertical opening as follows:

- (a) The shutters shall close automatically and independently of each other upon smoke detection and sprinkler operation.
- (b) A manual means of operating and testing the operation of the shutter shall be provided.
- (c) The shutters shall be operated not less than once a week to ensure that they remain in proper operating condition.
- (d) The shutters shall operate at a speed not to exceed 0.15 m/s (30 ft/min) and shall be equipped with a sensitive leading edge.
- (e) The leading edge shall arrest the progress of a moving shutter and cause it to retract a distance of approximately 150 mm (6 in.) upon the application of a force not exceeding 90 N (20 lbf) applied to the surface of the leading edge.
- (f) The shutter, following the retraction specified in 8.6.8.6(3)(e), shall continue to close.
- (g) The operating mechanism for the rolling shutter shall be provided with standby power complying with the provisions of NFPA 70, *National Electrical Code*®.

8.6.9 Mezzanines.

8.6.9.1 General.

8.6.9.1.1 A mezzanine shall not be included as a story for the purpose of determining the allowable number of stories in a building.

8.6.9.1.2 Multilevel residential housing areas in detention and correctional occupancies in accordance with Chapter 22 and Chapter 23 shall be exempt from the provisions of 8.6.9.2 and 8.6.9.3.

8.6.9.2 Area Limitations.

8.6.9.2.1 The aggregate area of mezzanines located within a room, other than those located in special purpose industrial occupancies, shall not exceed one-third the open area of the room in which the mezzanines are located. Enclosed space shall not be included in a determination of the size of the room in which the mezzanine is located.

8.6.9.2.2 No limit on the number of mezzanines in a room shall be required.

8.6.9.2.3 For purposes of determining the allowable mezzanine area, the aggregate area of the mezzanines shall not be included in the area of the room.

8.6.9.3 Openness. Mezzanines shall be in accordance with 8.6.9.3.1 or 8.6.9.3.2.

8.6.9.3.1 All portions of a mezzanine, other than walls not more than 1065 mm (42 in.) high, columns, and posts, shall be open to and unobstructed from the room in which the mezzanine is located, unless the occupant load of the aggregate area of the enclosed space does not exceed 10.

8.6.9.3.2 A mezzanine having two or more means of egress shall not be required to open into the room in which it is located if not less than one of the means of egress provides direct access from the enclosed area to an exit at the mezzanine level.

8.6.10 Concealed Spaces and Draft Stops.

8.6.10.1 Any concealed combustible space in which building materials having a flame spread index greater than Class A are exposed shall be draftstopped as follows:

- (1) Every exterior and interior wall and partition shall be firestopped at each floor level, at the top story ceiling level, and at the level of support for roofs.

- (2) Every unoccupied attic space shall be subdivided by draftstops into areas not to exceed 280 m² (3000 ft²).
- (3) Any concealed space between the ceiling and the floor or roof above shall be draftstopped for the full depth of the space along the line of support for the floor or roof structural members and, if necessary, at other locations to form areas not to exceed 93 m² (1000 ft²) for any space between the ceiling and floor, and 280 m² (3000 ft²) for any space between the ceiling and roof.

8.6.10.2 The requirements of 8.6.10.1 shall not apply where any of the following conditions are met:

- (1) Where the space is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7
- (2) Where concealed spaces serve as plenums (*see NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems*)
- (3) Where the installation is an existing installation

8.6.10.3 Draftstopping materials shall be not less than 13-mm (½-in.) thick gypsum board, 12-mm (½-in.) thick plywood, or other approved materials that are adequately supported.

8.6.10.4 The integrity of all draftstops shall be maintained.

8.6.10.5 In existing buildings, firestopping and draftstopping shall be provided as required by Chapter 12 through Chapter 42.

8.7 Special Hazard Protection.

8.7.1 General.

8.7.1.1* Protection from any area having a degree of hazard greater than that normal to the general occupancy of the building or structure shall be provided by one of the following means:

- (1) Enclosing the area with a fire barrier without windows that has a 1-hour fire resistance rating in accordance with Section 8.3
- (2) Protecting the area with automatic extinguishing systems in accordance with Section 9.7
- (3) Applying both 8.7.1.1(1) and 8.7.1.1(2) where the hazard is severe or where otherwise specified by Chapter 12 through Chapter 42

8.7.1.2 In new construction, where protection is provided with automatic extinguishing systems without fire-resistive separation, the space protected shall be enclosed with smoke partitions in accordance with Section 8.4, unless otherwise permitted by one of the following conditions:

- (1) Where mercantile occupancy general storage areas and stockrooms are protected by automatic sprinklers in accordance with Section 9.7
- (2) Where hazardous areas in industrial occupancies are protected by automatic extinguishing systems in accordance with 40.3.2

8.7.1.3 Doors in barriers required to have a fire resistance rating shall have a ¾-hour fire protection rating and shall be self-closing or automatic-closing in accordance with 7.2.1.8.

8.7.2* Explosion Protection. Where hazardous processes or storage is of such a character as to introduce an explosion potential, an explosion venting system or an explosion suppression system specifically designed for the hazard involved shall be provided.

8.7.3 Flammable Liquids and Gases.

8.7.3.1 The storage and handling of flammable liquids or gases shall be in accordance with the following applicable standards:

- (1) NFPA 30, *Flammable and Combustible Liquids Code*
- (2) NFPA 54, *National Fuel Gas Code*
- (3) NFPA 58, *Liquefied Petroleum Gas Code*

8.7.3.2* No storage or handling of flammable liquids or gases shall be permitted in any location where such storage would jeopardize egress from the structure, unless otherwise permitted by 8.7.3.1.

8.7.4 Laboratories.

8.7.4.1 Laboratories that use chemicals shall comply with NFPA 45, *Standard on Fire Protection for Laboratories Using Chemicals*, unless otherwise modified by other provisions of this Code.

8.7.4.2 Laboratories in health care occupancies and medical and dental offices shall comply with NFPA 99, *Standard for Health Care Facilities*.

8.7.5* Hyperbaric Facilities. All occupancies containing hyperbaric facilities shall comply with NFPA 99, *Standard for Health Care Facilities*, Chapter 19, unless otherwise modified by other provisions of this Code.

Chapter 9 Building Service and Fire Protection Equipment

9.1 Utilities.

9.1.1 Gas. Equipment using gas and related gas piping shall be in accordance with NFPA 54, *National Fuel Gas Code*, or NFPA 58, *Liquefied Petroleum Gas Code*, unless such installations are approved existing installations, which shall be permitted to be continued in service.

9.1.2 Electrical Systems. Electrical wiring and equipment shall be in accordance with NFPA 70, *National Electrical Code*®, unless such installations are approved existing installations, which shall be permitted to be continued in service.

9.1.3 Emergency Generators. Emergency generators, where required for compliance with this Code, shall be tested and maintained in accordance with NFPA 110, *Standard for Emergency and Standby Power Systems*.

9.1.4 Stored Electrical Energy Systems. Stored electrical energy systems shall be maintained in accordance with NFPA 111, *Standard on Stored Electrical Energy Emergency and Standby Power Systems*.

9.2 Heating, Ventilating, and Air-Conditioning.

9.2.1 Air-Conditioning, Heating, Ventilating Ductwork, and Related Equipment. Air-conditioning, heating, ventilating ductwork, and related equipment shall be in accordance with NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, or NFPA 90B, *Standard for the Installation of Warm Air Heating and Air-Conditioning Systems*, as applicable, unless such installations are approved existing installations, which shall be permitted to be continued in service.

9.2.2 Ventilating or Heat-Producing Equipment. Ventilating or heat-producing equipment shall be in accordance with NFPA 91, *Standard for Exhaust Systems for Air Conveying of Vapors*,

Gases, Mists, and Noncombustible Particulate Solids; NFPA 211, *Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances*; NFPA 31, *Standard for the Installation of Oil-Burning Equipment*; NFPA 54, *National Fuel Gas Code*; or NFPA 70, *National Electrical Code*®, as applicable, unless such installations are approved existing installations, which shall be permitted to be continued in service.

9.2.3 Commercial Cooking Equipment. Commercial cooking equipment shall be in accordance with NFPA 96, *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*, unless such installation are approved existing installations, which shall be permitted to be continued in service.

9.2.4 Ventilating Systems in Laboratories Using Chemicals. Ventilating systems in laboratories using chemicals shall be in accordance with NFPA 45, *Standard on Fire Protection for Laboratories Using Chemicals*, or NFPA 99, *Standard for Health Care Facilities*, as appropriate.

9.3 Smoke Control.

9.3.1* Where required by the provisions of another section of this *Code*, smoke control systems shall be installed, inspected, tested, and maintained in accordance with nationally recognized standards, engineering guides, or recommended practices.

9.3.2 The engineer of record shall clearly identify the intent of the system, the design method used, the appropriateness of the method used, and the required means of inspecting, testing, and maintaining the system.

9.3.3 Acceptance testing shall be performed by a special inspector in accordance with Section 9.8.

9.3.4 Smoke Control System Operation.

9.3.4.1 Floor- or zone-dependent smoke control systems shall be automatically activated by sprinkler waterflow or smoke detection systems.

9.3.4.2 Means for manual operation of smoke control systems shall be provided at an approved location.

9.4 Elevators, Escalators, and Conveyors.

9.4.1* General. An elevator, other than an elevator in accordance with 7.2.13, shall not be considered a component in a required means of egress but shall be permitted as a component in an accessible means of egress.

9.4.2 Code Compliance.

9.4.2.1 Except as modified herein, new elevators, escalators, dumbwaiters, and moving walks shall be in accordance with the requirements of ASME A17.1, *Safety Code for Elevators and Escalators*.

9.4.2.2 Except as modified herein, existing elevators, escalators, dumbwaiters, and moving walks shall conform to the requirements of ASME A17.3, *Safety Code for Existing Elevators and Escalators*.

9.4.3 Fire Fighters' Emergency Operations.

9.4.3.1 All new elevators shall conform to the fire fighters' emergency operations requirements of ASME A17.1, *Safety Code for Elevators and Escalators*.

9.4.3.2 All existing elevators having a travel distance of 7620 mm (300 in.) or more above or below the level that best serves the needs of emergency personnel for fire fighting or

rescue purposes shall conform to the fire fighters' emergency operations requirements of ASME A17.3, *Safety Code for Existing Elevators and Escalators*.

9.4.4 Number of Cars. The number of elevator cars permitted in a hoistway shall be in accordance with 8.6.8.3.

9.4.5* Elevator Machine Rooms. Elevator machine rooms that contain solid-state equipment for elevators, other than existing elevators, having a travel distance exceeding 15 m (50 ft) above the level of exit discharge or exceeding 9150 mm (360 in.) below the level of exit discharge shall be provided with independent ventilation or air-conditioning systems required to maintain temperature during fire fighters' service operation for elevator operation (*see 9.4.3*). The operating temperature shall be established by the elevator equipment manufacturer's specifications. When standby power is connected to the elevator, the machine room ventilation or air-conditioning shall be connected to standby power.

9.4.6 Elevator Testing. Elevators shall be subject to periodic inspections and tests as specified in ASME A17.1, *Safety Code for Elevators and Escalators*. All elevators equipped with fire fighters' emergency operations in accordance with 9.4.3 shall be subject to a monthly operation with a written record of the findings made and kept on the premises as required by ASME A17.1, *Safety Code for Elevators and Escalators*.

9.4.7 Openings. Conveyors, elevators, dumbwaiters, and pneumatic conveyors serving various stories of a building shall not open to an exit.

9.5 Rubbish Chutes, Incinerators, and Laundry Chutes.

9.5.1 Enclosure.

9.5.1.1 Rubbish chutes and laundry chutes shall be separately enclosed by walls or partitions in accordance with the provisions of Section 8.3.

9.5.1.2 Inlet openings serving chutes shall be protected in accordance with Section 8.3.

9.5.1.3 The doors of chutes specified in 9.5.1.2 shall open only to a room that is designed and used exclusively for accessing the chute opening.

9.5.1.4 The room used for accessing the chute opening shall be separated from other spaces in accordance with Section 8.7.

9.5.1.5 The requirements of 9.5.1.1 through 9.5.1.4 shall not apply where otherwise permitted by the following:

- (1) Existing installations having properly enclosed service chutes and properly installed and maintained service openings shall be permitted to have inlets open to a corridor or normally occupied space.
- (2) Rubbish chutes and laundry chutes shall be permitted to open into rooms not exceeding 37 m² (400 ft²) that are used for storage, provided that the room is protected by automatic sprinklers.

9.5.2 Installation and Maintenance. Rubbish chutes, laundry chutes, and incinerators shall be installed and maintained in accordance with NFPA 82, *Standard on Incinerators and Waste and Linen Handling Systems and Equipment*, unless such installations are approved existing installations, which shall be permitted to be continued in service.

9.6 Fire Detection, Alarm, and Communications Systems.

9.6.1* General.

9.6.1.1 The provisions of Section 9.6 shall apply only where specifically required by another section of this *Code*.

9.6.1.2 Fire detection, alarm, and communications systems installed to make use of an alternative permitted by this *Code* shall be considered required systems and shall meet the provisions of this *Code* applicable to required systems.

9.6.1.3 A fire alarm system required for life safety shall be installed, tested, and maintained in accordance with the applicable requirements of NFPA 70, *National Electrical Code*®, and NFPA 72®, *National Fire Alarm Code*®, unless it is an approved existing installation, which shall be permitted to be continued in use.

9.6.1.4 All systems and components shall be approved for the purpose for which they are installed.

9.6.1.5 Fire alarm system installation wiring or other transmission paths shall be monitored for integrity in accordance with 9.6.1.3.

9.6.1.6* To ensure operational integrity, the fire alarm system shall have an approved maintenance and testing program complying with the applicable requirements of NFPA 70, *National Electrical Code*®, and NFPA 72®, *National Fire Alarm Code*®.

9.6.1.7* Where a required fire alarm system is out of service for more than 4 hours in a 24-hour period, the authority having jurisdiction shall be notified, and the building shall be evacuated or an approved fire watch shall be provided for all parties left unprotected by the shutdown until the fire alarm system has been returned to service.

9.6.1.8 For the purposes of this *Code*, a complete fire alarm system shall provide functions for initiation, notification, and control, which shall perform as follows:

- (1) The initiation function provides the input signal to the system.
- (2) The notification function is the means by which the system advises that human action is required in response to a particular condition.
- (3) The control function provides outputs to control building equipment to enhance protection of life.

9.6.1.9 All required documentation regarding the design of fire detection, alarm, and communications systems and the procedures for maintenance, inspection, and testing of fire detection, alarm, and communications systems shall be maintained at an approved, secured location for the life of the system.

9.6.1.10 Testing and maintenance records required by NFPA 72®, *National Fire Alarm Code*®, shall be maintained at an approved, secured location.

9.6.2 Signal Initiation.

9.6.2.1 Where required by other sections of this *Code*, actuation of the complete fire alarm system shall be initiated by, but shall not be limited to, any or all of the following means:

- (1) Manual fire alarm initiation
- (2) Automatic detection
- (3) Extinguishing system operation

9.6.2.2 Manual fire alarm boxes shall be approved for the particular application and shall be used only for fire-protective signaling purposes. Combination fire alarm and guard's tour stations shall be acceptable.

9.6.2.3 A manual fire alarm box shall be provided in the natural exit access path near each required exit from an area, unless modified by another section of this *Code*.

9.6.2.4* Additional manual fire alarm boxes shall be located so that, on any given floor in any part of the building, no horizontal distance on that floor exceeding 60 m (200 ft) shall need to be traversed to reach a manual fire alarm box.

9.6.2.5 For fire alarm systems using automatic fire detection or waterflow detection devices, not less than one manual fire alarm box shall be provided to initiate a fire alarm signal. The manual fire alarm box shall be located where required by the authority having jurisdiction.

9.6.2.6* Each manual fire alarm box on a system shall be accessible, unobstructed, and visible.

9.6.2.7 Where a sprinkler system provides automatic detection and alarm system initiation, it shall be provided with an approved alarm initiation device that operates when the flow of water is equal to or greater than that from a single automatic sprinkler.

9.6.2.8 Where a total (complete) coverage smoke detection system is required by another section of this *Code*, automatic detection of smoke in accordance with NFPA 72®, *National Fire Alarm Code*®, shall be provided in all occupiable areas, common areas, and work spaces in environments that are suitable for proper smoke detector operation.

9.6.2.9 Where a partial smoke detection system is required by another section of this *Code*, automatic detection of smoke in accordance with NFPA 72®, *National Fire Alarm Code*®, shall be provided in all common areas and work spaces, such as corridors, lobbies, storage rooms, equipment rooms, and other tenantless spaces in environments that are suitable for proper smoke detector operation. Selective smoke detection unique to other sections of this *Code* shall be provided as required by those sections.

9.6.2.10 Smoke Alarms.

9.6.2.10.1 Where required by another section of this *Code*, single-station and multiple-station smoke alarms shall be in accordance with NFPA 72®, *National Fire Alarm Code*®. System smoke detectors in accordance with NFPA 72®, *National Fire Alarm Code*®, and arranged to function in the same manner as single-station or multiple-station smoke alarms shall be permitted in lieu of smoke alarms.

9.6.2.10.2 Smoke alarms, other than battery-operated devices as permitted by other sections of this *Code*, or battery-operated devices complying with 9.6.1.3 and the low-power wireless system requirements of NFPA 72®, *National Fire Alarm Code*®, shall receive their operating power from the building electrical system.

9.6.2.10.3* In new construction, where two or more smoke alarms are required within a dwelling unit, suite of rooms, or similar area, they shall be arranged so that operation of any smoke alarm shall cause the alarm in all smoke alarms within the dwelling unit, suite of rooms, or similar area to sound, unless otherwise permitted by the following:

- (1) The requirement of 9.6.2.10.3 shall not apply where permitted by another section of this *Code*.
- (2) The requirement of 9.6.2.10.3 shall not apply to configurations that provide equivalent distribution of the alarm signal.

9.6.2.10.4 The alarms shall sound only within an individual dwelling unit, suite of rooms, or similar area and shall not actuate the building fire alarm system, unless otherwise permitted by the authority having jurisdiction. Remote annunciation shall be permitted.

9.6.2.11 Where required by Chapter 11 through Chapter 42, an automatic fire detection system shall be provided in hazardous areas for initiation of the signaling system.

9.6.3 Occupant Notification.

9.6.3.1 Occupant notification shall be provided to alert occupants of a fire or other emergency where required by other sections of this *Code*.

9.6.3.2 Occupant notification shall be in accordance with 9.6.3.3 through 9.6.3.11, unless otherwise provided in 9.6.3.2.1 through 9.6.3.2.4.

9.6.3.2.1* Elevator lobby, hoistway, and associated machine room smoke detectors used solely for elevator recall, and heat detectors used solely for elevator power shutdown, shall not be required to activate the building evacuation alarm if the power supply and installation wiring to such detectors are monitored by the building fire alarm system, and if the activation of such detectors results in an audible and visible alarm signal at a constantly attended location.

9.6.3.2.2* Smoke detectors used solely for closing dampers or heating, ventilating, and air-conditioning system shutdown shall not be required to activate the building evacuation alarm.

9.6.3.2.3* Detectors located at doors for the exclusive operation of automatic door release shall not be required to activate the building evacuation alarm.

9.6.3.2.4 Detectors in accordance with 22.3.4.3.1(2) and 23.3.4.3.1(2) shall not be required to activate the building evacuation alarm.

9.6.3.3 Where permitted by Chapter 11 through Chapter 42, a presignal system shall be permitted where the initial fire alarm signal is automatically transmitted without delay to a municipal fire department, to a fire brigade (if provided), and to an on-site staff person trained to respond to a fire emergency.

9.6.3.4 Where permitted by Chapter 11 through Chapter 42, a positive alarm sequence shall be permitted, provided that it is in accordance with *NFPA 72®*, *National Fire Alarm Code®*.

9.6.3.5 Unless otherwise provided in 9.6.3.5.1 through 9.6.3.5.6, notification signals for occupants to evacuate shall be audible and visible signals in accordance with *NFPA 72®*, *National Fire Alarm Code®*, and ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*, or other means of notification acceptable to the authority having jurisdiction shall be provided.

9.6.3.5.1 Areas not subject to occupancy by persons who are hearing impaired shall not be required to comply with the provisions for visible signals.

9.6.3.5.2 Visible-only signals shall be provided where specifically permitted in health care occupancies in accordance with the provisions of Chapter 18 and Chapter 19.

9.6.3.5.3 Existing alarm systems shall not be required to comply with the provision for visible signals.

9.6.3.5.4 Visible signals shall not be required in lodging or rooming houses in accordance with the provisions of Chapter 26.

9.6.3.5.5 Visible signals shall not be required in exit stair enclosures.

9.6.3.5.6 Visible signals shall not be required in elevator cars.

9.6.3.6 The general evacuation alarm signal shall operate in accordance with one of the methods prescribed by 9.6.3.6.1 through 9.6.3.6.4.

9.6.3.6.1 The general evacuation alarm signal shall operate throughout the entire building.

9.6.3.6.2* Where total evacuation of occupants is impractical due to building configuration, only the occupants in the affected zones shall be notified initially. Provisions shall be made to selectively notify occupants in other zones to afford orderly evacuation of the entire building.

9.6.3.6.3 Where occupants are incapable of evacuating themselves because of age, physical or mental disabilities, or physical restraint, the private operating mode as described in *NFPA 72®*, *National Fire Alarm Code®*, shall be permitted to be used. Only the attendants and other personnel required to evacuate occupants from a zone, area, floor, or building shall be required to be notified. The notification shall include means to readily identify the zone, area, floor, or building in need of evacuation.

9.6.3.6.4 In mall buildings in accordance with Chapter 36 and Chapter 37, notification within the mall shall be permitted in accordance with 36.4.4.4.3.1(3) and 37.4.4.4.3.1(3).

9.6.3.6.5 The general evacuation signal shall not be required to operate in exit stair enclosures.

9.6.3.6.6 The general evacuation signal shall not be required to operate in elevator cars.

9.6.3.7 Audible alarm notification appliances shall be of such character and so distributed as to be effectively heard above the average ambient sound level that exists under normal conditions of occupancy.

9.6.3.8 Audible alarm notification appliances shall produce signals that are distinctive from audible signals used for other purposes in a given building.

9.6.3.9 Automatically transmitted or live voice evacuation or relocation instructions shall be permitted to be used to notify occupants and shall be in accordance with *NFPA 72®*, *National Fire Alarm Code®*.

9.6.3.10 Unless otherwise permitted by another section of this *Code*, audible and visible fire alarm notification appliances shall comply with either 9.6.3.10.1 or 9.6.3.10.2.

9.6.3.10.1 Audible and visible fire alarm notification appliances shall be used only for fire alarm system or other emergency purposes.

9.6.3.10.2 Voice communication systems shall be permitted to be used for other purposes, subject to the approval of the authority having jurisdiction, if the fire alarm system takes precedence over all other signals.

9.6.3.11 Alarm notification signals shall take precedence over all other signals.

9.6.4 Emergency Forces Notification.

9.6.4.1 Where required by another section of this *Code*, emergency forces notification shall be provided to alert the municipal fire department and fire brigade (if provided) of fire or other emergency.

9.6.4.2 Where fire department notification is required by another section of this *Code*, the fire alarm system shall be arranged to transmit the alarm automatically via any of the following means acceptable to the authority having jurisdiction and shall be in accordance with *NFPA 72®*, *National Fire Alarm Code®*

- (1) Auxiliary alarm system
- (2) Central station connection
- (3) Proprietary system
- (4) Remote station connection

9.6.4.3 For existing installations where none of the means of notification specified in 9.6.4.2(1) through 9.6.4.2(4) is available, an approved plan for notification of the municipal fire department shall be permitted.

9.6.5 Emergency Control.

9.6.5.1 A fire alarm and control system, where required by another section of this *Code*, shall be arranged to actuate automatically the control functions necessary to make the protected premises safer for building occupants.

9.6.5.2 Where required by another section of this *Code*, the following functions shall be actuated by the complete fire alarm system:

- (1) Release of hold-open devices for doors or other opening protectives
- (2) Stairwell or elevator shaft pressurization
- (3) Smoke management or smoke control systems
- (4) Emergency lighting control
- (5) Unlocking of doors

9.6.5.3 The functions specified in 9.6.5.2 shall be permitted to be actuated by any fire alarm and control system where otherwise not required by this *Code*. Additionally, such a fire alarm and control system shall be permitted to recall elevators, as required by Section 9.4, if the activation of the system for such recall is by means of the elevator lobby, hoistway, or associated machine room detectors only.

9.6.5.4* Installation of emergency control devices shall be in accordance with *NFPA 72®*, *National Fire Alarm Code®*. The performance of emergency control functions shall not impair the effective response of all required alarm notification functions.

9.6.6 Location of Controls. Operator controls, alarm indicators, and manual communications capability shall be installed in a control center at a convenient location acceptable to the authority having jurisdiction.

9.6.7 Annunciation.

9.6.7.1 Where alarm annunciation is required by another section of this *Code*, it shall comply with 9.6.7.2 through 9.6.7.7.

9.6.7.2 Alarm annunciation at the control center shall be by means of audible and visible indicators.

9.6.7.3 For the purposes of alarm annunciation, each floor of the building, other than floors of existing buildings, shall be considered as not less than one zone, unless otherwise permitted by 9.6.7.4.3, 9.6.7.4.4, or another section of this *Code*.

9.6.7.4 If a floor area exceeds 2090 m² (22,500 ft²), additional fire alarm zoning shall be provided, and the length of any single fire alarm zone shall not exceed 91 m (300 ft) in any direction, except as provided in 9.6.7.4.1 through 9.6.7.4.4 or otherwise modified by another section of this *Code*.

9.6.7.4.1 Where permitted by another section of this *Code*, fire alarm zones shall be permitted to exceed 2090 m² (22,500 ft²), and the length of a zone shall be permitted to exceed 91 m (300 ft) in any direction.

9.6.7.4.2 Where the building is protected by an automatic sprinkler system in accordance with 9.7.1.1(1), the area of the fire alarm zone shall be permitted to coincide with the allowable area of the sprinkler system.

9.6.7.4.3 Where the building is protected by an automatic sprinkler system in accordance with 9.7.1.1(2), the sprinkler system shall be permitted to be annunciated on the fire alarm system as a single zone.

9.6.7.4.4 Where the building is protected by an automatic sprinkler system in accordance with 9.7.1.1(3), the sprinkler system shall be permitted to be annunciated on the fire alarm system as a single zone.

9.6.7.5 A system trouble signal shall be annunciated at the control center by means of audible and visible indicators.

9.6.7.6 A system supervisory signal shall be annunciated at the control center by means of audible and visible indicators.

9.6.7.7 Where the system serves more than one building, each building shall be annunciated separately.

9.7 Automatic Sprinklers and Other Extinguishing Equipment.

9.7.1 Automatic Sprinklers.

9.7.1.1* Each automatic sprinkler system required by another section of this *Code* shall be in accordance with one of the following:

- (1) *NFPA 13, Standard for the Installation of Sprinkler Systems*
- (2) *NFPA 13R, Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*
- (3) *NFPA 13D, Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*

9.7.1.2 Sprinkler piping serving not more than six sprinklers for any isolated hazardous area shall be permitted to be connected directly to a domestic water supply system having a capacity sufficient to provide 6.1 mm/min (0.15 gpm/ft²) throughout the entire enclosed area. An indicating shutoff valve, supervised in accordance with 9.7.2 or *NFPA 13, Standard for the Installation of Sprinkler Systems*, shall be installed in an accessible, visible, location between the sprinklers and the connection to the domestic water supply.

9.7.1.3* In areas protected by automatic sprinklers, automatic heat-detection devices required by other sections of this *Code* shall not be required.

9.7.1.4 Automatic sprinkler systems installed to make use of an alternative permitted by this *Code* shall be considered required systems and shall meet the provisions of this *Code* that apply to required systems.

9.7.2 Supervision.

9.7.2.1* Supervisory Signals. Where supervised automatic sprinkler systems are required by another section of this *Code*, supervisory attachments shall be installed and monitored for integrity in accordance with *NFPA 72®*, *National Fire Alarm Code®*, and a distinctive supervisory signal shall be provided to indicate a condition that would impair the satisfactory operation of the sprinkler system. System components and parameters that shall

be monitored shall include, but shall not be limited to, control valves, fire pump power supplies and running conditions, water tank levels and temperatures, tank pressure, and air pressure on dry-pipe valves. Supervisory signals shall sound and shall be displayed either at a location within the protected building that is constantly attended by qualified personnel or at an approved, remotely located receiving facility.

9.7.2.2 Alarm Signal Transmission. Where supervision of automatic sprinkler systems is provided in accordance with another provision of this *Code*, waterflow alarms shall be transmitted to an approved, proprietary alarm-receiving facility, a remote station, a central station, or the fire department. Such connection shall be in accordance with 9.6.1.3.

9.7.3 Other Automatic Extinguishing Equipment.

9.7.3.1 In any occupancy where the character of the fuel for fire is such that extinguishment or control of fire is accomplished by a type of automatic extinguishing system in lieu of an automatic sprinkler system, such system shall be installed in accordance with the appropriate standard, as determined in accordance with Table 9.7.3.1.

Table 9.7.3.1 Fire Suppression System Installation Standards

Fire Suppression System	Installation Standard
Low-expansion foam systems	NFPA 11, <i>Standard for Low-Expansion Foam</i>
Medium- and high-expansion foam systems	NFPA 11A, <i>Standard for Medium- and High-Expansion Foam Systems</i>
Carbon dioxide systems	NFPA 12, <i>Standard on Carbon Dioxide Extinguishing Systems</i>
Halon 1301 systems	NFPA 12A, <i>Standard on Halon 1301 Fire Extinguishing Systems</i>
Water spray fixed systems	NFPA 15, <i>Standard for Water Spray Fixed Systems for Fire Protection</i>
Deluge foam-water sprinkler systems	NFPA 16, <i>Standard for the Installation of Deluge Foam-Water Sprinkler and Foam-Water Spray Systems</i>
Dry chemical systems	NFPA 17, <i>Standard for Dry Chemical Extinguishing Systems</i>
Wet chemical systems	NFPA 17A, <i>Standard for Wet Chemical Extinguishing Systems</i>
Water mist systems	NFPA 750, <i>Standard on Water Mist Fire Protection Systems</i>
Clean agent extinguishing systems	NFPA 2001, <i>Standard on Clean Agent Fire Extinguishing Systems</i>

9.7.3.2 If the extinguishing system is installed in lieu of a required, supervised automatic sprinkler system, the activation of the extinguishing system shall activate the building fire alarm system, where provided. The actuation of an extinguishing system that is not installed in lieu of a required, supervised automatic sprinkler system shall be indicated at the building fire alarm system, where provided.

9.7.4 Manual Extinguishing Equipment.

9.7.4.1* Where required by the provisions of another section of this *Code*, portable fire extinguishers shall be installed, in-

spected, and maintained in accordance with NFPA 10, *Standard for Portable Fire Extinguishers*.

9.7.4.2 Where required by the provisions of another section of this *Code*, standpipe and hose systems shall be provided in accordance with NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*. Where standpipe and hose systems are installed in combination with automatic sprinkler systems, installation shall be in accordance with the appropriate provisions established by NFPA 13, *Standard for the Installation of Sprinkler Systems*, and NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*.

9.7.5 Maintenance and Testing. All automatic sprinkler and standpipe systems required by this *Code* shall be inspected, tested, and maintained in accordance with NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*.

9.7.6* Sprinkler System Shutdown.

9.7.6.1 Where a required automatic sprinkler system is out of service for more than 4 hours in a 24-hour period, the authority having jurisdiction shall be notified, and the building shall be evacuated or an approved fire watch shall be provided for all parties left unprotected by the shutdown until the sprinkler system has been returned to service.

9.7.6.2 Sprinkler impairment procedures shall comply with NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*.

9.7.7 Documentation. All required documentation regarding the design of the fire protection system and the procedures for maintenance, inspection, and testing of the fire protection system shall be maintained at an approved, secured location for the life of the fire protection system.

9.7.8 Record Keeping. Testing and maintenance records required by NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, shall be maintained at an approved, secured location.

9.8 Special Inspections and Tests.

9.8.1 Where required by another section of this *Code*, special inspections and tests shall be performed to verify the operation of the fire protection system in its final condition for acceptance by the authority having jurisdiction.

9.8.2 The design documents shall provide the procedures and methods to be used and items subject to special inspections and tests.

9.8.3 The special inspector shall submit an inspection and test report to the authority having jurisdiction and registered design professional in responsible charge.

Chapter 10 Interior Finish, Contents, and Furnishings

10.1 General.

10.1.1 Application. The interior finish, contents, and furnishings provisions set forth in this chapter shall apply to new construction and existing buildings.

10.1.2 Automatic Sprinkler Systems. Where another provision of this chapter requires an automatic sprinkler system, the automatic sprinkler system shall be installed in accordance with the subparagraph of 9.7.1.1 as permitted by the applicable occupancy chapter.

10.1.3 Definitions. The following is a list of terms used in this chapter:

- (1) **Contents and Furnishings.** See 3.3.36.
- (2) **Flashover.** See 3.3.85.
- (3) **Interior Finish.** See 3.3.120.
- (4) **Interior Ceiling Finish.** See 3.3.120.1.
- (5) **Interior Floor Finish.** See 3.3.120.2.
- (6) **Interior Wall Finish.** See 3.3.120.3.

10.2* Interior Finish.

10.2.1 General.

10.2.1.1 Classification of interior finish materials shall be in accordance with tests made under conditions simulating actual installations, provided that the authority having jurisdiction shall be permitted to establish the classification of any material on which a rating by standard test is not available, unless otherwise provided in 10.2.1.2.

10.2.1.2 Materials applied directly to the surface of walls and ceilings in a total thickness of less than 0.9 mm ($\frac{1}{32}$ in.) shall be exempt from tests simulating actual installation if they meet the requirements of Class A interior wall or ceiling finish when tested in accordance with 10.2.3 using inorganic reinforced cement board as the substrate material.

10.2.2* Use of Interior Finishes.

10.2.2.1 Requirements for interior wall and ceiling finish shall apply as follows:

- (1) Where specified elsewhere in this *Code* for specific occupancies (see *Chapter 7* and *Chapter 11* through *Chapter 42*)
- (2) As specified in 10.2.4

10.2.2.2* Requirements for interior floor finish shall apply under any of the following conditions:

- (1) Where floor finish requirements are specified elsewhere in the *Code*
- (2)*Where carpet or carpet-like material not meeting the requirements of ASTM D 2859, *Flammability of Finished Textile Floor Covering Materials*, is used
- (3) Where the fire performance of the floor finish cannot be demonstrated to be equivalent to floor finishes with a critical radiant flux of at least 0.1 W/cm²
- (4) Where the fire performance of the floor finish is unknown

10.2.3* Interior Wall or Ceiling Finish Testing and Classification. Interior wall or ceiling finish that is required elsewhere in this *Code* to be Class A, Class B, or Class C shall be classified based on test results from NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, except as indicated in 10.2.3.1 or 10.2.3.2.

10.2.3.1 Exposed portions of structural members complying with the requirements for Type IV(2HH) construction in accordance with NFPA 220, *Standard on Types of Building Construction*, shall be exempt from testing and classification in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*.

10.2.3.2 Interior wall and ceiling finish tested in accordance with NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, and meeting the conditions of 10.2.3.7.3 shall be permitted to be used where interior wall and ceiling finish is required to be Class A in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*.

10.2.3.3 For fire retardant coatings, see 10.2.6.

10.2.3.4* Products required to be tested in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, shall be classified as follows in accordance with their flame spread and smoke development, except as indicated in 10.2.3.4.1.

- (1) Class A interior wall and ceiling finish shall be characterized by the following:
 - (a) Flame spread, 0–25
 - (b) Smoke development, 0–450
 - (c) No continued propagation of fire in any element thereof when so tested
- (2) Class B interior wall and ceiling finish shall be characterized by the following:
 - (a) Flame spread, 26–75
 - (b) Smoke development, 0–450
- (3) Class C interior wall and ceiling finish shall be characterized by the following:
 - (a) Flame spread, 76–200
 - (b) Smoke development, 0–450

10.2.3.4.1 Existing interior finish shall be exempt from the smoke development criteria of 10.2.3.4.

10.2.3.5 The classification of interior finish specified in 10.2.3.4 shall be that of the basic material used by itself or in combination with other materials.

10.2.3.6 Wherever the use of Class C interior wall and ceiling finish is required, Class A or Class B shall be permitted. Where Class B interior wall and ceiling finish is required, Class A shall be permitted.

10.2.3.7* Products tested in accordance with NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*, shall comply with the criteria of 10.2.3.7.1 or 10.2.3.7.2. Products tested in accordance with NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, shall comply with the criteria of 10.2.3.7.3.

10.2.3.7.1* The following criteria shall be met when using method A of the test protocol of NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*:

- (1) Flame shall not spread to the ceiling during the 40-kW exposure.
- (2) During the 150-kW exposure, the following criteria shall be met:
 - (a) Flame shall not spread to the outer extremities of the sample on the 2440 mm × 3660 mm (96 in. × 144 in.) wall.
 - (b) The specimen shall not burn to the outer extremities of the 610-mm (24-in.) wide samples mounted vertically in the corner of the room.
 - (c) Burning droplets that are judged to be capable of igniting the textile wall covering or that persist in burning for 30 seconds or more shall not be formed and dropped to the floor.
 - (d) Flashover shall not occur.
 - (e) The maximum instantaneous net peak rate of heat release shall not exceed 300 kW.

10.2.3.7.2 The following conditions shall be met when using method B of the test protocol of NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*:

- (1) Flame shall not spread to the ceiling during the 40-kW exposure.
- (2) During the 150-kW exposure, the following criteria shall be met:
 - (a) Flame shall not spread to the outer extremities of the sample on the 2440 mm × 3660 mm (96 in. × 144 in.) wall.
 - (b) Flashover shall not occur.

10.2.3.7.3 The following conditions shall be met when using the test protocol of NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*:

- (1) Flames shall not spread to the ceiling during the 40-kW exposure.
- (2) During the 160-kW exposure, the following criteria shall be met:
 - (a) Flame shall not spread to the outer extremities of the sample on the 2440 mm × 3660 mm (96 in. × 144 in.) wall.
 - (b) Flashover shall not occur.
- (3) For new installations, the total smoke released throughout the test shall not exceed 1000 m².

10.2.4* Specific Materials.

10.2.4.1* Textile Wall and Textile Ceiling Materials. The use of textile materials on walls or ceilings shall comply with one of the following conditions:

- (1) Textile materials having a Class A rating (*see 10.2.3.4*) shall be permitted on the walls or ceilings of rooms or areas protected by an approved automatic sprinkler system.
- (2) Textile materials having a Class A rating (*see 10.2.3.4*) shall be permitted on partitions that do not exceed three-quarters of the floor-to-ceiling height or do not exceed 2440 mm (96 in.) in height, whichever is less.
- (3) Textile materials having a Class A rating (*see 10.2.3.4*) shall be permitted to extend not more than 1220 mm (48 in.) above the finished floor on ceiling-height walls and ceiling-height partitions.
- (4) Previously approved existing installations of textile material having a Class A rating (*see 10.2.3.4*) shall be permitted to be continued to be used.
- (5) Textile materials shall be permitted on walls and partitions where tested in accordance with NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*. (*See 10.2.3.7.*)

10.2.4.2* Expanded Vinyl Wall or Ceiling Coverings. The use of expanded vinyl wall or ceiling coverings shall comply with one of the following conditions:

- (1) Materials having a Class A rating (*see 10.2.3.4*) shall be permitted on the walls or ceilings of rooms or areas protected by an approved automatic sprinkler system.
- (2) Materials having a Class A rating (*see 10.2.3.4*) shall be permitted on partitions that do not exceed three-quarters of the floor-to-ceiling height or do not exceed 2440 mm (96 in.) in height, whichever is less.
- (3) Materials having a Class A rating (*see 10.2.3.4*) shall be permitted to extend not more than 1220 mm (48 in.)

above the finished floor on ceiling-height walls and ceiling-height partitions.

- (4) Existing installations of materials with the appropriate wall finish classification for the occupancy involved, and with classification in accordance with the provisions in 10.2.3.4, shall be permitted to be continued to be used.
- (5) Materials shall be permitted on walls and partitions where tested in accordance with NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*. (*See 10.2.3.7.*)
- (6) Materials shall be permitted on walls, partitions, and ceilings where tested in accordance with NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*. (*See 10.2.3.7.*)

10.2.4.3 Cellular or Foamed Plastic. Cellular or foamed plastic materials shall not be used as interior wall and ceiling finish unless specifically permitted by 10.2.4.3.1 or 10.2.4.3.2.

10.2.4.3.1 Cellular or foamed plastic materials shall be permitted where subjected to fire tests that substantiate their combustibility characteristics for the use intended under actual fire conditions using large-scale tests performed on a finished foamed plastic assembly of the maximum thickness intended for use that is related to the actual end-use configuration.

10.2.4.3.2 Cellular or foamed plastic shall be permitted for trim not in excess of 10 percent of the wall or ceiling area, provided that it is not less than 320 kg/m³ (20 lb/ft³) in density, is limited to 13 mm (½ in.) in thickness and 100 mm (4 in.) in width, and complies with the requirements for Class A or Class B interior wall and ceiling finish as described in 10.2.3.4; however, the smoke rating shall not be limited.

10.2.4.4* Light-Transmitting Plastics. Light-transmitting plastics shall be permitted to be used as interior wall and ceiling finish if approved by the authority having jurisdiction.

10.2.4.5 Decorations and Furnishings. Decorations and furnishings that do not meet the definition of interior finish as defined in 3.3.120 shall be regulated by the provisions of Section 10.3.

10.2.5 Trim and Incidental Finish. Interior wall and ceiling finish not in excess of 10 percent of the aggregate wall and ceiling areas of any room or space shall be permitted to be Class C materials in occupancies where interior wall and ceiling finish of Class A or Class B is required.

10.2.6* Fire-Retardant Coatings.

10.2.6.1* The required flame spread or smoke development classification of existing surfaces of walls, partitions, columns, and ceilings shall be permitted to be secured by applying approved fire-retardant coatings to surfaces having higher flame spread ratings than permitted. Such treatments shall comply with the requirements of NFPA 703, *Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*.

10.2.6.2 Fire-retardant coatings shall possess the desired degree of permanency and shall be maintained so as to retain the effectiveness of the treatment under the service conditions encountered in actual use.

10.2.7 Interior Floor Finish Testing and Classification.

10.2.7.1 Carpet and carpet-like interior floor finishes shall comply with ASTM D 2859, *Standard Test Method for Flammability of Finished Textile Floor Covering Materials*.

10.2.7.2* Floor coverings, other than carpet for which 10.2.2.2 establishes requirements for fire performance, shall have a minimum critical radiant flux of 0.1 W/cm^2 .

10.2.7.3* Interior floor finishes shall be classified in accordance with 10.2.7.4 based on test results from NFPA 253, *Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source*.

10.2.7.4 Interior floor finishes shall be classified as follows in accordance with the critical radiant flux ratings:

- (1) Class I interior floor finish shall be characterized by a critical radiant flux not less than 0.45 W/cm^2 as determined by the test described in 10.2.7.3.
- (2) Class II interior floor finish shall be characterized by a critical radiant flux not less than 0.22 W/cm^2 but less than 0.45 W/cm^2 as determined by the test described in 10.2.7.3.

10.2.7.5 Wherever the use of Class II interior floor finish is required, Class I interior floor finish shall be permitted.

10.2.8 Automatic Sprinklers.

10.2.8.1 Unless specifically prohibited elsewhere in this *Code*, where an approved automatic sprinkler system is in accordance with Section 9.7, Class C interior wall and ceiling finish materials shall be permitted in any location where Class B is required, and Class B interior wall and ceiling finish materials shall be permitted in any location where Class A is required.

10.2.8.2 Unless specifically prohibited elsewhere in this *Code*, where an approved automatic sprinkler system is in accordance with Section 9.7, Class II interior floor finish shall be permitted in any location where Class I interior floor finish is required, and where Class II is required, no critical radiant flux rating shall be required.

10.3 Contents and Furnishings.

10.3.1* Where required by the applicable provisions of this *Code*, draperies, curtains, and other similar loosely hanging furnishings and decorations shall be flame resistant as demonstrated by testing in accordance with NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*.

10.3.2* Where required by the applicable provisions of this *Code*, upholstered furniture and mattresses shall be resistant to a cigarette ignition (that is, smoldering) in accordance with the following:

- (1) Where required by the applicable provisions of this *Code*, the components of the upholstered furniture, unless located in rooms or spaces protected by an approved automatic sprinkler system, shall meet the requirements for Class I when tested in accordance with NFPA 260, *Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture*.
- (2) Where required by the applicable provisions of this *Code*, mocked-up composites of the upholstered furniture, unless located in rooms or spaces protected by an approved automatic sprinkler system, shall have a char length not exceeding 38 mm (1½ in.) when tested in accordance with NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*.
- (3)*Where required by the applicable provisions of this *Code*, mattresses, unless located in rooms or spaces protected by an approved automatic sprinkler system, shall have a char length not exceeding 51 mm (2 in.) when tested in accordance with Part 1632 of the *Code of Federal Regulations* 16.

10.3.3* Where required by the applicable provisions of this *Code*, upholstered furniture, unless the furniture is located in a building protected throughout by an approved automatic sprinkler system, shall have limited rates of heat release when tested in accordance with ASTM E 1537, *Standard Method for Fire Testing of Real Scale Upholstered Furniture Items*, as follows:

- (1) The peak rate of heat release for the single upholstered furniture item shall not exceed 250 kW.
- (2) The total energy released by the single upholstered furniture item during the first 5 minutes of the test shall not exceed 40 MJ.

10.3.4* Where required by the applicable provisions of this *Code*, mattresses, unless the mattress is located in a building protected throughout by an approved automatic sprinkler system, shall have limited rates of heat release when tested in accordance with ASTM E 1590, *Standard Method for Fire Testing of Real Scale Mattresses*, as follows:

- (1) The peak rate of heat release for the mattress shall not exceed 250 kW.
- (2) The total energy released by the mattress during the first 5 minutes of the test shall not exceed 40 MJ.

10.3.5* Furnishings or decorations of an explosive or highly flammable character shall not be used.

10.3.6 Fire-retardant coatings shall be maintained to retain the effectiveness of the treatment under service conditions encountered in actual use.

10.3.7* Where required by the applicable provisions of this *Code*, furnishings and contents made with foamed plastic materials that are unprotected from ignition shall have a heat release rate not exceeding 100 kW when tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*.

Chapter 11 Special Structures and High-Rise Buildings

11.1 General Requirements.

11.1.1 Application. The requirements of Section 11.1 through Section 11.11 apply to occupancies regulated by Chapter 12 through Chapter 42 that are in a special structure. The applicable provisions of Chapter 12 through Chapter 42 shall apply, except as modified by this chapter. Section 11.8 applies to high-rise buildings only where specifically required by Chapter 12 through Chapter 42.

11.1.2 Multiple Occupancies. See 6.1.14.

11.1.3 Definitions. See the defined terms within each special structure section.

11.1.4 Classification of Occupancy. Occupancies regulated by Chapter 12 through Chapter 42 that are in special structures shall meet the requirements of those chapters, except as modified by this chapter.

11.1.5 Classification of Hazard of Contents. Classification of hazard of contents shall be in accordance with Section 6.2.

11.1.6 Minimum Construction Requirements. Minimum construction requirements shall be in accordance with the applicable occupancy chapter.

11.1.7 Occupant Load. The occupant load of special structures shall be based on the use of the structure as regulated by Chapter 12 through Chapter 42.

11.1.8 Automatic Sprinkler Systems. Where another provision of this chapter requires an automatic sprinkler system, the automatic sprinkler system shall be installed in accordance with the subparts of 9.7.1.1 as permitted by the applicable occupancy chapter.

11.2 Open Structures.

11.2.1 Application.

11.2.1.1 General. The provisions of Section 11.1 shall apply.

11.2.1.2 Definition — Open Structure. See 3.3.217.6.

11.2.2* Means of Egress.

11.2.2.1 General. The means of egress provisions of the applicable occupancy, Chapter 12 through Chapter 42, shall apply, except as modified by 11.2.2.2 through 11.2.2.10.

11.2.2.2 Means of Egress Components.

11.2.2.2.1 Fire Escape Ladders. Open structures that are designed for occupancy by not more than three persons shall be permitted to be served by fire escape ladders complying with 7.2.9.

11.2.2.3 Capacity of Means of Egress. Open structures shall be exempt from the requirements for capacity of means of egress.

11.2.2.4 Number of Means of Egress.

11.2.2.4.1 The grade level of open structures, which by their very nature contain an infinite number of means of egress, shall be exempt from the requirements for number of means of egress.

11.2.2.4.2 Open structures occupied by not more than three persons, with travel distance of not more than 61 m (200 ft), shall be permitted to have a single exit.

11.2.2.5 Arrangement of Means of Egress. (No modifications.)

11.2.2.6 Travel Distance to Exits. Open structures shall be exempt from travel distance limitations.

11.2.2.7 Discharge from Exits. Open structures permitted to have a single exit per 11.2.2.4 shall be permitted to have 100 percent of the exit discharge through areas on the level of exit discharge.

11.2.2.8 Illumination of Means of Egress. Open structures shall be exempt from illumination of means of egress requirements.

11.2.2.9 Emergency Lighting. Open structures shall be exempt from emergency lighting requirements.

11.2.2.10 Marking of Means of Egress. Open structures shall be exempt from marking of means of egress requirements.

11.2.3 Protection.

11.2.3.1 Protection of Vertical Openings. Open structures shall be exempt from protection of vertical opening requirements.

11.2.3.2 Protection from Hazards. Every open structure, other than those structures with only occasional occupancy, shall have automatic, manual, or other protection that is appropriate to the particular hazard and that is designed to minimize danger to occupants in case of fire or other emergency before they have time to use the means of egress.

11.2.3.3 Interior Finish. (No modifications.)

11.2.3.4 Detection, Alarm, and Communications Systems. Open structures shall be exempt from requirements for detection, alarm, and communications systems.

11.2.3.5 Extinguishing Requirements. (No modifications.)

11.3 Towers.

11.3.1 Application.

11.3.1.1 General. The provisions of Section 11.1 shall apply.

11.3.1.2 Definition — Tower. See 3.3.224.

11.3.1.3 Use of Accessory Levels.

11.3.1.3.1 Sprinklered Towers. In towers protected throughout by an automatic sprinkler system in accordance with Section 9.7, the levels located below the observation level shall be permitted to be occupied only for the following uses that support tower operations:

- (1) Electrical and mechanical equipment rooms, including emergency power, radar, communications, and electronics rooms
- (2)*Incidental accessory uses

11.3.1.3.2 Nonsprinklered Towers. The levels located within a tower below the observation level and the equipment room for that level in nonsprinklered towers shall not be occupied.

11.3.2 Means of Egress.

11.3.2.1 General. The means of egress provisions of the applicable occupancy chapter, Chapter 12 through Chapter 42, shall apply, except as modified by 11.3.2.2 through 11.3.2.10.

11.3.2.2 Means of Egress Components.

11.3.2.2.1 Fire Escape Ladders. Towers, such as forest fire observation or railroad signal towers, that are designed for occupancy by not more than three persons shall be permitted to be served by fire escape ladders complying with 7.2.9.

11.3.2.2.2 Elevators. Towers subject to occupancy by not more than 90 persons shall be permitted to use elevators in the means of egress in accordance with 7.2.13.

11.3.2.3 Capacity of Means of Egress.

11.3.2.3.1 Means of egress for towers shall be provided for the number of persons expected to occupy the space.

11.3.2.3.2 Spaces not subject to human occupancy because of machinery or equipment shall be excluded from consideration.

11.3.2.4* Number of Means of Egress.

11.3.2.4.1 Towers shall be permitted to have a single exit if the following conditions are met:

- (1) The tower shall be subject to occupancy by fewer than 25 persons.
- (2) The tower shall not be used for living or sleeping purposes.
- (3) The tower shall be of Type I, Type II, or Type IV construction. (See 8.2.1.)
- (4) The tower interior wall and ceiling finish shall be Class A or Class B.
- (5) No combustible materials shall be located within the tower, under the tower, or within the immediate vicinity of the tower, except necessary furniture.
- (6) No high hazard occupancies shall be located within the tower or within its immediate vicinity.

(7) Where the tower is located above a building, the single exit from the tower shall be provided by one of the following:

- (a) An exit enclosure separated from the building with no door openings to or from the building
- (b) An exit enclosure leading directly to an exit enclosure serving the building, with walls and door separating the exit enclosures from each other, and another door allowing access to the top floor of the building that provides access to a second exit serving that floor

11.3.2.4.2 Towers with 360-degree line-of-sight requirements shall be permitted to have a single means of egress for a distance of travel not exceeding 23 m (75 ft), or 30 m (100 ft) if the tower is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

11.3.2.5 Arrangement of Means of Egress. (No modifications.)

11.3.2.6 Travel Distance to Exits. Towers where ladders are permitted by 11.3.2.2.1 shall be exempt from travel distance limitations.

11.3.2.7 Discharge from Exits. Towers permitted to have a single exit per 11.3.2.4 shall be permitted to have 100 percent of the exit discharge through areas on the level of exit discharge.

11.3.2.8 Illumination of Means of Egress. Towers where ladders are permitted by 11.3.2.2.1 shall be exempt from illumination of means of egress requirements.

11.3.2.9 Emergency Lighting.

11.3.2.9.1 Towers where ladders are permitted by 11.3.2.2.1 shall be exempt from emergency lighting requirements.

11.3.2.9.2 Locations not routinely inhabited by humans shall be exempt from emergency lighting requirements.

11.3.2.9.3 Structures occupied only during daylight hours, with windows arranged to provide the required level of illumination of all portions of the means of egress during such hours, shall be exempt from emergency lighting requirements where approved by the authority having jurisdiction.

11.3.2.10 Marking of Means of Egress.

11.3.2.10.1 Towers where ladders are permitted by 11.3.2.2.1 shall be exempt from marking of means of egress requirements.

11.3.2.10.2 Locations not routinely inhabited by humans shall be exempt from marking of means of egress requirements.

11.3.3 Protection.

11.3.3.1 Protection of Vertical Openings.

11.3.3.1.1 Towers where ladders are permitted by 11.3.2.2.1 shall be exempt from protection of vertical opening requirements.

11.3.3.1.2 In towers where the support structure is open and there is no occupancy below the top floor level, stairs shall be permitted to be open with no enclosure required, or fire escape stairs shall be permitted.

11.3.3.2 Protection from Hazards. Every tower, other than structures with only occasional occupancy, shall have automatic, manual, or other protection that is appropriate to the particular hazard and that is designed to minimize danger to occupants in case of fire or other emergency before they have time to use the means of egress.

11.3.3.3 Interior Finish. (No modifications.)

11.3.3.4 Detection, Alarm, and Communications Systems. Towers designed for occupancy by not more than three persons shall be exempt from requirements for detection, alarm, and communications systems.

11.3.3.5 Extinguishing Requirements. (No modifications.)

11.3.3.6 Corridors. (No modifications.)

11.4 Water-Surrounded Structures.

11.4.1 Application.

11.4.1.1 General. The provisions of Section 11.1 and Section 11.4 shall apply to those structures that are not under the jurisdiction of the U.S. Coast Guard and not designed and arranged in accordance with U.S. Coast Guard regulations.

11.4.1.2 Definition — Water-Surrounded Structure. See 3.3.217.12.

11.4.2 Means of Egress.

11.4.2.1 General. The means of egress provisions of the applicable occupancy chapter, Chapter 12 through Chapter 42, shall apply, except as modified by 11.4.2.2 through 11.4.2.10.

11.4.2.2 Means of Egress Components. (No modifications.)

11.4.2.3 Capacity of Means of Egress. Spaces in water-surrounded structures that are not subject to human occupancy because of machinery or equipment shall be exempt from the requirements for capacity of means of egress.

11.4.2.4 Number of Means of Egress. (No modifications.)

11.4.2.5 Arrangement of Means of Egress. (No modifications.)

11.4.2.6 Travel Distance to Exits. (No modifications.)

11.4.2.7 Discharge from Exits. Structures permitted to have a single exit per the applicable occupancy chapter shall be permitted to have 100 percent of the exit discharge through areas on the level of exit discharge.

11.4.2.8 Illumination of Means of Egress. (No modifications.)

11.4.2.9 Emergency Lighting.

11.4.2.9.1 Locations not routinely inhabited by humans are exempt from emergency lighting requirements.

11.4.2.9.2 Structures occupied only during daylight hours, with windows arranged to provide the required level of illumination of all portions of the means of egress during such hours, shall be exempt from emergency lighting requirements where approved by the authority having jurisdiction.

11.4.2.10 Marking of Means of Egress. Locations not routinely inhabited by humans shall be exempt from marking of means of egress requirements.

11.4.3 Protection.

11.4.3.1 Protection of Vertical Openings. (No modifications.)

11.4.3.2 Protection from Hazards. Every water-surrounded structure, other than structures with only occasional occupancy, shall have automatic, manual, or other protection that is appropriate to the particular hazard and that is designed to minimize danger to occupants in case of fire or other emergency before they have time to use the means of egress.

11.4.3.3 Interior Finish. (No modifications.)

11.4.3.4 Detection, Alarm, and Communications Systems. (No modifications.)

11.4.3.5 Extinguishing Requirements. (No modifications.)

11.4.3.6 Corridors. (No modifications.)

11.5* Piers.

11.5.1 Application. The provisions of Section 11.1 shall apply.

11.5.2 Number of Means of Egress. Piers used exclusively to moor cargo vessels and to store material shall be exempt from number of means of egress requirements where provided with proper means of egress from structures thereon to the pier and a single means of access to the mainland, as appropriate to the pier's arrangement.

11.5.3 Arrangement of Means of Egress. Piers not meeting the requirements of 11.5.2 and occupied for other than cargo handling and storage shall have means of egress arranged in accordance with Chapter 12 through Chapter 42. In addition, one of the following measures shall be provided on piers extending over 46 m (150 ft) from shore to minimize the possibility that fire under or on the pier blocks the escape of occupants to shore:

- (1) The pier shall be arranged to provide two separate ways to travel to shore, such as by two well-separated walkways or independent structures.
- (2) The pier deck shall be open, fire resistive, and set on non-combustible supports.
- (3) The pier shall be open, unobstructed, and not less than 15 m (50 ft) in width if less than 150 m (500 ft) long, or its width shall be not less than 10 percent of its length if more than 150 m (500 ft) long.
- (4) The pier deck shall be provided with an approved automatic sprinkler system in accordance with Section 9.7 for combustible substructures and all superstructures. Such sprinkler system shall be supervised where required by the applicable occupancy chapter (Chapter 12 through Chapter 42).

11.6* Vehicles and Vessels.

11.6.1 Vehicles. Where immobile, attached to a building, or permanently fixed to a foundation, and where subject to human occupancy, the following vehicles shall comply with the requirements of this *Code* that are appropriate to buildings of similar occupancy:

- (1) Trailers
- (2) Railroad cars
- (3) Streetcars
- (4) Buses
- (5) Conveyances similar to those in 11.6.1(1) through 11.6.1(4)

11.6.2 Vessels. Any ship, barge, or other vessel permanently fixed to a foundation or mooring, or unable to get underway by means of its own power, and occupied for purposes other than navigation shall be subject to the requirements of this *Code* that apply to buildings of similar occupancy.

11.7 Underground and Limited Access Structures.

11.7.1 Application. The provisions of Section 11.1 shall apply.

11.7.2* Definitions. The following is a list of terms used in Section 11.7:

- (1) **Underground Structure.** See 3.3.217.11.
- (2) **Limited Access Structure.** See 3.3.217.3.

11.7.3 Special Provisions for Underground and Limited Access Structures.

11.7.3.1 A structure or portion of a structure that does not have openings in compliance with 11.7.3.1(A) and 11.7.3.1(B) shall be designated as a limited access structure and shall comply with 11.7.3.4 and 11.7.3.5.

(A) Single-Story Structures. Single-story structures shall have grade level doors or emergency access openings in accordance with 11.7.3.2 on two sides of the building, spaced not more than 38 m (125 ft) apart on the exterior walls.

(B) Multiple-Story Structures. Multiple-story structures shall comply with the following:

- (1) The story at grade level shall comply with 11.7.3.1(A).
- (2) Other stories shall be provided with emergency access openings in accordance with 11.7.3.2 on two sides of the building, spaced not more than 9140 mm (360 in.) apart.

11.7.3.2 Emergency access openings shall consist of a window, panel, or similar opening that complies with all of the following:

- (1) The opening shall have dimensions of not less than 560 mm (22 in.) in width and 610 mm (24 in.) in height and shall be unobstructed to allow for ventilation and rescue operations from the exterior.
- (2) The bottom of the opening shall be not more than 1120 mm (44 in.) above the floor.
- (3) The opening shall be readily identifiable from both the exterior and interior.
- (4) The opening shall be readily openable from both the exterior and interior.

11.7.3.3 A structure or portion of a structure shall not be considered an underground structure if the story is provided, on not less than two sides, with not less than 1.9 m² (20 ft²) of emergency access opening located entirely above the adjoining grade level in each 15 lineal m (50 lineal ft) of exterior enclosing wall area.

11.7.3.4 Underground and limited access structures, and all areas and floor levels traversed in traveling to the exit discharge, shall be protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7, unless such structures meet one of the following criteria:

- (1) They have an occupant load of 50 or fewer persons in new underground or limited access portions of the structure.
- (2) They have an occupant load of 100 or fewer persons in existing underground or limited access portions of the structure.
- (3) The structure is a single-story underground or limited access structure that is permitted to have a single exit per Chapter 12 through Chapter 42, with a common path of travel not greater than 15 m (50 ft).

11.7.3.5 Underground or limited access portions of structures and all areas traversed in traveling to the exit discharge, other than in one- and two-family dwellings, shall be provided with emergency lighting in accordance with Section 7.9.

11.7.4 Additional Provisions for Underground Structures.

11.7.4.1 A structure or portion of a structure shall not be considered an underground structure if the story is provided, on not less than two sides, with not less than 1.9 m² (20 ft²) of emergency access opening located entirely above the adjoining grade level in each 15 lineal m (50 lineal ft) of exterior enclosing wall area.

11.7.4.2 The requirements of 11.7.3 shall apply.

11.7.4.3 Exits from underground structures with an occupant load of more than 100 persons in the underground portions of the structure and having a floor used for human occupancy located more than 9140 mm (360 in.) below the lowest level of exit discharge, or having more than one level located below the lowest level of exit discharge, shall meet the following criteria:

- (1) Exits shall be cut off from the level of exit discharge per 7.1.3.2.
- (2) Exits shall be provided with outside smoke-venting facilities or other means to prevent the exits from becoming charged with smoke from any fire in the areas served by the exits.

11.7.4.4 The underground portions of an underground structure, other than an existing underground structure, shall be provided with approved automatic smoke venting in accordance with Section 9.3 where the underground structure has the following features:

- (1) An occupant load of more than 100 persons in the underground portions of the structure
- (2) A floor level used for human occupancy located more than 9140 mm (360 in.) below the lowest level of exit discharge, or having more than one level located below the lowest level of exit discharge
- (3) Combustible contents, combustible interior finish, or combustible construction

11.7.4.5 Exit stair enclosures in underground structures having a floor level used for human occupancy located more than 9140 mm (360 in.) below the lowest level of exit discharge, or having more than one level located below the lowest level of exit discharge, shall be provided with signage in accordance with 7.2.2.5.4 at each floor level landing traversed in traveling to the exit discharge. The signs shall include a chevron-shaped indicator to show direction to the exit discharge.

11.8 High-Rise Buildings.

11.8.1 General.

11.8.1.1 Where required by Chapter 12 through Chapter 42, the provisions of Section 11.8 shall apply to high-rise buildings as defined in 3.3.27.7.

11.8.1.2 In addition to the requirements of Section 11.8, compliance with all other applicable provisions of this *Code* shall be required.

11.8.2 Extinguishing Requirements.

11.8.2.1* High-rise buildings shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7. A sprinkler control valve and a water-flow device shall be provided for each floor.

11.8.2.2 High-rise buildings shall be protected throughout by a Class I standpipe system in accordance with Section 9.7.

11.8.3 Detection, Alarm, and Communications Systems.

11.8.3.1* A fire alarm system using an approved, emergency voice/alarm communication system shall be installed in accordance with Section 9.6.

11.8.3.2 Two-way telephone service shall be in accordance with 11.8.3.2(A) and 11.8.3.2(B):

(A) Two-way telephone communication service shall be provided for fire department use. This system shall be in

accordance with *NFPA 72®*, *National Fire Alarm Code®*. The communications system shall operate between the central control station and every elevator car, every elevator lobby, and each floor level of exit stairs.

(B) The requirement of 11.8.3.2(A) shall not apply where the fire department radio system is approved as an equivalent system.

11.8.4 Emergency Lighting and Standby Power.

11.8.4.1 Emergency lighting in accordance with Section 7.9 shall be provided.

11.8.4.2 Requirements for standby power shall be as specified in 11.8.4.2(A) through 11.8.4.2(D).

(A)* Class I, Type 60, standby power in accordance with Article 701 of *NFPA 70*, *National Electrical Code®*, and *NFPA 110*, *Standard for Emergency and Standby Power Systems*, shall be provided.

(B) The standby power system shall have a capacity and rating sufficient to supply all equipment required to be connected by 11.8.4.2(D).

(C) Selective load pickup and load shedding shall be permitted in accordance with *NFPA 70*, *National Electrical Code®*.

(D) The standby power system shall be connected to the following:

- (1) Fire alarm system
- (2) Electric fire pump
- (3) Central control station equipment and lighting
- (4) Not less than one elevator serving all floors, with standby power transferable to any elevator
- (5) Mechanical equipment for smokeproof enclosures
- (6) Mechanical equipment required to conform with the requirements of Section 9.3

11.8.5* Central Control Station. A central control station shall be provided in a location approved by the fire department. The control station shall contain the following:

- (1) Voice fire alarm system panels and controls
- (2) Fire department two-way telephone communication service panels and controls where required by another section of this *Code*
- (3) Fire detection and fire alarm system annunciation panels
- (4) Elevator floor location and operation annunciators
- (5) Sprinkler valve and waterflow annunciators
- (6) Emergency generator status indicators
- (7) Controls for any automatic stairway door unlocking system
- (8) Fire pump status indicators
- (9) A telephone for fire department use with controlled access to the public telephone system

11.9 Permanent Membrane Structures.

11.9.1 Application.

11.9.1.1 General. The provisions of Section 11.1 shall apply.

11.9.1.2 Use of Membrane Roofs. Membrane roofs shall be used in accordance with the following:

- (1) Membrane materials shall not be used where fire resistance ratings are required for walls or roofs.
- (2) Where every part of the roof, including the roof membrane, is not less than 6100 mm (240 in.) above any floor, balcony, or gallery, a noncombustible or limited-combustible membrane shall be permitted to be used as the roof in any type of construction.

- (3) With approval of the authority having jurisdiction, membrane materials shall be permitted to be used where every part of the roof membrane is sufficiently above every significant fire potential such that the imposed temperature cannot exceed the capability of the membrane, including seams, to maintain its structural integrity.

11.9.1.3 Testing. Testing of membrane materials for compliance with the requirements of Section 11.9 for use of the categories of noncombustible and limited-combustible materials shall be performed on weathered-membrane material as defined in 3.3.

11.9.1.4 Flame Spread Classification. Flame spread of all membrane materials exposed within the structure shall be Class A in accordance with Section 10.2.

11.9.1.5 Roof Covering Classification. Roof membranes shall have a roof covering classification, as required by the applicable building codes, when tested in accordance with NFPA 256, *Standard Methods of Fire Tests of Roof Coverings*.

11.9.1.6 Flame Resistance.

11.9.1.6.1 All membrane structure fabric shall be flame resistant in accordance with 10.3.1.

11.9.1.6.2 One of the following shall serve as evidence that the fabric materials have the required flame resistance:

- (1) The authority having jurisdiction shall require a certificate or other evidence of acceptance by an organization acceptable to the authority having jurisdiction.
- (2) The authority having jurisdiction shall require a report of tests made by other inspection authorities or organizations acceptable to the authority having jurisdiction.

11.9.1.6.3 Where required by the authority having jurisdiction, confirmatory field tests shall be conducted using test specimens from the original material, which shall have been affixed at the time of manufacture to the exterior of the structure.

11.9.2 Tensioned-Membrane Structures.

11.9.2.1 The design, materials, and construction of the building shall be based on plans and specifications prepared by a licensed architect or engineer knowledgeable in tensioned-membrane construction.

11.9.2.2 Material loads and strength shall be based on physical properties of the materials verified and certified by an approved testing laboratory.

11.9.2.3 The membrane roof for structures in climates subject to freezing temperatures and ice buildup shall be composed of two layers separated by an air space through which heated air can be moved to guard against ice accumulation. As an alternative to the two layers, other approved methods that protect against ice accumulation shall be permitted.

11.9.2.4 Roof drains shall be equipped with electrical elements to protect against ice buildup that can prevent the drains from functioning. Such heating elements shall be served by on-site standby electrical power in addition to the normal public service. As an alternative to such electrical elements, other approved methods that protect against ice accumulation shall be permitted.

11.9.3 Air-Supported and Air-Inflated Structures.

11.9.3.1 General. In addition to the general provisions of 11.9.1, the requirements of 11.9.3 shall apply to air-supported and air-inflated structures.

11.9.3.2 Pressurization (Inflation) System. The pressurization system shall consist of one or more operating blower units. The system shall include automatic control of auxiliary blower units to maintain the required operating pressure. Such equipment shall meet the following requirements:

- (1) Blowers shall be powered by continuous-rated motors at the maximum power required.
- (2) Blowers shall have personnel protection, such as inlet screens and belt guards.
- (3) Blower systems shall be weather protected.
- (4) Blower systems shall be equipped with backdraft check dampers.
- (5) Not less than two blower units shall be provided, each of which has capacity to maintain full inflation pressure with normal leakage.
- (6) The blowers shall be designed to be incapable of over-pressurization.
- (7) The auxiliary blower unit(s) shall operate automatically if there is any loss of internal pressure or if an operating blower unit becomes inoperative.
- (8) The design inflation pressure and the capacity of each blower system shall be certified by a professional engineer.

11.9.3.3 Standby Power System.

11.9.3.3.1* A fully automatic standby power system shall be provided. The system shall be either an auxiliary engine generator set capable of running the blower system or a supplementary blower unit that is sized for 1 times the normal operating capacity and is powered by an internal combustion engine.

11.9.3.3.2 The standby power system shall be fully automatic to ensure continuous inflation in the event of any failure of the primary power. The system shall be capable of operating continuously for a minimum of 4 hours.

11.9.3.3.3 The sizing and capacity of the standby power system shall be certified by a professional engineer.

11.9.4 Maintenance and Operation.

11.9.4.1 Instructions in both operation and maintenance shall be transmitted to the owner by the manufacturer of the tensioned-membrane, air-supported, or air-inflated structure.

11.9.4.2 Annual inspection and required maintenance of each structure shall be performed to ensure safety conditions. At least biennially, the inspection shall be performed by a professional engineer, registered architect, or individual certified by the manufacturer.

11.9.5 Services.

11.9.5.1 Fired Heaters.

11.9.5.1.1 Only labeled heating devices shall be used.

11.9.5.1.2 Fuel-fired heaters and their installation shall be approved by the authority having jurisdiction.

11.9.5.1.3 Containers for liquefied petroleum gases shall be installed not less than 1525 mm (60 in.) from any temporary membrane structure and shall be in accordance with the provisions of NFPA 58, *Liquefied Petroleum Gas Code*.

11.9.5.1.4 Tanks shall be secured in the upright position and protected from vehicular traffic.

11.9.5.2 Electric Heaters.

11.9.5.2.1 Only labeled heaters shall be permitted.

11.9.5.2.2 Heaters shall be connected to electricity by electric cable that is suitable for outside use and is of sufficient size to handle the electrical load.

11.10 Temporary Membrane Structures.

11.10.1 Application.

11.10.1.1 **General.** The provisions of Section 11.1 shall apply.

11.10.1.2 **Required Approval.** Membrane structures designed to meet all the requirements of Section 11.10 shall be permitted to be used as temporary buildings subject to the approval of the authority having jurisdiction.

11.10.1.3 **Alternative Requirements.** Temporary tensioned-membrane structures shall be permitted to comply with Section 11.11 instead of Section 11.10.

11.10.1.4 **Roof Covering Classification.** Roof membranes shall have a roof covering classification, as required by the applicable building codes, when tested in accordance with NFPA 256, *Standard Methods of Fire Tests of Roof Coverings*.

11.10.1.5 Flame Resistance.

11.10.1.5.1 All membrane structure fabric shall be flame resistant in accordance with 10.3.1.

11.10.1.5.2 One of the following shall serve as evidence that the fabric materials have the required flame resistance:

- (1) The authority having jurisdiction shall require a certificate or other evidence of acceptance by an organization acceptable to the authority having jurisdiction.
- (2) The authority having jurisdiction shall require a report of tests made by other inspection authorities or organizations acceptable to the authority having jurisdiction.

11.10.1.5.3 Where required by the authority having jurisdiction, confirmatory field tests shall be conducted using test specimens from the original material, which shall have been affixed at the time of manufacture to the exterior of the structure.

11.10.2 Fire Hazards.

11.10.2.1 The ground enclosed by any temporary membrane structure, and the ground for a reasonable distance but for not less than 3050 mm (120 in.) outside of such a structure, shall be cleared of all flammable or combustible material or vegetation that is not used for necessary support equipment. The clearing work shall be accomplished to the satisfaction of the authority having jurisdiction prior to the erection of such a structure. The premises shall be kept free from such flammable or combustible materials during the period for which the premises are used by the public.

11.10.2.2 Where prohibited by the authority having jurisdiction, smoking shall not be permitted in any temporary membrane structure.

11.10.3 **Fire-Extinguishing Equipment.** Portable fire-extinguishing equipment of approved types shall be furnished and maintained in temporary membrane structures in such quantity and in such locations as directed by the authority having jurisdiction.

11.10.4 Tensioned-Membrane Structures.

11.10.4.1 The design, materials, and construction of the building shall be based on plans and specifications prepared

by a licensed architect or engineer knowledgeable in tensioned-membrane construction.

11.10.4.2 Material loads and strength shall be based on physical properties of the materials verified and certified by an approved testing laboratory.

11.10.4.3 The membrane roof for structures in climates subject to freezing temperatures and ice buildup shall be composed of two layers separated by an air space through which heated air can be moved to guard against ice accumulation. As an alternative to the two layers, other approved methods that protect against ice accumulation shall be permitted.

11.10.4.4 Roof drains shall be equipped with electrical elements to protect against ice buildup that can prevent the drains from functioning. Such heating elements shall be served by on-site standby electrical power in addition to the normal public service. As an alternative to such electrical elements, other approved methods that protect against ice accumulation shall be permitted.

11.10.5 Air-Supported and Air-Inflated Structures.

11.10.5.1 **General.** In addition to the general provisions of 11.10.1, the requirements of 11.10.5 shall apply to air-supported and air-inflated structures.

11.10.5.2 **Pressurization (Inflation) System.** The pressurization system shall consist of one or more operating blower units. The system shall include automatic control of auxiliary blower units to maintain the required operating pressure. Such equipment shall meet the following requirements:

- (1) Blowers shall be powered by continuous-rated motors at the maximum power required.
- (2) Blowers shall have personnel protection, such as inlet screens and belt guards.
- (3) Blower systems shall be weather protected.
- (4) Blower systems shall be equipped with backdraft check dampers.
- (5) Not less than two blower units shall be provided, each of which has capacity to maintain full inflation pressure with normal leakage.
- (6) The blowers shall be designed to be incapable of over-pressurization.
- (7) The auxiliary blower unit(s) shall operate automatically if there is any loss of internal pressure or if an operating blower unit becomes inoperative.
- (8) The design inflation pressure and the capacity of each blower system shall be certified by a professional engineer.

11.10.5.3 Standby Power System.

11.10.5.3.1 A fully automatic standby power system shall be provided. The system shall be either an auxiliary engine generator set capable of running the blower system or a supplementary blower unit that is sized for 1 times the normal operating capacity and is powered by an internal combustion engine.

11.10.5.3.2 The standby power system shall be fully automatic to ensure continuous inflation in the event of any failure of the primary power. The system shall be capable of operating continuously for a minimum of 4 hours.

11.10.5.3.3 The sizing and capacity of the standby power system shall be certified by a professional engineer.

11.10.6 Maintenance and Operation.

11.10.6.1 Instructions in both operation and maintenance shall be transmitted to the owner by the manufacturer of the tensioned-membrane, air-supported, or air-inflated structure.

11.10.6.2 Annual inspection and required maintenance of each structure shall be performed to ensure safety conditions. At least biennially, the inspection shall be performed by a professional engineer, registered architect, or individual certified by the manufacturer.

11.10.7 Services.**11.10.7.1 Fired Heaters.**

11.10.7.1.1 Only labeled heating devices shall be used.

11.10.7.1.2 Fuel-fired heaters and their installation shall be approved by the authority having jurisdiction.

11.10.7.1.3 Containers for liquefied petroleum gases shall be installed not less than 1525 mm (60 in.) from any temporary membrane structure and shall be in accordance with the provisions of NFPA 58, *Liquefied Petroleum Gas Code*.

11.10.7.1.4 Tanks shall be secured in the upright position and protected from vehicular traffic.

11.10.7.2 Electric Heaters.

11.10.7.2.1 Only labeled heaters shall be permitted.

11.10.7.2.2 Heaters used inside a temporary membrane structure shall be approved.

11.10.7.2.3 Heaters shall be connected to electricity by electric cable that is suitable for outside use and is of sufficient size to handle the electrical load.

11.11 Tents.**11.11.1 General.**

11.11.1.1 The provisions of Section 11.1 shall apply.

11.11.1.2 Tents shall be permitted only on a temporary basis.

11.11.1.3 Tents shall be erected to cover not more than 75 percent of the premises, unless otherwise approved by the authority having jurisdiction.

11.11.2 Flame Resistance.

11.11.2.1 All tent fabric shall be flame resistant in accordance with 10.3.1.

11.11.2.2 One of the following shall serve as evidence that the tent fabric materials have the required flame resistance:

- (1) The authority having jurisdiction shall require a certificate or other evidence of acceptance by an organization acceptable to the authority having jurisdiction.
- (2) The authority having jurisdiction shall require a report of tests made by other inspection authorities or organizations acceptable to the authority having jurisdiction.

11.11.2.3 Where required by the authority having jurisdiction, confirmatory field tests shall be conducted using test specimens from the original material, which shall have been affixed at the time of manufacture to the exterior of the tent.

11.11.3 Location and Spacing.

11.11.3.1 There shall be a minimum of 3050 mm (120 in.) between stake lines.

11.11.3.2 Adjacent tents shall be spaced to provide an area to be used as a means of emergency egress. Where 3050 mm (120 in.) between stake lines does not meet the requirements for means of egress, the distance necessary for means of egress shall govern.

11.11.3.3 Tents not occupied by the public and not used for the storage of combustible material shall be permitted to be erected less than 3050 mm (120 in.) from other structures where the authority having jurisdiction deems such close spacing to be safe from hazard to the public.

11.11.3.4 Tents, each not exceeding 112 m² (1200 ft²) in ground area and located in fairgrounds or similar open spaces, shall not be required to be separated from each other, provided that safety precautions meet the approval of the authority having jurisdiction.

11.11.3.5 The placement of tents relative to other structures shall be at the discretion of the authority having jurisdiction, with consideration given to occupancy, use, opening, exposure, and other similar factors.

11.11.4 Fire Hazards.

11.11.4.1 The ground enclosed by any tent, and the ground for a reasonable distance but for not less than 3050 mm (120 in.) outside of such a tent, shall be cleared of all flammable or combustible material or vegetation that is not used for necessary support equipment. The clearing work shall be accomplished to the satisfaction of the authority having jurisdiction prior to the erection of such a tent. The premises shall be kept free from such flammable or combustible materials during the period for which the premises are used by the public.

11.11.4.2 Where prohibited by the authority having jurisdiction, smoking shall not be permitted in any tent.

11.11.5 Fire-Extinguishing Equipment. Portable fire-extinguishing equipment of approved types shall be furnished and maintained in tents in such quantity and in such locations as directed by the authority having jurisdiction.

11.11.6 Services.**11.11.6.1 Fired Heaters.**

11.11.6.1.1 Only labeled heating devices shall be used.

11.11.6.1.2 Fuel-fired heaters and their installation shall be approved by the authority having jurisdiction.

11.11.6.1.3 Containers for liquefied petroleum gases shall be installed not less than 1525 mm (60 in.) from any tent and shall be in accordance with the provisions of NFPA 58, *Liquefied Petroleum Gas Code*.

11.11.6.1.4 Tanks shall be secured in the upright position and protected from vehicular traffic.

11.11.6.2 Electric Heaters.

11.11.6.2.1 Only labeled heaters shall be permitted.

11.11.6.2.2 Heaters used inside a tent shall be approved.

11.11.6.2.3 Heaters shall be connected to electricity by electric cable that is suitable for outside use and is of sufficient size to handle the electrical load.

Chapter 12 New Assembly Occupancies

12.1 General Requirements.

12.1.1 Application. The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as an assembly occupancy (*see 1.3.1*)
- (2) Additions made to, or used as, an assembly occupancy (*see 4.6.7*)
- (3) Alterations, modernizations, or renovations of existing assembly occupancies (*see 4.6.8*)
- (4) Existing buildings or portions thereof upon change of occupancy to an assembly occupancy (*see 4.6.12*)

12.1.2 Multiple Occupancies.

12.1.2.1 General. Multiple occupancies shall be in accordance with 6.1.14.

12.1.2.2* Simultaneous Occupancy. Exits shall be sufficient for simultaneous occupancy of both the assembly occupancy and other parts of the building, except where the authority having jurisdiction determines that the conditions are such that simultaneous occupancy will not occur.

12.1.2.3 Assembly and Mercantile Occupancies in Mall Buildings.

12.1.2.3.1 The provisions of Chapter 12 shall apply to the assembly occupancy tenant space.

12.1.2.3.2 The provisions of 36.4.4 shall be permitted to be used outside the assembly occupancy tenant space.

12.1.3* Definitions. A list of terms used in this chapter follows:

- (1) **Aisle Accessway.** See 3.3.8.
- (2) **Exhibit.** See 3.3.58.
- (3) **Exhibitor.** See 3.3.59.
- (4) **Exposition.** See 3.3.65.
- (5) **Exposition Facility.** See 3.3.69.1.
- (6) **Festival Seating.** See 3.3.188.1.
- (7) **Flow Time.** See 3.3.88.
- (8) **Fly Gallery.** See 3.3.89.
- (9) **Gridiron.** See 3.3.96.
- (10) **Legitimate Stage.** See 3.3.210.1.
- (11) **Life Safety Evaluation.** See 3.3.126.
- (12) **Multilevel Play Structure.** See 3.3.217.5.
- (13) **Multipurpose Assembly Occupancy.** See 3.3.152.2.1.
- (14) **Pinrail.** See 3.3.165.
- (15) **Platform.** See 3.3.166.
- (16) **Proscenium Wall.** See 3.3.229.2.
- (17) **Regular Stage.** See 3.3.210.2.
- (18) **Smoke-Protected Assembly Seating.** See 3.3.188.4.
- (19) **Special Amusement Building.** See 3.3.27.10.
- (20) **Stage.** See 3.3.210.
- (21) **Temporary Platform.** See 3.3.166.1.

12.1.4* Classification of Occupancy. See 6.1.2.

12.1.5 Classification of Hazard of Contents. Contents of assembly occupancies shall be classified in accordance with the provisions of Section 6.2.

12.1.6 Minimum Construction Requirements. The location of an assembly occupancy shall be limited as shown in Table 12.1.6, unless otherwise permitted by the following (*see 8.2.1*):

- (1) This requirement shall not apply to outdoor grandstands of Type I or Type II construction.
- (2) This requirement shall not apply to outdoor grandstands of Type III, Type IV, or Type V construction that meet the requirements of 12.4.8.
- (3) This requirement shall not apply to grandstands of noncombustible construction supported by the floor in a building meeting the construction requirements of Table 12.1.6.
- (4) This requirement shall not apply to assembly occupancies within mall buildings in accordance with 36.4.4.

12.1.7 Occupant Load.

12.1.7.1* General. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

12.1.7.1.1 In areas not in excess of 930 m² (10,000 ft²), the occupant load shall not exceed one person in 0.46 m² (5 ft²).

12.1.7.1.2 In areas in excess of 930 m² (10,000 ft²), the occupant load shall not exceed one person in 0.65 m² (7 ft²).

12.1.7.2 Waiting Spaces. In theaters and other assembly occupancies where persons are admitted to the building at times when seats are not available, or when the permitted occupant load has been reached based on 12.1.7.1 and persons are allowed to wait in a lobby or similar space until seats or space is available, the following requirements shall apply:

- (1) Such use of a lobby or similar space shall not encroach upon the required clear width of exits.
- (2) The waiting spaces shall be restricted to areas other than the required means of egress.
- (3) Exits shall be provided for the waiting spaces on the basis of one person for each 0.28 m² (3 ft²) of waiting space area.
- (4) Exits for waiting spaces shall be in addition to the exits specified for the main auditorium area and shall conform in construction and arrangement to the general rules for exits given in this chapter.

12.1.7.3 Life Safety Evaluation. Where the occupant load of an assembly occupancy exceeds 6000, a life safety evaluation shall be performed in accordance with 12.4.1.

12.1.7.4 Outdoor Facilities. In outdoor facilities, where approved by the authority having jurisdiction, the number of occupants who are each provided with not less than 1.4 m² (15 ft²) of lawn surface shall be permitted to be excluded from the maximum occupant load of 6000 of 12.1.7.3 in determining the need for a life safety evaluation.

12.2 Means of Egress Requirements.

12.2.1 General. All means of egress shall be in accordance with Chapter 7 and this chapter.

12.2.2 Means of Egress Components.

12.2.2.1 Components of means of egress shall be limited to the types described in 12.2.2.2 through 12.2.2.12.

12.2.2.2 Doors.

12.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

Table 12.1.6 Construction Type Limitations

Type of Construction	Below LED	LED	Number of Levels above LED			
			1	2	3	≥4
I(443)†‡§ I(332)†‡§ II(222)†‡§	Any assembly◊	Any assembly	Any assembly	Any assembly	Any assembly	Any assembly; If OL > 300◊
II(111)†‡§	Any assembly◊ Limited to 1 level below LED	Any assembly	Any assembly	Any assembly; If OL > 1000◊	Assembly with OL ≤ 1000◊	NP
III(211)‡ IV(2HH) V(111)	Any assembly◊ Limited to 1 level below LED	Any assembly	Any assembly	Any assembly; If OL > 300◊	Assembly with OL ≤ 1000◊	NP
II(000)	Assembly with OL ≤ 1000◊ Limited to 1 level below LED	Any assembly; If OL > 1000◊	Assembly with OL ≤ 300◊	NP	NP	NP
III(200) V(000)	Assembly with OL ≤ 1000◊ Limited to 1 level below LED	Assembly with OL ≤ 1000	Assembly with OL ≤ 300◊	NP	NP	NP

NP: Not permitted.

LED: Level of exit discharge.

OL: Occupant load.

Note: For the purpose of this table, a mezzanine is not counted as a level.

†Where every part of the structural framework of roofs in Type I or Type II construction is 6100 mm (240 in.) or more above the floor immediately below, omission of all fire protection of the structural members shall be permitted, including protection of trusses, roof framing, decking, and portions of columns above 6100 mm (240 in.).

‡Where seating treads and risers serve as floors, such seating treads and risers shall be permitted to be of 1-hour fire resistance-rated construction. Structural members supporting seating treads and risers shall conform to the requirements of Table 12.1.6. Joints between seating tread and riser units shall be permitted to be unrated, provided that such joints do not involve separation from areas containing high hazard contents and the facility is constructed and operated in accordance with 12.4.2.

§In open-air fixed seating facilities, including stadia, omission of fire protection of structural members exposed to the outside atmosphere shall be permitted where substantiated by an approved engineering analysis.

◊Permitted if all the following are protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7: (1) The level of the assembly occupancy, (2) any level below the level of the assembly occupancy, (3) in the case of an assembly occupancy located below the level of exit discharge, any level intervening between that level and the level of exit discharge, including the level of exit discharge.

12.2.2.2.2 Assembly occupancies with occupant loads of 300 or less in malls (see 36.4.4.2.2) shall be permitted to have horizontal or vertical security grilles or doors complying with 7.2.1.4.1.4 on the main entrance/exits.

12.2.2.2.3 Any door in a required means of egress from an area having an occupant load of 100 or more persons shall be permitted to be provided with a latch or lock only if the latch or lock is panic hardware or fire exit hardware complying with 7.2.1.7, unless otherwise permitted by the following:

- (1) This requirement shall not apply to delayed-egress locks as permitted in 12.2.2.2.5.
- (2) This requirement shall not apply to access-controlled egress doors as permitted in 12.2.2.2.6.

12.2.2.2.4 Locking devices complying with 7.2.1.5.4 shall be permitted to be used on a single door or a single pair of doors if both of the following conditions apply:

- (1) The door or pair of doors serve as the main exit and the assembly occupancy has an occupant load not greater than 500.
- (2) Any latching devices on such a door(s) from an assembly occupancy having an occupant load of 100 or more are released by panic hardware or fire exit hardware.

12.2.2.2.5 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted on doors other than main entrance/exit doors.

12.2.2.2.6 Doors in the means of egress shall be permitted to be equipped with an approved access control system complying with 7.2.1.6.2, and such doors shall not be locked from the egress side when the assembly occupancy is occupied. (See 7.2.1.1.3.)

12.2.2.2.7 Revolving doors complying with the requirements of 7.2.1.10 shall be permitted.

12.2.2.2.8 The provisions of 7.2.1.11.1.1 to allow turnstiles where revolving doors are permitted shall not apply.

12.2.2.2.9 No turnstiles or other devices that restrict the movement of persons shall be installed in any assembly occupancy in such a manner as to interfere with required means of egress facilities.

12.2.2.3 Stairs.

12.2.2.3.1 General. Stairs complying with 7.2.2 shall be permitted, unless one of the following criteria applies:

- (1) *Stairs serving seating that is designed to be repositioned shall not be required to comply with 7.2.2.3.1.
- (2) This requirement shall not apply to stages and platforms as permitted by 12.4.5.

12.2.2.3.2 Catwalk, Gallery, and Gridiron Stairs.

12.2.2.3.2.1 Noncombustible grated stair treads and landing floors shall be permitted in means of egress from lighting and access catwalks, galleries, and gridirons.

12.2.2.3.2.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted in means of egress from lighting and access catwalks, galleries, and gridirons.

12.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

12.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

12.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted, and the following alternatives shall also apply:

- (1) Ramps not part of an accessible means of egress and serving only stages or nonpublic areas shall be permitted to have a slope not steeper than 1 in 8.
- (2) Ramped aisles not part of an accessible means of egress shall be permitted to have a slope not steeper than 1 in 8.

12.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

12.2.2.8 Reserved.

12.2.2.9 Reserved.

12.2.2.10 Fire Escape Ladders.

12.2.2.10.1 Fire escape ladders complying with 7.2.9 shall be permitted.

12.2.2.10.2 For ladders serving catwalks, the three-person limitation in 7.2.9.1(3) shall be permitted to be increased to ten persons.

12.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

12.2.2.12 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

12.2.3 Capacity of Means of Egress.

12.2.3.1 The capacity of means of egress shall be in accordance with one of the following:

- (1) Section 7.3 for other than theater-type seating or smoke-protected assembly seating
- (2) 12.2.3.2 for rooms with theater-type seating or similar seating arranged in rows
- (3) 12.4.2 for smoke-protected assembly seating.

12.2.3.2* Minimum clear widths of aisles and other means of egress serving theater-type seating, or similar seating arranged in rows, shall be in accordance with Table 12.2.3.2.

Table 12.2.3.2 Capacity Factors

No. of Seats	Clear Width per Seat Served			
	Stairs		Passageways, Ramps, and Doorways	
	mm	in.	mm	in.
Unlimited	7.6 AB	0.3 AB	5.6 C	0.22 C

12.2.3.3 The minimum clear widths shown in Table 12.2.3.2 shall be modified in accordance with all of the following:

- (1) If risers exceed 178 mm in height, the stair width in Table 12.2.3.2 shall be multiplied by factor A, where A equals the following:

$$A = 1 + \frac{\text{riser height} - 178}{125}$$

- (2) If risers exceed 7 in. in height, the stair width in Table 12.2.3.2 shall be multiplied by factor A, where A equals the following:

$$A = 1 + \frac{\text{riser height} - 7}{5}$$

- (3) Stairs not having a handrail within a 760-mm (30-in.) horizontal distance shall be 25 percent wider than otherwise calculated; that is, their width shall be multiplied by factor B, where B equals the following:

$$B = 1.25$$

- (4) Ramps steeper than 1 in 10 slope where used in ascent shall have their width increased by 10 percent; that is, their width shall be multiplied by factor C, where C equals the following:

$$C = 1.10$$

12.2.3.4 Lighting and Access Catwalks. The requirements of 12.2.3.2 and 12.2.3.3 shall not apply to lighting and access catwalks as permitted by 12.4.5.9.

12.2.3.5 Reserved.

12.2.3.6 Main Entrance/Exit. Every assembly occupancy shall be provided with a main entrance/exit.

12.2.3.6.1 The main entrance/exit shall be of a width that accommodates one-half of the total occupant load and shall

be at the level of exit discharge or shall connect to a stairway or ramp leading to a street.

12.2.3.6.2 Each level of an assembly occupancy shall have access to the main entrance/exit, and such access shall have the capacity to accommodate 50 percent of the occupant load of such levels.

12.2.3.6.3 Where the main entrance/exit from an assembly occupancy is through a lobby or foyer, the aggregate capacity of all exits from the lobby or foyer shall be permitted to provide the required capacity of the main entrance/exit, regardless of whether all such exits serve as entrances to the building.

12.2.3.6.4 A bowling establishment shall have a main entrance/exit of a capacity that accommodates 50 percent of the total occupant load without regard to the number of aisles that it serves.

12.2.3.6.5* In assembly occupancies where there is no well-defined main entrance/exit, exits shall be permitted to be distributed around the perimeter of the building, provided that the total exit width furnishes not less than 100 percent of the width needed to accommodate the permitted occupant load.

12.2.3.7 Other Exits. Each level of an assembly occupancy shall have access to the main entrance/exit and shall be provided with additional exits of a width to accommodate not less than one-half of the total occupant load served by that level.

12.2.3.7.1 Additional exits shall discharge in accordance with 12.2.7.

12.2.3.7.2 Additional exits shall be located as far apart as practicable and as far from the main entrance/exit as practicable.

12.2.3.7.3 Additional exits shall be accessible from a cross aisle or a side aisle.

12.2.3.7.4 In assembly occupancies where there is no well-defined main entrance/exit, exits shall be permitted to be distributed around the perimeter of the building, provided that the total exit width furnishes not less than 100 percent of the width required to accommodate the permitted occupant load.

12.2.3.8 The width of any exit access corridor serving 50 or more persons shall be not less than 1120 mm (44 in.).

12.2.4* Number of Exits.

12.2.4.1 The number of exits shall be in accordance with Section 7.4, other than exits for fenced outdoor assembly occupancies in accordance with 12.2.4.4.

12.2.4.2 Reserved.

12.2.4.3 Reserved.

12.2.4.4 A fenced outdoor assembly occupancy shall have not less than two widely separated means of egress from the enclosure, unless otherwise required by one of the following:

- (1) If more than 6000 persons are to be served by such means of egress, there shall be not less than three means of egress.
- (2) If more than 9000 persons are to be served by such means of egress, there shall be not less than four means of egress.

12.2.4.5 Balconies or mezzanines having an occupant load not exceeding 50 shall be permitted to be served by a single means of egress, and such means of egress shall be permitted to lead to the floor below.

12.2.4.6 Balconies or mezzanines having an occupant load exceeding 50 but not exceeding 100 shall have not less than

two remote means of egress, but both such means of egress shall be permitted to lead to the floor below.

12.2.4.7 Balconies or mezzanines having an occupant load exceeding 100 shall have means of egress as described in 7.4.1.

12.2.4.8 A second means of egress shall not be required from lighting and access catwalks, galleries, and gridirons where a means of escape to a floor or a roof is provided. Ladders, alternating tread devices, or spiral stairs shall be permitted in such means of escape.

12.2.5 Arrangement of Means of Egress.

12.2.5.1 General.

12.2.5.1.1 Means of egress shall be arranged in accordance with Section 7.5.

12.2.5.1.2 A common path of travel shall be permitted for the first 6100 mm (240 in.) from any point where the common path serves any number of occupants, and for the first 23 m (75 ft) from any point where the common path serves not more than 50 occupants.

12.2.5.1.3 Dead-end corridors shall not exceed 6100 mm (240 in.).

12.2.5.2 Access Through Hazardous Areas. Means of egress from a room or space for assembly purposes shall not be permitted through kitchens, storerooms, restrooms, closets, legitimate stages, projection rooms, or hazardous areas as described in 12.3.2.

12.2.5.3 Auditorium and Area Floors. Where the floor area of auditoriums and arenas is used for assembly occupancy activities/events, not less than 50 percent of the occupant load shall have means of egress provided without passing through adjacent fixed seating areas.

12.2.5.4 General Requirements for Access and Egress Routes Within Assembly Areas.

12.2.5.4.1 Festival seating, as defined in 3.3.188.1, shall be prohibited within a building, unless otherwise permitted by the following:

- (1) Festival seating shall be permitted in assembly occupancies having occupant loads of 1000 or less.
- (2) Festival seating shall be permitted in assembly occupancies where occupant loads exceed 1000 and where an approved life safety evaluation has been performed. (*See 12.4.1.*)

12.2.5.4.2* Access and egress routes shall be maintained so that any individual is able to move without undue hindrance, on personal initiative and at any time, from an occupied position to the exits.

12.2.5.4.3* Access and egress routes shall be maintained so that crowd management, security, and emergency medical personnel are able to reach any individual at any time, without undue hindrance.

12.2.5.4.4* The width of aisle accessways and aisles shall provide sufficient egress capacity for the number of persons accommodated by the catchment area served by the aisle accessway or aisle in accordance with 12.2.3.2, or for smoke-protected assembly seating in accordance with 12.4.2.

12.2.5.4.5 Where aisle accessways or aisles converge to form a single path of egress travel, the required egress capacity of that path shall not be less than the combined required capacity of the converging aisle accessways and aisles.

12.2.5.4.6 Those portions of aisle accessways and aisles where egress is possible in either of two directions shall be uniform in required width unless otherwise permitted by 12.2.5.4.7.

12.2.5.4.7 The requirement of 12.2.5.4.6 shall not apply to those portions of aisle accessways where the required width, not including the seat space described by 12.2.5.7.3, does not exceed 305 mm (12 in.).

12.2.5.4.8 In the case of side boundaries for aisle accessways or aisles, other than those for nonfixed seating at tables, the clear width shall be measured to boundary elements such as walls, guardrails, handrails, edges of seating, tables, and side edges of treads, and said measurement shall be made horizontally to the vertical projection of the elements, resulting in the smallest width measured perpendicularly to the line of travel.

12.2.5.5* Aisle Accessways Serving Seating Not at Tables.

12.2.5.5.1* The required clear width of aisle accessways between rows of seating shall be determined as follows:

- (1) Horizontal measurements shall be made, between vertical planes, from the back of one seat to the front of the most forward projection of the seat immediately behind it.
- (2) Where the entire row consists of automatic or self-rising seats that comply with ASTM F 851, *Test Method for Self-Rising Seat Mechanisms*, the measurement shall be permitted to be made with the seats in the up position.

12.2.5.5.2 The aisle accessway between rows of seating shall have a clear width of not less than 305 mm (12 in.), and this minimum shall be increased as a function of row length in accordance with 12.2.5.5.4 and 12.2.5.5.5.

12.2.5.5.3 If used by not more than four persons, no minimum clear width shall be required for the portion of an aisle accessway having a length not exceeding 1830 mm (72 in.), measured from the center of the seat farthest from the aisle.

12.2.5.5.4* Rows of seating served by aisles or doorways at both ends shall not exceed 100 seats per row.

12.2.5.5.4.1 The 305-mm (12-in.) minimum clear width of aisle accessway between such rows shall be increased by 7.6 mm (0.3 in.) for every seat over a total of 14 but shall not be required to exceed 560 mm (22 in.).

12.2.5.5.4.2 The requirement of 12.2.5.5.4.1 shall not apply to smoke-protected assembly seating as permitted by 12.4.2.4.

12.2.5.5.5 Rows of seating served by an aisle or doorway at one end only shall have a path of travel not exceeding 9140 mm (360 in.) in length from any seat to an aisle.

12.2.5.5.5.1 The 305-mm (12-in.) minimum clear width of aisle accessway between rows of seating as specified in 12.2.5.5.5 shall be increased by 15 mm (0.6 in.) for every seat over a total of seven.

12.2.5.5.5.2 The requirements of 12.2.5.5.5 and 12.2.5.5.5.1 shall not apply to smoke-protected assembly seating as permitted by 12.4.2.5 and 12.4.2.6.

12.2.5.5.6 Rows of seating using tablet-arm chairs shall be permitted only if the clear width of aisle accessways complies with the requirements of 12.2.5.5 when measured under one of the following conditions:

- (1) The clear width is measured with the tablet arm in the usable position.

- (2) The clear width is measured with the tablet arm in the stored position where the tablet arm automatically returns to the stored position when raised manually to a vertical position in one motion and falls to the stored position by force of gravity.

12.2.5.5.7 The depth of seat boards shall not be less than 230 mm (9 in.) where the same level is not used for both seat boards and footboards.

12.2.5.5.8 Footboards, independent of seats, shall be provided so that there is no horizontal opening that allows the passage of a 13-mm (½-in.) diameter sphere.

12.2.5.6 Aisles Serving Seating Not at Tables.

12.2.5.6.1 General. Aisles shall be provided so that the number of seats served by the nearest aisle is in accordance with 12.2.5.5.2 through 12.2.5.5.5, unless otherwise permitted by the following:

- (1) Aisles shall not be required in bleachers, provided that all of the following conditions are met:
 - (a) Egress from the front row shall not be obstructed by a rail, a guard, or other obstruction.
 - (b) The row spacing shall be 710 mm (28 in.) or less.
 - (c) The rise per row, including the first row, shall be 150 mm (6 in.) or less.
 - (d) The number of rows shall not exceed 16.
 - (e) The seat spaces shall not be physically defined.
 - (f) Seat boards that are also used as stepping surfaces for descent shall provide a walking surface with a width not less than 305 mm (12 in.), and, where a depressed footboard exists, the gap between seat boards of adjacent rows shall not exceed 305 mm (12 in.), measured horizontally.
 - (g) The leading edges of seat boards used as stepping surfaces shall be provided with a contrasting marking stripe so that the location of the leading edge is readily apparent, particularly where viewed in descent and the following shall also apply:
 - i. The marking stripe shall be not less than 25 mm (1 in.) wide and shall not exceed 51 mm (2 in.) in width.
 - ii. The marking stripe shall not be required where bleacher surfaces and environmental conditions, under all conditions of use, are such that the location of each leading edge is readily apparent, particularly when viewed in descent.

12.2.5.6.2 Dead-End Aisles. Dead-end aisles shall not exceed 6100 mm (240 in.) in length, unless otherwise permitted by the following:

- (1) A dead-end aisle shall be permitted to exceed 6100 mm (240 in.) in length where seats served by the dead-end aisle are not more than 24 seats from another aisle, measured along a row of seats having a clear width of not less than 305 mm (12 in.) plus 15 mm (0.6 in.) for each additional seat over a total of 7 in the row.
- (2) A 16-row, dead-end aisle shall be permitted in folding and telescopic seating and grandstands.
- (3) Aisle termination in accordance with 12.4.2.7 for smoke-protected assembly seating shall be permitted.

12.2.5.6.3* Minimum Aisle Width. The minimum clear width of aisles shall be sufficient to provide egress capacity in accordance with 12.2.3.2 but shall be not less than the following:

- (1) 1220 mm (48 in.) for stairs having seating on each side, or 915 mm (36 in.) where aisle does not serve more than 50 seats
- (2) 915 mm (36 in.) for stairs having seating on only one side
- (3) 585 mm (23 in.) between a handrail and seating, or between a guardrail and seating where the aisle is subdivided by a handrail
- (4) 1065 mm (42 in.) for level or ramped aisles having seating on both sides, or 915 mm (36 in.) where aisle does not serve more than 50 seats
- (5) 915 mm (36 in.) for level or ramped aisles having seating on only one side
- (6) 585 mm (23 in.) between a handrail or guardrail and seating where the aisle does not serve more than five rows on one side

12.2.5.6.4* Aisle Stairs and Ramps. The following shall apply to aisle stairs and ramps:

- (1) Aisles having a gradient steeper than 1 in 20, but not steeper than 1 in 8, shall consist of a ramp.
- (2) Aisles having a gradient steeper than 1 in 8 shall consist of an aisle stair.
- (3) The marking stripe exemption of 12.2.5.6.8.3 shall not be permitted for aisle stairs.
- (4) Aisles in folding and telescopic seating shall be permitted to be stepped aisles.
- (5) The limitation on height between landings in Table 7.2.2.2.1(a) and Table 7.2.2.2.1(b) shall not apply to aisle stairs.

12.2.5.6.5 Aisle Stair Treads. Aisle stair treads shall meet the following criteria:

- (1) There shall be no variation in the depth of adjacent treads that exceeds 4.8 mm ($\frac{3}{16}$ in.).
- (2)*Treads shall be not less than 280 mm (11 in.).
- (3) All treads shall extend the full width of the aisle.

12.2.5.6.6 Aisle Stair Risers. Aisle stair risers shall meet the following criteria:

- (1) Riser heights shall be not less than 100 mm (4 in.), unless otherwise permitted by the following:
 - (a) The riser height of aisle stairs in folding and telescopic seating shall be permitted to be not less than 90 mm ($3\frac{1}{2}$ in.) but shall not exceed 280 mm (11 in.).
 - (b) Where the gradient of an aisle is steeper than 205 mm (8 in.) in rise in 280 mm (11 in.) of run for the purpose of maintaining necessary sight lines in the adjoining seating area, the riser height shall be permitted to exceed 205 mm (8 in.) but shall not exceed 230 mm (9 in.).
- (2) Riser heights shall not exceed 205 mm (8 in.), unless otherwise permitted by 12.2.5.6.6(3).
- (3) The riser height of aisle stairs in folding and telescopic seating shall be permitted to be not more than 280 mm (11 in.).
- (4) Riser heights shall be designed to be uniform in each aisle, and the construction-caused nonuniformities shall not exceed 4.8 mm ($\frac{3}{16}$ in.) between adjacent risers, unless the following conditions apply:
 - (a) Riser height shall be permitted to be nonuniform only for the purpose of accommodating changes in gradient necessary to maintain sight lines within a seating area, in which case the riser height shall be permitted to exceed 4.8 mm ($\frac{3}{16}$ in.) in any flight.

- (b) Where nonuniformities permitted by 12.2.5.6.6(4)(a) exceed 4.8 mm ($\frac{3}{16}$ in.) between adjacent risers, the exact location of such nonuniformities shall be indicated by a distinctive marking stripe on each tread at the nosing or leading edge adjacent to the nonuniform risers.

12.2.5.6.7* Aisle Handrails.

12.2.5.6.7.1 Ramped aisles having a gradient exceeding 1 in 20 and aisle stairs shall be provided with handrails at one side or along the centerline and in accordance with 7.2.2.4.4.1, 7.2.2.4.4.5, and 7.2.2.4.4.6.

12.2.5.6.7.2 Where seating exists on both sides of the aisle, the handrails shall be noncontinuous with gaps or breaks at intervals not exceeding five rows to facilitate access to seating and to allow crossing from one side of the aisle to the other.

12.2.5.6.7.3 The gaps or breaks permitted by 12.2.5.6.7.2 shall have a clear width of not less than 560 mm (22 in.) and shall not exceed 915 mm (36 in.), measured horizontally, and the handrail shall have rounded terminations or bends.

12.2.5.6.7.4 Where handrails are provided in the middle of aisle stairs, an additional intermediate rail shall be located approximately 305 mm (12 in.) below the main handrail.

12.2.5.6.7.5 Handrails shall not be required where otherwise permitted by the following:

- (1) Handrails shall not be required for ramped aisles having a gradient not steeper than 1 in 8 and having seating on both sides where the aisle does not serve as an accessible route.
- (2) The requirement for a handrail shall be satisfied by the use of a guard provided with a rail that complies with the graspability requirements for handrails and located at a consistent height between 865 mm and 1065 mm (34 in. and 42 in.), measured using one of the following methods:
 - (a) Vertically from the top of the rail to the leading edge (nosing) of stair treads
 - (b) Vertically from the top of the rail to the adjacent walking surface in the case of a ramp

12.2.5.6.8* Aisle Marking.

12.2.5.6.8.1 A contrasting marking stripe shall be provided on each tread at the nosing or leading edge so that the location of such tread is readily apparent, particularly when viewed in descent.

12.2.5.6.8.2 The marking stripe shall be not less than 25 mm (1 in.) wide and shall not exceed 51 mm (2 in.) in width.

12.2.5.6.8.3 The marking stripe shall not be required where tread surfaces and environmental conditions, under all conditions of use, are such that the location of each tread is readily apparent, particularly when viewed in descent.

12.2.5.7* Aisle Accessways Serving Seating at Tables.

12.2.5.7.1 The required clear width of an aisle accessway shall be not less than 305 mm (12 in.) where measured in accordance with 12.2.5.7.3 and shall be increased as a function of length in accordance with 12.2.5.7.4, unless otherwise permitted by 12.2.5.7.2.

12.2.5.7.2* If used by not more than four persons, no minimum clear width shall be required for the portion of an aisle accessway having a length not exceeding 1830 mm (72 in.) and located farthest from an aisle.

12.2.5.7.3* Where nonfixed seating is located between a table and an aisle accessway or aisle, the measurement of required clear width of the aisle accessway or aisle shall be made to a line 485 mm (19 in.), measured perpendicularly to the edge of the table, away from the edge of said table.

12.2.5.7.4* The minimum required clear width of an aisle accessway, measured in accordance with 12.2.5.4.8 and 12.2.5.7.3, shall be increased beyond the 305-mm (12-in.) requirement of 12.2.5.7.1 by 13 mm (½ in.) for each additional 305 mm (12 in.) or fraction thereof beyond 3660 mm (144 in.) of aisle accessway length, where measured from the center of the seat farthest from an aisle.

12.2.5.7.5 The path of travel along the aisle accessway shall not exceed 11 m (36 ft) from any seat to the closest aisle or egress doorway.

12.2.5.8 Aisles Serving Seating at Tables.

12.2.5.8.1* Aisles that contain steps or that are ramped, such as aisles serving dinner theater-style configurations, shall comply with the requirements of 12.2.5.6.

12.2.5.8.2* The width of aisles serving seating at tables shall be not less than 1120 mm (44 in.) where serving an occupant load exceeding 50, and 915 mm (36 in.) where serving an occupant load of 50 or fewer.

12.2.5.8.3* Where nonfixed seating is located between a table and an aisle, the measurement of required clear width of the aisle shall be made to a line 485 mm (19 in.), measured perpendicularly to the edge of the table, away from the edge of said table.

12.2.5.9 Approval of Layouts.

12.2.5.9.1 Where required by the authority having jurisdiction, plans drawn to scale showing the arrangement of furnishings or equipment shall be submitted to the authority by the building owner, manager, or authorized agent to substantiate conformance with the provisions of 12.2.5.

12.2.5.9.2 The layout plans shall constitute the only acceptable arrangement, unless one of the following criteria is met:

- (1) The plans are revised.
- (2) Additional plans are submitted and approved.
- (3) Temporary deviations from the specifications of the approved plans are used, provided that the occupant load is not increased and the intent of 12.2.5.9 is maintained.

12.2.6 Travel Distance to Exits. Exits shall be arranged so that the total length of travel from any point to reach an exit shall not exceed 61 m (200 ft) in any assembly occupancy, unless otherwise permitted by the following:

- (1) The travel distance shall not exceed 76 m (250 ft) in assembly occupancies protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (2) The travel distance requirement shall not apply to smoke-protected assembly seating as permitted by 12.4.2.8, 12.4.2.9, and 12.4.2.10.

12.2.7 Discharge from Exits.

12.2.7.1 Exit discharge shall comply with Section 7.7.

12.2.7.2 The level of exit discharge shall be measured at the point of principal entrance to the building.

12.2.7.3 Where the principal entrance to an assembly occupancy is via a terrace, either raised or depressed, such terrace shall be permitted to be considered to be the level of exit discharge for the purposes of Table 12.1.6 where the following criteria are met:

- (1) The terrace is at least as long, measured parallel to the building, as the total width of the exit(s) it serves but not less than 1525 mm (60 in.) long.
- (2) The terrace is at least as wide, measured perpendicularly to the building, as the exit(s) it serves but not less than 3050 mm (120 in.) wide.
- (3) Required stairs leading from the terrace to grade are protected in accordance with 7.2.2.6.3 or are not less than 3050 mm (120 in.) from the building.

12.2.8 Illumination of Means of Egress. Means of egress, other than for private party tents not exceeding 112 m² (1200 ft²), shall be illuminated in accordance with Section 7.8.

12.2.9 Emergency Lighting.

12.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9.

12.2.9.2 Private party tents not exceeding 112 m² (1200 ft²) shall not be required to have emergency lighting.

12.2.10 Marking of Means of Egress.

12.2.10.1 Means of egress shall be provided with signs in accordance with Section 7.10.

12.2.10.2 Exit markings shall not be required on the seating side of vomitories from seating areas where exit marking is provided in the concourse and where such marking is readily apparent from the vomitories.

12.2.11 Special Means of Egress Features.

12.2.11.1 Guards and Railings.

12.2.11.1.1* Sightline-Constrained Rail Heights. Unless subject to the requirements of 12.2.11.1.2, a fascia or railing system complying with the guard requirements of 7.2.2.4 and having a height of not less than 660 mm (26 in.) shall be provided where the floor or footboard elevation is more than 760 mm (30 in.) above the floor or grade below and where the fascia or railing system would otherwise interfere with the sightlines of immediately adjacent seating.

12.2.11.1.2 At Foot of Aisles.

12.2.11.1.2.1 A fascia or railing system complying with the guard requirements of 7.2.2.4 shall be provided for the full width of the aisle where the foot of the aisle is more than 760 mm (30 in.) above the floor or grade below.

12.2.11.1.2.2 The fascia or railing shall be not less than 915 mm (36 in.) high and shall provide not less than 1065 mm (42 in.), measured diagonally, between the top of the rail and the nosing of the nearest tread.

12.2.11.1.3 At Cross Aisles. Guards and railings at cross aisles shall meet the following criteria:

- (1) Cross aisles located behind seating rows shall be provided with railings not less than 660 mm (26 in.) above the adjacent floor of the aisle.
- (2) The requirement of 12.2.11.1.3(1) shall not apply where the backs of seats located at the front of the aisle project 610 mm (24 in.) or more above the adjacent floor of the aisle.

- (3) Where cross aisles exceed 760 mm (30 in.) above the floor or grade below, guards shall be provided in accordance with 7.2.2.4.

12.2.11.1.4 At Side and Back of Seating Areas. Guards complying with the guard requirements of 7.2.2.4 shall be provided with a height not less than 1065 mm (42 in.) above the aisle, aisle accessway, or footboard where the floor elevation exceeds 760 mm (30 in.) above the floor or grade to the side or back of seating.

12.2.11.1.5 Below Seating. Openings between footboards and seat boards shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

12.2.11.1.6 Locations Not Requiring Guards. Guards shall not be required in the following locations:

- (1) Guards shall not be required on the audience side of stages, of raised platforms, and of other raised floor areas such as runways, ramps, and side stages used for entertainment or presentations.
- (2) Permanent guards shall not be required at vertical openings in the performance area of stages.
- (3) Guards shall not be required where the side of an elevated walking surface is required to be open for the normal functioning of special lighting or for access and use of other special equipment.

12.3 Protection.

12.3.1 Protection of Vertical Openings. Any vertical opening shall be enclosed or protected in accordance with 8.6, unless otherwise permitted by the following:

- (1) *Stairs or ramps shall be permitted to be unenclosed between balconies or mezzanines and main assembly areas located below, provided that the balcony or mezzanine is open to the main assembly area.
- (2) Exit access stairs from lighting and access catwalks, galleries, and gridirons shall not be required to be enclosed.
- (3) Assembly occupancies protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7 shall be permitted to have unprotected vertical openings in accordance with 8.6.8.2.

12.3.2 Protection from Hazards.

12.3.2.1 Service Equipment, Hazardous Operations or Processes, and Storage Facilities.

12.3.2.1.1 Rooms containing high-pressure boilers, refrigerating machinery of other than the domestic refrigerator type, large transformers, or other service equipment subject to explosion shall meet the following requirements.

- (1) Such rooms shall not be located directly under or abutting required exits.
- (2) Such rooms shall be separated from other parts of the building by fire barriers in accordance with Section 8.3 that have a fire resistance rating of not less than 1 hour or shall be protected by automatic extinguishing systems in accordance with Section 8.7.

12.3.2.1.2 Rooms or spaces for the storage, processing, or use of materials specified in 12.3.2.1.2(1) through 12.3.2.1.2(3) shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour or protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:

(a) Boiler and furnace rooms, unless otherwise permitted by the following:

- i. The requirement of 12.3.2.1.2(1)(a) shall not apply to rooms enclosing furnaces, heating and air-handling equipment, or compressor equipment with a total aggregate input rating less than 211 MJ (200,000 Btu), provided that such rooms are not used for storage.
- ii. The requirements of 12.3.2.1.2(1)(a) shall not apply to attic locations of the rooms addressed in 12.3.2.1.2(1)(a)i provided such rooms comply with the draft stopping requirements of 8.6.10.

(b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction

(c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards

- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:

(a) Laundries

(b) Maintenance shops, including woodworking and painting areas

(c) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction

(d) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards

- (3) Where automatic extinguishing is used to meet the requirements of 12.3.2, the protection shall be permitted to be in accordance with 9.7.1.2.

12.3.2.2 Cooking Equipment. Cooking equipment shall be protected in accordance with 9.2.3 unless the cooking equipment meets one of the following:

(1) Outdoor equipment

(2) Portable equipment not flue connected

(3) Equipment used only for food warming

12.3.3 Interior Finish.

12.3.3.1 Interior finish shall be in accordance with Section 10.2.

12.3.3.2 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in all corridors and lobbies and shall be Class A in enclosed stairways.

12.3.3.3 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in general assembly areas having occupant loads of more than 300 and shall be Class A, Class B, or Class C in assembly areas having occupant loads of 300 or fewer.

12.3.3.4 Screens on which pictures are projected shall comply with requirements of Class A or Class B interior finish in accordance with Section 10.2.

12.3.3.5 Interior Floor Finish.

12.3.3.5.1 Interior floor finish shall comply with Section 10.2.

12.3.3.5.2 Interior floor finish in exit enclosures and exit access corridors and in spaces not separated from them by walls complying with 12.3.6 shall be not less than Class II.

12.3.3.5.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2, as applicable.

12.3.4 Detection, Alarm, and Communications Systems.

12.3.4.1 General. Assembly occupancies with occupant loads of more than 300 and all theaters with more than one audience-viewing room shall be provided with an approved fire alarm system in accordance with 9.6.1 and 12.3.4, unless otherwise permitted by the following:

- (1) Assembly occupancies that are a part of a multiple occupancy protected as a mixed occupancy (*see 6.1.14*) shall be permitted to be served by a common fire alarm system, provided that the individual requirements of each occupancy are met.
- (2) Voice communication or public address systems complying with 12.3.4.3.3 shall not be required to comply with 9.6.1.

12.3.4.2 Initiation.

12.3.4.2.1 Initiation of the required fire alarm system shall be by manual means in accordance with 9.6.2.1(1), and the system shall be provided with an emergency power source, unless otherwise permitted by the following:

- (1) This requirement shall not apply to fire alarm systems initiated by means of an approved automatic fire detection system in accordance with 9.6.2.1(2) that provides fire detection throughout the building.
- (2) This requirement shall not apply to fire alarm systems initiated by means of an approved automatic sprinkler system in accordance with 9.6.2.1(3) that provides fire detection and protection throughout the building.

12.3.4.2.2 The initiating device shall be capable of transmitting an alarm to a receiving station, located within the building, that is constantly attended when the assembly occupancy is occupied.

12.3.4.2.3* In assembly occupancies with occupant loads of more than 300, automatic detection shall be provided in all hazardous areas that are not normally occupied, unless such areas are protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

12.3.4.3 Notification. The required fire alarm system shall sound an audible alarm in a constantly attended receiving station within the building when occupied for purposes of initiating emergency action.

12.3.4.3.1 Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.

12.3.4.3.2 Reserved.

12.3.4.3.3 Occupant notification shall be by means of visible signals and voice announcements, either live or prerecorded, initiated by the person in the constantly attended location.

12.3.4.3.4 The announcement shall be made via an approved voice communication or public address system, provided with an emergency power source, that is audible above the ambient noise level of the assembly occupancy.

12.3.4.3.5 Where the authority having jurisdiction determines that a constantly attended location is impractical, a fire alarm system in accordance with Section 9.6 shall be used that meets the following criteria:

- (1) It shall be initiated by manual fire alarm boxes in accordance with 9.6.2.1(1) or other approved means.
- (2) It shall automatically provide prerecorded evacuation instructions in accordance with 9.6.3.10.

12.3.5 Extinguishment Requirements.

12.3.5.1 Buildings containing assembly occupancies with occupant loads of more than 300 shall be protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7 as follows (*see also 12.1.6, 12.2.6, 12.3.2, and 12.3.6*):

- (1) Throughout the story containing the assembly occupancy
- (2) Throughout all stories below the story containing the assembly occupancy
- (3) In the case of an assembly occupancy located below the level of exit discharge, throughout all stories intervening between that story and the level of exit discharge, including the level of exit discharge

12.3.5.2 The requirements of 12.3.5.1 shall not apply to the following:

- (1) Assembly occupancies used primarily for worship with fixed seating that are not part of a multiple occupancy protected as a mixed occupancy (*see 6.1.14*)
- (2)*Assembly occupancies consisting of a single multipurpose room of less than 1115 m² (12,000 ft²) that are not used for exhibition or display and are not part of a mixed occupancy
- (3) Gymnasiums, skating rinks, and swimming pools used exclusively for participant sports with no audience facilities for more than 300 persons
- (4) In the following locations in stadia and arenas:
 - (a) Over the floor area used for contest, performance, or entertainment
 - (b) Over the seating areas
 - (c) Over open-air concourses where an approved engineering analysis substantiates the ineffectiveness of the sprinkler protection due to building height and combustible loading
- (5) In the following areas in unenclosed stadia and arenas:
 - (a) In press boxes less than 93 m² (1000 ft²)
 - (b) In storage facilities less than 93 m² (1000 ft²) if enclosed with not less than 1-hour fire resistance-rated construction
 - (c) In enclosed areas underneath grandstands that comply with 12.4.8.5

12.3.5.3 Where another provision of this chapter requires an automatic sprinkler system, the sprinkler system shall be installed in accordance with 9.7.1.1(1).

12.3.6 Corridors. Interior corridors and lobbies shall be constructed in accordance with 7.1.3.1 and Section 8.3, unless otherwise permitted by the following:

- (1) Corridor and lobby protection shall not be required where assembly rooms served by the corridor or lobby have at least 50 percent of their exit capacity discharging directly to the outside, independent of corridors and lobbies.
- (2) Corridor and lobby protection shall not be required in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

- (3) Lobbies serving only one assembly area that meet the requirements for intervening rooms (*see* 7.5.1.6) shall not be required to have a fire resistance rating.
- (4) Where the corridor ceiling is an assembly having a 1-hour fire resistance rating where tested as a wall, the corridor walls shall be permitted to terminate at the corridor ceiling.
- (5) Corridor and lobby protection shall not be required in buildings protected throughout by an approved, total (complete) coverage smoke detection system, providing occupant notification and installed in accordance with Section 9.6.

12.4 Special Provisions.

12.4.1 Life Safety Evaluation.

12.4.1.1* Where a life safety evaluation is required by other provisions of the *Code*, it shall comply with the following:

- (1) The life safety evaluation shall be performed by persons acceptable to the authority having jurisdiction.
- (2) The life safety evaluation shall include a written assessment of safety measures for conditions listed in 12.4.1.2.
- (3) The life safety evaluation shall be approved annually by the authority having jurisdiction and shall be updated for special or unusual conditions.

12.4.1.2 Life safety evaluations shall include an assessment of the following conditions and related appropriate safety measures:

- (1) Nature of the events and the participants and attendees
- (2) Access and egress movement, including crowd density problems
- (3) Medical emergencies
- (4) Fire hazards
- (5) Permanent and temporary structural systems
- (6) Severe weather conditions
- (7) Earthquakes
- (8) Civil or other disturbances
- (9) Hazardous materials incidents within and near the facility
- (10) Relationships among facility management, event participants, emergency response agencies, and others having a role in the events accommodated in the facility

12.4.1.3* Life safety evaluations shall include assessments of both building systems and management features upon which reliance is placed for the safety of facility occupants, and such assessments shall consider scenarios appropriate to the facility.

12.4.2* Smoke-Protected Assembly Seating.

12.4.2.1 To be considered smoke protected, an assembly seating facility shall comply with the following:

- (1) All enclosed areas with walls and ceilings in buildings or structures containing smoke-protected assembly seating shall be protected with an approved, supervised automatic sprinkler system in accordance with Section 9.7, unless otherwise permitted by the following:
 - (a) The requirement of 12.4.2.1 (1) shall not apply to the floor area used for the contest, performance, or entertainment, provided that the roof construction is more than 15 m (50 ft) above the floor level and use is restricted to low fire hazard uses.
 - (b)*Sprinklers shall not be required to be located over the floor area used for contest, performance, or entertainment and over the seating areas where an

approved engineering analysis substantiates the ineffectiveness of the sprinkler protection due to building height and combustible loading.

- (2) All means of egress serving a smoke-protected assembly seating area shall be provided with smoke-actuated ventilation facilities or natural ventilation designed to maintain the level of smoke at not less than 1830 mm (72 in.) above the floor of the means of egress.

12.4.2.2 To use the provisions of smoke-protected assembly seating, a facility shall be subject to a life safety evaluation in accordance with 12.4.1.

12.4.2.3 Where using Table 12.4.2.3, the number of seats specified shall be within a single assembly space, and interpolation shall be permitted between the specific values shown. A single seating space shall be permitted to have multiple levels, floors or mezzanines. The minimum clear widths shown shall be modified in accordance with all of the following:

- (1) If risers exceed 178 mm in height, the stair width in Table 12.4.2.3 shall be multiplied by factor *A*, where *A* equals the following:

$$A = 1 + \frac{\text{riser height} - 178}{125}$$

- (2) If risers exceed 7 in. in height, the stair width in Table 12.4.2.3 shall be multiplied by factor *A*, where *A* equals the following:

$$A = 1 + \frac{\text{riser height} - 7}{5}$$

- (3) Stairs not having a handrail within a 760-mm (30-in.) horizontal distance shall be 25 percent wider than otherwise calculated; that is, their width shall be multiplied by factor *B*, where *B* equals the following:

$$B = 1.25$$

- (4) Ramps steeper than 1 in 10 slope where used in ascent shall have their width increased by 10 percent; that is, their width shall be multiplied by factor *C*, where *C* equals the following:

$$C = 1.10$$

Table 12.4.2.3 Capacity Factors for Smoke-Protected Assembly Seating

No. of Seats	Clear Width per Seat Served			
	Stairs		Passageways, Ramps, and Doorways	
	mm	in.	mm	in.
2,000	7.6 AB	0.300 AB	5.6 C	0.220 C
5,000	5.1 AB	0.200 AB	3.8 C	0.150 C
10,000	3.3 AB	0.130 AB	2.5 C	0.100 C
15,000	2.4 AB	0.096 AB	1.8 C	0.070 C
20,000	1.9 AB	0.076 AB	1.4 C	0.056 C
≥25,000	1.5 AB	0.060 AB	1.1 C	0.044 C

12.4.2.4 Where smoke-protected assembly seating conforms to the requirements of 12.4.2, for rows of seats served by aisles or doorways at both ends, the number of seats per row shall not exceed 100, and the clear width of not less than 305 mm (12 in.) for aisle accessways shall be increased by 7.6 mm (0.3 in.) for every additional seat beyond the number stipulated in Table 12.4.2.4; however, the minimum clear width shall not be required to exceed 560 mm (22 in.).

Table 12.4.2.4 Smoke-Protected Assembly Seating Aisle Accessways

Total Number of Seats in the Space	Number of Seats per Row Permitted to Have a Clear Width Aisle Accessway of Not Less than 305 mm (12 in.)	
	Aisle or Doorway at Both Ends of Row	Aisle or Doorway at One End of Row
<4,000	14	7
4,000–6,999	15	7
7,000–9,999	16	8
10,000–12,999	17	8
13,000–15,999	18	9
16,000–18,999	19	9
19,000–21,999	20	10
≥22,000	21	11

12.4.2.5 Where smoke-protected assembly seating conforms to the requirements of 12.4.2, for rows of seats served by an aisle or doorway at one end only, the aisle accessway clear width of not less than 305 mm (12 in.) shall be increased by 15 mm (0.6 in.) for every additional seat beyond the number stipulated in Table 12.4.2.4; however, the minimum clear width shall not be required to exceed 560 mm (22 in.).

12.4.2.6 Smoke-protected assembly seating conforming with the requirements of 12.4.2 shall be permitted to have a common path of travel of 15 m (50 ft) from any seat to a point where a person has a choice of two directions of egress travel.

12.4.2.7 Where smoke-protected assembly seating conforms to the requirements of 12.4.2, the dead ends in aisle stairs shall not exceed a distance of 21 rows, unless both of the following criteria are met:

- (1) The seats served by the dead-end aisle are not more than 40 seats from another aisle
- (2) The 40-seat distance is measured along a row of seats having an aisle accessway with a clear width of not less than 305 mm (12 in.) plus 7.6 mm (0.3 in.) for each additional seat above 7 in the row

12.4.2.8 Where smoke-protected assembly seating conforms to the requirements of 12.4.2, the travel distance from each seat to the nearest entrance to an egress vomitory portal or egress concourse shall not exceed 122 m (400 ft).

12.4.2.9 Where smoke-protected assembly seating conforms to the requirements of 12.4.2, the travel distance from the entrance to the vomitory portal or from the egress concourse to an approved egress stair, ramp, or walk at the building exterior shall not exceed 61 m (200 ft).

12.4.2.10 The travel distance requirements of 12.4.2.8 and 12.4.2.9 shall not apply to outdoor assembly seating facilities of Type I or Type II construction, where all portions of the means of egress are essentially open to the outside.

12.4.3 Limited Access or Underground Buildings.

12.4.3.1 Limited access or underground buildings shall comply with 12.4.3 and Section 11.7.

12.4.3.2 Underground buildings or portions of buildings having a floor level more than 9140 mm (360 in.) below the level of exit discharge shall comply with the requirements of 12.4.3.3 through 12.4.3.5, unless otherwise permitted by the following:

- (1) This requirement shall not apply to areas within buildings used only for service to the building, such as boiler/heater rooms, cable vaults, and dead storage.
- (2) This requirement shall not apply to auditoriums without intervening occupiable levels.

12.4.3.3 Each level more than 9140 mm (360 in.) below the level of exit discharge shall be divided into not less than two smoke compartments by a smoke barrier complying with Section 8.5 and shall have a 1-hour fire resistance rating.

12.4.3.3.1 Smoke compartments shall comply with the following:

- (1) Each smoke compartment shall have access to not less than one exit without passing through the other required compartment.
- (2) Any doors connecting required compartments shall be tight-fitting, minimum 1-hour rated fire door assemblies designed and installed to minimize smoke leakage and to close and latch automatically upon detection of smoke.

12.4.3.3.2 Each smoke compartment shall be provided with a mechanical means of moving people vertically, such as an elevator or escalator.

12.4.3.3.3 Each smoke compartment shall have an independent air supply and exhaust system capable of smoke control or smoke exhaust functions that provide a smoke exhaust rate of not less than six air changes per hour.

12.4.3.3.4 Throughout each smoke compartment shall be provided an automatic smoke detection system designed such that the activation of any two detectors causes the smoke control system to operate and the building voice alarm to sound.

12.4.3.4 Any required smoke control or exhaust system shall be provided with a standby power system complying with Article 701 of NFPA 70, *National Electrical Code*®.

12.4.3.5 The building shall be provided with an approved, supervised voice alarm system, in accordance with Section 9.6, that complies with 9.6.3.10 and provides a prerecorded evacuation message.

12.4.4 High-Rise Buildings. High-rise assembly occupancy buildings and high-rise mixed occupancy buildings that house assembly occupancies in the high-rise portions of the building shall comply with Section 11.8.

12.4.5 Stages and Platforms. (See 3.3.210 and 3.3.166.)

12.4.5.1 Materials and Design. Materials used in the construction of platforms and stages shall conform to the applicable requirements of the local building code.

12.4.5.2 Platform Construction.

12.4.5.2.1 Temporary platforms shall be permitted to be constructed of any materials.

12.4.5.2.2 The space between the floor and the temporary platform above shall not be used for any purpose other than the electrical wiring to platform equipment.

12.4.5.2.3 Permanent platforms shall be of the materials required for the type of building construction in which the permanent platform is located, except that the finish floor shall be permitted to be of wood in all types of construction.

12.4.5.2.4 Where the space beneath the permanent platform is used for storage or any purpose other than equipment wiring or plumbing, the floor construction shall not be less than 1-hour fire resistive.

12.4.5.3 Stage Construction.

12.4.5.3.1 Regular stages shall be of the materials required for the type of building construction in which they are located. In all cases, the finish floor shall be permitted to be of wood.

12.4.5.3.2 Legitimate stages shall be constructed of materials required for Type I buildings, except that the area extending from the proscenium opening to the back wall of the stage, and for a distance of 1830 mm (72 in.) beyond the proscenium opening on each side, shall be permitted to be constructed of steel or heavy timber covered with a wood floor not less than 38 mm (1½ in.) in actual thickness.

12.4.5.3.3 Openings through stage floors shall be equipped with tight-fitting traps with approved safety locks, and such traps shall comply with one of the following:

- (1) The traps shall be of wood having an actual thickness of not less than 38 mm (1½ in.).
- (2) The traps shall be of a material that provides fire and heat resistance at least equivalent to that provided by wood traps having an actual thickness of not less than 38 mm (1½ in.).

12.4.5.4 Accessory Rooms.

12.4.5.4.1 Workshops, storerooms, permanent dressing rooms, and other accessory spaces contiguous to stages shall be separated from each other and other building areas by 1-hour fire resistance-rated construction and protected openings.

12.4.5.4.2 The separation requirements of 12.4.5.4.1 shall not be required for stages having a floor area not exceeding 93 m² (1000 ft²).

12.4.5.5 Ventilators. Regular stages in excess of 93 m² (1000 ft²) and legitimate stages shall be provided with emergency ventilation to provide a means of removing smoke and combustion gases directly to the outside in the event of a fire and shall be achieved by one or a combination of the methods specified in 12.4.5.5.1 through 12.4.5.5.3.

12.4.5.5.1 Smoke Control.

12.4.5.5.1.1 A means complying with Section 9.3 shall be provided to maintain the smoke level at not less than 1830 mm (72 in.) above the highest level of assembly seating or above the top of the proscenium opening where a proscenium wall and opening protection are provided.

12.4.5.5.1.2 The system shall be activated independently by each of the following:

- (1) Activation of the sprinkler system in the stage area
- (2) Activation of smoke detectors over the stage area
- (3) Activation by manually operated switch at an approved location

12.4.5.5.1.3 The emergency ventilation system shall be supplied by both normal and standby power.

12.4.5.5.1.4 The fan(s) power wiring and ducts shall be located and properly protected to ensure not less than 20 minutes of operation in the event of activation.

12.4.5.5.2 Roof Vents.

12.4.5.5.2.1 Two or more vents shall be located near the center of and above the highest part of the stage area.

12.4.5.5.2.2 The vents shall be raised above the roof and shall provide a net-free vent area equal to 5 percent of the stage area.

12.4.5.5.2.3 Vents shall be constructed to open automatically by approved heat-activated devices, and supplemental means shall be provided for manual operation and periodic testing of the ventilator from the stage floor.

12.4.5.5.2.4 Vents shall be labeled.

12.4.5.5.3 Other Means.

12.4.5.5.3.1 Approved, alternate means of removing smoke and combustion gases shall be permitted.

12.4.5.6 Proscenium Walls. Legitimate stages shall be completely separated from the seating area by a proscenium wall of not less than 2-hour fire-resistive, noncombustible construction.

12.4.5.6.1 The proscenium wall shall extend not less than 1220 mm (48 in.) above the roof of the auditorium in combustible construction.

12.4.5.6.2 All openings in the proscenium wall of a legitimate stage shall be protected by a fire assembly having a 1½-hour fire protection rating.

12.4.5.6.3 The main proscenium opening used for viewing performances shall be provided with an automatic-closing fire-resistive curtain as described in 12.4.5.7.

12.4.5.6.4 Proscenium walls shall not be required in smoke-protected assembly seating facilities constructed and operated in accordance with 12.4.2.

12.4.5.7* Proscenium Opening Protection. Where required by 12.4.5.6, the proscenium opening shall be protected by a fire curtain or an approved water curtain complying with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

12.4.5.7.1 The fire curtain or water curtain shall be designed to activate upon automatic detection of a fire and upon manual activation.

12.4.5.7.2 The fire curtain shall be a listed minimum 20-minute opening protective assembly or shall be constructed as required in 12.4.5.7.2(A) through 12.4.5.7.2(G).

(A) **Fabrics.** Curtains shall be made of one or more thicknesses of a noncombustible fabric or a fabric with a noncombustible base material and shall comply with the following:

- (1) The fabric shall be permitted to be given a coating, provided that the modified fabric meets the criteria detailed in 12.4.5.7.
- (2) Curtain fabrics shall have a weight of not less than 1.3 kg/m² (2½ lb/yd²).

(B) Tensile Strength Requirements. Curtain fabric shall have tensile strength requirements of not less than 540 N/m (400 lbf/in.) in both the warp and fill directions.

(C) Wire-Insertion Reinforcement Requirements. The fabric shall be reinforced with noncorrosive wire intertwined with the base fiber at a rate of not less than one wire per yarn. Wire shall not be required, and fabric weight shall be permitted to be less than 1.3 kg/m² (2½ lb/yd²) if it can be substantiated by approved tests that it is equivalent in strength and durability.

(D) Fire Test. A sample curtain with not less than two vertical seams shall be subjected to the standard fire test specified in NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*, as applicable to nonbearing walls and partitions for a period of 30 minutes, as follows:

- (1) The curtain shall overlap the furnace edges by a length that is appropriate to seal the top and sides.
- (2) The curtain shall have a bottom pocket containing not less than 5 kg/linear m (4 lb/linear ft) of batten.
- (3) The unexposed surface of the curtain shall not glow, and neither flame nor smoke shall penetrate the curtain during the test period.
- (4) Unexposed surface temperature and hose stream test requirements shall not be applicable to this proscenium fire safety curtain test.

(E) Smoke Test. Curtain fabrics shall have a smoke density not to exceed 25 where tested in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, and the curtain fabric shall be tested in the condition in which it is to be used.

(F) Curtain Operation. The complete installation of every proscenium curtain shall be subjected to operating tests, as follows:

- (1) Any theater in which a proscenium curtain is placed shall not be open to public performance until after the proscenium curtain has been accepted and approved by the authority having jurisdiction.
- (2) The curtain shall be automatic-closing without the use of applied power.
- (3) The curtain also shall be capable of manual operation.

(G) Curtain Position. All proscenium curtains shall be in the closed position, except during performances, rehearsals, or similar activities.

12.4.5.8 Gridiron, Fly Galleries, and Pinrails.

12.4.5.8.1 Structural framing designed only for the attachment of portable or fixed theater equipment, gridirons, galleries, and catwalks shall be constructed of materials consistent with the building type of construction, and a fire resistance rating shall not be required.

12.4.5.8.2 Combustible materials shall be permitted to be used for the floors of galleries and catwalks of all types of construction.

12.4.5.9 Catwalks. The clear width of lighting and access catwalks and the means of egress from galleries and gridirons shall be not less than 560 mm (22 in.).

12.4.5.10 Fire Protection. Every stage shall be protected by an approved, supervised automatic sprinkler system in compliance with Section 9.7.

12.4.5.10.1 Protection shall be provided throughout the stage and in storerooms, workshops, permanent dressing rooms, and other accessory spaces contiguous to such stages.

12.4.5.10.2 Sprinklers shall not be required for stages 93 m² (1000 ft²) or less in area and 15 m (50 ft) or less in height where the following criteria are met:

- (1) Curtains, scenery, or other combustible hangings are not retractable vertically.
- (2) Combustible hangings are limited to borders, legs, a single main curtain, and a single backdrop.

12.4.5.10.3 Sprinklers shall not be required under stage areas less than 1220 mm (48 in.) in clear height that are used exclusively for chair or table storage and lined on the inside with 16-mm (¾-in.) Type X gypsum wallboard or the approved equivalent.

12.4.5.11 Flame-Retardant Requirements.

12.4.5.11.1 Combustible scenery of cloth, film, vegetation (dry), and similar materials shall meet the requirements of NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*.

12.4.5.11.2 Foamed plastics (*see definition of cellular or foamed plastic in 3.3.30*) shall be permitted to be used only by specific approval of the authority having jurisdiction.

12.4.5.11.3 Scenery and stage properties not separated from the audience by proscenium opening protection shall be of either noncombustible or limited-combustible materials.

12.4.5.11.4 In theaters, motion picture theaters, and television stage settings, with or without horizontal projections, and in simulated caves and caverns of foamed plastic, any single fuel package shall have a heat release rate not to exceed 100 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*.

12.4.5.12* Standpipes.

12.4.5.12.1 Regular stages over 93 m² (1000 ft²) in area and all legitimate stages shall be equipped with 38-mm (1½-in.) hose lines for first aid fire fighting at each side of the stage.

12.4.5.12.2 Hose connections shall be in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, unless Class II or Class III standpipes in accordance with NFPA 14, *Standard for the Installation of Standpipe, Private Hydrant, and Hose Systems*, are used.

12.4.6 Projection Rooms.

12.4.6.1 Projection rooms shall comply with 12.4.6.2 through 12.4.6.10.

12.4.6.2 Where cellulose nitrate film is used, the projection room shall comply with NFPA 40, *Standard for the Storage and Handling of Cellulose Nitrate Motion Picture Film*.

12.4.6.3 Film or video projectors or spotlights utilizing light sources that produce particulate matter, or toxic gases or light sources that produce hazardous radiation, without protective shielding, shall be located within a projection room complying with 12.3.2.1.2.

12.4.6.4 Every projection room shall be of permanent construction consistent with the construction requirements for the type of building in which the projection room is located and shall comply with the following:

- (1) Openings shall not be required to be protected.
- (2) The room shall have a floor area of not less than 7.4 m² (80 ft²) for a single machine and not less than 3.7 m² (40 ft²) for each additional machine.
- (3) Each motion picture projector, floodlight, spotlight, or similar piece of equipment shall have a clear working space of not less than 760 mm (30 in.) on each side and at its rear, but only one such space shall be required between adjacent projectors.

12.4.6.5 The projection room and the rooms appurtenant to it shall have a ceiling height of not less than 2285 mm (90 in.).

12.4.6.6 Each projection room for safety film shall have not less than one out-swinging, self-closing door not less than 760 mm (30 in.) wide and 2030 mm (80 in.) high.

12.4.6.7 The aggregate of ports and openings for projection equipment shall not exceed 25 percent of the area of the wall between the projection room and the auditorium, and all openings shall be provided with glass or other approved material so as to completely close the opening.

12.4.6.8 Projection room ventilation shall comply with 12.4.6.8.1 and 12.4.6.8.2.

12.4.6.8.1 Supply Air.

12.4.6.8.1.1 Each projection room shall be provided with adequate air supply inlets arranged to provide well-distributed air throughout the room.

12.4.6.8.1.2 Air inlet ducts shall provide an amount of air equivalent to the amount of air being exhausted by projection equipment.

12.4.6.8.1.3 Air shall be permitted to be taken from the outside; from adjacent spaces within the building, provided that the volume and infiltration rate is sufficient; or from the building air conditioning system, provided that it is arranged to supply sufficient air whether or not other systems are in operation.

12.4.6.8.2 Exhaust Air.

12.4.6.8.2.1 Projection booths shall be permitted to be exhausted through the lamp exhaust system.

12.4.6.8.2.2 The lamp exhaust system shall be positively interconnected with the lamp so that the lamp cannot operate unless there is sufficient airflow required for the lamp.

12.4.6.8.2.3 Exhaust air ducts shall terminate at the exterior of the building in such a location that the exhaust air cannot be readily recirculated into any air supply system.

12.4.6.8.2.4 The projection room ventilation system shall be permitted also to serve appurtenant rooms, such as the generator room and the rewind room.

12.4.6.9 Each projection machine shall be provided with an exhaust duct that draws air from each lamp and exhausts it directly to the outside of the building.

12.4.6.9.1 The lamp exhaust shall be permitted to exhaust air from the projection room to provide room air circulation.

12.4.6.9.2 Such ducts shall be of rigid materials, except for a flexible connector approved for the purpose.

12.4.6.9.3 The projection lamp and projection room exhaust systems shall be permitted to be combined but shall not be interconnected with any other exhaust system or return-air system within the buildings.

12.4.6.9.4 Specifications for electric arc and xenon projection equipment shall comply with 12.4.6.9.4(A) and 12.4.6.9.4(B).

(A) Electric Arc Projection Equipment. The exhaust capacity shall be 0.09 m³/s (200 ft³/min) for each lamp connected to the lamp exhaust system, or as recommended by the equipment manufacturer, and auxiliary air shall be permitted to be introduced into the system through a screened opening to stabilize the arc.

(B) Xenon Projection Equipment. The lamp exhaust system shall exhaust not less than 0.14 m³/s (300 ft³/min) per lamp, or not less than the exhaust volume required or recommended by the equipment manufacturer, whichever is greater.

12.4.6.10 Miscellaneous equipment and storage shall be protected as follows:

- (1) Each projection room shall be provided with rewind and film storage facilities.
- (2) Flammable liquids containers shall be permitted in projection rooms, provided that the following criteria are met:
 - (a) There are not more than four containers per projection room.
 - (b) No container has capacity exceeding 0.5 L (16 oz).
 - (c) Containers are of a nonbreakable type.
- (3) Appurtenant electrical equipment, such as rheostats, transformers, and generators, shall be permitted to be located within the booth or in a separate room of equivalent construction.

12.4.7* Special Amusement Buildings.

12.4.7.1* General. Special amusement buildings, regardless of occupant load, shall meet the requirements for assembly occupancies in addition to the requirements of 12.4.7, unless the special amusement building is a multilevel play structure that is not more than 3050 mm (120 in.) in height and has aggregate horizontal projections not exceeding 15 m² (160 ft²).

12.4.7.2* Automatic Sprinklers. Every special amusement building, other than buildings or structures not exceeding 3050 mm (120 in.) in height and not exceeding 15 m² (160 ft²) in aggregate horizontal projection, shall be protected throughout by an approved, supervised automatic sprinkler system installed and maintained in accordance with Section 9.7.

12.4.7.3 Temporary Water Supply. Where the special amusement building required to be sprinklered by 12.4.7.2 is movable or portable, the sprinkler water supply shall be permitted to be provided by an approved, temporary means.

12.4.7.4 Smoke Detection. Where the nature of the special amusement building is such that it operates in reduced lighting levels, the building shall be protected throughout by an approved automatic smoke detection system in accordance with Section 9.6.

12.4.7.5 Alarm Initiation. Actuation of any smoke detection system device shall sound an alarm at a constantly attended location on the premises.

12.4.7.6 Illumination. Actuation of the automatic sprinkler system, or any other suppression system, or actuation of a smoke detection system having an approved verification or cross-zoning operation capability shall provide the following:

- (1) Cause illumination in the means of egress to increase to that required by Section 7.8
- (2) Stop any conflicting or confusing sounds and visuals

12.4.7.7 Exit Marking.

12.4.7.7.1 Exit marking shall be in accordance with Section 7.10.

12.4.7.7.2 Floor proximity exit signs shall be provided in accordance with 7.10.1.6.

12.4.7.7.3* In special amusement buildings where mazes, mirrors, or other designs are used to confound the egress path, approved directional exit marking that becomes apparent in an emergency shall be provided.

12.4.7.8 Interior Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A throughout.

12.4.8 Grandstands.

12.4.8.1 General. Grandstands shall comply with the provisions of this chapter as modified by 12.4.8.

12.4.8.2 Seating.

12.4.8.2.1 Where grandstand seating without backs is used indoors, rows of seats shall be spaced not less than 560 mm (22 in.) back-to-back.

12.4.8.2.2 The depth of footboards and seat boards in grandstands shall be not less than 230 mm (9 in.); where the same level is not used for both seat foundations and footrests, footrests independent of seats shall be provided.

12.4.8.2.3 Seats and footrests of grandstands shall be supported securely and fastened in such a manner that they cannot be displaced inadvertently.

12.4.8.2.4 Individual seats or chairs shall be permitted only if secured in rows in an approved manner, unless seats do not exceed 16 in number and are located on level floors and within railed-in enclosures, such as boxes.

12.4.8.2.5 The maximum number of seats permitted between the farthest seat in an aisle in grandstands and bleachers shall not exceed that shown in Table 12.4.8.2.5.

Table 12.4.8.2.5 Maximum Number of Seats Between Farthest Seat and an Aisle

Application	Outdoors	Indoors
Grandstands	11	6
Bleachers	20	9
[(see 12.2.5.6.1(1))]		

12.4.8.3 Special Requirements — Wood Grandstands.

12.4.8.3.1 The distance between an outdoor wood grandstand and a building shall be not less than two-thirds of the grandstand height and in no case less than 3050 mm (120 in.) of a building, unless otherwise permitted by the following:

- (1) The distance requirement shall not apply to buildings of not less than 1-hour fire resistance-rated construction with openings protected against the fire exposure hazard created by the grandstand.
- (2) The distance requirement shall not apply where a wall of not less than 1-hour fire resistance-rated construction separates the grandstand from the building.

12.4.8.3.2 An outdoor wood grandstand unit shall not exceed 929 m² (10,000 ft²) in ground area or 61 m (200 ft) in length, and the following requirements also shall apply:

- (1) Grandstand units of the maximum size shall be placed not less than 6100 mm (240 in.) apart or shall be separated by walls of 1-hour fire resistance rating.
- (2) The number of grandstand units erected in any one group shall not exceed three.
- (3) Each group of grandstand units shall be separated from any other group by a wall of 2-hour fire resistance-rated construction extending 610 mm (24 in.) above the seat platforms or by an open space of not less than 15 m (50 ft).

12.4.8.3.3 The ground area or length required by 12.4.8.3.2 shall be permitted to be doubled where one of the following criteria is met:

- (1) Where the grandstand is constructed entirely of labeled fire-retardant-treated wood that has passed the standard rain test, ASTM D 2898, *Test Method for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing*
- (2) Where the grandstand is constructed of members conforming to dimensions for heavy timber construction (Type IV (2HH))

12.4.8.3.4 The highest level of seat platforms above the ground or the surface at the front of any wood grandstand shall not exceed 6100 mm (240 in.).

12.4.8.3.5 The highest level of seat platforms above the ground, or the surface at the front of a portable grandstand within a tent or membrane structure, shall not exceed 3660 mm (144 in.).

12.4.8.3.6 The height requirements specified in 12.4.8.3.4 and 12.4.8.3.5 shall be permitted to be doubled where constructed entirely of labeled fire-retardant-treated wood that has passed the standard rain test, ASTM D 2898, *Test Method for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing*, or where constructed of members conforming to dimensions for heavy timber construction (Type IV (2HH)).

12.4.8.4 Special Requirements — Portable Grandstands.

12.4.8.4.1 Portable grandstands shall conform to the requirements of 12.4.8 for grandstands and the requirements of 12.4.8.4.2 through 12.4.8.4.7.

12.4.8.4.2 Portable grandstands shall be self-contained and shall have within them all necessary parts to withstand and restrain all forces that might be developed during human occupancy.

12.4.8.4.3 Portable grandstands shall be designed and manufactured so that, if any structural members essential to the strength and stability of the structure have been omitted during erection, the presence of unused connection fittings shall make the omissions self-evident.

12.4.8.4.4 Portable grandstand construction shall be skillfully accomplished to produce the strength required by the design.

12.4.8.4.5 Portable grandstands shall be provided with base plates, sills, floor runners, or sleepers of such area that the permitted bearing capacity of the supporting material is not exceeded.

12.4.8.4.6 Where portable grandstands rest directly on a base of such character that it is incapable of supporting the load without appreciable settlement, mud sills of suitable material,

having sufficient area to prevent undue or dangerous settlement, shall be installed under base plates, runners, or sleepers.

12.4.8.4.7 All bearing surfaces of portable grandstands shall be in contact with each other.

12.4.8.5 Spaces Underneath Grandstands. Spaces underneath a grandstand shall be kept free of flammable or combustible materials, unless protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7, unless otherwise permitted by the following:

- (1) This requirement shall not apply to accessory uses of 28 m² (300 ft²) or less, such as ticket booths, toilet facilities, or concession booths where constructed of noncombustible or fire-resistive construction in otherwise non-sprinklered facilities.
- (2) This requirement shall not apply to rooms that are enclosed in not less than 1-hour fire resistance-rated construction and are less than 93 m² (1000 ft²) in otherwise nonsprinklered facilities.

12.4.8.6 Guards and Railings.

12.4.8.6.1 Railings or guards not less than 1065 mm (42 in.) above the aisle surface or footrest or not less than 915 mm (36 in.) vertically above the center of the seat or seat board surface, whichever is adjacent, shall be provided along those portions of the backs and ends of all grandstands where the seats are more than 1220 mm (48 in.) above the floor or ground.

12.4.8.6.2 The requirement of 12.4.8.6.1 shall not apply where an adjacent wall or fence affords equivalent safeguard.

12.4.8.6.3 Where the front footrest of any grandstand is more than 610 mm (24 in.) above the floor, railings or guards not less than 825 mm (33 in.) above such footrests shall be provided.

12.4.8.6.4 The railings required by 12.4.8.6.3 shall be permitted to be not less than 660 mm (26 in.) high in grandstands or where the front row of seats includes backrests.

12.4.8.6.5 Cross aisles located within the seating area shall be provided with rails not less than 660 mm (26 in.) high along the front edge of the cross aisle.

12.4.8.6.6 The railings specified by 12.4.8.6.5 shall not be required where the backs of the seats in front of the cross aisle project 610 mm (24 in.) or more above the surface of the cross aisle.

12.4.8.6.7 Vertical openings between guardrails and footboards or seat boards shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

12.4.8.6.8 An opening between the seat board and footboard located more than 760 mm (30 in.) above grade shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

12.4.9 Folding and Telescopic Seating.

12.4.9.1 General Folding and telescopic seating shall comply with the provisions of this chapter as modified by 12.4.9.

12.4.9.2 Seating.

12.4.9.2.1 The horizontal distance of seats, measured back-to-back, shall be not less than 560 mm (22 in.) for seats without backs, and the following requirements shall also apply:

- (1) There shall be a space of not less than 305 mm (12 in.) between the back of each seat and the front of each seat immediately behind it.
- (2) If seats are of the chair type, the 305-mm (12-in.) dimension shall be measured to the front edge of the rear seat in its normal unoccupied position.
- (3) All measurements shall be taken between plumb lines.

12.4.9.2.2 The depth of footboards (footrests) and seat boards in folding and telescopic seating shall be not less than 230 mm (9 in.).

12.4.9.2.3 Where the same level is not used for both seat foundations and footrests, footrests independent of seats shall be provided.

12.4.9.2.4 Individual chair-type seats shall be permitted in folding and telescopic seating only if firmly secured in groups of not less than three.

12.4.9.2.5 The maximum number of seats permitted between the farthest seat in an aisle in folding and telescopic seating shall not exceed that shown in Table 12.4.8.2.5.

12.4.9.3 Guards and Railings.

12.4.9.3.1 Railings or guards not less than 1065 mm (42 in.) above the aisle surface or footrest or not less than 915 mm (36 in.) vertically above the center of the seat or seat board surface, whichever is adjacent, shall be provided along those portions of the backs and ends of all folding and telescopic seating where the seats are more than 1220 mm (48 in.) above the floor or ground.

12.4.9.3.2 The requirement of 12.4.9.3.1 shall not apply where an adjacent wall or fence affords equivalent safeguard.

12.4.9.3.3 Where the front footrest of folding or telescopic seating is more than 610 mm (24 in.) above the floor, railings or guards not less than 825 mm (33 in.) above such footrests shall be provided.

12.4.9.3.4 The railings required by 12.4.9.3.3 shall be permitted to be not less than 660 mm (26 in.) high where the front row of seats includes backrests.

12.4.9.3.5 Cross aisles located within the seating area shall be provided with rails not less than 660 mm (26 in.) high along the front edge of the cross aisle.

12.4.9.3.6 The railings specified by 12.4.9.3.5 shall not be required where the backs of the seats in front of the cross aisle project 610 mm (24 in.) or more above the surface of the cross aisle.

12.4.9.3.7 Vertical openings between guardrails and footboards or seat boards shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

12.4.9.3.8 An opening between the seat board and footboard located more than 760 mm (30 in.) above grade shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

12.4.10 Airport Loading Walkways.

12.4.10.1 Airport loading walkways shall conform to NFPA 415, *Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways*, and the provisions of 12.4.10.2 and 12.4.10.3.

12.4.10.2 Doors in the egress path from the aircraft through the airport loading walkway into the airport terminal building shall meet the following criteria:

- (1) They shall swing in the direction of egress from the aircraft.
- (2)*They shall not be permitted to have delayed egress locks.

12.4.10.3 Exit access shall be unimpeded from the airport loading walkway to the non-secured public areas of the airport terminal building.

12.5 Building Services.

12.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

12.5.2 Heating, Ventilating, and Air Conditioning Equipment. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

12.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

12.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

12.6 Reserved.

12.7 Operating Features.

12.7.1 Special Provisions for Food Service Operations.

12.7.1.1 All devices in connection with the preparation of food shall be installed and operated to avoid hazard to the safety of occupants.

12.7.1.2 All devices in connection with the preparation of food shall be of an approved type and shall be installed in an approved manner.

12.7.1.3 Food preparation facilities shall be protected in accordance with 9.2.3 and shall not be required to have openings protected between food preparation areas and dining areas.

12.7.1.4 Portable cooking equipment that is not flue-connected shall be permitted only as follows:

- (1) Equipment fueled by small heat sources that can be readily extinguished by water, such as candles or alcohol-burning equipment, including solid alcohol, shall be permitted to be used, provided that precautions satisfactory to the authority having jurisdiction are taken to prevent ignition of any combustible materials.
- (2) Candles shall be permitted to be used on tables used for food service where securely supported on substantial non-combustible bases located to avoid danger of ignition of combustible materials and only where approved by the authority having jurisdiction.
- (3) Candle flames shall be protected.
- (4) "Flaming sword" or other equipment involving open flames and flamed dishes, such as cherries jubilee or crêpe suzette, shall be permitted to be used, provided that precautions subject to the approval of the authority having jurisdiction are taken.
- (5)*Listed and approved LP-Gas commercial food service appliances shall be permitted to be used where in accordance with NFPA 58, *Liquefied Petroleum Gas Code*.

12.7.2 Open Flame Devices and Pyrotechnics. No open flame devices or pyrotechnic devices shall be used in any assembly occupancy, unless otherwise permitted by the following:

- (1) Pyrotechnic special effect devices shall be permitted to be used on stages before proximate audiences for ceremonial or religious purposes, as part of a demonstration in exhibits, or as part of a performance, provided that both of the following criteria are met:
 - (a) Precautions satisfactory to the authority having jurisdiction are taken to prevent ignition of any combustible material.
 - (b) Use of the pyrotechnic device complies with NFPA 1126, *Standard for the Use of Pyrotechnics before a Proximate Audience*.
- (2) Flame effects before an audience shall be permitted in accordance with NFPA 160, *Standard for Flame Effects Before an Audience*.
- (3) Open flame devices shall be permitted to be used in the following situations, provided that precautions satisfactory to the authority having jurisdiction are taken to prevent ignition of any combustible material or injury to occupants:
 - (a)*For ceremonial or religious purposes
 - (b) On stages and platforms where part of a performance
 - (c) Where candles on tables are securely supported on substantial noncombustible bases and candle flame is protected
- (4) This requirement shall not apply to heat-producing equipment complying with 9.2.2.
- (5) This requirement shall not apply to food service operations in accordance with 12.7.1.
- (6) Gas lights shall be permitted to be used, provided that precautions are taken, subject to the approval of the authority having jurisdiction, to prevent ignition of any combustible materials.

12.7.3 Furnishings, Decorations, and Scenery.

12.7.3.1 Fabrics and films used for decorative purposes, all draperies and curtains, and similar furnishings shall be in accordance with the provisions of 10.3.1.

12.7.3.2 The authority having jurisdiction shall impose controls on the quantity and arrangement of combustible contents in assembly occupancies to provide an adequate level of safety to life from fire.

12.7.3.3* Exposed foamed plastic materials and unprotected materials containing foamed plastic used for decorative purposes or stage scenery shall have a heat release rate not exceeding 100 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*.

12.7.3.4 The requirement of 12.7.3.3 shall not apply to individual foamed plastic items and items containing foamed plastic where the foamed plastic does not exceed 0.45 kg (1 lb) in weight.

12.7.4 Special Provisions for Exposition Facilities.

12.7.4.1 General. No display or exhibit shall be installed or operated to interfere in any way with access to any required exit or with the visibility of any required exit or required exit sign; nor shall any display block access to fire-fighting equipment.

12.7.4.2 Materials Not On Display. A storage room having an enclosure consisting of a smoke barrier having a fire resistance rating of 1 hour and protected by an automatic extinguishing system shall be provided for combustible materials not on display, including combustible packing crates used to ship exhibitors' supplies and products.

12.7.4.3 Exhibits.

12.7.4.3.1 Exhibits shall comply with 12.7.4.3.2 through 12.7.4.3.11.

12.7.4.3.2 The travel distance within the exhibit booth or exhibit enclosure to an exit access aisle shall not exceed 15 m (50 ft).

12.7.4.3.3 The upper deck of multilevel exhibits exceeding 28 m² (300 ft²) shall have not less than two remote means of egress.

12.7.4.3.4 Exhibit booths shall be constructed of the following:

- (1) Noncombustible or limited-combustible materials
- (2) Wood exceeding 6.3 mm (¼ in.) nominal thickness or wood not exceeding 6.3 mm (¼ in.) nominal thickness that is pressure-treated, fire-retardant wood meeting the requirements of NFPA 703, *Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*
- (3)*Flame-retardant materials complying with NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*
- (4) Textile wall coverings, such as carpeting and similar products used as wall or ceiling finishes, complying with the provisions of 10.2.2 and 10.2.4
- (5) Plastics limited to those that comply with 12.3.3 and Section 10.2
- (6) Foamed plastics and materials containing foamed plastics having a heat release rate for any single fuel package that does not exceed 100 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*
- (7) Cardboard, honeycombed paper, and other combustible materials having a heat release rate for any single fuel package that does not exceed 150 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*

12.7.4.3.5 Curtains, drapes, and decorations shall comply with the applicable portions of 10.3.1.

12.7.4.3.6 Acoustical and decorative material including, but not limited to, cotton, hay, paper, straw, moss, split bamboo, and wood chips shall be flame-retardant treated to the satisfaction of the authority having jurisdiction.

12.7.4.3.6.1 Materials that cannot be treated for flame retardancy shall not be used.

12.7.4.3.6.2 Foamed plastics and materials containing foamed plastics and used as decorative objects such as, but not limited to, mannequins, murals, and signs shall have a heat release rate for any single fuel package that does not exceed 150 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*.

12.7.4.3.6.3 Where the aggregate area of acoustical and decorative materials is less than 10 percent of the individual floor or wall area, such materials shall be permitted to be used subject to the approval of the authority having jurisdiction.

12.7.4.3.7 The following shall be protected by automatic extinguishing systems:

- (1) Single-level exhibit booths exceeding 28 m² (300 ft²) and covered with a ceiling
- (2) Each level of multilevel exhibit booths, including the uppermost level where the uppermost level is covered with a ceiling

12.7.4.3.7.1 The requirements of 12.7.4.3.7 shall not apply where otherwise permitted by the following:

- (1) Ceilings that are constructed of open grate design or listed dropout ceilings in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall not be considered ceilings within the context of 12.7.4.3.7.
- (2) Vehicles, boats, and similar exhibited products having over 9.3 m² (100 ft²) of roofed area shall be provided with smoke detectors acceptable to the authority having jurisdiction.
- (3)*The requirement of 12.7.4.3.7(2) shall not apply where fire protection of multilevel exhibit booths is consistent with the criteria developed through a life safety evaluation of the exhibition hall in accordance with 12.4.1, subject to approval of the authority having jurisdiction.

12.7.4.3.7.2 A single exhibit or group of exhibits with ceilings that do not require sprinklers shall be separated by a distance of not less than 3050 mm (120 in.) where the aggregate ceiling exceeds 28 m² (300 ft²).

12.7.4.3.7.3 The water supply and piping for the sprinkler system shall be permitted to be of an approved, temporary means that is provided by a domestic water supply, a standpipe system, or a sprinkler system.

12.7.4.3.8 Open flame devices within exhibit booths shall comply with 12.7.2.

12.7.4.3.9 Cooking and food-warming devices in exhibit booths shall comply with 12.7.1 and the following:

- (1) Gas-fired devices shall comply with the following:
 - (a) Natural gas-fired devices shall comply with 9.1.1.
 - (b) The requirement of 12.7.4.3.9(1)(a) shall not apply to compressed natural gas where permitted by the authority having jurisdiction.
 - (c) The use of LP-Gas cylinders shall be prohibited.
 - (d) Nonrefillable LP-Gas cylinders shall be approved for use where permitted by the authority having jurisdiction.
- (2) The devices shall be isolated from the public by not less than 1220 mm (48 in.) or by a barrier between the devices and the public.
- (3) Multi-well cooking equipment using combustible oils or solids shall comply with 9.2.3.
- (4) Single-well cooking equipment using combustible oils or solids shall meet the following criteria:
 - (a) They shall have lids available for immediate use.
 - (b) They shall be limited to 0.2 m² (288 in.²) of cooking surface.
 - (c) They shall be placed on noncombustible surface materials.
 - (d) They shall be separated from each other by a horizontal distance of not less than 610 mm (24 in.).
 - (e) The requirement of 12.7.4.3.9(4)(d) shall not apply to multiple single-well cooking equipment where the aggregate cooking surface area does not exceed 0.2 m² (288 in.²).

- (f) They shall be kept at a horizontal distance of not less than 610 mm (24 in.) from any combustible material.
- (5) A portable fire extinguisher in accordance with 9.7.4.1 shall be provided within the booth for each device, or an approved automatic extinguishing system shall be provided.

12.7.4.3.10 Combustible materials within exhibit booths shall be limited to a one-day supply. Storage of combustible materials behind the booth shall be prohibited. (*See 12.7.3.2 and 12.7.4.2.*)

12.7.4.3.11 Plans for the exposition, in an acceptable form, shall be submitted to the authority having jurisdiction for approval prior to setting up any exhibit.

12.7.4.3.11.1 The plan shall show all details of the proposed exposition.

12.7.4.3.11.2 No exposition shall occupy any exposition facility without approved plans.

12.7.4.4 Vehicles. Vehicles on display within an exposition facility shall comply with 12.7.4.4.1 through 12.7.4.4.5.

12.7.4.4.1 All fuel tank openings shall be locked and sealed in an approved manner to prevent the escape of vapors; fuel tanks shall not contain in excess of one-half their capacity or contain in excess of 38 L (10 gal) of fuel, whichever is less.

12.7.4.4.2 At least one battery cable shall be removed from the batteries used to start the vehicle engine, and the disconnected battery cable shall then be taped.

12.7.4.4.3 Batteries used to power auxiliary equipment shall be permitted to be kept in service.

12.7.4.4.4 Fueling or defueling of vehicles shall be prohibited.

12.7.4.4.5 Vehicles shall not be moved during exhibit hours.

12.7.4.5 Prohibited Materials.

12.7.4.5.1 The following items shall be prohibited within exhibit halls:

- (1) Compressed flammable gases
- (2) Flammable or combustible liquids
- (3) Hazardous chemicals or materials
- (4) Class II or greater lasers, blasting agents, and explosives

12.7.4.5.2 The authority having jurisdiction shall be permitted to allow the limited use of any items specified in 12.7.4.5.1 under special circumstances.

12.7.4.6 Alternatives. See Section 1.4.

12.7.5* Crowd Managers.

12.7.5.1 In assembly occupancies having occupant loads exceeding 1000, trained crowd managers or crowd manager supervisors shall be provided at a ratio of 1 crowd manager/supervisor for every 250 occupants, unless otherwise permitted by the following:

- (1) This requirement shall not apply to assembly occupancies used exclusively for religious worship with an occupant load not exceeding 2000.
- (2) The ratio of trained crowd managers to occupants shall be permitted to be reduced where, in the opinion of the authority having jurisdiction, the existence of an approved, supervised automatic sprinkler system and the nature of the event warrant.

12.7.5.2 The crowd manager shall receive approved training in crowd management techniques.

12.7.6* Drills.

12.7.6.1 The employees or attendants of assembly occupancies shall be trained and drilled in the duties they are to perform in case of fire, panic, or other emergency to effect orderly exiting.

12.7.6.2 Employees or attendants of assembly occupancies shall be instructed in the proper use of portable fire extinguishers and other manual fire suppression equipment where provided.

12.7.6.3* In the following assembly occupancies, an audible announcement shall be made, or a projected image shall be shown, prior to the start of each program that notifies occupants of the location of the exits to be used in case of a fire or other emergency:

- (1) Theaters
- (2) Motion picture theaters
- (3) Auditoriums
- (4) Other similar assembly occupancies with occupant loads exceeding 300 where there are noncontinuous programs

12.7.6.4 The requirement of 12.7.6.3 shall not apply to assembly occupancies in schools where used for nonpublic events.

12.7.7 Smoking.

12.7.7.1 Smoking in assembly occupancies shall be regulated by the authority having jurisdiction.

12.7.7.2 In rooms or areas where smoking is prohibited, plainly visible signs shall be posted that read as follows:

NO SMOKING

12.7.7.3 No person shall smoke in prohibited areas that are so posted, unless permitted by the authority having jurisdiction under both of the following conditions:

- (1) Smoking shall be permitted on a stage only where it is a necessary and rehearsed part of a performance
- (2) Smoking shall be permitted only where the smoker is a regular performing member of the cast.

12.7.7.4 Where smoking is permitted, suitable ashtrays or receptacles shall be provided in convenient locations.

12.7.8 Seating.

12.7.8.1 Secured Seating.

12.7.8.1.1 Seats in assembly occupancies accommodating more than 200 persons shall be securely fastened to the floor, except where fastened together in groups of not less than three and not exceeding seven and as permitted by 12.7.8.2.

12.7.8.1.2 All seats in balconies and galleries shall be securely fastened to the floor, except in places of religious worship.

12.7.8.2 Unsecured Seating.

12.7.8.2.1 Seats not secured to the floor shall be permitted in restaurants, night clubs, and other occupancies where fastening seats to the floor might be impracticable.

12.7.8.2.2 Unsecured seats shall be permitted, provided that, in the area used for seating, excluding such areas as dance floors and stages, there is not more than one seat for each 1.4 m² (15 ft²) of net floor area, and adequate aisles to reach exits are maintained at all times.

12.7.8.2.3 Seating diagrams shall be submitted for approval by the authority having jurisdiction to permit an increase in occupant load per 7.3.1.3.

12.7.8.3 Occupant Load Posting.

12.7.8.3.1 Every room constituting an assembly occupancy and not having fixed seats shall have the occupant load of the room posted in a conspicuous place near the main exit from the room.

12.7.8.3.2 Approved signs shall be maintained in a legible manner by the owner or authorized agent.

12.7.8.3.3 Signs shall be durable and shall indicate the number of occupants permitted for each room use.

12.7.9 Maintenance of Outdoor Grandstands.

12.7.9.1 The owner shall provide for not less than annual inspection and required maintenance of each outdoor grandstand to ensure safe conditions.

12.7.9.2 At least biennially, the inspection shall be performed by a professional engineer, registered architect, or individual certified by the manufacturer.

12.7.9.3 Where required by the authority having jurisdiction, the owner shall provide certification that such inspection has been performed.

12.7.10 Maintenance and Operation of Folding and Telescopic Seating.

12.7.10.1 Instructions in both maintenance and operation shall be transmitted to the owner by the manufacturer of the seating or his or her representative.

12.7.10.2 Maintenance and operation of folding and telescopic seating shall be the responsibility of the owner or his or her duly authorized representative and shall include the following:

- (1) During operation of the folding and telescopic seats, the opening and closing shall be supervised by responsible personnel who shall ensure that the operation is in accordance with the manufacturer's instructions.
- (2) Only attachments specifically approved by the manufacturer for the specific installation shall be attached to the seating.
- (3) An annual inspection and required maintenance of each grandstand shall be performed to ensure safe conditions. At least biennially, the inspection shall be performed by a professional engineer, registered architect, or individual certified by the manufacturer.

12.7.11 Clothing Clothing and personal effects shall not be stored in corridors, unless otherwise permitted by the following:

- (1) This requirement shall not apply to corridors protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (2) This requirement shall not apply to corridor areas protected by a smoke detection system in accordance with Section 9.6.
- (3) This requirement shall not apply to storage in metal lockers, provided that the required egress width is maintained.

Chapter 13 Existing Assembly Occupancies**13.1 General Requirements.****13.1.1 Application.**

13.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as assembly occupancies, unless otherwise specified by 13.1.1.2. (See 3.3.152.2 for definition of assembly occupancy; see also 12.1.1.)

13.1.1.2 An existing building housing an assembly occupancy established prior to the effective date of this *Code* shall be permitted to be approved for continued use if it conforms to or is made to conform to the provisions of this *Code* to the extent that, in the opinion of the authority having jurisdiction, reasonable life safety against the hazards of fire, explosion, and panic is provided and maintained.

13.1.1.3 Additions to existing buildings shall conform to the requirements for new construction.

13.1.1.4 Existing portions of buildings shall be upgraded if the addition results in an increase in the required minimum number of separate means of egress in accordance with 7.4.1.2.

13.1.1.5 Existing portions of the structure shall not be required to be modified, provided that both of the following are met:

- (1) The new construction has not diminished the fire safety features of the facility.
- (2) The addition does not result in an increase in the required minimum number of separate means of egress in accordance with 7.4.1.2.

13.1.1.6 An assembly occupancy in which an occupant load increase results in an increase in the required minimum number of separate means of egress, in accordance with 7.4.1.2, shall meet the requirements for new construction.

13.1.2 Multiple Occupancies.

13.1.2.1 General. Multiple occupancies shall be in accordance with 6.1.14.

13.1.2.2* Simultaneous Occupancy. Exits shall be sufficient for simultaneous occupancy of both the assembly occupancy and other parts of the building, except where the authority having jurisdiction determines that the conditions are such that simultaneous occupancy will not occur.

13.1.2.3 Assembly and Mercantile Occupancies in Mall Buildings.

13.1.2.3.1 The provisions of Chapter 13 shall apply to the assembly occupancy tenant space.

13.1.2.3.2 The provisions of 37.4.4 shall be permitted to be used outside the assembly occupancy tenant space.

13.1.3* Definitions. A list of terms used in the chapter follows:

- (1) **Aisle Accessway.** See 3.3.8.
- (2) **Exhibit.** See 3.3.58.
- (3) **Exhibitor.** See 3.3.59.
- (4) **Exposition.** See 3.3.65.
- (5) **Exposition Facility.** See 3.3.69.1.
- (6) **Festival Seating.** See 3.3.188.1.
- (7) **Flow Time.** See 3.3.88.
- (8) **Fly Gallery.** See 3.3.89.
- (9) **Gridiron.** See 3.3.96.
- (10) **Legitimate Stage.** See 3.3.210.1.
- (11) **Life Safety Evaluation.** See 3.3.126.
- (12) **Multilevel Play Structure.** See 3.3.217.5.
- (13) **Pinrail.** See 3.3.165.
- (14) **Platform.** See 3.3.166.
- (15) **Proscenium Wall.** See 3.3.229.2.
- (16) **Regular Stage.** See 3.3.210.2.
- (17) **Smoke-Protected Assembly Seating.** See 3.3.188.4.
- (18) **Special Amusement Building.** See 3.3.27.10.
- (19) **Stage.** See 3.3.210.
- (20) **Temporary Platform.** See 3.3.166.1.

13.1.4* Classification of Occupancy. See 6.1.2.

13.1.5 Classification of Hazard of Contents. Contents of assembly occupancies shall be classified in accordance with the provisions of Section 6.2.

13.1.6 Minimum Construction Requirements. The location of an assembly occupancy shall be limited as shown in Table 13.1.6, unless otherwise permitted by the following (*see* 8.2.1.):

- (1) This requirement shall not apply to outdoor grandstands of Type I or Type II construction.
- (2) This requirement shall not apply to outdoor grandstands of Type III, Type IV, or Type V construction and that meet the requirements of 13.4.8.
- (3) This requirement shall not apply to grandstands of noncombustible construction supported by the floor in a building meeting the construction requirements of Table 13.1.6.
- (4) This requirement shall not apply to assembly occupancies within mall buildings in accordance with 37.4.4.

13.1.7 Occupant Load.

13.1.7.1* General. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

13.1.7.1.1 In areas not in excess of 930 m² (10,000 ft²), the occupant load shall not exceed one person in 0.46 m² (5 ft²).

13.1.7.1.2 In areas in excess of 930 m² (10,000 ft²), the occupant load shall not exceed one person in 0.65 m² (7 ft²).

13.1.7.1.3 The authority having jurisdiction shall be permitted to establish the occupant load as the number of persons for which the existing means of egress is adequate, provided that measures are established to prevent occupancy by a greater number of persons.

Table 13.1.6 Construction Type Limitations

Type of Construction	Below LED	LED	Number of Levels above LED			
			1	2	3	≥4
I(443) ^{††} I(332) ^{††} II(222) ^{††}	Any assembly [§]	Any assembly	Any assembly	Any assembly	Any assembly	Any assembly; If OL > 1000 [§]
II(111) ^{††}	Any assembly [§] Limited to 1 level below LED	Any assembly	Any assembly	Any assembly; If OL > 1000 [§]	Assembly with OL ≤ 1000 [§]	NP
III(211) IV(2HH) V(111)	Any assembly [§] Limited to 1 level below LED	Any assembly	Any assembly	Any assembly; If OL > 300 [§]	Assembly with OL ≤ 1000 [§]	NP
II(000)	Assembly with OL ≤ 1000 [§] Limited to 1 level below LED	Any assembly; If OL > 1000 [§]	Assembly with OL ≤ 300 [§]	NP	NP	NP
III(200) V(000)	Assembly with OL ≤ 1000 [§] Limited to 1 level below LED	Any assembly; If OL > 1000 [§]	Assembly with OL ≤ 300 [§]	NP	NP	NP

NP: Not permitted.

LED: Level of exit discharge.

OL: Occupant load.

Note: For the purpose of this table, a mezzanine is not counted as a level.

[†]Where every part of the structural framework of roofs in Type I or Type II construction is 6100 mm (240 in.) or more above the floor immediately below, omission of all fire protection of the structural members shall be permitted, including protection of trusses, roof framing, decking, and portions of columns above 6100 mm (240 in.).

^{††}In open-air fixed seating facilities, including stadia, omission of fire protection of structural members exposed to the outside atmosphere shall be permitted where substantiated by an approved engineering analysis.

[§]Permitted if all the following are protected throughout by an approved automatic sprinkler system in accordance with Section 9.7:

- (1) The level of the assembly occupancy
- (2) Any level intervening between the level of the assembly occupancy and the level of exit discharge
- (3) The level of the exit discharge if there are any openings between the level of exit discharge and the exits serving the assembly occupancy

13.1.7.2 Waiting Spaces. In theaters and other assembly occupancies where persons are admitted to the building at times when seats are not available, or when the permitted occupant load has been reached based on 13.1.7.1 and persons are allowed to wait in a lobby or similar space until seats or space is available, the following requirements shall apply:

- (1) Such use of a lobby or similar space shall not encroach upon the required clear width of exits.
- (2) The waiting spaces shall be restricted to areas other than the required means of egress.
- (3) Exits shall be provided for the waiting spaces on the basis of one person for each 0.28 m² (3 ft²) of waiting space area.
- (4) Exits for waiting spaces shall be in addition to the exits specified for the main auditorium area and shall conform in construction and arrangement to the general rules for exits given in this chapter.

13.1.7.3 Life Safety Evaluation. Where the occupant load of an assembly occupancy exceeds 6000, a life safety evaluation shall be performed in accordance with 13.4.1.

13.1.7.4 Outdoor Facilities. In outdoor facilities, where approved by the authority having jurisdiction the number of occupants who are each provided with not less than 1.4 m² (15 ft²) of lawn surface shall be permitted to be excluded from the maximum occupant load of 6000 of 13.1.7.3 in determining the need for a life safety evaluation.

13.2 Means of Egress Requirements.

13.2.1 General. All means of egress shall be in accordance with Chapter 7 and this chapter.

13.2.2 Means of Egress Components.

13.2.2.1 Components of means of egress shall be limited to the types described in 13.2.2.2 through 13.2.2.12.

13.2.2.2 Doors.

13.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

13.2.2.2.2 Assembly occupancies with occupant loads of 300 or less in malls (*see 37.4.4.2.2*) shall be permitted to have horizontal or vertical security grilles or doors complying with 7.2.1.4.1.4 on the main entrance/exits.

13.2.2.2.3 Any door in a required means of egress from an area having an occupant load of 100 or more persons shall be permitted to be provided with a latch or lock only if the latch or lock is panic hardware or fire exit hardware complying with 7.2.1.7, unless otherwise permitted by the following:

- (1) This requirement shall not apply to delayed-egress locks as permitted in 13.2.2.2.5.
- (2) This requirement shall not apply to access-controlled egress doors as permitted in 13.2.2.2.6.

13.2.2.2.4 Locking devices complying with 7.2.1.5.4 shall be permitted to be used on a single door or a single pair of doors if both of the following conditions apply:

- (1) The door or pair of doors serve as the main exit from assembly occupancies having an occupant load not greater than 600.
- (2) Any latching devices on such a door(s) from an assembly occupancy having an occupant load of 100 or more are released by panic hardware or fire exit hardware.

13.2.2.2.5 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted on doors other than main entrance/exit doors.

13.2.2.2.6 Doors in the means of egress shall be permitted to be equipped with an approved access control system complying with 7.2.1.6.2, and such doors shall not be locked from the egress side when the assembly occupancy is occupied. (*See 7.2.1.1.3.*)

13.2.2.2.7 Revolving doors complying with the requirements of 7.2.1.10 for new construction shall be permitted.

13.2.2.2.8 The provisions of 7.2.1.11.1.1 to allow turnstiles where revolving doors are permitted shall not apply.

13.2.2.2.9 No turnstiles or other devices that restrict the movement of persons shall be installed in any assembly occupancy in such a manner as to interfere with required means of egress facilities.

13.2.2.3 Stairs.

13.2.2.3.1 General. Stairs complying with 7.2.2 shall be permitted, unless one of the following criteria applies:

- (1) *Stairs serving seating that is designed to be repositioned shall not be required to comply with 7.2.2.3.1.
- (2) This requirement shall not apply to stages and platforms as permitted by 13.4.5.

13.2.2.3.2 Catwalk, Gallery, and Gridiron Stairs.

13.2.2.3.2.1 Noncombustible grated stair treads and landing floors shall be permitted in means of egress from lighting and access catwalks, galleries, and gridirons.

13.2.2.3.2.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted in means of egress from lighting and access catwalks, galleries, and gridirons.

13.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

13.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

13.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

13.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

13.2.2.8 Escalators and Moving Walks. Escalators and moving walks complying with 7.2.7 shall be permitted.

13.2.2.9 Fire Escape Stairs. Fire escape stairs complying with 7.2.8 shall be permitted.

13.2.2.10 Fire Escape Ladders.

13.2.2.10.1 Fire escape ladders complying with 7.2.9 shall be permitted.

13.2.2.10.2 For ladders serving catwalks, the three-person limitation in 7.2.9.1(3) shall be permitted to be increased to ten persons.

13.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

13.2.2.12 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

13.2.3 Capacity of Means of Egress.

13.2.3.1 The capacity of means of egress shall be in accordance with one of the following:

- (1) Section 7.3 for other than theater-type seating or smoke-protected assembly seating
- (2) 13.2.3.2 for rooms with theater-type seating or similar seating arranged in rows
- (3) 13.4.2 for smoke-protected assembly seating

13.2.3.2* Minimum clear widths of aisles and other means of egress serving theater-type seating, or similar seating arranged in rows, shall be in accordance with Table 13.2.3.2.

Table 13.2.3.2 Capacity Factors

No. of Seats	Clear Width per Seat Served			
	Stairs		Passageways, Ramps, and Doorways	
	mm	in.	mm	in.
Unlimited	7.6 AB	0.3 AB	5.6 C	0.22 C

13.2.3.3 The minimum clear widths shown in Table 13.2.3.2 shall be modified in accordance with all of the following:

- (1) If risers exceed 178 mm in height, the stair width in Table 13.2.3.2 shall be multiplied by factor *A*, where *A* equals the following:

$$A = 1 + \frac{\text{riser height} - 178}{125}$$

- (2) If risers exceed 7 in. in height, the stair width in Table 13.2.3.2 shall be multiplied by factor *A*, where *A* equals the following:

$$A = 1 + \frac{\text{riser height} - 7}{5}$$

- (3) Stairs not having a handrail within a 760-mm (30-in.) horizontal distance shall be 25 percent wider than otherwise calculated; that is, their width shall be multiplied by factor *B*, where *B* equals the following:

$$B = 1.25$$

- (4) Ramps steeper than 1 in 10 slope where used in ascent shall have their width increased by 10 percent; that is, their width shall be multiplied by factor *C*, where *C* equals the following:

$$C = 1.10$$

13.2.3.4 Lighting and Access Catwalks. The requirements of 13.2.3.2 and 13.2.3.3 shall not apply to lighting and access catwalks as permitted by 13.4.5.9.

13.2.3.5 Bleachers Aisles. In seating composed entirely of bleachers for which the row-to-row dimension is 71 cm (28 in.) or less, and from which front egress is not limited, aisles shall not be required to exceed 1675 mm (66 in.) in width.

13.2.3.6 Main Entrance/Exit. Every assembly occupancy shall be provided with a main entrance/exit.

13.2.3.6.1 The main entrance/exit shall be of a width that accommodates one-half of the total occupant load and shall be at the level of exit discharge or shall connect to a stairway or ramp leading to a street.

13.2.3.6.2 Reserved.

13.2.3.6.3 Where the main entrance/exit from an assembly occupancy is through a lobby or foyer, the aggregate capacity of all exits from the lobby or foyer shall be permitted to provide the required capacity of the main entrance/exit, regardless of whether all such exits serve as entrances to the building.

13.2.3.6.4 A bowling establishment shall have a main entrance/exit of a capacity that accommodates 50 percent of the total occupant load without regard to the number of aisles that it serves.

13.2.3.6.5* In assembly occupancies where there is no well-defined main entrance/exit, exits shall be permitted to be distributed around the perimeter of the building, provided that the total exit width furnishes not less than 100 percent of the width needed to accommodate the permitted occupant load.

13.2.3.7 Other Exits. Each level of an assembly occupancy shall have access to the main entrance/exit and shall be provided with additional exits of a width to accommodate not less than one-half of the total occupant load served by that level.

13.2.3.7.1 Additional exits shall discharge in accordance with 13.2.7.

13.2.3.7.2 Additional exits shall be located as far apart as practicable and as far from the main entrance/exit as practicable.

13.2.3.7.3 Additional exits shall be accessible from a cross aisle or a side aisle.

13.2.3.7.4 In assembly occupancies where there is no well-defined main entrance/exit, exits shall be permitted to be distributed around the perimeter of the building, provided that the total exit width furnishes not less than 100 percent of the width required to accommodate the permitted occupant load.

13.2.4* Number of Exits.

13.2.4.1 The number of exits shall be in accordance with Section 7.4, other than fenced outdoor assembly occupancies in accordance with 13.2.4.4, unless otherwise permitted by 13.2.4.2 or 13.2.4.3.

13.2.4.2 Assembly occupancies with occupant loads of 600 or fewer shall have two separate means of egress.

13.2.4.3 Assembly occupancies with occupant loads greater than 600 but fewer than 1000 shall have three separate means of egress.

13.2.4.4 A fenced outdoor assembly occupancy shall have not less than two widely separated means of egress from the enclosure, unless otherwise required by one of the following:

- (1) If more than 6000 persons are to be served by such means of egress, there shall be not less than three means of egress.
- (2) If more than 9000 persons are to be served by such means of egress, there shall be not less than four means of egress.

13.2.4.5 Balconies or mezzanines having an occupant load not exceeding 50 shall be permitted to be served by a single means of egress, and such means of egress shall be permitted to lead to the floor below.

13.2.4.6 Balconies or mezzanines having an occupant load exceeding 50 but not exceeding 100 shall have not less than two remote means of egress, but both such means of egress shall be permitted to lead to the floor below.

13.2.4.7 Balconies or mezzanines having an occupant load exceeding 100 shall have means of egress as described in 7.4.1.

13.2.4.8 A second means of egress shall not be required from lighting and access catwalks, galleries, and gridirons where a means of escape to a floor or a roof is provided. Ladders, alternating tread devices, or spiral stairs shall be permitted in such means of escape.

13.2.5 Arrangement of Means of Egress.

13.2.5.1 General. Means of egress shall be arranged in accordance with Section 7.5.

13.2.5.1.1 The common paths of travel shall be permitted for the first 6100 mm (240 in.) from any point where the common path serves any number of occupants, and for the first 23 m (75 ft) from any point where the common path serves not more than 50 occupants.

13.2.5.1.2 Dead-end corridors shall not exceed 6100 mm (240 in.).

13.2.5.2 Access Through Hazardous Areas. Means of egress shall not be permitted through kitchens, storerooms, restrooms, closets, or hazardous areas as described in 13.3.2.

13.2.5.3 Reserved.

13.2.5.4 General Requirements for Access and Egress Routes Within Assembly Areas.

13.2.5.4.1 Festival seating, as defined in 3.3.188.1, shall be prohibited within a building, unless otherwise permitted by the following:

- (1) Festival seating shall be permitted in assembly occupancies having occupant loads of 1000 or less.
- (2) Festival seating shall be permitted in assembly occupancies where occupant loads exceed 1000 and where an approved life safety evaluation has been performed. (*See 13.4.1.*)

13.2.5.4.2* Access and egress routes shall be maintained so that any individual is able to move without undue hindrance, on personal initiative and at any time, from an occupied position to the exits.

13.2.5.4.3* Access and egress routes shall be maintained so that crowd management, security, and emergency medical personnel are able to reach any individual at any time, without undue hindrance.

13.2.5.4.4* The width of aisle accessways and aisles shall provide sufficient egress capacity for the number of persons accommodated by the catchment area served by the aisle accessway or aisle in accordance with 13.2.3.2, or for smoke-protected assembly seating in accordance with 13.4.2.

13.2.5.4.5 Where aisle accessways or aisles converge to form a single path of egress travel, the required egress capacity of that path shall not be less than the combined required capacity of the converging aisle accessways and aisles.

13.2.5.4.6 Those portions of aisle accessways and aisles where egress is possible in either of two directions shall be uniform in required width unless otherwise permitted by 13.2.5.4.7.

13.2.5.4.7 The requirement of 13.2.5.4.6 shall not apply to those portions of aisle accessways where the required width, not including the seat space described by 13.2.5.7.3, does not exceed 305 mm (12 in.).

13.2.5.4.8 In the case of side boundaries for aisle accessways or aisles, other than those for nonfixed seating at tables, the clear width shall be measured to boundary elements such as walls, guardrails, handrails, edges of seating, tables, and side edges of treads, and said measurement shall be made horizontally to the vertical projection of the elements, resulting in the smallest width measured perpendicularly to the line of travel.

13.2.5.5* Aisle Accessways Serving Seating Not at Tables.

13.2.5.5.1* The required clear width of aisle accesses between rows of seating shall be determined as follows:

- (1) Horizontal measurements shall be made, between vertical planes, from the back of one seat to the front of the most forward projection of the seat immediately behind it.
- (2) Where the entire row consists of automatic or self-rising seats that comply with ASTM F 851, *Test Method for Self-Rising Seat Mechanisms*, the measurement shall be permitted to be made with the seats in the up position.

13.2.5.5.2 The aisle accessway between rows of seating shall have a clear width of not less than 305 mm (12 in.), and this minimum shall be increased as a function of row length in accordance with 13.2.5.5.4 and 13.2.5.5.5.

13.2.5.5.3 If used by not more than four persons, no minimum clear width shall be required for the portion of an aisle accessway having a length not exceeding 1830 mm (72 in.), measured from the center of the seat farthest from the aisle.

13.2.5.5.4* Rows of seating served by aisles or doorways at both ends shall not exceed 100 seats per row.

13.2.5.5.4.1 The 305-mm (12-in.) minimum clear width of aisle accessway between such rows shall be increased by 7.6 mm (0.3 in.) for every seat over a total of 14 but shall not be required to exceed 560 mm (22 in.).

13.2.5.5.4.2 The requirement of 13.2.5.5.4.1 shall not apply to smoke-protected assembly seating as permitted by 13.4.2.4.

13.2.5.5.5 Rows of seating served by an aisle or doorway at one end only shall have a path of travel not exceeding 9140 mm (360 in.) in length from any seat to an aisle.

13.2.5.5.5.1 The 305-mm (12-in.) minimum clear width of aisle accessway between rows of seating as specified in 13.2.5.5.5 shall be increased by 15 mm (0.6 in.) for every seat over a total of seven.

13.2.5.5.5.2 The requirements of 13.2.5.5.5 and 13.2.5.5.5.1 shall not apply to smoke-protected assembly seating as permitted by 13.4.2.5 and 13.4.2.6.

13.2.5.5.6 Rows of seating using tablet-arm chairs shall be permitted only if the clear width of aisle accessways complies with the requirements of 13.2.5.5 when measured under one of the following conditions:

- (1) The clear width is measured with the tablet arm in the usable position.
- (2) The clear width is measured with the tablet arm in the stored position where the tablet arm automatically returns to the stored position when raised manually to a vertical position in one motion and falls to the stored position by force of gravity.

13.2.5.5.7 The depth of seat boards shall not be less than 230 mm (9 in.) where the same level is not used for both seat boards and footboards.

13.2.5.5.8 Footboards, independent of seats, shall be provided so that there is no horizontal opening that allows the passage of a 13-mm (½-in.) diameter sphere.

13.2.5.6 Aisles Serving Seating Not at Tables.

13.2.5.6.1 General. Aisles shall be provided so that the number of seats served by the nearest aisle is in accordance with 13.2.5.5.2 through 13.2.5.5.4, unless otherwise permitted by the following:

- (1) Aisles shall not be required in bleachers, provided that all of the following conditions are met:
 - (a) Egress from the front row shall not be obstructed by a rail, a guard, or other obstruction.
 - (b) The row spacing shall be 710 mm (28 in.) or less.
 - (c) The rise per row, including the first row, shall be 150 mm (6 in.) or less.
 - (d) The number of rows shall not exceed 16.
 - (e) The seat spaces shall not be physically defined.
 - (f) Seat boards that are also used as stepping surfaces for descent shall provide a walking surface with a width of not less than 305 mm (12 in.), and, where a depressed footboard exists, the gap between seat boards of adjacent rows shall not exceed 305 mm (12 in.), measured horizontally.
 - (g) The leading edges of seat boards used as stepping surfaces shall be provided with a contrasting marking stripe so that the location of the leading edge is readily apparent, particularly where viewed in descent and the following shall also apply:
 - i. The marking stripe shall be not less than 25 mm (1 in.) wide and shall not exceed 51 mm (2 in.) in width.
 - ii. The marking stripe shall not be required where bleacher surfaces and environmental conditions, under all conditions of use, are such that the location of each leading edge is readily apparent, particularly when viewed in descent.

13.2.5.6.2 Dead-End Aisles. Dead-end aisles shall not exceed 6100 mm (240 in.) in length, unless otherwise permitted by the following:

- (1) A dead-end aisle shall be permitted to exceed 6100 mm (240 in.) in length where seats served by the dead-end aisle are not more than 24 seats from another aisle, measured along a row of seats having a clear width of not less than 305 mm (12 in.) plus 15 mm (0.6 in.) for each additional seat over a total of 7 in the row.
- (2) A 16-row, dead-end aisle shall be permitted in folding and telescopic seating and grandstands.
- (3) Aisle termination in accordance with 13.4.2.7 for smoke-protected assembly seating shall be permitted.
- (4) Bleacher aisles in accordance with 13.2.3.5 shall not be considered as dead-end aisles.

13.2.5.6.3* Minimum Aisle Width. The minimum clear width of aisles shall be sufficient to provide egress capacity in accordance with 13.2.3.2 but shall be not less than the following:

- (1) 1065 mm (42 in.) for stairs having seating on each side, unless otherwise permitted by the following:

- (a) The minimum clear width required by 13.2.5.6.3(1) shall be permitted to be not less than 760 mm (30 in.) for catchment areas having not more than 60 seats.
- (b) The minimum clear width required by 13.2.5.6.3(1) shall be permitted to be not less than 915 mm (36 in.) where an aisle does not serve more than 50 seats.
- (2) 915 mm (36 in.) for stairs having seating on only one side, or 760 mm (30 in.) for catchment areas having not more than 60 seats
- (3) 510 mm (20 in.) between a handrail and seating or between a guardrail and seating where the aisle is subdivided by a handrail
- (4) 1065 mm (42 in.) for level or ramped aisles having seating on both sides, unless otherwise permitted by the following:
 - (a) The minimum clear width required by 13.2.5.6.3(4) shall be not less than 760 mm (30 in.) for catchment areas having not more than 60 seats.
 - (b) The minimum clear width required by 13.2.5.6.3(4) shall be not less than 915 mm (36 in.) where an aisle does not serve more than 50 seats.
- (5) 915 mm (36 in.) for level or ramped aisles having seating on only one side, or 760 mm (30 in.) for catchment areas having not more than 60 seats
- (6) 580 mm (23 in.) between a handrail or guardrail and seating where aisle does not serve more than five rows on one side

13.2.5.6.4* Aisle Stairs and Ramps. The following shall apply to aisle stairs and ramps:

- (1) Aisles having a gradient steeper than 1 in 20, but not steeper than 1 in 8, shall consist of a ramp.
- (2) Aisles having a gradient steeper than 1 in 8 shall consist of an aisle stair.
- (3) The marking stripe exemption of 13.2.5.6.8.3 shall not be permitted for aisle stairs.
- (4) Aisles in folding and telescopic seating shall be permitted to be stepped aisles.
- (5) The limitation on height between landings in Table 7.2.2.2.1(a) and Table 7.2.2.2.1(b) shall not apply to aisle stairs.

13.2.5.6.5 Aisle Stair Treads. Aisle stair treads shall meet the following criteria:

- (1) There shall be no variation in the depth of adjacent treads that exceeds 4.8 mm (⅜ in.), unless otherwise permitted by the following:
 - (a) *In aisle stairs where a single intermediate tread is provided halfway between seating platforms, such intermediate treads shall be permitted to be of a relatively smaller but uniform depth but shall be not less than 330 mm (13 in.).
 - (b) The following shall apply to grandstands, bleachers, and folding and telescopic seating:
 - i. Steps shall not be required to be provided in aisles to overcome differences in level unless the gradient exceeds 1 unit of rise in 10 units of run.
 - ii. Where the rise of the seating platform exceeds 280 mm (11 in.), an intermediate step shall be provided for the full width of the aisle and shall be proportioned to provide two steps of equal rise per platform.

- iii. Where the rise of the seating platform exceeds 455 mm (18 in.), two intermediate steps for the full width of the aisle shall be provided and proportioned to provide three steps of equal rise per platform that are uniform and not less than 230 mm (9 in.).

- iv. The full length of the nose of each step in the aisle required by 13.2.5.6.5(1)(b)iii shall be conspicuously marked.

(2)*Treads shall be not less than 280 mm (11 in.).

(3) All treads shall extend the full width of the aisle.

13.2.5.6.6 Aisle Stair Risers. Aisle stair risers shall meet the following criteria:

- (1) Riser heights shall be not less than 100 mm (4 in.) unless otherwise permitted by the following:
 - (a) The riser height of aisle stairs in folding and telescopic seating shall be permitted to be not less than 90 mm (3½ in.).
 - (b) Where the gradient of an aisle is steeper than 205 mm (8 in.) in rise in 280 mm (11 in.) of run for the purpose of maintaining necessary sight lines in the adjoining seating area, the riser height shall be permitted to exceed 205 mm (8 in.) but shall not exceed 280 mm (11 in.).
- (2) Riser heights shall not exceed 205 mm (8 in.) unless otherwise permitted by 13.2.5.6.6(3).
- (3) The riser height of aisle stairs in folding and telescopic seating shall be permitted to be not more than 280 mm (11 in.).
- (4) Riser heights shall be designed to be uniform in each aisle, and the construction-caused nonuniformities shall not exceed 4.8 mm (⅜ in.) between adjacent risers, unless the following conditions apply:
 - (a) Riser height shall be permitted to be nonuniform only for the purpose of accommodating changes in gradient necessary to maintain sight lines within a seating area, in which case the riser height shall be permitted to exceed 4.8 mm (⅜ in.) in any flight.
 - (b) Where nonuniformities permitted by 13.2.5.6.6(4)(a) exceed 4.8 mm (⅜ in.) between adjacent risers, the exact location of such nonuniformities shall be indicated by a distinctive marking stripe on each tread at the nosing or leading edge adjacent to the nonuniform risers.

13.2.5.6.7* Aisle Handrails.

13.2.5.6.7.1 Ramped aisles having a gradient exceeding 1 in 12 and aisle stairs shall be provided with handrails at one side or along the centerline and in accordance with 7.2.2.4.4.1, 7.2.2.4.4.5, and 7.2.2.4.4.6.

13.2.5.6.7.2 Where seating exists on both sides of the aisle, the handrails shall be noncontinuous with gaps or breaks at intervals not exceeding five rows to facilitate access to seating and to allow crossing from one side of the aisle to the other.

13.2.5.6.7.3 The gaps or breaks permitted by 13.2.5.6.7.2 shall have a clear width of not less than 560 mm (22 in.) and shall not exceed 915 mm (36 in.), measured horizontally, and the handrail shall have rounded terminations or bends.

13.2.5.6.7.4 Where handrails are provided in the middle of aisle stairs, an additional intermediate rail shall be located approximately 305 mm (12 in.) below the main handrail.

13.2.5.6.7.5 Handrails shall not be required where otherwise permitted by the following:

- (1) Handrails shall not be required for ramped aisles having a gradient not steeper than 1 in 8 and having seating on both sides.
- (2) The requirement for a handrail shall be satisfied by the use of a guard provided with a rail that complies with the graspability requirements for handrails and located at a consistent height between 865 mm (34 in.) and 1065 mm (42 in.), measured using one of the following methods:
 - (a) Vertically from the top of the rail to the leading edge (nosing) of stair treads
 - (b) Vertically from the top of the rail to the adjacent walking surface in the case of a ramp
- (3) Handrails shall not be required where risers do not exceed 180 mm (7 in.) in height.

13.2.5.6.8* Aisle Marking.

13.2.5.6.8.1 A contrasting marking stripe shall be provided on each tread at the nosing or leading edge so that the location of such tread is readily apparent, particularly when viewed in descent.

13.2.5.6.8.2 The marking stripe shall be not less than 25 mm (1 in.) wide and shall not exceed 51 mm (2 in.) in width.

13.2.5.6.8.3 The marking stripe shall not be required where tread surfaces and environmental conditions, under all conditions of use, are such that the location of each tread is readily apparent, particularly when viewed in descent.

13.2.5.7* Aisle Accessways Serving Seating at Tables.

13.2.5.7.1 The required clear width of an aisle accessway shall be not less than 305 mm (12 in.) where measured in accordance with 13.2.5.7.3 and shall be increased as a function of length in accordance with 13.2.5.7.4, unless otherwise permitted by 13.2.5.7.2.

13.2.5.7.2* If used by not more than four persons, no minimum clear width shall be required for the portion of an aisle accessway having a length not exceeding 1830 mm (72 in.) and located farthest from an aisle.

13.2.5.7.3* Where nonfixed seating is located between a table and an aisle accessway or aisle, the measurement of required clear width of the aisle accessway or aisle shall be made to a line 485 mm (19 in.), measured perpendicularly to the edge of the table, away from the edge of said table.

13.2.5.7.4* The minimum required clear width of an aisle accessway, measured in accordance with 13.2.5.4.8 and 13.2.5.7.3, shall be increased beyond the 305-mm (12-in.) requirement of 13.2.5.7.1 by 13 mm (½ in.) for each additional 305 mm (12 in.) or fraction thereof beyond 3660 mm (144 in.) of aisle accessway length, where measured from the center of the seat farthest from an aisle.

13.2.5.7.5 The path of travel along the aisle accessway shall not exceed 11 m (36 ft) from any seat to the closest aisle or egress doorway.

13.2.5.8 Aisles Serving Seating at Tables.

13.2.5.8.1* Aisles that contain steps or that are ramped, such as aisles serving dinner theater-style configurations, shall comply with the requirements of 13.2.5.6.

13.2.5.8.2* The width of aisles serving seating at tables shall be not less than 1120 mm (44 in.) where serving an occupant load exceeding 50, and 915 mm (36 in.) where serving an occupant load of 50 or fewer.

13.2.5.8.3* Where nonfixed seating is located between a table and an aisle, the measurement of required clear width of the aisle shall be made to a line 485 mm (19 in.), measured perpendicularly to the edge of the table, away from the edge of said table.

13.2.5.9 Approval of Layouts.

13.2.5.9.1 Where required by the authority having jurisdiction, plans drawn to scale showing the arrangement of furnishings or equipment shall be submitted to the authority by the building owner, manager, or authorized agent to substantiate conformance with the provisions of 13.2.5.

13.2.5.9.2 The layout plans shall constitute the only acceptable arrangement, unless one of the following criteria is met:

- (1) The plans are revised
- (2) Additional plans are submitted and approved.
- (3) Temporary deviations from the specifications of the approved plans are used, provided that the occupant load is not increased and the intent of 13.2.5.9 is maintained.

13.2.6 Travel Distance to Exits. Exits shall be arranged so that the total length of travel from any point to reach an exit shall not exceed 61 m (200 ft) in any assembly occupancy, unless otherwise permitted by the following:

- (1) The travel distance shall not exceed 76 m (250 ft) in assembly occupancies protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.
- (2) The travel distance requirement shall not apply to smoke-protected assembly seating as permitted by 13.4.2.8, 13.4.2.9, and 13.4.2.10.

13.2.7 Discharge from Exits.

13.2.7.1 Exit discharge shall comply with Section 7.7.

13.2.7.2 The level of exit discharge shall be measured at the point of principal entrance to the building.

13.2.7.3 Where the principal entrance to an assembly occupancy is via a terrace, either raised or depressed, such terrace shall be permitted to be considered to be the level of exit discharge for the purposes of Table 13.1.6 where the following criteria are met:

- (1) The terrace is at least as long, measured parallel to the building, as the total width of the exit(s) it serves but not less than 1525 mm (60 in.) long.
- (2) The terrace is at least as wide, measured perpendicularly to the building, as the exit(s) it serves but not less than 1525 mm (60 in.) wide.
- (3) Required stairs leading from the terrace to grade are protected in accordance with 7.2.2.6.3 or are not less than 3050 mm (120 in.) from the building.

13.2.8 Illumination of Means of Egress. Means of egress, other than for private party tents not exceeding 112 m² (1200 ft²), shall be illuminated in accordance with Section 7.8.

13.2.9 Emergency Lighting.

13.2.9.1 Emergency lighting, other than that permitted by 13.2.9.3, shall be provided in accordance with Section 7.9.

13.2.9.2 Private party tents not exceeding 112 m² (1200 ft²) shall not be required to have emergency lighting.

13.2.9.3 Assembly occupancies with an occupant load not exceeding 300 and used exclusively for a place of worship shall not be required to have emergency lighting.

13.2.10 Marking of Means of Egress.

13.2.10.1 Means of egress shall be provided with signs in accordance with Section 7.10.

13.2.10.2 Exit markings shall not be required on the seating side of vomitories from seating areas where exit marking is provided in the concourse and where such marking is readily apparent from the vomitories.

13.2.11 Special Means of Egress Features.

13.2.11.1 Guards and Railings: Boxes, Balconies, and Galleries. Boxes, balconies, and galleries shall meet the following criteria:

- (1) The fasciae of boxes, balconies, and galleries shall rise not less than 660 mm (26 in.) above the adjacent floor or shall have substantial railings not less than 660 mm (26 in.) above the adjacent floor.
- (2) The height of the rail above footrests on the adjacent floor immediately in front of a row of seats shall be not less than 660 mm (26 in.), and the following also shall apply:
 - (a) Railings at the ends of aisles shall be not less than 915 mm (36 in.) high for the full width of the aisle.
 - (b) Railings at the end of aisles shall be not less than 915 mm (36 in.) high at the ends of aisles where steps occur.
- (3) Aisle accessways adjacent to orchestra pits and vomitories, and all cross aisles, shall be provided with railings not less than 660 mm (26 in.) above the adjacent floor.
- (4) The requirement of 13.2.11.1(3) shall not apply where the backs of seats located at the front of the aisle project 610 mm (24 in.) or more above the adjacent floor of the aisle.
- (5) Guardrails shall not be required on the audience side of stages, raised platforms, and other raised floor areas such as runways, ramps, and side stages used for entertainment or presentations.
- (6) Permanent guardrails shall not be required at vertical openings in the performance area of stages.
- (7) Guardrails shall not be required where the side of an elevated walking surface is required to be open for the normal functioning of special lighting or for access and use of other special equipment.

13.3 Protection.

13.3.1 Protection of Vertical Openings. Any vertical opening shall be enclosed or protected in accordance with 8.6, unless otherwise permitted by the following:

- (1)*Stairs or ramps shall be permitted to be unenclosed between balconies or mezzanines and main assembly areas located below, provided that the balcony or mezzanine is open to the main assembly area.
- (2) Exit access stairs from lighting and access catwalks, galleries, and gridirons shall not be required to be enclosed.

- (3) Assembly occupancies protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7 shall be permitted to have unprotected vertical openings in accordance with 8.6.8.2.
- (4) Use of the following alternative materials shall be permitted where assemblies constructed of such materials are in good repair and free of any condition that would diminish their original fire resistance characteristics:
 - (a) Existing wood lath and plaster
 - (b) Existing 13-mm (½-in.) gypsum wallboard
 - (c) Existing installations of 6.3-mm (¼ in.) thick wired glass that are, or are rendered, inoperative and fixed in the closed position
 - (d) Other existing materials having similar fire resistance capabilities

13.3.2 Protection from Hazards.

13.3.2.1 Service Equipment, Hazardous Operations or Processes, and Storage Facilities.

13.3.2.1.1 Rooms containing high-pressure boilers, refrigerating machinery of other than the domestic refrigerator type, large transformers, or other service equipment subject to explosion shall meet the following requirements:

- (1) Such rooms shall not be located directly under or abutting required exits.
- (2) Such rooms shall be separated from other parts of the building by fire barriers in accordance with Section 8.3 that have a fire resistance rating of not less than 1 hour or shall be protected by automatic extinguishing systems in accordance with Section 8.7.

13.3.2.1.2 Rooms or spaces for the storage, processing, or use of materials specified in 13.3.2.1.2(1) through 13.3.2.1.2(3) shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Boiler and furnace rooms, unless otherwise protected by the following:
 - i. The requirement of 13.3.2.1.2(1)(a) shall not apply to rooms enclosing furnaces, heating and air-handling equipment, or compressor equipment with a total aggregate input rating less than 211 MJ (200,000 Btu), provided that such rooms are not used for storage.
 - ii. The requirement of 13.3.2.1.2(1)(a) shall not apply to attic locations of the rooms addressed in 13.3.2.1.2(1)(a)i provided such rooms comply with the draftstopping requirements of 8.6.10.
 - (b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction.
 - (c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Laundries
 - (b) Maintenance shops, including woodworking and painting areas

- (c) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction
- (d) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards

- (3) Where automatic extinguishing is used to meet the requirements of 13.3.2, the protection shall be permitted to be in accordance with 9.7.1.2.

13.3.2.2 **Cooking Equipment.** Cooking equipment shall be protected in accordance with 9.2.3 unless the cooking equipment meets one of the following:

- (1) Outdoor equipment
- (2) Portable equipment not flue connected
- (3) Equipment used only for food warming

13.3.3 Interior Finish.

13.3.3.1 Interior finish shall be in accordance with Section 10.2.

13.3.3.2 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in all corridors and lobbies and shall be Class A in enclosed stairways.

13.3.3.3 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in general assembly areas having occupant loads of more than 300, and shall be Class A, Class B, or Class C in assembly areas having occupant loads of 300 or fewer.

13.3.3.4 Screens on which pictures are projected shall comply with requirements of Class A or Class B interior finish in accordance with Section 10.2.

13.3.3.5 **Interior Floor Finish.** (No requirements.)

13.3.4 Detection, Alarm, and Communications Systems.

13.3.4.1 **General.** Assembly occupancies with occupant loads of more than 300 and all theaters with more than one audience-viewing room shall be provided with an approved fire alarm system in accordance with 9.6.1 and 13.3.4, unless otherwise permitted by the following:

- (1) Assembly occupancies that are a part of a multiple occupancy protected as a mixed occupancy (*see 6.1.14*) shall be permitted to be served by a common fire alarm system, provided that the individual requirements of each occupancy are met.
- (2) Voice communication or public address systems complying with 13.3.4.3.3 shall not be required to comply with 9.6.1.
- (3) This requirement shall not apply to assembly occupancies where, in the judgment of the authority having jurisdiction, adequate alternative provisions exist or are provided for the discovery of a fire and for alerting the occupants promptly.

13.3.4.2 Initiation.

13.3.4.2.1 Initiation of the required fire alarm system shall be by manual means in accordance with 9.6.2.1(1), and the system shall be provided with an emergency power source, unless otherwise permitted by the following:

- (1) This requirement shall not apply to fire alarm systems initiated by means of an approved automatic fire detection system in accordance with 9.6.2.1(2) that provides fire detection throughout the building.
- (2) This requirement shall not apply to fire alarm systems initiated by means of an approved automatic sprinkler system in accordance with 9.6.2.1(3) that provides fire detection and protection throughout the building.

13.3.4.2.2 The initiating device shall be capable of transmitting an alarm to a receiving station, located within the building, that is constantly attended when the assembly occupancy is occupied.

13.3.4.2.3* In assembly occupancies with occupant loads of more than 300, automatic detection shall be provided in all hazardous areas that are not normally occupied, unless such areas are protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

13.3.4.3 Notification. The required fire alarm system shall sound an audible alarm in a constantly attended receiving station within the building when occupied for purposes of initiating emergency action.

13.3.4.3.1 Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.

13.3.4.3.2 A presignal system in accordance with 9.6.3.3 shall be permitted.

13.3.4.3.3 Occupant notification shall be by means of voice announcements, either live or prerecorded, initiated by the person in the constantly attended location.

13.3.4.3.4 The announcement shall be made via an approved voice communication or public address system that is audible above the ambient noise level of the assembly occupancy.

13.3.4.3.5 Where the authority having jurisdiction determines that a constantly attended location is impractical, a fire alarm system in accordance with Section 9.6 shall be used that meets the following criteria:

- (1) It shall be initiated by manual fire alarm boxes in accordance with 9.6.2.1(1) or other approved means.
- (2) It shall automatically provide prerecorded evacuation instructions in accordance with 9.6.3.10.

13.3.5 Extinguishment Requirements. See also 13.1.6, 13.2.6, and 13.3.2.

13.3.5.1 Any assembly occupancy used or capable of being used for exhibition or display purposes shall be protected throughout by an approved automatic sprinkler system in accordance with Section 9.7 where the exhibition or display area exceeds 1400 m² (15,000 ft²).

13.3.5.2 The sprinklers specified by 13.3.5.1 shall not be required where otherwise permitted by the following:

- (1) In stadia and arenas:
 - (a) Over the floor area used for contest, performance, or entertainment
 - (b) Over the seating areas
 - (c) Over open-air concourses where an approved engineering analysis substantiates the ineffectiveness of the sprinkler protection due to building height and combustible loading
- (2) In the following areas in unenclosed stadia and arenas:
 - (a) Press boxes less than 93 m² (1000 ft²)
 - (b) Storage facilities less than 1000 ft² (93 m²) if enclosed with not less than 1-hour fire resistance-rated construction
 - (c) Enclosed areas underneath grandstands that comply with 13.4.8.5

13.3.5.3 Where another provision of this chapter requires an automatic sprinkler system, the sprinkler system shall be installed in accordance with 9.7.1.1(1).

13.3.6 Corridors. (No requirements.)

13.4 Special Provisions.

13.4.1 Life Safety Evaluation.

13.4.1.1* Where a life safety evaluation is required by other provisions of the *Code*, it shall comply with the following:

- (1) The life safety evaluation shall be performed by persons acceptable to the authority having jurisdiction.
- (2) The life safety evaluation shall include a written assessment of safety measures for conditions listed in 13.4.1.2.
- (3) The life safety evaluation shall be approved annually by the authority having jurisdiction and shall be updated for special or unusual conditions.

13.4.1.2 Life safety evaluations shall include an assessment of the following conditions and the related appropriate safety measures:

- (1) Nature of the events and the participants and attendees
- (2) Access and egress movement, including crowd density problems
- (3) Medical emergencies
- (4) Fire hazards
- (5) Permanent and temporary structural systems
- (6) Severe weather conditions
- (7) Earthquakes
- (8) Civil or other disturbances
- (9) Hazardous materials incidents within and near the facility
- (10) Relationships among facility management, event participants, emergency response agencies, and others having a role in the events accommodated in the facility

13.4.1.3* Life safety evaluations shall include assessments of both building systems and management features upon which reliance is placed for the safety of facility occupants, and such assessments shall consider scenarios appropriate to the facility.

13.4.2* Smoke-Protected Assembly Seating.

13.4.2.1 To be considered smoke protected, an assembly seating facility shall comply with the following:

- (1) All enclosed areas with walls and ceilings in buildings or structures containing smoke-protected assembly seating shall be protected with an approved automatic sprinkler system in accordance with Section 9.7, unless otherwise permitted by the following:
 - (a) The requirement of 13.4.2.1(1) shall not apply to the floor area used for the contest, performance, or entertainment, provided that the roof construction is more than 15 m (50 ft) above the floor level and use is restricted to low fire hazard uses.
 - (b)*Sprinklers shall not be required to be located over the floor area used for contest, performance, or entertainment and over the seating areas where an approved engineering analysis substantiates the ineffectiveness of the sprinkler protection due to building height and combustible loading.
- (2) All means of egress serving a smoke-protected assembly seating area shall be provided with smoke-actuated ventilation facilities or natural ventilation designed to maintain the level of smoke at not less than 1830 m (72 in.) above the floor of the means of egress.

13.4.2.2 To use the provisions of smoke-protected assembly seating, a facility shall be subject to a life safety evaluation in accordance with 13.4.1.

13.4.2.3 Where using Table 13.4.2.3, the number of seats specified shall be within a single assembly space, and interpolation shall be permitted between the specific values shown. A single seating space shall be permitted to have multiple levels, floors, or mezzanines. The minimum clear widths shown shall be modified in accordance with all of the following:

- (1) If risers exceed 178 mm in height, the stair width in Table 13.4.2.3 shall be multiplied by factor *A*, where *A* equals the following:

$$A = 1 + \frac{\text{riser height} - 178}{125}$$

- (2) If risers exceed 7 in. in height, the stair width in Table 13.4.2.3 shall be multiplied by factor *A*, where *A* equals the following:

$$A = 1 + \frac{\text{riser height} - 7}{5}$$

- (3) Stairs not having a handrail within a 760-mm (30-in.) horizontal distance shall be 25 percent wider than otherwise calculated; that is, their width shall be multiplied by factor *B*, where *B* equals the following:

$$B = 1.25$$

- (4) Ramps steeper than 1 in 10 slope used in ascent shall have their width increased by 10 percent; that is, their width shall be multiplied by factor *C*, where *C* equals the following:

$$C = 1.10$$

Table 13.4.2.3 Capacity Factors for Smoke-Protected Assembly Seating

Number of Seats	Clear Width per Seat Served			
	Stairs		Passageways, Ramps, and Doorways	
	mm	in.	mm	in.
2,000	7.6 AB	0.300 AB	5.6 C	0.220 C
5,000	5.1 AB	0.200 AB	3.8 C	0.150 C
10,000	3.3 AB	0.130 AB	2.5 C	0.100 C
15,000	2.4 AB	0.096 AB	1.8 C	0.070 C
20,000	1.9 AB	0.076 AB	1.4 C	0.056 C
≥25,000	1.5 AB	0.060 AB	1.1 C	0.044 C

13.4.2.4 Where smoke-protected assembly seating conforms to the requirements of 13.4.2, for rows of seats served by aisles or doorways at both ends, the number of seats per row shall not exceed 100, and the clear width of not less than 305 mm (12 in.) for aisle accessways shall be increased by 7.6 mm (0.3 in.) for every additional seat beyond the number stipulated in Table 13.4.2.4; however, the minimum clear width shall not be required to exceed 560 mm (22 in.).

13.4.2.5 Where smoke-protected assembly seating conforms with the requirements of 13.4.2, for rows of seats served by an aisle or doorway at one end only, the aisle accessway clear width of not less than 305 mm (12 in.) shall be increased by 15 mm (0.6 in.) for every additional seat beyond the number stipulated in Table 13.4.2.4; however, the minimum clear width shall not be required to exceed 560 mm (22 in.).

Table 13.4.2.4 Smoke-Protected Assembly Seating Aisle Accessways

Total Number of Seats in the Space	Number of Seats per Row Permitted to Have a Clear Width Aisle Accessway of Not Less than 305 mm (12 in.)	
	Aisle or Doorway at Both Ends of Row	Aisle or Doorway at One End of Row
<4,000	14	7
4,000–6,999	15	7
7,000–9,999	16	8
10,000–12,999	17	8
13,000–15,999	18	9
16,000–18,999	19	9
19,000–21,999	20	10
≥22,000	21	11

13.4.2.6 Smoke-protected assembly seating conforming with the requirements of 13.4.2 shall be permitted to have a common path of travel of 15 m (50 ft) from any seat to a point where a person has a choice of two directions of egress travel.

13.4.2.7 Where smoke-protected assembly seating conforms to the requirements of 13.4.2, the dead ends in aisle stairs shall not exceed a distance of 21 rows, unless both of the following criteria are met:

- (1) The seats served by the dead-end aisle are not more than 40 seats from another aisle.
- (2) The 40-seat distance is measured along a row of seats having an aisle accessway with a clear width of not less than 305 mm (12 in.) plus 7.6 mm (0.3 in.) for each additional seat above 7 in the row.

13.4.2.8 Where smoke-protected assembly seating conforms to the requirements of 13.4.2, the travel distance from each seat to the nearest entrance to an egress vomitory portal or egress concourse shall not exceed 122 m (400 ft).

13.4.2.9 Where smoke-protected assembly seating conforms to the requirements of 13.4.2, the travel distance from the entrance to the vomitory portal or from the egress concourse to an approved egress stair, ramp, or walk at the building exterior shall not exceed 61 m (200 ft).

13.4.2.10 The travel distance requirements of 13.4.2.8 and 13.4.2.9 shall not apply to outdoor assembly seating facilities of Type I or Type II construction, where all portions of the means of egress are essentially open to the outside.

13.4.3 **Limited Access or Underground Buildings.** Limited access or underground buildings shall comply with Section 11.7.

13.4.4 **High-Rise Buildings.** Existing high-rise buildings that house assembly occupancies in high-rise portions of the building shall have the highest level of the assembly occupancy and all levels below protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7. (See also 13.1.6.)

13.4.5 **Stages and Platforms.** See 3.3.210 and 3.3.166.

13.4.5.1 **Materials and Design.** (Reserved)

13.4.5.2 Platform Construction. (Reserved)**13.4.5.3 Stage Construction. (Reserved)****13.4.5.4 Accessory Rooms. (Reserved)**

13.4.5.5 Ventilators. Regular stages in excess of 93 m² (1000 ft²) and legitimate stages shall be provided with emergency ventilation to provide a means of removing smoke and combustion gases directly to the outside in the event of a fire and shall be achieved by one or a combination of the methods specified in 13.4.5.5.1 through 13.4.5.5.3.

13.4.5.5.1 Smoke Control.

13.4.5.5.1.1 A means complying with Section 9.3 shall be provided to maintain the smoke level at not less than 1830 mm (72 in.) above the highest level of assembly seating or above the top of the proscenium opening where a proscenium wall and opening protection are provided.

13.4.5.5.1.2 The system shall be activated independently by each of the following:

- (1) Activation of the sprinkler system in the stage area
- (2) Activation of smoke detectors over the stage area
- (3) Activation by manually operated switch at an approved location

13.4.5.5.1.3 The emergency ventilation system shall be supplied by both normal and standby power.

13.4.5.5.1.4 The fan(s) power wiring and ducts shall be located and properly protected to ensure not less than 20 minutes of operation in the event of activation.

13.4.5.5.2 Roof Vents.

13.4.5.5.2.1 Two or more vents shall be located near the center of and above the highest part of the stage area.

13.4.5.5.2.2 The vents shall be raised above the roof and shall provide a net-free vent area equal to 5 percent of the stage area.

13.4.5.5.2.3 Vents shall be constructed to open automatically by approved heat-activated devices, and supplemental means shall be provided for manual operation and periodic testing of the ventilator from the stage floor.

13.4.5.5.2.4 Vents shall be labeled.

13.4.5.5.2.5 Existing roof vents that are not labeled shall be permitted where they conform to the following requirements.

- (1) Vents shall open by spring action or force of gravity sufficient to overcome the effects of neglect, rust, dirt, frost, snow, or expansion by heat or warping of the framework, and the following requirements also shall apply:
 - (a) Glass, if used in vents, shall be protected against falling onto the stage.
 - (b) A wire screen, if used under the glass, shall be placed so that if clogged, it does not reduce the required venting area, interfere with the operating mechanism, or obstruct the distribution of water from an automatic sprinkler.
 - (c) Vents shall be arranged to open automatically by the use of fusible links.
 - (d) The fusible links and operating cable shall hold each door closed against a minimum 133-N (30-lb) counterforce that shall be exerted on each door through its entire arc of travel and for not less than 115 degrees.
 - (e) Vents shall be provided with manual control.

- (f) Springs, where employed to actuate vent doors, shall be capable of maintaining full required tension.
- (g) Springs shall not be stressed more than 50 percent of their rated capacity and shall not be located directly in the airstream nor exposed to the outside.
- (h) A fusible link shall be placed in the cable control system on the underside of the vent at or above the roofline, or as approved by the building official.
- (i) The fusible link shall be located so as not to be affected by the operation of an automatic sprinkler system.
- (j) Remote, manual, or electric controls shall provide for both opening and closing of the vent doors for periodic testing and shall be located at a point on stage designated by the authority having jurisdiction.
- (k) Where remote control vents are electrical, power failure shall not affect instant operation of the vent in the event of fire.
- (l) Hand winches shall be permitted to be employed to facilitate operation of manually controlled vents.

13.4.5.5.3 Other Means. Approved, alternate means of removing smoke and combustion gases shall be permitted.

13.4.5.6 Proscenium Walls. (Reserved)**13.4.5.7 Proscenium Curtain.**

13.4.5.7.1 The proscenium opening of every legitimate stage shall be provided with a curtain constructed and mounted so as to intercept hot gases, flames, and smoke and to prevent flame from a fire on the stage from becoming visible from the auditorium side for a 5-minute period where the curtain is of asbestos.

13.4.5.7.2 Materials other than asbestos shall be permitted if they have passed a 30-minute fire test in a small-scale 915 mm × 915 mm (36 in. × 36 in.) furnace with the sample mounted in the horizontal plane at the top of the furnace and subjected to the standard time-temperature curve.

13.4.5.7.3 The curtain shall be automatic-closing without the use of applied power.

13.4.5.7.4 All proscenium curtains shall be in the closed position, except during performances, rehearsals, or similar activities.

13.4.5.7.5 In lieu of the protection required by 13.4.5.7 through 13.4.5.7.4, all the following shall be provided:

- (1) A noncombustible opaque fabric curtain shall be arranged so that it closes automatically.
- (2) An automatic, fixed waterspray deluge system shall be located on the auditorium side of the proscenium opening and shall be arranged so that the entire face of the curtain will be wetted, and the following requirements also shall apply:
 - (a) The system shall be activated by combination of rate-of-rise and fixed-temperature detectors located on the ceiling of the stage.
 - (b) Detectors shall be spaced in accordance with their listing.
 - (c) The water supply shall be controlled by a deluge valve and shall be sufficient to keep the curtain completely wet for 30 minutes or until the valve is closed by fire department personnel.
- (3) The curtain shall be automatically operated in case of fire by a combination of rate-of-rise and fixed-temperature detectors that also activates the deluge spray system.

- (4) Stage sprinklers and vents shall be automatically operated by fusible elements in case of fire.
- (5) Operation of the stage sprinkler system or spray deluge valve shall automatically activate the emergency ventilating system and close the curtain.
- (6) The curtain, vents, and spray deluge system valve shall also be capable of manual operation.

13.4.5.7.6 This requirement shall not apply to proscenium fire curtains or water curtains complying with 12.4.5.7.

13.4.5.8 Gridirons, Fly Galleries, and Pinrails. (Reserved)

13.4.5.9 Catwalks. The clear width of lighting and access catwalks and the means of egress from galleries and gridirons shall be not less than 560 mm (22 in.).

13.4.5.10 Fire Protection. Every stage shall be protected by an approved automatic sprinkler system in compliance with Section 9.7.

13.4.5.10.1 Protection shall be provided throughout the stage and in storerooms, workshops, permanent dressing rooms, and other accessory spaces contiguous to such stages.

13.4.5.10.2 Sprinklers shall not be required for stages 93 m² (1000 ft²) or less in area where the following criteria are met:

- (1) Curtains, scenery, or other combustible hangings are not retractable vertically.
- (2) Combustible hangings are limited to borders, legs, a single main curtain, and a single backdrop.

13.4.5.10.3 Sprinklers shall not be required under stage areas less than 1220 mm (48 in.) in clear height that are used exclusively for chair or table storage and lined on the inside with 16-mm (5/8-in.) Type X gypsum wallboard or the approved equivalent.

13.4.5.11 Flame-Retardant Requirements.

13.4.5.11.1 Combustible scenery of cloth, film, vegetation (dry), and similar materials shall meet the requirements of NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*.

13.4.5.11.2 Foamed plastics (*see definition of cellular or foamed plastic in 3.3.30*) shall be permitted to be used only by specific approval of the authority having jurisdiction.

13.4.5.11.3 Scenery and stage properties on thrust stages shall be of either noncombustible or limited-combustible materials.

13.4.5.12* Standpipes.

13.4.5.12.1 Stages over 93 m² (1000 ft²) in area shall be equipped with 38-mm (1½-in.) hose lines for first aid fire fighting at each side of the stage.

13.4.5.12.2 Hose connections shall be in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, unless Class II or Class III standpipes in accordance with NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*, are used.

13.4.6 Projection Rooms.

13.4.6.1 Projection rooms shall comply with 13.4.6.2 through 13.4.6.10.

13.4.6.2 Where cellulose nitrate film is used, the projection room shall comply with NFPA 40, *Standard for the Storage and Handling of Cellulose Nitrate Film*.

13.4.6.3 Film or video projectors or spotlights utilizing light sources that produce particulate matter, or toxic gases or light sources that produce hazardous radiation without protective shielding, shall be located within a projection room complying with 13.3.2.1.2.

13.4.6.4 Every projection room shall be of permanent construction consistent with the construction requirements for the type of building in which the projection room is located and shall comply with the following:

- (1) Openings shall not be required to be protected.
- (2) The room shall have a floor area of not less than 7.4 m² (80 ft²) for a single machine and not less than 3.7 m² (40 ft²) for each additional machine.
- (3) Each motion picture projector, floodlight, spotlight, or similar piece of equipment shall have a clear working space of not less than 760 mm (30 in.) on each side and at its rear, but only one such space shall be required between adjacent projectors.

13.4.6.5 The projection room and the rooms appurtenant to it shall have a ceiling height of not less than 2285 mm (90 in.).

13.4.6.6 Each projection room for safety film shall have not less than one out-swinging, self-closing door not less than 760 mm (30 in.) wide and 2030 mm (80 in.) high.

13.4.6.7 The aggregate of ports and openings for projection equipment shall not exceed 25 percent of the area of the wall between the projection room and the auditorium, and all openings shall be provided with glass or other approved material so as to completely close the opening.

13.4.6.8 Projection room ventilation shall comply with 13.4.6.8.1 and 13.4.6.8.2.

13.4.6.8.1 Supply Air.

13.4.6.8.1.1 Each projection room shall be provided with adequate air supply inlets arranged to provide well-distributed air throughout the room.

13.4.6.8.1.2 Air inlet ducts shall provide an amount of air equivalent to the amount of air being exhausted by projection equipment.

13.4.6.8.1.3 Air shall be permitted to be taken from the outside; from adjacent spaces within the building, provided that the volume and infiltration rate is sufficient; or from the building air conditioning system, provided that it is arranged to supply sufficient air whether or not other systems are in operation.

13.4.6.8.2 Exhaust Air.

13.4.6.8.2.1 Projection booths shall be permitted to be exhausted through the lamp exhaust system.

13.4.6.8.2.2 The lamp exhaust system shall be positively interconnected with the lamp so that the lamp cannot operate unless there is sufficient airflow required for the lamp.

13.4.6.8.2.3 Exhaust air ducts shall terminate at the exterior of the building in such a location that the exhaust air cannot be readily recirculated into any air supply system.

13.4.6.8.2.4 The projection room ventilation system shall be permitted also to serve appurtenant rooms, such as the generator room and the rewind room.

13.4.6.9 Each projection machine shall be provided with an exhaust duct that draws air from each lamp and exhausts it directly to the outside of the building.

13.4.6.9.1 The lamp exhaust shall be permitted to exhaust air from the projection room to provide room air circulation.

13.4.6.9.2 Such ducts shall be of rigid materials, except for a flexible connector approved for the purpose.

13.4.6.9.3 The projection lamp and projection room exhaust systems shall be permitted to be combined but shall not be interconnected with any other exhaust system or return-air system within the buildings.

13.4.6.9.4 Specifications for electric arc and xenon projection equipment shall comply with 13.4.6.9.4(A) and 13.4.6.9.4(B).

(A) Electric Arc Projection Equipment. The exhaust capacity shall be $0.09 \text{ m}^3/\text{s}$ ($200 \text{ ft}^3/\text{min}$) for each lamp connected to the lamp exhaust system or as recommended by the equipment manufacturer, and auxiliary air shall be permitted to be introduced into the system through a screened opening to stabilize the arc.

(B) Xenon Projection Equipment. The lamp exhaust system shall exhaust not less than $0.14 \text{ m}^3/\text{s}$ ($300 \text{ ft}^3/\text{min}$) per lamp, or not less than the exhaust volume required or recommended by the equipment manufacturer, whichever is greater.

13.4.6.10 Miscellaneous equipment and storage shall be protected as follows:

- (1) Each projection room shall be provided with rewind and film storage facilities.
- (2) Flammable liquids containers shall be permitted in projection rooms, provided that the following criteria are met:
 - (a) There are not more than four containers per projection room.
 - (b) No container has capacity exceeding 0.5 L (16 oz).
 - (c) Containers are of a nonbreakable type.
- (3) Appurtenant electrical equipment, such as rheostats, transformers, and generators, shall be permitted to be located within the booth or in a separate room of equivalent construction.

13.4.7* Special Amusement Buildings.

13.4.7.1* General. Special amusement buildings, regardless of occupant load, shall meet the requirements for assembly occupancies in addition to the requirements of 13.4.7, unless the special amusement building is a multilevel play structure that is not more than 3050 mm (120 in.) in height and has aggregate horizontal projections not exceeding 15 m^2 (160 ft^2).

13.4.7.2* Automatic Sprinklers. Every special amusement building, other than buildings or structures not exceeding 3050 mm (120 in.) in height and not exceeding 15 m^2 (160 ft^2) in aggregate horizontal projection, shall be protected throughout by an approved, supervised automatic sprinkler system installed and maintained in accordance with Section 9.7.

13.4.7.3 Temporary Water Supply. Where the special amusement building required to be sprinklered by 13.4.7.2 is movable or portable, the sprinkler water supply shall be permitted to be provided by an approved, temporary means.

13.4.7.4 Smoke Detection. Where the nature of the special amusement building is such that it operates in reduced lighting levels, the building shall be protected throughout by an approved automatic smoke detection system in accordance with Section 9.6.

13.4.7.5 Alarm Initiation. Actuation of any smoke detection system device shall sound an alarm at a constantly attended location on the premises.

13.4.7.6 Illumination. Actuation of the automatic sprinkler system, or any other suppression system, or actuation of a smoke detection system having an approved verification or cross-zoning operation capability shall provide the following:

- (1) Cause illumination in the means of egress to increase to that required by Section 7.8
- (2) Stop any conflicting or confusing sounds and visuals

13.4.7.7 Exit Marking.

13.4.7.7.1 Exit marking shall be in accordance with Section 7.10.

13.4.7.7.2 Floor proximity exit signs shall be provided in accordance with 7.10.1.6.

13.4.7.7.3* In special amusement buildings where mazes, mirrors, or other designs are used to confound the egress path, approved directional exit marking that becomes apparent in an emergency shall be provided.

13.4.7.8 Interior Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A throughout in accordance with Section 10.2.

13.4.8 Grandstands.

13.4.8.1 General.

13.4.8.1.1 Grandstands shall comply with the provisions of this chapter as modified by 13.4.8.

13.4.8.1.2 Approved existing grandstands shall be permitted to be continued to be used.

13.4.8.2 Seating.

13.4.8.2.1 Where grandstand seating without backs is used indoors, rows of seats shall be spaced not less than 560 mm (22 in.) back-to-back.

13.4.8.2.2 The depth of footboards and seat boards in grandstands shall be not less than 230 mm (9 in.), where the same level is not used for both seat foundations and footrests, footrests independent of seats shall be provided.

13.4.8.2.3 Seats and footrests of grandstands shall be supported securely and fastened in such a manner that they cannot be displaced inadvertently.

13.4.8.2.4 Individual seats or chairs shall be permitted only if secured firmly in rows in an approved manner, unless seats do not exceed 16 in number and are located on level floors and within railed-in enclosures, such as boxes.

13.4.8.2.5 The maximum number of seats permitted between the farthest seat in an aisle in grandstands and bleachers shall not exceed that shown in Table 13.4.8.2.5.

Table 13.4.8.2.5 Maximum Number of Seats Between Farthest Seat and an Aisle

Application	Outdoors	Indoors
Grandstands	11	6
Bleachers [(see 13.2.5.6.1(1))]	20	9

13.4.8.3 Special Requirements — Wood Grandstands.

13.4.8.3.1 The distance between an outdoor wood grandstand and a building shall be not less than two-thirds of the grandstand height and in no case less than 3050 mm (120 in.) of a building, unless otherwise permitted by the following:

- (1) The distance requirement shall not apply to buildings of not less than 1-hour fire resistance-rated construction with openings protected against the fire exposure hazard created by the grandstand.
- (2) The distance requirement shall not apply where a wall of not less than 1-hour fire resistance-rated construction separates the grandstand from the building.

13.4.8.3.2 An outdoor wood grandstand unit shall not exceed 929 m² (10,000 ft²) in ground area or 61 m (200 ft) in length, and the following requirements also shall apply.

- (1) Grandstand units of the maximum size shall be placed not less than 6100 mm (240 in.) apart or shall be separated by walls of 1-hour fire resistance rating.
- (2) The number of grandstand units erected in any one group shall not exceed three.
- (3) Each group of grandstand units shall be separated from any other group by a wall of 2-hour fire resistance-rated construction extending 610 mm (24 in.) above the seat platforms or by an open space of not less than 15 m (50 ft).

13.4.8.3.3 The ground area or length required by 13.4.8.3.2 shall be permitted to be doubled where one of the following criteria is met:

- (1) Where the grandstand is constructed entirely of labeled fire-retardant-treated wood that has passed the standard rain test, ASTM D 2898, *Test Method for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing*
- (2) Where the grandstand is constructed of members conforming to dimensions for heavy timber construction (Type IV (2HH))

13.4.8.3.4 The highest level of seat platforms above the ground or the surface at the front of any wood grandstand shall not exceed 6100 mm (240 in.).

13.4.8.3.5 The highest level of seat platforms above the ground, or the surface at the front of a portable grandstand within a tent or membrane structure, shall not exceed 3660 mm (144 in.).

13.4.8.3.6 The height requirements specified in 13.4.8.3.4 and 13.4.8.3.5 shall be permitted to be doubled where the grandstand is constructed entirely of labeled fire-retardant-treated wood that has passed the standard rain test, ASTM D 2898, *Test Method for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing*, or where constructed of members conforming to dimensions for heavy timber construction (Type IV (2HH)).

13.4.8.4 Special Requirements — Portable Grandstands.

13.4.8.4.1 Portable grandstands shall conform to the requirements of 13.4.8 for grandstands and the requirements of 13.4.8.4.2 through 13.4.8.4.7.

13.4.8.4.2 Portable grandstands shall be self-contained and shall have within them all necessary parts to withstand and restrain all forces that might be developed during human occupancy.

13.4.8.4.3 Portable grandstands shall be designed and manufactured so that if any structural members essential to the

strength and stability of the structure have been omitted during erection, the presence of unused connection fittings shall make the omissions self-evident.

13.4.8.4.4 Portable grandstands construction shall be skillfully accomplished to produce the strength required by the design.

13.4.8.4.5 Portable grandstands shall be provided with base plates, sills, floor runners, or sleepers of such area that the permitted bearing capacity of the supporting material is not exceeded.

13.4.8.4.6 Where portable grandstands rest directly on a base of such character that it is incapable of supporting the load without appreciable settlement, mud sills of suitable material, having sufficient area to prevent undue or dangerous settlement, shall be installed under base plates, runners, or sleepers.

13.4.8.4.7 All bearing surfaces shall be in contact with each other.

13.4.8.5 Spaces Underneath Grandstands. Spaces underneath a grandstand shall be kept free of flammable or combustible materials, unless protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7 or unless otherwise permitted by the following:

- (1) This requirement shall not apply to accessory uses of 28 m² (300 ft²) or less such as ticket booths, toilet facilities, or concession booths, where constructed of noncombustible or fire-resistive construction, in materials otherwise nonsprinklered facilities.
- (2) This requirement shall not apply to rooms that are enclosed in not less than 1-hour fire resistance-rated construction and are less than 93 m² (1000 ft²) in otherwise nonsprinklered facilities.

13.4.8.6 Guards and Railings.

13.4.8.6.1 Railings or guards not less than 1065 mm (42 in.) above the aisle surface or footrest or not less than 915 mm (36 in.) vertically above the center of the seat or seat board surface, whichever is adjacent, shall be provided along those portions of the backs and ends of all grandstands where the seats are in excess of 1220 mm (48 in.) above the floor or ground.

13.4.8.6.2 The requirement of 13.4.8.6.1 shall not apply where an adjacent wall or fence affords equivalent safeguard.

13.4.8.6.3 Where the front footrest of any grandstand is more than 610 mm (24 in.) above the floor, railings or guards not less than 825 mm (33 in.) above such footrests shall be provided.

13.4.8.6.4 The railings required by 13.4.8.6.3 shall be permitted to be not less than 660 mm (26 in.) high in grandstands or where the front row of seats includes backrests.

13.4.8.6.5 Cross aisles located within the seating area shall be provided with rails not less than 660 mm (26 in.) high along the front edge of the cross aisle.

13.4.8.6.6 The railings specified by 13.4.8.6.5 shall not be required where the backs of the seats in front of the cross aisle project 610 mm (24 in.) or more above the surface of the cross aisle.

13.4.8.6.7 Vertical openings between guardrails and footboards or seat boards shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

13.4.8.6.8 An opening between the seat board and footboard located more than 760 mm (30 in.) above grade shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

13.4.9 Folding and Telescopic Seating.

13.4.9.1 General.

13.4.9.1.1 Folding and telescopic seating shall comply with the provisions of this chapter as modified by 13.4.9.

13.4.9.1.2 Approved existing folding and telescopic seating shall be permitted to be continued to be used.

13.4.9.2 Seating.

13.4.9.2.1 The horizontal distance of seats, measured back-to-back, shall be not less than 560 mm (22 in.) for seats without backs, and the following requirements shall also apply:

- (1) There shall be a space of not less than 305 mm (12 in.) between the back of each seat and the front of each seat immediately behind it.
- (2) If seats are of the chair type, the 305-mm (12-in.) dimension shall be measured to the front edge of the rear seat in its normal unoccupied position.
- (3) All measurements shall be taken between plumb lines.

13.4.9.2.2 The depth of footboards (footrests) and seat boards in folding and telescopic seating shall be not less than 230 mm (9 in.).

13.4.9.2.3 Where the same level is not used for both seat foundations and footrests, footrests independent of seats shall be provided.

13.4.9.2.4 Individual chair-type seats shall be permitted in folding and telescopic seating only if firmly secured in groups of not less than three.

13.4.9.2.5 The maximum number of seats permitted between the farthest seat in an aisle in folding and telescopic seating shall not exceed that shown in Table 13.4.8.2.5.

13.4.9.3 Guards and Railings.

13.4.9.3.1 Railings or guards not less than 1065 mm (42 in.) above the aisle surface or footrest or not less than 915 mm (36 in.) vertically above the center of the seat or seat board surface, whichever is adjacent, shall be provided along those portions of the backs and ends of all folding and telescopic seating where the seats are more than 1220 mm (48 in.) above the floor or ground.

13.4.9.3.2 The requirement of 13.4.9.3.1 shall not apply where an adjacent wall or fence affords equivalent safeguard.

13.4.9.3.3 Where the front footrest of folding or telescopic seating is more than 610 mm (24 in.) above the floor, railings or guards not less than 825 mm (33 in.) above such footrests shall be provided.

13.4.9.3.4 The railings required by 13.4.9.3.3 shall be permitted to be not less than 660 mm (26 in.) high where the front row of seats includes backrests.

13.4.9.3.5 Cross aisles located within the seating area shall be provided with rails not less than 660 mm (26 in.) high along the front edge of the cross aisle.

13.4.9.3.6 The railings specified by 13.4.9.3.5 shall not be required where the backs of the seats in front of the cross aisle project 610 mm (24 in.) or more above the surface of the cross aisle.

13.4.9.3.7 Vertical openings between guardrails and footboards or seat boards shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

13.4.9.3.8 An opening between the seat board and footboard located more than 760 mm (30 in.) above grade shall be provided with intermediate construction so that a 100-mm (4-in.) diameter sphere cannot pass through the opening.

13.4.10 Airport Loading Walkways.

13.4.10.1 Airport loading walkways shall conform with NFPA 415, *Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways*, and the provisions of 13.4.10.2 and 13.4.10.3.

13.4.10.2 Doors in the egress path from the aircraft through the airport loading walkway into the airport terminal building shall meet the following criteria:

- (1) They shall swing in the direction of egress from the aircraft.
- (2)*They shall not be permitted to have delayed egress locks.

13.4.10.3 Exit access shall be unimpeded from the airport loading walkway to the non-secured public areas of the airport terminal building.

13.5 Building Services.

13.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

13.5.2 Heating, Ventilating, and Air Conditioning Equipment. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

13.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

13.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

13.6 Reserved.

13.7 Operating Features.

13.7.1 Special Provisions for Food Service Operations.

13.7.1.1 All devices in connection with the preparation of food shall be installed and operated to avoid hazard to the safety of occupants.

13.7.1.2 All devices in connection with the preparation of food shall be of an approved type and shall be installed in an approved manner.

13.7.1.3 Food preparation facilities shall be protected in accordance with 9.2.3 and shall not be required to have openings protected between food preparation areas and dining areas.

13.7.1.4 Portable cooking equipment that is not flue-connected shall be permitted only as follows:

- (1) Equipment fueled by small heat sources that can be readily extinguished by water, such as candles or alcohol-burning equipment, including solid alcohol, shall be permitted to be used, provided that precautions satisfactory to the authority having jurisdiction are taken to prevent ignition of any combustible materials.

- (2) Candles shall be permitted to be used on tables used for food service where securely supported on substantial non-combustible bases located to avoid danger of ignition of combustible materials and only where approved by the authority having jurisdiction.
- (3) Candle flames shall be protected.
- (4) "Flaming sword" or other equipment involving open flames and flamed dishes, such as cherries jubilee or crêpe suzette, shall be permitted to be used, provided that precautions subject to the approval of the authority having jurisdiction are taken.
- (5)*Listed and approved LP-Gas commercial food service appliances shall be permitted to be used where in accordance with NFPA 58, *Liquefied Petroleum Gas Code*.

13.7.2 Open Flame Devices and Pyrotechnics. No open flame devices or pyrotechnic devices shall be used in any assembly occupancy, unless otherwise permitted by the following:

- (1) Pyrotechnic special effect devices shall be permitted to be used on stages before proximate audiences for ceremonial or religious purposes, as part of a demonstration in exhibits, or as part of a performance, provided that both of the following are met:
 - (a) Precautions satisfactory to the authority having jurisdiction are taken to prevent ignition of any combustible material.
 - (b) Use of the pyrotechnic device complies with NFPA 1126, *Standard for the Use of Pyrotechnics before a Proximate Audience*.
- (2) Flame effects before an audience shall be permitted in accordance with NFPA 160, *Standard for Flame Effects Before an Audience*.
- (3) Open flame devices shall be permitted to be used in the following situations, provided that precautions satisfactory to the authority having jurisdiction are taken to prevent ignition of any combustible material or injury to occupants:
 - (a)*For ceremonial or religious purposes
 - (b) On stages and platforms where part of a performance
 - (c) Where candles on tables are securely supported on substantial noncombustible bases and candle flame is protected
- (4) This requirement shall not apply to heat-producing equipment complying with 9.2.2.
- (5) This requirement shall not apply to food service operations in accordance with 13.7.1.
- (6) Gas lights shall be permitted to be used, provided that precautions are taken, subject to the approval of authority having jurisdiction, to prevent ignition of any combustible materials.

13.7.3 Furnishings, Decorations, and Scenery.

13.7.3.1 Fabrics and films used for decorative purposes, all draperies and curtains, and similar furnishings shall be in accordance with the provisions of 10.3.1.

13.7.3.2 The authority having jurisdiction shall impose controls on the quantity and arrangement of combustible contents in assembly occupancies to provide an adequate level of safety to life from fire.

13.7.3.3* Exposed foamed plastic materials and unprotected materials containing foamed plastic used for decorative purposes or stage scenery shall have a heat release rate not exceeding 100 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*.

13.7.3.4 The requirement of 13.7.3.3 shall not apply to individual foamed plastic items and items containing foamed plastic where the foamed plastic does not exceed 0.45 kg (1 lb) in weight.

13.7.4 Special Provisions for Exposition Facilities.

13.7.4.1 General. No display or exhibit shall be installed or operated to interfere in any way with access to any required exit or with the visibility of any required exit or required exit sign; nor shall any display block access to fire-fighting equipment.

13.7.4.2 Materials Not on Display. A storage room having an enclosure consisting of a smoke barrier having a fire resistance rating of 1 hour and protected by an automatic extinguishing system shall be provided for combustible materials not on display, including combustible packing crates used to ship exhibitors' supplies and products.

13.7.4.3 Exhibits.

13.7.4.3.1 Exhibits shall comply with 13.7.4.3.2 through 13.7.4.3.11.

13.7.4.3.2 The travel distance within the exhibit booth or exhibit enclosure to an exit access aisle shall not exceed 15 m (50 ft).

13.7.4.3.3 The upper deck of multilevel exhibits greater than 28 m² (300 ft²) shall have not less than two remote means of egress.

13.7.4.3.4 Exhibit booths shall be constructed of the following:

- (1) Noncombustible or limited-combustible materials
- (2) Wood exceeding 6.3 mm (¼ in.) nominal thickness or wood not exceeding 6.3 mm (¼ in.) nominal thickness that is pressure-treated, fire-retardant wood meeting the requirements of NFPA 703, *Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*
- (3)*Flame-retardant materials complying with NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*
- (4) Textile wall coverings, such as carpeting and similar products used as wall or ceiling finishes, complying with the provisions of 10.2.2 and 10.2.4
- (5) Plastics limited to those that comply with 13.3.3 and Section 10.2
- (6) Foamed plastics and materials containing foamed plastics having a heat release rate for any single fuel package that does not exceed 100 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*
- (7) Cardboard, honeycombed paper, and other combustible materials having a heat release rate for any single fuel package that does not exceed 150 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*

13.7.4.3.5 Curtains, drapes, and decorations shall comply with the applicable portions of 10.3.1.

13.7.4.3.6 Acoustical and decorative material including, but not limited to, cotton, hay, paper, straw, moss, split bamboo, and wood chips shall be flame-retardant treated to the satisfaction of the authority having jurisdiction.

13.7.4.3.6.1 Materials that cannot be treated for flame retardancy shall not be used.

13.7.4.3.6.2 Foamed plastics and materials containing foamed plastics and used as decorative objects such as, but not limited to, mannequins, murals, and signs shall have a heat release rate for any single fuel package that does not exceed 150 kW where tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*.

13.7.4.3.6.3 Where the aggregate area of acoustical and decorative materials is less than 10 percent of the individual floor or wall area, such materials shall be permitted to be used subject to the approval of the authority having jurisdiction.

13.7.4.3.7 The following shall be protected by automatic extinguishing systems:

- (1) Single-level exhibit booths exceeding 28 m² (300 ft²) and covered with a ceiling
- (2) Each level of multilevel exhibit booths, protected throughout, including the uppermost level where the uppermost level is covered with a ceiling

13.7.4.3.7.1 The requirements of 13.7.4.3.7 shall not apply where otherwise permitted by the following:

- (1) Ceilings of open grate design or listed dropout ceilings in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall not be considered ceilings within the context of 13.7.4.3.7.
- (2) Vehicles, boats, and similar exhibited products having over 9.3 m² (100 ft²) of roofed area shall be provided with smoke detectors acceptable to the authority having jurisdiction.
- (3)*The requirement of 13.7.4.3.7(2) shall not apply where fire protection of multilevel exhibit booths is consistent with the criteria developed through a life safety evaluation of the exhibition hall in accordance with 13.4.1, subject to approval of the authority having jurisdiction.

13.7.4.3.7.2 A single exhibit or group of exhibits with ceilings that do not require sprinklers shall be separated by a distance not less than 3050 mm (120 in.) where the aggregate ceiling exceeds 28 m² (300 ft²).

13.7.4.3.7.3 The water supply and piping for the sprinkler system shall be permitted to be of approved, temporary means that is provided by a domestic water supply, a standpipe system, or a sprinkler system.

13.7.4.3.8 Open flame devices within exhibit booths shall comply with 13.7.2.

13.7.4.3.9 Cooking and food-warming devices in exhibit booths shall comply with 13.7.1 and the following:

- (1) Gas-fired devices shall comply with the following:
 - (a) Natural gas-fired devices shall comply with 9.1.1.
 - (b) The requirement of 13.7.4.3.9(1)(a) shall not apply to compressed natural gas where permitted by the authority having jurisdiction.
 - (c) The use of LP-Gas cylinders shall be prohibited.
 - (d) Nonrefillable LP-Gas cylinders shall be permitted for use where approved by the authority having jurisdiction.
- (2) The devices shall be isolated from the public by not less than 1220 mm (48 in.) or by a barrier between the devices and the public.
- (3) Multi-well cooking equipment using combustible oils or solids shall comply with 9.2.3.

(4) Single-well cooking equipment using combustible oils or solids shall meet the following criteria:

- (a) They shall have lids available for immediate use.
 - (b) They shall be limited to 0.2 m² (288 in.²) of cooking surface.
 - (c) They shall be placed on noncombustible surface materials.
 - (d) They shall be separated from each other by a horizontal distance of not less than 610 mm (24 in.).
 - (e) The requirement of 13.7.4.3.9(4)(d) shall not apply to multiple single-well cooking equipment where the aggregate cooking surface area does not exceed 0.2 m² (288 in.²).
 - (f) They shall be kept at a horizontal distance of not less than 610 mm (24 in.) from any combustible material.
- (5) A portable fire extinguisher in accordance with 9.7.4.1 shall be provided within the booth for each device, or an approved automatic extinguishing system shall be provided.

13.7.4.3.10 Combustible materials within exhibit booths shall be limited to a one-day supply. Storage of combustible materials behind the booth shall be prohibited. (*See 13.7.3.2 and 13.7.4.2.*)

13.7.4.3.11 Plans for the exposition, in an acceptable form, shall be submitted to the authority having jurisdiction for approval prior to setting up any exhibit.

13.7.4.3.11.1 The plan shall show all details of the proposed exposition.

13.7.4.3.11.2 No exposition shall occupy any exposition facility without approved plans.

13.7.4.4 Vehicles. Vehicles on display within an exposition facility shall comply with 13.7.4.4.1 through 13.7.4.4.5.

13.7.4.4.1 All fuel tank openings shall be locked and sealed in an approved manner to prevent the escape of vapors; fuel tanks shall not contain in excess of one-half their capacity or contain in excess of 38 L (10 gal) of fuel, whichever is less.

13.7.4.4.2 At least one battery cable shall be removed from the batteries used to start the vehicle engine, and the disconnected battery cable shall then be taped.

13.7.4.4.3 Batteries used to power auxiliary equipment shall be permitted to be kept in service.

13.7.4.4.4 Fueling or defueling of vehicles shall be prohibited.

13.7.4.4.5 Vehicles shall not be moved during exhibit hours.

13.7.4.5 Prohibited Materials.

13.7.4.5.1 The following items shall be prohibited within exhibit halls:

- (1) Compressed flammable gases
- (2) Flammable or combustible liquids
- (3) Hazardous chemicals or materials
- (4) Class II or greater lasers, blasting agents, and explosives

13.7.4.5.2 The authority having jurisdiction shall be permitted to allow the limited use of any items specified in 13.7.4.5.1 under special circumstances.

13.7.4.6 Alternatives. See Section 1.4.

13.7.5* Crowd Managers.

13.7.5.1 In assembly occupancies having occupant loads exceeding 1000, trained crowd managers or crowd manager supervisors shall be provided at a ratio of 1 crowd manager/supervisor for every 250 occupants, unless otherwise permitted by the following:

- (1) This requirement shall not apply to assembly occupancies used exclusively for religious worship with an occupant load not exceeding 2000.
- (2) The ratio of trained crowd managers to occupants shall be permitted to be reduced where, in the opinion of the authority having jurisdiction, the existence of an approved, supervised automatic sprinkler system and the nature of the event warrant.

13.7.5.2 The crowd manager shall receive approved training in crowd management techniques.

13.7.6* Drills.

13.7.6.1 The employees or attendants of assembly occupancies shall be trained and drilled in the duties they are to perform in case of fire, panic, or other emergency to effect orderly exiting.

13.7.6.2 Employees or attendants of assembly occupancies shall be instructed in the proper use of portable fire extinguishers and other manual fire suppression equipment where provided.

13.7.6.3* In the following assembly occupancies, an audible announcement shall be made, or a projected image shall be shown, prior to the start of each program that notifies occupants of the location of the exits to be used in case of a fire or other emergency:

- (1) Theaters
- (2) Motion picture theaters
- (3) Auditoriums
- (4) Other similar assembly occupancies with occupant loads exceeding 300 where there are noncontinuous programs

13.7.6.4 The requirement of 13.7.6.3 shall not apply to assembly occupancies in schools where used for nonpublic events.

13.7.7 Smoking.

13.7.7.1 Smoking in assembly occupancies shall be regulated by the authority having jurisdiction.

13.7.7.2 In rooms or areas where smoking is prohibited, plainly visible signs shall be posted that read as follows:

NO SMOKING

13.7.7.3 No person shall smoke in prohibited areas that are so posted, unless permitted by the authority having jurisdiction under both of the following conditions:

- (1) Smoking shall be permitted on a stage only where it is a necessary and rehearsed part of a performance
- (2) Smoking shall be permitted only where the smoker is a regular performing member of the cast

13.7.7.4 Where smoking is permitted, suitable ashtrays or receptacles shall be provided in convenient locations.

13.7.8 Seating.**13.7.8.1 Secured Seating.**

13.7.8.1.1 Seats in assembly occupancies accommodating more than 200 persons shall be securely fastened to the floor,

except where fastened together in groups of not less than three and not exceeding seven and as permitted by 13.7.8.2.

13.7.8.1.2 All seats in balconies and galleries shall be securely fastened to the floor, except in places of religious worship.

13.7.8.2 Unsecured Seating.

13.7.8.2.1 Seats not secured to the floor shall be permitted in restaurants, night clubs, and other occupancies where fastening seats to the floor might be impracticable.

13.7.8.2.2 Unsecured seats shall be permitted, provided that, in the area used for seating, excluding such areas of dance floors and stages, there is not more than one seat for each 1.4 m² (15 ft²) of net floor area, and adequate aisles to reach exits are maintained at all times.

13.7.8.2.3 Seating diagrams shall be submitted for approval by the authority having jurisdiction to permit an increase in occupant load per 7.3.1.3.

13.7.8.3 Occupant Load Posting.

13.7.8.3.1 Every room constituting an assembly occupancy and not having fixed seats shall have the occupant load of the room posted in a conspicuous place near the main exit from the room.

13.7.8.3.2 Approved signs shall be maintained in a legible manner by the owner or authorized agent.

13.7.8.3.3 Signs shall be durable and shall indicate the number of occupants permitted for each room use.

13.7.9 Maintenance of Outdoor Grandstands.

13.7.9.1 The owner shall provide for not less than annual inspection and required maintenance of each outdoor grandstand to ensure safe conditions.

13.7.9.2 At least biennially, the inspection shall be performed by a professional engineer, registered architect, or individual certified by the manufacturer.

13.7.9.3 Where required by the authority having jurisdiction, the owner shall provide certification that such inspection has been performed.

13.7.10 Maintenance and Operation of Folding and Telescopic Seating.

13.7.10.1 Instructions in both maintenance and operation shall be transmitted to the owner by the manufacturer of the seating or his or her representative.

13.7.10.2 Maintenance and operation of folding and telescopic seating shall be the responsibility of the owner or his or her duly authorized representative and shall include the following:

- (1) During operation of the folding and telescopic seats, the opening and closing shall be supervised by responsible personnel who shall ensure that the operation is in accordance with the manufacturer's instructions.
- (2) Only attachments specifically approved by the manufacturer for the specific installation shall be attached to the seating.
- (3) An annual inspection and required maintenance of each grandstand shall be performed to ensure safe conditions. At least biennially, the inspection shall be performed by a professional engineer, registered architect, or individual certified by the manufacturer.

13.7.11 Clothing. Clothing and personal effects shall not be stored in corridors, unless otherwise permitted by the following:

- (1) This requirement shall not apply to corridors protected by an approved automatic sprinkler system in accordance with Section 9.7.
- (2) This requirement shall not apply to corridor areas protected by a smoke detection system in accordance with Section 9.6.
- (3) This requirement shall not apply to storage in metal lockers, provided that the required egress width is maintained.

Chapter 14 New Educational Occupancies

14.1 General Requirements.

14.1.1 Application.

14.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as educational occupancies (*see 1.3.1*)
- (2) Additions made to, or used as, an educational occupancy (*see 4.6.7*)
- (3) Alterations, modernizations, or renovations of existing educational occupancies (*see 4.6.8*)
- (4) Existing buildings or portions thereof upon change of occupancy to an educational occupancy (*see 4.6.12*)

14.1.1.2 Educational facilities that do not meet the definition of an educational occupancy shall not be required to comply with this chapter but shall comply with the following requirements:

- (1) Instructional building — business occupancy
- (2) Classrooms under 50 persons — business occupancy
- (3) Classrooms, 50 persons and over — assembly occupancy
- (4) Laboratories, instructional — business occupancy
- (5) Laboratories, noninstructional — industrial

14.1.2 Multiple Occupancies.

14.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

14.1.2.2 Assembly and Educational.

14.1.2.2.1 Spaces subject to assembly occupancy shall comply with Chapter 12, including 12.1.2, which provides that, where auditorium and gymnasium egress lead through corridors or stairways also serving as egress for other parts of the building, the egress capacity shall be sufficient to allow simultaneous egress from auditorium and classroom sections.

14.1.2.2.2 In the case of an assembly occupancy of a type suitable for use only by the school occupant load and therefore not subject to simultaneous occupancy, the same egress capacity shall be permitted to serve both sections.

14.1.2.3 Dormitory and Classrooms.

14.1.2.3.1 Any building used for both classroom and dormitory purposes shall comply with the applicable provisions of Chapter 28 in addition to complying with Chapter 14.

14.1.2.3.2 Where classroom and dormitory sections are not subject to simultaneous occupancy, the same egress capacity shall be permitted to serve both sections.

14.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Common Atmosphere.** See 3.3.20.1.
- (2) **Flexible Plan and Open Plan Educational or Day-Care Building.** See 3.3.27.6.
- (3) **Separate Atmosphere.** See 3.3.20.2.

14.1.4 Classification of Occupancy. See 6.1.3.

14.1.4.1 Educational occupancies shall include all buildings used for educational purposes through the twelfth grade by six or more persons for 4 or more hours per day or more than 12 hours per week.

14.1.4.2 Educational occupancies shall include part-day pre-schools, kindergartens, and other schools whose purpose is primarily educational, even though the children who attend such schools are of preschool age.

14.1.4.3 In cases where instruction is incidental to some other occupancy, the section of this *Code* governing such other occupancy shall apply.

14.1.4.4 Other occupancies associated with educational institutions shall be in accordance with the appropriate parts of this *Code*. (*See Chapters 18, 20, 26, 28, 30, 40, and 42 and 6.1.14.*)

14.1.5 Classification of Hazard of Contents. The contents of educational occupancies shall be classified in accordance with the provisions of Section 6.2.

14.1.6 Minimum Construction Requirements. (No requirements)

14.1.7 Occupant Load.

14.1.7.1 The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

14.1.7.2 The occupant load of an educational occupancy, or a portion thereof, shall be permitted to be modified from that specified in 14.1.7.1 if the necessary aisles and exits are provided.

14.1.7.3 An approved aisle or seating diagram shall be required by the authority having jurisdiction to substantiate the modification permitted in 14.1.7.2.

14.2 Means of Egress Requirements.

14.2.1 General.

14.2.1.1 Means of egress shall be in accordance with Chapter 7 and Section 14.2.

14.2.1.2 Rooms normally occupied by preschool, kindergarten, or first-grade students shall be located on a level of exit discharge, unless otherwise permitted by 14.2.1.4.

14.2.1.3 Rooms normally occupied by second-grade students shall not be located more than one story above a level of exit discharge, unless otherwise permitted by 14.2.1.4.

14.2.1.4 Rooms or areas located on floor levels other than as specified in 14.2.1.2 and 14.2.1.3 shall be permitted to be used where provided with independent means of egress dedicated for use by the preschool, kindergarten, first-grade, or second-grade students.

14.2.2 Means of Egress Components.

14.2.2.1 Components of means of egress shall be limited to the types described in 14.2.2.2 through 14.2.2.10.

14.2.2.2 Doors.

14.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

14.2.2.2.2 Any door in a required means of egress from an area having an occupant load of 100 or more persons shall be permitted to be provided with a latch or lock only if the latch or lock is panic hardware or fire exit hardware complying with 7.2.1.7.

14.2.2.2.3 Special locking arrangements complying with 7.2.1.6 shall be permitted.

14.2.2.3* Stairs. Stairs complying with 7.2.2 shall be permitted.

14.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

14.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

14.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

14.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

14.2.2.8 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

14.2.2.9 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

14.2.2.10 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

14.2.3 Capacity of Means of Egress.

14.2.3.1 Capacity of means of egress shall be in accordance with Section 7.3.

14.2.3.2 Minimum Corridor Width. Exit access corridors shall have not less than 1830 mm (72 in.) of clear width.

14.2.4 Number of Exits. Not less than two separate exits shall be as follows:

- (1) Provided on every story
- (2) Accessible from every part of every story and mezzanine

14.2.5 Arrangement of Means of Egress. See also Section 7.5.

14.2.5.1 Means of egress shall be arranged in accordance with Section 7.5.

14.2.5.2 No dead-end corridor shall exceed 6100 mm (240 in.), other than in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, in which case dead-end corridors shall not exceed 15 m (50 ft).

14.2.5.3 No common path of travel shall exceed 23 m (75 ft), other than for the first 30 m (100 ft) in a building protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

14.2.5.4 Every room that is normally subject to student occupancy shall have an exit access door leading directly to an exit access corridor or exit, unless otherwise permitted by the following:

- (1) This requirement shall not apply where an exit door opens directly to the outside or to an exterior balcony or corridor as described in 14.2.5.8.

(2) One room shall be permitted to intervene between a normally occupied student room and an exit access corridor, provided that all of the following criteria are met:

- (a) The travel from a room served by an intervening room to the corridor door or exit shall not exceed 23 m (75 ft).
- (b) Clothing, personal effects, or other materials deemed hazardous by the authority having jurisdiction shall be stored in metal lockers, provided that they do not obstruct the exit access, or the intervening room shall be sprinklered in accordance with Section 9.7.
- (c) One of the following means of protection shall be provided:
 - i. The intervening room shall have approved fire detection that activates the building alarm.
 - ii. The building shall be protected by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

14.2.5.5 Doors that swing into an exit access corridor shall be arranged to prevent interference with corridor travel. (*See also 7.2.1.4.4.*)

14.2.5.6 Aisles shall be not less than 760 mm (30 in.) wide.

14.2.5.7 The space between parallel rows of seats shall not be subject to the minimum aisle width, provided that the number of seats that intervene between any seat and an aisle does not exceed six.

14.2.5.8* Exterior Corridors or Balconies. Exterior exit access shall comply with 7.5.3.

14.2.6 Travel Distance to Exits.

14.2.6.1 Travel distance to an exit shall not exceed 46 m (150 ft) from any point in a building. (*See also Section 7.6.*)

14.2.6.2 Travel distance shall not exceed 61 m (200 ft) in educational occupancies protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

14.2.7 Discharge from Exits. Discharge from exits shall be arranged in accordance with Section 7.7.

14.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

14.2.9 Emergency Lighting. Emergency lighting shall be provided in accordance with Section 7.9.

14.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

14.2.11 Special Means of Egress Features.**14.2.11.1* Windows for Rescue.**

14.2.11.1.1 Every room or space greater than 23.2 m² (250 ft²) and used for classroom or other educational purposes or normally subject to student occupancy shall have not less than one outside window for emergency rescue that complies with the following unless otherwise permitted by 14.2.11.1.2:

- (1) Such windows shall be openable from the inside without the use of tools and shall provide a clear opening of not less than 510 mm (20 in.) in width, 610 mm (24 in.) in height, and 0.5 m² (5.7 ft²) in area.
- (2) The bottom of the opening shall be not more than 1120 mm (44 in.) above the floor, and any latching device shall be capable of being operated from not more than 1370 mm (54 in.) above the finished floor.

- (3) The clear opening shall allow a rectangular solid, with a width and height that provides not less than the required 0.5-m² (5.7-ft²) opening and a depth of not less than 510 mm (20 in.), to pass fully through the opening.
- (4) Such windows shall be accessible by the fire department and shall open into an area having access to a public way.

14.2.11.1.2 The requirements of 14.2.11.1.1 shall not apply to the following:

- (1) Buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7
- (2) Where the room or space has a door leading directly to the outside of the building
- (3) Rooms located higher than three stories above grade

14.3 Protection.

14.3.1 Protection of Vertical Openings.

14.3.1.1 Any vertical opening, other than unprotected vertical openings in accordance with 8.6.8.2, shall be enclosed or protected in accordance with Section 8.6.

14.3.1.2 Where the provisions of 8.6.6 are used, the requirements of 14.3.5.4 shall be met.

14.3.2 Protection from Hazards.

14.3.2.1 Rooms or spaces for the storage, processing, or use of materials shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour or protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Boiler and furnace rooms, unless such rooms enclose only air-handling equipment
 - (b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction
 - (c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
 - (d) Janitor closets (*see also 14.3.2.1(4).*)
- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Laundries
 - (b) Maintenance shops, including woodworking and painting areas
 - (c) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction
 - (d) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
- (3) Where automatic extinguishing is used to meet the requirements of 14.3.2.1(1) or (2), the protection shall be permitted in accordance with 9.7.1.2.
- (4) Where janitor closets addressed in 14.3.2.1(1)(d) are protected in accordance with the sprinkler option of 14.3.2.1(1), the janitor closet doors shall be permitted to have ventilating louvers.

14.3.2.2 Cooking facilities shall be protected in accordance with 9.2.3. Openings shall not be required to be protected between food preparation areas and dining areas.

14.3.2.3 Stages shall be protected in accordance with Chapter 12.

14.3.3 Interior Finish.

14.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

14.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be permitted as follows:

- (1) Exits — Class A
- (2) Other than exits — Class A or Class B
- (3) Low-height partitions not exceeding 1525 mm (60 in.) and used in locations other than exits — Class A, Class B, or Class C

14.3.3.3 Interior Floor Finish.

14.3.3.3.1 Interior floor finish shall comply with Section 10.2.

14.3.3.3.2 Interior floor finish in exit enclosures and exit access corridors and spaces not separated from them by walls complying with 14.3.6 shall be not less than Class II.

14.3.3.3.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

14.3.4 Detection, Alarm, and Communications Systems.

14.3.4.1 General.

14.3.4.1.1 Educational occupancies shall be provided with a fire alarm system in accordance with Section 9.6.

14.3.4.1.2 The requirement of 14.3.4.1.1 shall not apply to buildings meeting all of the following criteria:

- (1) Buildings having an area not exceeding 93 m² (1000 ft²)
- (2) Buildings containing a single classroom
- (3) Buildings located not less than 15 m (50 ft) from another building

14.3.4.2 Initiation.

14.3.4.2.1 General. Initiation of the required fire alarm system, other than as permitted by 14.3.4.2.3, shall be by manual means in accordance with 9.6.2.1(1).

14.3.4.2.2 Automatic Initiation. In buildings provided with automatic sprinkler protection, the operation of the sprinkler system shall automatically activate the fire alarm system in addition to the initiation means required in 14.3.4.2.1.

14.3.4.2.3 Alternative Protection System. Manual fire alarm boxes shall be permitted to be eliminated in accordance with 14.3.4.2.3.1 or 14.3.4.2.3.2.

14.3.4.2.3.1* Manual fire alarm boxes pull stations shall be permitted to be eliminated where all of the following conditions apply:

- (1) Interior corridors are protected by smoke detectors using an alarm verification system as described in *NFPA 72®*, *National Fire Alarm Code*.
- (2) Auditoriums, cafeterias, and gymnasiums, etc., are protected by heat or other approved detection devices.
- (3) Shops and laboratories involving dusts or vapors are protected by heat or other approved detection devices.
- (4) Provision is made at a central point to manually activate the evacuation signal or to evacuate only affected areas.

14.3.4.2.3.2* Manual fire alarm boxes shall be permitted to be eliminated where all of the following conditions apply:

- (1) The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (2) Provision is made at a central point to manually activate the evacuation signal, or to evacuate only affected areas.

14.3.4.3 Notification.

14.3.4.3.1 Occupant Notification.

14.3.4.3.1.1* Occupant notification shall be accomplished automatically in accordance with 9.6.3.

14.3.4.3.1.2 Positive alarm sequence shall be permitted in accordance with 9.6.3.4.

14.3.4.3.1.3 Where acceptable to the authority having jurisdiction, the fire alarm system shall be permitted to be used for other emergency signaling or for class changes, provided that the fire alarm is distinctive in signal and overrides all other use.

14.3.4.3.1.4 To prevent students from being returned to a building that is burning, the recall signal shall be separate and distinct from any other signals, and such signal shall be permitted to be given by use of distinctively colored flags or banners.

14.3.4.3.1.5 If the recall signal required by 14.3.4.3.1.4 is electric, the push buttons or other controls shall be kept under lock, the key for which shall be in the possession of the principal or another designated person in order to prevent a recall at a time when there is an actual fire.

14.3.4.3.1.6 Regardless of the method of recall signal, the means of giving the recall signal shall be kept under lock.

14.3.4.3.2 **Emergency Forces Notification.** Fire department notification shall be accomplished in accordance with 9.6.4.

14.3.5 Extinguishment Requirements.

14.3.5.1 Every portion of educational buildings below the level of exit discharge shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

14.3.5.2 **Reserved.**

14.3.5.3 **Reserved.**

14.3.5.4 Buildings with unprotected openings in accordance with 8.6.6 shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

14.3.5.5 Where another provision of this chapter requires an automatic sprinkler system, the sprinkler system shall be installed in accordance with 9.7.1.1(1).

14.3.6 **Corridors.** Corridors shall be separated from other parts of the story by walls having a 1-hour fire resistance rating in accordance with Section 8.3, unless otherwise permitted by the following:

- (1) Corridor protection shall not be required where all spaces normally subject to student occupancy have not less than one door opening directly to the outside or to an exterior exit access balcony or corridor in accordance with 7.5.3.
- (2) In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, corridor walls shall not be required to be rated, provided that such walls form smoke partitions in accordance with Section 8.4.

- (3) Where the corridor ceiling is an assembly having a 1-hour fire resistance rating where tested as a wall, the corridor walls shall be permitted to terminate at the corridor ceiling.
- (4) Lavatories shall not be required to be separated from corridors, provided that they are separated from all other spaces by walls having not less than a 1-hour fire resistance rating in accordance with Section 8.3.
- (5) Lavatories shall not be required to be separated from corridors, provided the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

14.3.7 Subdivision of Building Spaces.

14.3.7.1 Educational occupancies shall be subdivided into compartments by smoke partitions having not less than a 1-hour fire resistance rating and complying with Section 8.4 where one or both of the following conditions exist:

- (1) The maximum floor area, including the aggregate area of all floors having a common atmosphere, exceeds 2800 m² (30,000 ft²).
- (2) The length or width of the building exceeds 91 m (300 ft).

14.3.7.2 The requirement of 14.3.7.1 shall not apply to the following:

- (1) Where all spaces normally subject to student occupancy have not less than one door opening directly to the outside or to an exterior or exit access balcony or corridor in accordance with 7.5.3
- (2) Buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7

14.3.7.3 The area of any smoke compartment required by 14.3.7.1 shall not exceed 2800 m² (30,000 ft²), with no dimension exceeding 91 m (300 ft).

14.4 Special Provisions.

14.4.1 **Limited Access Buildings and Underground Buildings.** Limited access buildings and underground buildings shall comply with Section 11.7.

14.4.2 **High-Rise Buildings.** High-rise buildings shall comply with Section 11.8.

14.4.3 Flexible Plan and Open Plan Buildings.

14.4.3.1 Flexible plan and open plan buildings shall comply with the requirements of this chapter as modified by 14.4.3.2 through 14.4.3.5.

14.4.3.2 Each room occupied by more than 300 persons shall have two or more means of egress entering into separate atmospheres.

14.4.3.3 Where three or more means of egress are required, the number of means of egress permitted to enter into the same atmosphere shall not exceed two.

14.4.3.4 Flexible plan buildings shall be permitted to have walls and partitions rearranged periodically only if revised plans or diagrams have been approved by the authority having jurisdiction.

14.4.3.5 Flexible plan buildings shall be evaluated while all folding walls are extended and in use as well as when they are in the retracted position.

14.5 Building Services.

14.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

14.5.2 Heating, Ventilating, and Air Conditioning Equipment.

14.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

14.5.2.2 Unvented fuel-fired heating equipment, other than gas space heaters in compliance with NFPA 54/ANSI Z223.1, *National Fuel Gas Code*, shall be prohibited.

14.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

14.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

14.6 Reserved.**14.7 Operating Features.**

14.7.1 Emergency Plan. Emergency plans shall be provided in accordance with Section 4.8.

14.7.2 Emergency Egress and Relocation Drills.

14.7.2.1* Emergency egress and relocation drills shall be conducted in accordance with Section 4.7 and the applicable provisions of 14.7.2.2.

14.7.2.2 Emergency egress and relocation drills shall be conducted as follows:

- (1) Not less than one emergency egress and relocation drill shall be conducted every month the facility is in session, unless both of the following criteria are met:
 - (a) In climates where the weather is severe, the monthly emergency egress and relocation drills shall be permitted to be deferred.
 - (b) The required number of emergency egress and relocation drills shall be conducted, and not less than four shall be conducted before the drills are deferred.
- (2) All occupants of the building shall participate in the drill.
- (3) One additional emergency egress and relocation drill, other than for educational occupancies that are open on a year-round basis, shall be required within the first 30 days of operation.

14.7.2.3 All emergency and relocation drill alarms shall be sounded on the fire alarm system.

14.7.3 Inspection.

14.7.3.1* It shall be the duty of principals and teachers to inspect all exit facilities daily to ensure that all stairways, doors, and other exits are in proper condition.

14.7.3.2 Open plan buildings shall require extra surveillance to ensure that exit paths are maintained clear of obstruction and are obvious.

14.7.4 Furnishings and Decorations.

14.7.4.1 Draperies, curtains, and other similar furnishings and decorations in educational occupancies shall be in accordance with the provisions of 10.3.1.

14.7.4.2 Clothing and personal effects shall not be stored in corridors, unless otherwise permitted by the following:

- (1) This requirement shall not apply to corridors protected by an automatic sprinkler system in accordance with Section 9.7.
- (2) This requirement shall not apply to corridor areas protected by a smoke detection system in accordance with Section 9.6.
- (3) This requirement shall not apply to storage in metal lockers, provided that the required egress width is maintained.

14.7.4.3 Artwork and teaching materials shall be permitted to be attached directly to the walls in accordance with the following:

- (1) The artwork and teaching materials shall not exceed 20 percent of the wall area in a building that is not protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7
- (2) The artwork and teaching materials shall not exceed 50 percent of the wall area in a building that is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7

14.7.5 Open Flames. Approved open flames shall be permitted in laboratories and vocational/technical areas.

Chapter 15 Existing Educational Occupancies**15.1 General Requirements.****15.1.1 Application.**

15.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as educational occupancies. (*See also 14.1.1.*)

15.1.1.2 Educational facilities that do not meet the definition of an educational occupancy shall not be required to comply with this chapter but shall comply with the following requirements:

- (1) Instructional building — business occupancy
- (2) Classrooms under 50 persons — business occupancy
- (3) Classrooms, 50 persons and over — assembly occupancy
- (4) Laboratories, instructional — business occupancy
- (5) Laboratories, noninstructional — industrial

15.1.2 Multiple Occupancies.

15.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

15.1.2.2 Assembly and Educational.

15.1.2.2.1 Spaces subject to assembly occupancy shall comply with Chapter 13, including 13.1.2, which provides that, where auditorium and gymnasium egress lead through corridors or stairways also serving as egress for other parts of the building, the egress capacity shall be sufficient to allow simultaneous egress from auditorium and classroom sections.

15.1.2.2.2 In the case of an assembly occupancy of a type suitable for use only by the school occupant load and therefore not subject to simultaneous occupancy, the same egress capacity shall be permitted to serve both sections.

15.1.2.3 Dormitory and Classrooms.

15.1.2.3.1 Any building used for both classroom and dormitory purposes shall comply with the applicable provisions of Chapter 29 in addition to complying with Chapter 15.

15.1.2.3.2 Where classroom and dormitory sections are not subject to simultaneous occupancy, the same egress capacity shall be permitted to serve both sections.

15.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Common Atmosphere.** See 3.3.20.1.
- (2) **Flexible Plan and Open Plan Educational or Day-Care Building.** See 3.3.27.6.
- (3) **Separate Atmosphere.** See 3.3.20.2.

15.1.4 Classification of Occupancy. See 6.1.3.

15.1.4.1 Educational occupancies shall include all buildings used for educational purposes through the twelfth grade by six or more persons for 4 or more hours per day or more than 12 hours per week.

15.1.4.2 Educational occupancies shall include part-day preschools, kindergartens, and other schools whose purpose is primarily educational, even though the children who attend such schools are of preschool age.

15.1.4.3 In cases where instruction is incidental to some other occupancy, the section of this *Code* governing such other occupancy shall apply.

15.1.4.4 Other occupancies associated with educational institutions shall be in accordance with the appropriate parts of this *Code*. (See Chapter 19, Chapter 21, Chapter 26, Chapter 29, Chapter 31, Chapter 40, Chapter 42, and 6.1.14.)

15.1.5 Classification of Hazard of Contents. The contents of educational occupancies shall be classified in accordance with the provisions of Section 6.2.

15.1.6 Minimum Construction Requirements. (No requirements)

15.1.7 Occupant Load.

15.1.7.1 The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

15.1.7.2 The occupant load of an educational occupancy, or a portion thereof, shall be permitted to be modified from that specified in 15.1.7.1 if the necessary aisles and exits are provided.

15.1.7.3 An approved aisle or seating diagram shall be required by the authority having jurisdiction to substantiate the modification permitted in 15.1.7.2.

15.2 Means of Egress Requirements.**15.2.1 General.**

15.2.1.1 Means of egress shall be in accordance with Chapter 7 and Section 15.2.

15.2.1.2 Rooms normally occupied by preschool, kindergarten, or first-grade students shall be located on a level of exit discharge, unless otherwise permitted by 15.2.1.4.

15.2.1.3 Rooms normally occupied by second-grade students shall not be located more than one story above a level of exit discharge, unless otherwise permitted by 15.2.1.4.

15.2.1.4 Rooms or areas located on floor levels other than as specified in 15.2.1.2 and 15.2.1.3 shall be permitted to be used where provided with independent means of egress dedicated for use by the preschool, kindergarten, first-grade, or second-grade students.

15.2.2 Means of Egress Components.

15.2.2.1 Components of means of egress shall be limited to the types described in 15.2.2.2 through 15.2.2.10.

15.2.2.2 Doors.

15.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

15.2.2.2.2 Any required exit door subject to use by 100 or more persons shall be permitted to be provided with a latch or lock only if the latch or lock is panic hardware or fire exit hardware complying with 7.2.1.7.

15.2.2.2.3 Special locking arrangements complying with 7.2.1.6 shall be permitted.

15.2.2.3* Stairs.

15.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

15.2.2.3.2 Existing Class A stairs shall be permitted.

15.2.2.3.3 Existing Class B stairs shall be permitted where not used for student access.

15.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

15.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

15.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

15.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

15.2.2.8 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

15.2.2.9 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

15.2.2.10 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

15.2.3 Capacity of Means of Egress.

15.2.3.1 Capacity of means of egress shall be in accordance with Section 7.3.

15.2.3.2 Minimum Corridor Width. Exit access corridors shall have not less than 1830 mm (72 in.) of clear width.

15.2.4 Number of Exits. Not less than two separate exits shall be as follows:

- (1) Provided on every story
- (2) Accessible from every part of every story and mezzanine

15.2.5 Arrangement of Means of Egress.

15.2.5.1 Means of egress shall be arranged in accordance with Section 7.5.

15.2.5.2 No dead-end corridor shall exceed 6100 mm (240 in.), other than in buildings protected throughout by an

approved, supervised automatic sprinkler system in accordance with Section 9.7, in which case dead-end corridors shall not exceed 15 m (50 ft).

15.2.5.3 No common path of travel shall exceed 23 m (75 ft), other than for the first 30 m (100 ft) in a building protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

15.2.5.4 Every room that is normally subject to student occupancy shall have an exit access door leading directly to an exit access corridor or exit, unless otherwise permitted by the following:

- (1) This requirement shall not apply where an exit door opens directly to the outside or to an exterior balcony or corridor as described in 15.2.5.8.
- (2) One room shall be permitted to intervene between a normally occupied student room and an exit access corridor, provided that all of the following criteria are met:
 - (a) The travel from a room served by an intervening room to the corridor door or exit shall not exceed 23 m (75 ft).
 - (b) Clothing, personal effects, or other materials deemed hazardous by the authority having jurisdiction shall be stored in metal lockers, provided that they do not obstruct the exit access, or the intervening room shall be sprinklered in accordance with Section 9.7.
 - (c) One of the following means of protection shall be provided:
 - i. The intervening room shall have approved fire detection that activates the building alarm.
 - ii. The building shall be protected by an approved automatic sprinkler system in accordance with Section 9.7.
- (3) Approved existing arrangements shall be permitted to continue in use.

15.2.5.5 Doors that swing into an exit access corridor shall be arranged to prevent interference with corridor travel. (*See also 7.2.1.4.4.*)

15.2.5.6 Aisles shall be not less than 760 mm (30 in.) wide.

15.2.5.7 The space between parallel rows of seats shall not be subject to the minimum aisle width, provided that the number of seats that intervene between any seat and an aisle does not exceed six.

15.2.5.8* Exterior Corridors or Balconies. Exterior exit access shall comply with 7.5.3.

15.2.6 Travel Distance to Exits.

15.2.6.1 Travel distance to an exit shall not exceed 46 m (150 ft) from any point in a building, unless otherwise permitted by 15.2.6.2 or 15.2.6.3 (*see also Section 7.6*).

15.2.6.2 Travel distance shall not exceed 61 m (200 ft) in educational occupancies protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

15.2.6.3 Approved existing travel distances shall be permitted to continue in use.

15.2.7 Discharge from Exits. Discharge from exits shall be arranged in accordance with Section 7.7.

15.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

15.2.9 Emergency Lighting.

15.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9 unless otherwise permitted by 15.2.9.2.

15.2.9.2 Approved existing emergency lighting installations shall be permitted to be continued in use.

15.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

15.2.11 Special Means of Egress Features.

15.2.11.1* Windows for Rescue.

15.2.11.1.1 Every room or space greater than 23.2 m² (250 ft²) and used for classroom or other educational purposes or normally subject to student occupancy shall have not less than one outside window for emergency rescue that complies with the following, unless otherwise permitted by 15.2.11.1.2:

- (1) Such windows shall be openable from the inside without the use of tools and shall provide a clear opening of not less than 510 mm (20 in.) in width, 610 mm (24 in.) in height, and 0.5 m² (5.7 ft²) in area.
- (2) The bottom of the opening shall be not more than 1120 mm (44 in.) above the floor, and any latching device shall be capable of being operated from not more than 1370 mm (54 in.) above the finished floor.
- (3) The clear opening shall allow a rectangular solid, with a width and height that provides not less than the required 0.5-m² (5.7-ft²) opening and a depth of not less than 510 mm (20 in.), to pass fully through the opening.

15.2.11.1.2 The requirements of 15.2.11.1.1 shall not apply to the following:

- (1) Buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.
- (2) Where the room or space has a door leading directly to the outside of the building.
- (3) Rooms located higher than three stories above grade.
- (4) Where awning-type or hopper-type windows that are hinged or subdivided to provide a clear opening of not less than 0.38 m² (4 ft²) or any dimension of not less than 560 mm (22 in.), the following shall apply:
 - (a) Such windows shall be permitted to continue in use.
 - (b) Screen walls or devices located in front of required windows shall not interfere with rescue requirements.
- (5) Where the room or space complies with the following:
 - (a) Doors shall exist that allow travel between adjacent classrooms.
 - (b) Where doors are used to travel from classroom to classroom, they shall provide one of the following:
 - i. Direct access to exits in both directions
 - ii. Direct access to an exit in one direction and to a separate smoke compartment that provides access to another exit in the other direction
 - (c) The corridor shall be separated from the classrooms by a wall that resists the passage of smoke, and all doors between the classrooms and the corridor shall be self-closing or automatic-closing in accordance with 7.2.1.8.
 - (d) The length of travel to exits along such paths shall not exceed 46 m (150 ft).

- (e) Each communicating door shall be marked in accordance with Section 7.10.
- (f) No locking device shall be permitted on the communicating doors.

15.3 Protection.

15.3.1 Protection of Vertical Openings.

15.3.1.1 Any vertical opening, other than unprotected vertical openings in accordance with 8.6.8.2, shall be enclosed or protected in accordance with Section 8.6.

15.3.1.2 Where the provisions of 8.6.6 are used, the requirements of 15.3.5.2 shall be met.

15.3.1.3 Stairway enclosures shall not be required under the following conditions:

- (1) Where a stairway serves only one adjacent floor, other than a basement
- (2) Where a stairway is not connected with stairways serving other floors
- (3) Where a stairway is not connected with corridors serving other than the two floors involved

15.3.2 Protection from Hazards.

15.3.2.1 Rooms or spaces for the storage, processing, or use of materials shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour or protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Boiler and furnace rooms, unless such rooms enclose only air-handling equipment
 - (b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction
 - (c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
 - (d) Janitor closets [see also 15.3.2.1(4)]
- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a) Laundries
 - (b) Maintenance shops, including woodworking and painting areas
 - (c) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction
 - (d) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
- (3) Where automatic extinguishing is used to meet the requirements of 15.3.2.1(1) or 15.3.2.1(2), the protection shall be permitted in accordance with 9.7.1.2.
- (4) Where janitor closets addressed in 15.3.2.1(1)(d) are protected in accordance with the sprinkler option of 15.3.2.1(1), the janitor closet doors shall be permitted to have ventilating louvers.

15.3.2.2 Cooking facilities shall be protected in accordance with 9.2.3. Openings shall not be required to be protected between food preparation areas and dining areas.

15.3.2.3 Stages shall be protected in accordance with Chapter 13.

15.3.3 Interior Finish.

15.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

15.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be permitted as follows:

- (1) Exits — Class A
- (2) Corridors and lobbies — Class A or Class B
- (3) Low-height partitions not exceeding 1525 mm (60 in.) and used in locations other than exits — Class A, Class B, or Class C

15.3.3.3 Interior Floor Finish. (No requirements.)

15.3.4 Detection, Alarm, and Communications Systems.

15.3.4.1 General.

15.3.4.1.1 Educational occupancies shall be provided with a fire alarm system in accordance with Section 9.6.

15.3.4.1.2 The requirement of 15.3.4.1.1 shall not apply to buildings meeting all of the following criteria:

- (1) Buildings having an area not exceeding 93 m² (1000 ft²)
- (2) Buildings containing a single classroom
- (3) Buildings located not less than 15 m (50 ft) from another building

15.3.4.2 Initiation.

15.3.4.2.1 General. Initiation of the required fire alarm system shall be by manual means in accordance with 9.6.2.1(1), unless otherwise permitted by the following:

- (1) Manual fire alarm boxes shall not be required where permitted by 15.3.4.2.3.
- (2) In buildings where all normally occupied spaces are provided with a two-way communication system between such spaces and a constantly attended receiving station from where a general evacuation alarm can be sounded, the manual fire alarm boxes shall not be required, except in locations specifically designated by the authority having jurisdiction.

15.3.4.2.2 Automatic Initiation. In buildings provided with automatic sprinkler protection, the operation of the sprinkler system shall automatically activate the fire alarm system in addition to the initiation means required in 15.3.4.2.1.

15.3.4.2.3 Alternative Protection System. Manual fire alarm boxes shall be permitted to be eliminated in accordance with 15.3.4.2.3.1 or 15.3.4.2.3.2.

15.3.4.2.3.1* Manual fire alarm boxes shall be permitted to be eliminated where all of the following conditions apply:

- (1) Interior corridors are protected by smoke detectors using an alarm verification system as described in *NFPA 72[®], National Fire Alarm Code*.
- (2) Auditoriums, cafeterias, and gymnasiums are protected by heat or other approved detection devices.
- (3) Shops and laboratories involving dusts or vapors are protected by heat or other approved detection devices.
- (4) Provision is made at a central point to manually activate the evacuation signal or to evacuate only affected areas.

15.3.4.2.3.2* Manual fire alarm boxes shall be permitted to be eliminated where all of the following conditions apply:

- (1) The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (2) Provision is made at a central point to manually activate the evacuation signal, or to evacuate only affected areas.

15.3.4.3 Notification.

15.3.4.3.1 Occupant Notification.

15.3.4.3.1.1* Occupant notification shall be accomplished automatically in accordance with 9.6.3.4.

15.3.4.3.1.2 Positive alarm sequence shall be permitted in accordance with 9.6.3.4.

15.3.4.3.1.3 Where acceptable to the authority having jurisdiction, the fire alarm system shall be permitted to be used for other emergency signaling or for class changes, provided that the fire alarm is distinctive in signal and overrides all other use.

15.3.4.3.1.4 To prevent students from being returned to a building that is burning, the recall signal shall be separate and distinct from any other signals and such signal shall be permitted to be given by use of distinctively colored flags or banners.

15.3.4.3.1.5 If the recall signal required by 15.3.4.3.1.4 is electric, the push buttons or other controls shall be kept under lock, the key for which shall be in the possession of the principal or another designated person in order to prevent a recall at a time when there is an actual fire.

15.3.4.3.1.6 Regardless of the method of recall signal, the means of giving the recall signal shall be kept under lock.

15.3.4.3.2 Emergency Forces Notification. Wherever any of the school authorities determine that an actual fire exists, they shall immediately call the local fire department using the public fire alarm system or other available facilities.

15.3.5 Extinguishment Requirements.

15.3.5.1 Where student occupancy exists below the level of exit discharge, every portion of such floor shall be protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

15.3.5.2 Where student occupancy does not exist on floors below the level of exit discharge, such floors shall be separated from the rest of the building by 1-hour fire resistance-rated construction or shall be protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

15.3.5.3 Automatic sprinkler protection shall not be required where student occupancy exists below the level of exit discharge, provided that both of the following criteria are met:

- (1) The approval of the authority having jurisdiction shall be required.
- (2) Windows for rescue and ventilation shall be provided in accordance with 15.2.11.1.

15.3.5.4 Buildings with unprotected openings in accordance with 8.6.6 shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

15.3.5.5 Where another provision of this chapter requires an automatic sprinkler system, the sprinkler system shall be installed in accordance with 9.7.1.1(1).

15.3.6 Corridors. Corridors shall be separated from other parts of the story by walls having a ½-hour fire resistance rating in accordance with Section 8.3, unless otherwise permitted by the following.

- (1) Corridor protection shall not be required where all spaces normally subject to student occupancy have not less than one door opening directly to the outside or to an exterior exit access balcony or corridor in accordance with 7.5.3.
- (2)*In buildings protected throughout by an approved automatic sprinkler system with valve supervision in accordance with Section 9.7, corridor walls shall not be required to be rated, provided that such walls form smoke partitions in accordance with Section 8.4.
- (3) Where the corridor ceiling is an assembly having a ½-hour fire resistance rating where tested as a wall, the corridor wall shall be permitted to terminate at the corridor ceiling.
- (4) Lavatories shall not be required to be separated from corridors, provided that they are separated from all other spaces by walls having not less than a ½-hour fire resistance rating in accordance with Section 8.3.
- (5) Lavatories shall not be required to be separated from corridors, provided the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (6) Existing doors in ½-hour fire resistance-rated corridor walls shall be permitted to be 44-mm (1¾-in.) thick solid-bonded wood core doors or the equivalent.

15.3.7 Subdivision of Building Spaces.

15.3.7.1 Educational occupancies shall be subdivided into compartments by smoke partitions having not less than a 1-hour fire resistance rating and complying with Section 8.4 where one or both of the following conditions exist:

- (1) The maximum area of a compartment, including the aggregate area of all floors having a common atmosphere, exceeds 2800 m² (30,000 ft²).
- (2) The length or width of the building exceeds 91 m (300 ft).

15.3.7.2 The requirements of 15.3.7.1 shall not apply to the following:

- (1) Where all classrooms have exterior exit access in accordance with 7.5.3.
- (2) Buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7

15.3.7.3 The area of any smoke compartment required by 15.3.7.1 shall not exceed 2800 m² (30,000 ft²), with no dimension exceeding 91 m (300 ft).

15.4 Special Provisions.

15.4.1 Limited Access Buildings and Underground Buildings. Limited access buildings and underground buildings shall comply with Section 11.7.

15.4.2 High-Rise Buildings. High-rise buildings shall comply with 11.8.2.1.

15.4.3 Flexible Plan and Open Plan Buildings.

15.4.3.1 Flexible plan and open plan buildings shall comply with the requirements of this chapter as modified by 15.4.3.2 through 15.4.3.5.

15.4.3.2 Each room occupied by more than 300 persons shall have two or more means of egress entering into separate atmospheres.

15.4.3.3 Where three or more means of egress are required, the number of means of egress permitted to enter into the same atmosphere shall not exceed two.

15.4.3.4 Flexible plan buildings shall be permitted to have walls and partitions rearranged periodically only if revised plans or diagrams have been approved by the authority having jurisdiction.

15.4.3.5 Flexible plan buildings shall be evaluated while all folding walls are extended and in use as well as when they are in the retracted position.

15.5 Building Services.

15.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

15.5.2 Heating, Ventilating, and Air Conditioning Equipment.

15.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

15.5.2.2 Unvented fuel-fired heating equipment, other than gas space heaters in compliance with NFPA 54/ANSI Z223.1, *National Fuel Gas Code*, shall be prohibited.

15.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

15.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

15.6 Reserved.

15.7 Operating Features.

15.7.1 Emergency Plan. Emergency plans shall be provided in accordance with Section 4.8.

15.7.2 Emergency Egress and Relocation Drills.

15.7.2.1* Emergency egress and relocation drills shall be conducted in accordance with Section 4.7 and the applicable provisions of 15.7.2.2.

15.7.2.2 Emergency egress and relocation drills shall be conducted as follows:

- (1) Not less than one emergency egress and relocation drill shall be conducted every month the facility is in session, unless both of the following criteria are met:
 - (a) In climates where the weather is severe, the monthly emergency egress and relocation drills shall be permitted to be deferred.
 - (b) The required number of emergency egress and relocation drills shall be conducted, and not less than four shall be conducted before the drills are deferred.
- (2) All occupants of the building shall participate in the drill.
- (3) One additional emergency egress and relocation drill, other than for educational occupancies that are open on a year-round basis, shall be required within the first 30 days of operation.

15.7.2.3 All emergency and relocation drill alarms shall be sounded on the fire alarm system.

15.7.3 Inspection.

15.7.3.1* It shall be the duty of principals and teachers to inspect all exit facilities daily to ensure that all stairways, doors, and other exits are in proper condition.

15.7.3.2 Open plan buildings shall require extra surveillance to ensure that exit paths are maintained clear of obstruction and are obvious.

15.7.4 Furnishings and Decorations.

15.7.4.1 Draperies, curtains, and other similar furnishings and decorations in educational occupancies shall be in accordance with the provisions of 10.3.1.

15.7.4.2 Clothing and personal effects shall not be stored in corridors, unless otherwise permitted by the following:

- (1) This requirement shall not apply to corridors protected by an automatic sprinkler system in accordance with Section 9.7.
- (2) This requirement shall not apply to corridor areas protected by a smoke detection system in accordance with Section 9.6.
- (3) This requirement shall not apply to storage in metal lockers, provided that the required egress width is maintained.

15.7.4.3 Artwork and teaching materials shall be permitted to be attached directly to the walls in accordance with the following:

- (1) The artwork and teaching materials shall not exceed 20 percent of the wall area in a building that is not protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.
- (2) The artwork and teaching materials shall not exceed 50 percent of the wall area in a building that is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

15.7.5 Open Flames. Approved open flames shall be permitted in laboratories and vocational/technical areas.

Chapter 16 New Day-Care Occupancies

16.1 General Requirements.

16.1.1* Application.

16.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as day-care occupancies (*see 1.3.1*)
- (2) Additions made to, or used as, a day-care occupancy (*see 4.6.7*)
- (3) Alterations, modernizations, or renovations of existing day-care occupancies (*see 4.6.8*)
- (4) Existing buildings or portions thereof upon change of occupancy to a day-care occupancy (*see 4.6.12*)

16.1.1.2 The requirements of Section 16.1 through Section 16.5 and Section 16.7 shall apply to day-care occupancies in which more than 12 clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day.

16.1.1.3 The requirements of Section 16.1 (other than 16.1.6) and Section 16.4 through Section 16.7 shall apply to day-care homes as defined in 16.1.3.

16.1.1.4 Where a facility houses more than one age group or self-preservation capability, the strictest requirements applicable to any group present shall apply throughout the day-care occupancy or building, as appropriate to a given area, unless the area housing such a group is maintained as a separate fire area.

16.1.1.5 Places of religious worship shall not be required to meet the provisions of this chapter where providing day care while services are being held in the building.

16.1.2 Multiple Occupancies.

16.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

16.1.2.2 Where the mixed occupancies provisions of 6.1.14.3 are utilized, the following provisions shall also apply:

- (1) General. The day-care occupancy shall be separated from the other occupancies by not less than 1-hour fire resistance-rated barriers constructed in accordance with Section 8.3.
- (2) Day-Care Occupancies in Apartment Buildings. If the two exit accesses from a day-care occupancy enter the same corridor as an apartment occupancy, the exit accesses shall be separated in the corridor by a smoke partition complying with both of the following:
 - (a) Having not less than a 1-hour fire resistance rating and constructed in accordance with Section 8.4
 - (b) Located so that it has an exit on each side

16.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Day-Care Home.** See 3.3.110.1.
- (2) **Flexible Plan and Open Plan Educational or Day-Care Building.** See 3.3.27.6.
- (3) **Self-Preservation (Day-Care Occupancy).** See 3.3.191.
- (4) **Separate Atmosphere.** See 3.3.20.2.

16.1.4 Classification of Occupancy. See 6.1.4.

16.1.4.1 General. Occupancies that include part-day pre-schools, kindergartens, and other schools whose purpose is primarily educational, even though the children who attend such schools are of preschool age, shall comply with the provisions of Chapter 14.

16.1.4.2 Adult-Day-Care Occupancies.

16.1.4.2.1 Adult day-care occupancies shall include any building or portion thereof used for less than 24 hours per day to house more than three adults requiring care, maintenance, and supervision by other than their relative(s).

16.1.4.2.2 Clients in adult day-care occupancies shall be ambulatory or semiambulatory and shall not be bedridden.

16.1.4.2.3 Clients in adult day-care occupancies shall not exhibit behavior that is harmful to themselves or to others.

16.1.4.3* Conversions. A conversion from a day-care home to a day-care occupancy with more than 12 clients shall be permitted only if the day-care occupancy conforms to the requirements of this chapter for new day-care occupancies with more than 12 clients.

16.1.5 Classification of Hazard of Contents. The contents of day-care occupancies shall be classified as ordinary hazard in accordance with Section 6.2.

16.1.6 Location and Construction.

16.1.6.1 Day-care occupancies, other than day-care homes, shall be limited to the locations, construction types, and sprinkler protection features specified in Table 16.1.6.1.

16.1.6.2 Where day-care occupancies, other than day-care homes, with clients who are 24 months or less in age or who are incapable of self-preservation are located one or more stories

Table 16.1.6.1 Location and Construction Type Limitations

Location of Day-Care Occupancy	Sprinklered Building	Construction Type
1 story below LED	Yes	I(443), I(332), II(222), II(111), II(000), III(211), IV(2HH), or V(111)
	No	Not permitted
Level of exit discharge	Yes	Any type
	No	Any type
1 story above LED	Yes	Any type
	No	I(443), I(332), II(222)
2 or 3 stories above LED	Yes	I(443), I(332), II(222), II(111), II(000), III(211), or V(111)
	No	Not permitted
>3 stories above LED but not high-rise	Yes	I(443), I(332), II(222), or II(111)
	No	Not permitted
High-rise	Yes	I(443), I(332), or II(222)
	No	Not permitted

LED: Level of exit discharge.

above the level of exit discharge, or where day-care occupancies are located two or more stories above the level of exit discharge, smoke partitions shall be provided to divide such stories into not less than two compartments. The smoke partitions shall be constructed in accordance with Section 8.4 but shall not be required to have a fire resistance rating.

16.1.7 Occupant Load.

16.1.7.1 The occupant load, in number of persons for whom means of egress and other provisions are required, either shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

16.1.7.2 Where the occupant load is determined as the maximum probable population of the space in accordance with 16.1.7.1, an approved aisle, seating, and exiting diagram shall be required by the authority having jurisdiction to substantiate such a modification.

16.2 Means of Egress Requirements.

16.2.1 General. Means of egress shall be in accordance with Chapter 7 and Section 16.2.

16.2.2 Means of Egress Components.

16.2.2.1 General. Components of means of egress shall be limited to the types described in 16.2.2.2 through 16.2.2.10.

16.2.2.2 Doors.

16.2.2.2.1 General. Doors complying with 7.2.1 shall be permitted.

16.2.2.2.2 Panic Hardware or Fire Exit Hardware. Any door in a required means of egress from an area having an occupant load of 100 or more persons shall be permitted to be provided with a latch or lock only if the latch or lock is panic hardware or fire exit hardware complying with 7.2.1.7.

16.2.2.2.3 Special Locking Arrangements. Special locking arrangements complying with 7.2.1.6 shall be permitted.

16.2.2.2.4* Closet Doors. Every closet door latch shall be such that clients can open the door from inside the closet.

16.2.2.2.5 Bathroom Doors. Every bathroom door lock shall be designed to allow opening of the locked door from the outside by an opening device that shall be readily accessible to the staff.

16.2.2.3* Stairs. Stairs complying with 7.2.2 shall be permitted.

16.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

16.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

16.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

16.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

16.2.2.8 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

16.2.2.9 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

16.2.2.10 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

16.2.3 Capacity of Means of Egress. Capacity of means of egress shall be in accordance with Section 7.3.

16.2.4 Number of Exits. Not less than two separate exits shall be as follows:

- (1) Provided on every story
- (2) Accessible from every part of every story and mezzanine

16.2.5 Arrangement of Means of Egress. See also 16.1.6.2.

16.2.5.1 Means of egress shall be arranged in accordance with Section 7.5.

16.2.5.2 No dead-end corridor shall exceed 6100 mm (240 in.), other than in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, in which case dead-end corridors shall not exceed 15 m (50 ft).

16.2.5.3 No common path of travel shall exceed 23 m (75 ft), other than for the first 30 m (100 ft) in a building protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

16.2.6 Travel Distance to Exits.

16.2.6.1 Travel distance shall be measured in accordance with Section 7.6.

16.2.6.2 Travel distance shall meet the following criteria unless otherwise permitted by 16.2.6.3:

- (1) The travel distance between any room door intended as an exit access and an exit shall not exceed 30 m (100 ft).
- (2) The travel distance between any point in a room and an exit shall not exceed 46 m (150 ft).
- (3) The travel distance between any point in a sleeping room and an exit access door in that room shall not exceed 15 m (50 ft).

16.2.6.3 The travel distance required by 16.2.6.2(1) and 16.2.6.2(2) shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

16.2.7 Discharge from Exits. Discharge from exits shall be arranged in accordance with Section 7.7.

16.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

16.2.9 Emergency Lighting. Emergency lighting shall be provided in accordance with Section 7.9 in the following areas:

- (1) Interior stairs and corridors
- (2) Assembly use spaces
- (3) Flexible and open plan buildings
- (4) Interior or limited access portions of buildings
- (5) Shops and laboratories

16.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

16.2.11 Special Means of Egress Features.**16.2.11.1 Windows for Rescue.**

16.2.11.1.1 Every room or space normally subject to client occupancy, other than bathrooms, shall have not less than one outside window for emergency rescue that complies with the following unless otherwise permitted by 16.2.11.1.2:

- (1) Such windows shall be openable from the inside without the use of tools and shall provide a clear opening of not less than 510 mm (20 in.) in width, 610 mm (24 in.) in height, and 0.5 m² (5.7 ft²) in area.
- (2) The bottom of the opening shall be not more than 1120 mm (44 in.) above the floor.
- (3) The clear opening shall allow a rectangular solid, with a width and height that provides not less than the required 0.5-m² (5.7-ft²) opening and a depth of not less than 510 mm (20 in.), to pass fully through the opening.

16.2.11.1.2 The requirements of 16.2.11.1.1 shall not apply to the following:

- (1) Buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7
- (2) Where the room or space has a door leading directly to the outside of the building

16.3 Protection.

16.3.1 Protection of Vertical Openings. Any vertical opening, other than unprotected vertical openings in accordance with 8.6.8.2, shall be enclosed or protected in accordance with Section 8.6.

16.3.2 Protection from Hazards.

16.3.2.1 Rooms or spaces for the storage, processing, or use of materials specified in 16.3.2.1(1) through 16.3.2.1(3) shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour, or protection of such rooms by automatic extinguishing systems as specified in Section 8.7, in the following areas:
 - (a) Boiler and furnace rooms, unless such rooms enclose only air-handling equipment
 - (b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction
 - (c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
 - (d) Janitor closets
- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a)*Laundries
 - (b) Maintenance shops, including woodworking and painting areas
 - (c) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction
 - (d) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
- (3) Where automatic extinguishing is used to meet the requirements of 16.3.2.1(1) and 16.3.2.1(2), the protection shall be permitted in accordance with 9.7.1.2.

16.3.2.2 Janitor closets protected in accordance with 16.3.2.1(1)(d) shall be permitted to have doors fitted with ventilating louvers where the space is protected by automatic sprinklers.

16.3.2.3 Cooking facilities shall be protected in accordance with 9.2.3 unless otherwise permitted by 16.3.2.4 or 16.3.2.5.

16.3.2.4 Openings shall not be required to be protected between food preparation areas and dining areas.

16.3.2.5 Approved domestic cooking equipment used for food warming or limited cooking shall not be required to be protected.

16.3.3 Interior Finish.

16.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

16.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A in stairways, corridors, and lobbies; in all other occupied areas, interior wall and ceiling finish shall be Class A or Class B.

16.3.3.3 Interior Floor Finish.

16.3.3.3.1 Interior floor finish shall comply with Section 10.2.

16.3.3.3.2 Interior floor finish in exit enclosures and exit access corridors and spaces not separated from them by walls complying with 14.3.6 shall be not less than Class II.

16.3.3.3.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

16.3.4 Detection, Alarm, and Communications Systems.

16.3.4.1 General. Day-care occupancies, other than day-care occupancies housed in one room, shall be provided with a fire alarm system in accordance with Section 9.6.

16.3.4.2 Initiation. Initiation of the required fire alarm system shall be by manual means and by operation of any required smoke detectors and required sprinkler systems. (See 16.3.4.5.)

16.3.4.3 Occupant Notification.

16.3.4.3.1 Occupant notification shall be in accordance with 9.6.3.

16.3.4.3.2 Positive alarm sequence shall be permitted in accordance with 9.6.3.4.

16.3.4.3.3 Where occupant notification appliances are provided in all occupied rooms and corridors, the private operating mode as described in *NFPA 72®*, *National Fire Alarm Code®*, shall be permitted to be used in either or both of the following locations:

- (1) The occupied rooms
- (2) The corridors

16.3.4.4 Emergency Forces Notification. Fire department notification shall be accomplished in accordance with 9.6.4.

16.3.4.5 Detection. A smoke detection system in accordance with Section 9.6 shall be installed in day-care occupancies, other than those housed in one room, and such system shall comply with both of the following:

- (1) Detectors shall be installed on each story in front of the doors to the stairways and in the corridors of all floors occupied by the day-care occupancy.
- (2) Detectors also shall be installed in lounges, recreation areas, and sleeping rooms in the day-care occupancy.

16.3.5 Extinguishment Requirements.

16.3.5.1 Any required sprinkler systems shall be in accordance with Section 9.7.

16.3.5.2 Required sprinkler systems shall be installed in accordance with 9.7.1.1(1).

16.3.5.3 Buildings with unprotected openings in accordance with 8.6.6 shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

16.3.6 Corridors. Every interior corridor shall be constructed of walls having not less than a 1-hour fire resistance rating in accordance with Section 8.3, unless otherwise permitted by the following:

- (1) Corridor protection shall not be required where all spaces normally subject to client occupancy have not less than one door opening directly to the outside or to an exterior exit access balcony or corridor in accordance with 7.5.3.
- (2) In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, corridor walls shall not be required to be rated, provided that such walls form smoke partitions in accordance with Section 8.4.
- (3) Where the corridor ceiling is an assembly having a 1-hour fire resistance rating where tested as a wall, the corridor walls shall be permitted to terminate at the corridor ceiling.

- (4) Lavatories shall not be required to be separated from corridors, provided that they are separated from all other spaces by walls having not less than a 1-hour fire resistance rating in accordance with Section 8.3.
- (5) Lavatories shall not be required to be separated from corridors, provided the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

16.4 Special Provisions.

16.4.1 Limited Access Buildings and Underground Buildings. Limited access buildings and underground buildings shall comply with Section 11.7.

16.4.2 High-Rise Buildings. High-rise buildings that house day-care occupancies on floors more than 23 m (75 ft) above the lowest level of fire department vehicle access shall comply with Section 11.8.

16.4.3 Flexible Plan and Open Plan Buildings.

16.4.3.1 Flexible plan and open plan buildings shall comply with the requirements of this chapter as modified by 16.4.3.2 through 16.4.3.5.

16.4.3.2 Flexible plan buildings shall be permitted to have walls and partitions rearranged periodically only if revised plans or diagrams have been approved by the authority having jurisdiction.

16.4.3.3 Flexible plan buildings shall be evaluated while all folding walls are extended and in use as well as when they are in the retracted position.

16.4.3.4 Each room occupied by more than 300 persons shall have two or more means of egress entering into separate atmospheres.

16.4.3.5 Where three or more means of egress are required from a single room, the number of means of egress permitted to enter into a common atmosphere shall not exceed two.

16.5 Building Services.

16.5.1 Utilities.

16.5.1.1 Utilities shall comply with the provisions of Section 9.1.

16.5.1.2 Special protective covers for all electrical receptacles shall be installed in all areas occupied by clients.

16.5.2 Heating, Ventilating, and Air Conditioning Equipment.

16.5.2.1 Heating, ventilating, and air conditioning equipment shall be in accordance with Section 9.2.

16.5.2.2 Unvented fuel-fired heating equipment, other than gas space heaters in compliance with NFPA 54/ANSI Z223.1, *National Fuel Gas Code*, shall be prohibited.

16.5.2.3 Any heating equipment in spaces occupied by clients shall be provided with partitions, screens, or other means to protect clients from hot surfaces and open flames; if solid partitions are used to provide such protection, provisions shall be made to ensure adequate air for combustion and ventilation for the heating equipment.

16.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors, other than those in day-care homes, shall comply with the provisions of Section 9.4.

16.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes, other than

those in day-care homes, shall comply with the provisions of Section 9.5.

16.6 Day-Care Homes.

16.6.1 General Requirements.

16.6.1.1 Application.

16.6.1.1.1 The requirements of Section 16.6 shall apply to the following:

- (1) New buildings or portions thereof used as day-care homes (*see 1.3.1*)
- (2) Additions made to, or used as, a day-care home (*see 4.6.7*)
- (3) Alterations, modernizations, or renovations of existing day-care homes (*see 4.6.8*)
- (4) Existing buildings or portions thereof upon change of occupancy to a day-care home (*see 4.6.12*)

16.6.1.1.2 The requirements of Section 16.6 shall apply to day-care homes in which more than 3, but not more than 12, clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day, generally within a dwelling unit. (*See also 16.6.1.4.*)

16.6.1.1.3 Where a facility houses more than one age group or one self-preservation capability, the strictest requirements applicable to any group present shall apply throughout the day-care home or building, as appropriate to a given area, unless the area housing such a group is maintained as a separate fire area.

16.6.1.1.4 Facilities that supervise clients on a temporary basis with a parent or guardian in close proximity shall not be required to meet the provisions of Section 16.6.

16.6.1.1.5 Places of religious worship shall not be required to meet the provisions of Section 16.6 where operating a nursery while services are being held in the building.

16.6.1.2 Multiple Occupancies. See 16.1.2.

16.6.1.3 Definitions. See 16.1.3.

16.6.1.4 Classification of Occupancy.

16.6.1.4.1 Subclassification of Day-Care Homes. Subclassification of day-care homes shall comply with 16.6.1.4.1(A) and 16.6.1.4.1(B).

(A) **Family Day-Care Home.** A family day-care home shall be a day-care home in which more than three, but fewer than seven, clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day, generally within a dwelling unit.

(B) **Group Day-Care Home.** A group day-care home shall be a day-care home in which not less than 7, but not more than 12, clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day, generally within a dwelling unit.

16.6.1.4.2* Conversions. A conversion from a day-care home to a day-care occupancy with more than 12 clients shall be permitted only if the day-care occupancy conforms with the requirements of Chapter 16 for new day-care occupancies with more than 12 clients.

16.6.1.5 Classification of Hazard of Contents. See 16.1.5.

16.6.1.6 Location and Construction. No day-care home shall be located more than one story below the level of exit discharge.

16.6.1.7 Occupant Load.

16.6.1.7.1 In family day-care homes, the following shall apply:

- (1) The minimum staff-to-client ratio shall be not less than one staff for up to six clients, including the caretaker's own children under age six.
- (2) There shall be not more than two clients incapable of self-preservation.

16.6.1.7.2 In group day-care homes the following shall apply:

- (1) The minimum staff-to-client ratio shall be not less than two staff for up to 12 clients.
- (2) There shall be not more than three clients incapable of self-preservation.
- (3) The staff-to-client ratio shall be permitted to be modified by the authority having jurisdiction where safeguards in addition to those specified by Section 16.6 are provided.

16.6.2 Means of Escape Requirements.

16.6.2.1 General. Means of escape shall comply with Section 24.2.

16.6.2.2 Reserved.

16.6.2.3 Reserved.

16.6.2.4 Number of Means of Escape. The number of means of escape shall comply with Section 24.2 and 16.6.2.4.1 through 16.6.2.4.4.

16.6.2.4.1 In group day-care homes, every story occupied by clients shall have not less than two remotely located means of escape.

16.6.2.4.2 Every room used for sleeping, living, or dining purposes shall comply with the following:

- (1) There shall be not less than two means of escape, not less than one of which shall be a door or stairway providing a means of unobstructed travel to the outside of the building at street or ground level.
- (2) The second means of escape shall be permitted to be a window in accordance with 16.2.11.1.
- (3) No room or space that is accessible only by a ladder or folding stairs or through a trap door shall be occupied for living or sleeping purposes.

16.6.2.4.3 In group day-care homes where spaces on the story above the level of exit discharge are used by clients, not less than one means of escape shall be an exit discharging directly to the outside, and the second means of escape shall be permitted to be a window in accordance with 16.2.11.1.

16.6.2.4.4 Where clients occupy a story below the level of exit discharge, not less than one means of escape shall be an exit discharging directly to the outside, the vertical travel to ground level shall not exceed 2440 mm (96 in.), and the second means of escape shall be permitted to be a window in accordance with 16.2.11.1.

16.6.2.5 Arrangement of Means of Egress.

16.6.2.5.1 A story used above or below the level of exit discharge shall be in accordance with 16.6.2.4.3 and 16.6.2.4.4.

16.6.2.5.2 For group day-care homes, means of egress shall be arranged in accordance with Section 7.5.

16.6.2.5.3 No dead-end corridors shall exceed 6100 mm (240 in.).

16.6.2.6 Travel Distance.

16.6.2.6.1 Travel distance shall meet the following criteria unless otherwise permitted by 16.6.2.6.2:

- (1) The travel distance between any room door intended as an exit access and an exit shall not exceed 30 m (100 ft).
- (2) The travel distance between any point in a room and an exit shall not exceed 46 m (150 ft).
- (3) The travel distance between any point in a sleeping room and an exit access to that room shall not exceed 15 m (50 ft).

16.6.2.6.2 The travel distance in 16.6.2.6(1) and 16.6.2.6(2) shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

16.6.2.7 Discharge from Exits. See 16.6.2.4.

16.6.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

16.6.2.9 Emergency Lighting. (No requirements.)

16.6.2.10 Marking of Means of Egress. (No requirements.)

16.6.3 Protection.**16.6.3.1 Protection of Vertical Openings.**

16.6.3.1.1 For group day-care homes, the doorway between the level of exit discharge and any story below shall be equipped with a fire door assembly having a 20-minute fire protection rating.

16.6.3.1.2 Where the story above the level of exit discharge is used for sleeping purposes, there shall be a fire door assembly having a 20-minute fire protection rating at the top or bottom of each stairway.

16.6.3.2 Protection from Hazards. (No requirements.)

16.6.3.3 Interior Finish.

16.6.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

16.6.3.3.2 Interior Wall and Ceiling Finish.

16.6.3.3.2.1 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in corridors, stairways, lobbies, and exits. In the exits of family day-care homes, interior wall and ceiling finish materials in accordance with Section 10.2 shall be Class A or Class B.

16.6.3.3.2.2 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A, Class B, or Class C in occupied spaces.

16.6.3.3.3 Interior Floor Finish.

16.6.3.3.3.1 Interior floor finish shall comply with Section 10.2.

16.6.3.3.3.2 Interior floor finish in exit enclosures shall be not less than Class II.

16.6.3.3.3.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

16.6.3.4 Detection, Alarm, and Communications Systems.

16.6.3.4.1 Smoke alarms shall be installed within day-care homes in accordance with 9.6.2.10.

16.6.3.4.2 Where a day-care home is located within a building of another occupancy, such as in an apartment building or office building, any corridors serving the day-care home shall be provided with a smoke detection system in accordance with Section 9.6.

16.6.3.4.3 One of the following shall be provided in all rooms used for sleeping:

- (1) Single-station or multiple-station smoke alarms in accordance with 9.6.2.10 that are powered by the building electrical system
- (2) System detectors with integral sounding devices in accordance with 9.6.1.3

16.6.3.5 Extinguishment Requirements. Any required sprinkler systems shall be in accordance with Section 9.7 and shall be installed in accordance with 9.7.1.1(1), 9.7.1.1(2), or 9.7.1.1(3), as appropriate with respect to the scope of the installation standard.

16.7 Operating Features.

16.7.1* Emergency Plans. Emergency plans shall be provided in accordance with Section 4.8.

16.7.2 Emergency Egress and Relocation Drills.

16.7.2.1* Emergency egress and relocation drills shall be conducted in accordance with Section 4.7 and the applicable provisions of 16.7.2.2.

16.7.2.2 Emergency egress and relocation drills shall be conducted as follows:

- (1) Not less than one emergency egress and relocation drill shall be conducted every month the facility is in session, unless both of the following criteria are met:
 - (a) In climates where the weather is severe, the monthly emergency egress and relocation drills shall be permitted to be deferred.
 - (b) The required number of emergency egress and relocation drills shall be conducted, and not less than four shall be conducted before the drills are deferred.
- (2) All occupants of the building shall participate in the drill.
- (3) One additional emergency egress and relocation drill, other than for day-care occupancies that are open on a year-round basis, shall be required within the first 30 days of operation.

16.7.3 Inspections.

16.7.3.1 Fire prevention inspections shall be conducted monthly by a trained senior member of the staff, after which a copy of the latest inspection report shall be posted in a conspicuous place in the day-care facility.

16.7.3.2* It shall be the duty of site administrators and staff members to inspect all exit facilities daily to ensure that all stairways, doors, and other exits are in proper condition.

16.7.3.3 Open plan buildings shall require extra surveillance to ensure that exit paths are maintained clear of obstruction and are obvious.

16.7.4 Furnishings and Decorations.

16.7.4.1 Draperies, curtains, and other similar furnishings and decorations in day-care occupancies shall be in accordance with the provisions of 10.3.1.

16.7.4.2 Clothing and personal effects shall not be stored in corridors, unless otherwise permitted by the following:

- (1) This requirement shall not apply to corridors protected by an automatic sprinkler system in accordance with Section 9.7.
- (2) This requirement shall not apply to corridor areas protected by a smoke detection system in accordance with Section 9.6.
- (3) This requirement shall not apply to storage in metal lockers, provided that the required egress width is maintained.

16.7.4.3 Artwork and teaching materials shall be permitted to be attached directly to the walls in accordance with the following:

- (1) The artwork and teaching materials shall not exceed 20 percent of the wall area in a building that is not protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (2) The artwork and teaching materials shall not exceed 50 percent of the wall area in a building that is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

16.7.5* Day-Care Staff. Adequate adult staff shall be on duty, alert, awake, and in the facility at all times where clients are present.

Chapter 17 Existing Day-Care Occupancies

17.1 General Requirements.

17.1.1* Application.

17.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as day-care occupancies. (*See also 16.1.1.1.*)

17.1.1.2 The requirements of Section 17.1 through Section 17.5 and Section 17.7 shall apply to existing day-care occupancies in which more than 12 clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day. An existing day-care occupancy shall be permitted the option of meeting the requirements of Chapter 16 in lieu of Chapter 17. An existing day-care occupancy that meets the requirements of Chapter 16 shall be judged as meeting the requirements of Chapter 17.

17.1.1.3 The requirements of Section 17.1 (other than 17.1.6) and Section 17.4 through Section 17.7 shall apply to existing day-care homes as defined in 17.1.3. An existing day-care home shall be permitted the option of meeting the requirements of Chapter 16 in lieu of Chapter 17. An existing day-care home that meets the requirements of Chapter 16 shall be judged as meeting the requirements of Chapter 17.

17.1.1.4 Where a facility houses clients of more than one self-preservation capability, the strictest requirements applicable to any group present shall apply throughout the day-care occupancy or building, as appropriate to a given area, unless the area housing such a group is maintained as a separate fire area.

17.1.1.5 Places of religious worship shall not be required to meet the provisions of this chapter where providing day care while services are being held in the building.

17.1.2 Mixed Occupancies.

17.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

17.1.2.2 Where the mixed occupancies provisions of 6.1.14.3 are utilized, the following provisions shall also apply:

- (1) General. The day-care occupancy shall be separated from the other occupancies by not less than 1-hour fire resistance-rated barriers constructed in accordance with Section 8.3.
- (2) Day-Care Occupancies in Apartment Buildings. If the two exit accesses from a day-care occupancy enter the same corridor as an apartment occupancy, the exit accesses shall be separated in the corridor by a smoke partition complying with both of the following:
 - (a) Having not less than a 1-hour fire resistance rating and constructed in accordance with Section 8.4
 - (b) Located so that it has an exit on each side.

17.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Day-Care Home.** See 3.3.110.1.
- (2) **Flexible Plan and Open Plan Educational or Day-Care Building.** See 3.3.27.6.
- (3) **Self-Preservation (Day-Care Occupancy).** See 3.3.191.
- (4) **Separate Atmosphere.** See 3.3.20.2.

17.1.4 Classification of Occupancy. See 6.1.4.

17.1.4.1 General. Occupancies that include part-day preschools, kindergartens, and other schools whose purpose is primarily educational, even though the children who attend such schools are of preschool age, shall comply with the provisions of Chapter 15.

17.1.4.2 Adult Day-Care Occupancies.

17.1.4.2.1 Adult day-care occupancies shall include any building or portion thereof used for less than 24 hours per day to house more than three adults requiring care, maintenance, and supervision by other than their relative(s).

17.1.4.2.2 Clients in adult day-care occupancies shall be ambulatory or semiambulatory and shall not be bedridden.

17.1.4.2.3 Clients in adult day-care occupancies shall not exhibit behavior that is harmful to themselves or to others.

17.1.4.3* Conversions. A conversion from a day-care home to a day-care occupancy with more than 12 clients shall be permitted only if the day-care occupancy conforms to the requirements of Chapter 16 for new day-care occupancies with more than 12 clients.

17.1.5 Classification of Hazard of Contents. The contents of day-care occupancies shall be classified as ordinary hazard in accordance with Section 6.2.

17.1.6 Location and Construction. Day-care occupancies, other than day-care homes, shall be limited to the locations, construction types, and sprinkler protection features specified in Table 17.1.6.

17.1.7 Occupant Load.

17.1.7.1 The occupant load, in number of persons for whom means of egress and other provisions are required, either shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or

Table 17.1.6 Location and Construction Type Limitations

Location of Day-Care Occupancy	Sprinklered Building	Construction Type
1 story below LED	Yes	I(443), I(332), II(222), II(111), II(000), III(211), IV(2HH), V(111)
	No	I(443), I(332), II(222), II(111), III(211), IV(2HH), V(111)
Level of exit discharge	Yes	Any type
	No	Any type
1 story above LED	Yes	Any type
	No	I(443), I(332), II(222)
2 stories above LED	No	II(111)*, III(211)*, V(111)*
	Yes	I(443), I(332), II(222)
	Yes	II(111)*, III(211)*, V(111)*
≥3 stories above LED but not high-rise	No	I(443), I(332), II(222)
	Yes	I(443), I(332), II(222)
	No	II(111)*
High-rise	Yes	I(443), I(332), II(222)
	No	Not permitted

LED: Level of exit discharge.

*Permitted only if clients capable of self-preservation.

shall be determined as the maximum probable population of the space under consideration, whichever is greater.

17.1.7.2 Where the occupant load is determined as the maximum probable population of the space in accordance with 17.1.7.1, an approved aisle, seating, and exiting diagram shall be required by the authority having jurisdiction to substantiate such a modification.

17.2 Means of Egress Requirements.

17.2.1 General. Means of egress shall be in accordance with Chapter 7 and Section 17.2.

17.2.2 Means of Egress Components.

17.2.2.1 General. Components of means of egress shall be limited to the types described in 17.2.2.2 through 17.2.2.10.

17.2.2.2 Doors.

17.2.2.2.1 General. Doors complying with 7.2.1 shall be permitted.

17.2.2.2.2 Panic Hardware or Fire Exit Hardware. Any door in a required means of egress from an area having an occupant load of 100 or more persons shall be permitted to be provided with a latch or lock only if the latch or lock is panic hardware or fire exit hardware complying with 7.2.1.7.

17.2.2.2.3 Special Locking Arrangements. Special locking arrangements complying with 7.2.1.6 shall be permitted.

17.2.2.2.4* Closet Doors. Every closet door latch shall be such that clients can open the door from inside the closet.

17.2.2.2.5 Bathroom Doors. Every bathroom door lock shall be designed to allow opening of the locked door from the outside by an opening device that shall be readily accessible to the staff.

17.2.2.3* Stairs.

17.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

17.2.2.3.2 Existing Class A stairs shall be permitted.

17.2.2.3.3 Existing Class B stairs shall be permitted where not used by clients.

17.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

17.2.2.5 Horizontal Exits.

17.2.2.5.1 Horizontal exits complying with 7.2.4 shall be permitted.

17.2.2.5.2 Areas of refuge, other than in buildings provided with smokeproof enclosures or buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, shall be provided by horizontal exits for occupants of day-care occupancies located above the fifth story.

17.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

17.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

17.2.2.8 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

17.2.2.9 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

17.2.2.10 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

17.2.3 Capacity of Means of Egress. Capacity of means of egress shall be in accordance with Section 7.3.

17.2.4 Number of Exits.

17.2.4.1 Not less than two separate exits shall be as follows:

- (1) Provided on every story
- (2) Accessible from every part of every story and mezzanine

17.2.4.2 Where the story below the level of exit discharge is occupied as a day-care occupancy, 17.2.4.2.1 and 17.2.4.2.2 shall apply.

17.2.4.2.1 One means of egress shall be an outside or interior stair in accordance with 7.2.2. An interior stair, if used, shall serve only the story below the level of exit discharge. The interior stair shall be permitted to communicate with the level of exit discharge; however, the exit route from the level of exit discharge shall not pass through the stair enclosure.

17.2.4.2.2 The second means of egress shall be permitted to be via an unenclosed stairway separated from the level of exit discharge in accordance with 8.6.5.

17.2.4.2.3 The path of egress travel on the level of exit discharge shall be protected in accordance with 7.1.3.1, unless one of the following criteria is met:

- (1) The path of egress on the level of exit discharge shall be permitted to be unprotected if the level of exit discharge and the level below the level of exit discharge are protected throughout by a smoke detection system
- (2) The path of egress on the level of exit discharge shall be permitted to be unprotected if the level of exit discharge and the level below the level of exit discharge are protected throughout by an approved automatic sprinkler system.

17.2.5 Arrangement of Means of Egress.

17.2.5.1 Means of egress shall be arranged in accordance with Section 7.5.

17.2.5.2 No dead-end corridor shall exceed 6100 mm (240 in.), other than in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, in which case dead-end corridors shall not exceed 15 m (50 ft).

17.2.5.3 No common path of travel shall exceed 23 m (75 ft), other than for the first 30 m (100 ft) in a building protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

17.2.5.4 The story used below the level of exit discharge shall be in accordance with 17.2.4.2.

17.2.6 Travel Distance to Exits.

17.2.6.1 Travel distance shall be measured in accordance with Section 7.6.

17.2.6.2 Travel distance shall meet the following criteria unless otherwise permitted by 17.2.6.3:

- (1) The travel distance between any room door intended as an exit access and an exit shall not exceed 30 m (100 ft).
- (2) The travel distance between any point in a room and an exit shall not exceed 46 m (150 ft).
- (3) The travel distance between any point in a sleeping room and an exit access door in that room shall not exceed 15 m (50 ft).

17.2.6.3 The travel distance required by 17.2.6.2(1) and 17.2.6.2(2) shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

17.2.7 Discharge from Exits. Discharge from exits shall be arranged in accordance with Section 7.7, unless otherwise provided in 17.2.4.2.

17.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

17.2.9 Emergency Lighting. Emergency lighting shall be provided in accordance with Section 7.9 in the following areas:

- (1) Interior stairs and corridors
- (2) Assembly use spaces
- (3) Flexible and open plan buildings
- (4) Interior or limited access portions of buildings
- (5) Shops and laboratories

17.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

17.2.11 Special Means of Egress Features.

17.2.11.1 Windows for Rescue.

17.2.11.1.1 Every room or space greater than 23.2 m² (250 ft²) and normally subject to client occupancy shall have not less than one outside window for emergency rescue that complies with the following unless otherwise permitted by 17.2.11.1.2:

- (1) Such windows shall be openable from the inside without the use of tools and shall provide a clear opening of not less than 510 mm (20 in.) in width, 610 mm (24 in.) in height, and 0.5 m² (5.7 ft²) in area.
- (2) The bottom of the opening shall be not more than 1120 mm (44 in.) above the floor.
- (3) The clear opening shall allow a rectangular solid, with a width and height that provides not less than the required 0.5 m² (5.7 ft²) opening and a depth of not less than 510 mm (20 in.), to pass fully through the opening.

17.2.11.1.2 The requirements of 17.2.11.1.1 shall not apply to the following:

- (1) Buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7
- (2) Where the room or space has a door leading directly to the outside of the building
- (3) Rooms located higher than three stories above grade
- (4) Where awning-type or hopper-type windows that are hinged or subdivided to provide a clear opening of not less than 0.38 m² (4 ft²) or any dimension of not less than 560 mm (22 in.), the following shall apply:
 - (a) Such windows shall be permitted to continue to be used.
 - (b) Screen walls or devices in front of required windows shall not interfere with normal rescue requirements.
- (5) Where the room or space complies with the following:
 - (a) Doors shall exist that allow travel between adjacent classrooms.
 - (b) Where doors are used to travel from classroom to classroom, they shall provide one of the following:
 - i. Direct access to exits in both directions
 - ii. Direct access to an exit in one direction and to a separate smoke compartment that provides access to another exit in the other direction
 - (c) The corridor shall be separated from the classrooms by a wall that resists the passage of smoke, and all doors between the classrooms and the corridor shall be self-closing in accordance with 7.2.1.8.
 - (d) The length of travel to exits along such paths shall not exceed 46 m (150 ft).
 - (e) Each communicating door shall be marked in accordance with Section 7.10.
 - (f) No locking device shall be permitted on the communicating doors.

17.3 Protection.

17.3.1 Protection of Vertical Openings. Any vertical opening, other than unprotected vertical openings in accordance with 8.6.8.2, shall be enclosed or protected in accordance with Section 8.6.

17.3.2 Protection from Hazards.

17.3.2.1 Rooms or spaces for the storage, processing, or use of materials specified in 17.3.2.1(1) through 17.3.2.1(3) shall be protected in accordance with the following:

- (1) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour or protection of such rooms, by automatic extinguishing systems as specified in Section 8.7, in the following areas:
 - (a) Boiler and furnace rooms, unless such rooms enclose only air-handling equipment
 - (b) Rooms or spaces used for the storage of combustible supplies in quantities deemed hazardous by the authority having jurisdiction
 - (c) Rooms or spaces used for the storage of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
 - (d) Janitor closets
- (2) Separation from the remainder of the building by fire barriers having a fire resistance rating of not less than 1 hour and protection of such rooms by automatic extinguishing systems as specified in Section 8.7 in the following areas:
 - (a)*Laundries
 - (b) Maintenance shops, including woodworking and painting areas
 - (c) Rooms or spaces used for processing or use of combustible supplies deemed hazardous by the authority having jurisdiction
 - (d) Rooms or spaces used for processing or use of hazardous materials or flammable or combustible liquids in quantities deemed hazardous by recognized standards
- (3) Where automatic extinguishing is used to meet the requirements of 17.3.2.1(1) and 17.3.2.1(2), the protection shall be permitted in accordance with 9.7.1.2.

17.3.2.2 Janitor closets protected in accordance with 17.3.2.1(1)(d) shall be permitted to have doors fitted with ventilating louvers where the space is protected by automatic sprinklers.

17.3.2.3 Cooking facilities shall be protected in accordance with 9.2.3 unless otherwise permitted by 17.3.2.4 or 17.3.2.5.

17.3.2.4 Openings shall not be required to be protected between food preparation areas and dining areas.

17.3.2.5 Approved domestic cooking equipment used for food warming or limited cooking shall not be required to be protected.

17.3.3 Interior Finish.

17.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

17.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B throughout.

17.3.3.3 Interior Floor Finish. (No requirements.)

17.3.4 Detection, Alarm, and Communications Systems.

17.3.4.1 General. Day-care occupancies, other than day-care occupancies housed in one room, shall be provided with a fire alarm system in accordance with Section 9.6.

17.3.4.2 Initiation. Initiation of the required fire alarm system shall be by manual means and by operation of any required smoke detectors and required sprinkler systems. (See 17.3.4.5.)

17.3.4.3 Occupant Notification.

17.3.4.3.1 Occupant notification shall be in accordance with 9.6.3.

17.3.4.3.2 Positive alarm sequence shall be permitted in accordance with 9.6.3.4.

17.3.4.3.3 Where occupant notification appliances are provided in all occupied rooms and corridors, the private operating mode as described in *NFPA 72®*, *National Fire Alarm Code®*, shall be permitted to be used in either or both of the following locations:

- (1) The occupied rooms
- (2) The corridors

17.3.4.4 Emergency Forces Notification. Fire department notification, other than for day-care occupancies with not more than 100 clients, shall be accomplished in accordance with 9.6.4.

17.3.4.5 Detection. A smoke detection system in accordance with Section 9.6 shall be installed in day-care occupancies, other than those housed in one room or those housing clients capable of self-preservation if no sleeping facilities are provided, and such system shall comply with both of the following:

- (1) Detectors shall be installed on each story in front of the doors to the stairways and in the corridors of all floors occupied by the day-care occupancy.
- (2) Detectors shall be installed in lounges, recreation areas, and sleeping rooms in the day-care occupancy.

17.3.5 Extinguishment Requirements.

17.3.5.1 Any required sprinkler system shall be in accordance with Section 9.7.

17.3.5.2 Required sprinkler systems, other than approved existing systems, shall be installed in accordance with 9.7.1.1(1).

17.3.5.3 Buildings with unprotected openings in accordance with 8.6.6 shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

17.3.6 Corridors. Every interior corridor shall be constructed of walls having not less than a ½-hour fire resistance rating in accordance with Section 8.3, unless otherwise permitted by the following:

- (1) Corridor protection shall not be required where all spaces normally subject to student occupancy have not less than one door opening directly to the outside or to an exterior exit access balcony or corridor in accordance with 7.5.3.
- (2) In buildings protected throughout by an approved automatic sprinkler system with valve supervision in accordance with Section 9.7, corridor walls shall not be required to be rated, provided that such walls form smoke partitions in accordance with Section 8.4.
- (3) Where the corridor ceiling is an assembly having a ½-hour fire resistance rating where tested as a wall, the corridor walls shall be permitted to terminate at the corridor ceiling.
- (4) Lavatories shall not be required to be separated from corridors, provided that they are separated from all other

spaces by walls having not less than a ½-hour fire resistance rating in accordance with Section 8.3.

- (5) Lavatories shall not be required to be separated from corridors, provided the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (6) Existing doors in ½-hour fire resistance-rated corridors shall be permitted to be 44-mm (1¾-in.) thick, solid-bonded wood core doors or the equivalent.

17.4 Special Provisions.

17.4.1 Limited Access Buildings and Underground Buildings. Limited access buildings and underground buildings shall comply with Section 11.7.

17.4.2 High-Rise Buildings. High-rise buildings that house day-care occupancies on floors more than 23 m (75 ft) above the lowest level of fire department vehicle access shall comply with Section 11.8.

17.4.3 Flexible Plan and Open Plan Buildings.

17.4.3.1 Flexible plan and open plan buildings shall comply with the requirements of this chapter as modified by 17.4.3.2 and 17.4.3.3.

17.4.3.2 Flexible plan buildings shall be permitted to have walls and partitions rearranged periodically only if revised plans or diagrams have been approved by the authority having jurisdiction.

17.4.3.3 Flexible plan buildings shall be evaluated while all folding walls are extended and in use as well as when they are in the retracted position.

17.5 Building Services.

17.5.1 Utilities.

17.5.1.1 Utilities shall comply with the provisions of Section 9.1.

17.5.1.2 Special protective covers for all electrical receptacles shall be installed in all areas occupied by clients.

17.5.2 Heating, Ventilating, and Air Conditioning Equipment.

17.5.2.1 Heating, ventilating, and air conditioning equipment shall be in accordance with Section 9.2.

17.5.2.2 Unvented fuel-fired heating equipment, other than gas space heaters in compliance with NFPA 54/ANSI Z 223.1, *National Fuel Gas Code*, shall be prohibited.

17.5.2.3 Any heating equipment in spaces occupied by clients shall be provided with partitions, screens, or other means to protect clients from hot surfaces and open flames; if solid partitions are used to provide such protection, provisions shall be made to ensure adequate air for combustion and ventilation for the heating equipment.

17.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors, other than those in day-care homes, shall comply with the provisions of Section 9.4.

17.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes, other than those in day-care homes, shall comply with the provisions of Section 9.5.

17.6 Day-Care Homes.**17.6.1 General Requirements.****17.6.1.1 Application.****17.6.1.1.1 Reserved.**

17.6.1.1.2* The requirements of Section 17.6 shall apply to existing day-care homes in which more than 3, but not more than 12, clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day, generally within a dwelling unit. An existing day-care home shall be permitted the option of meeting the requirements of Section 16.6 in lieu of Section 17.6. Any existing day-care home that meets the requirements of Chapter 16 shall be judged as meeting the requirements of this chapter. (See also 17.6.1.4.)

17.6.1.1.3 Where a facility houses clients of more than one self-preservation capability, the strictest requirements applicable to any group present shall apply throughout the day-care home or building, as appropriate to a given area, unless the area housing such a group is maintained as a separate fire area.

17.6.1.1.4 Facilities that supervise clients on a temporary basis with a parent or guardian in close proximity shall not be required to meet the provisions of Section 17.6.

17.6.1.1.5 Places of religious worship shall not be required to meet the provisions of Section 17.6 where operating a day-care home while services are being held in the building.

17.6.1.2 Multiple Occupancies. See 17.1.2.

17.6.1.3 Definitions. See 17.1.3.

17.6.1.4 Classification of Occupancy.

17.6.1.4.1 Subclassification of Day-Care Homes. Subclassification of day-care homes shall comply with 17.6.1.4.1(A) and 17.6.1.4.1(B).

(A) Family Day-Care Home. A family day-care home shall be a day-care home in which more than three, but fewer than seven, clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day, generally within a dwelling unit.

(B) Group Day-Care Home. A group day-care home shall be a day-care home in which not less than 7, but not more than 12, clients receive care, maintenance, and supervision by other than their relative(s) or legal guardian(s) for less than 24 hours per day, generally within a dwelling unit.

17.6.1.4.2* Conversions. A conversion from a day-care home to a day-care occupancy with more than 12 clients shall be permitted only if the day-care occupancy conforms to the requirements of Chapter 16 for new day-care occupancies with more than 12 clients.

17.6.1.5 Classification of Hazard of Contents. See 17.1.5.

17.6.1.6 Location and Construction. No day-care home shall be located more than one story below the ground.

17.6.1.7 Occupant Load.

17.6.1.7.1 In family day-care homes the following shall apply:

- (1) The minimum staff-to-client ratio shall be not less than one staff for up to six clients, including the caretaker's own children under age six.

- (2) There shall be not more than two clients incapable of self-preservation.

17.6.1.7.2 In group day-care homes the following shall apply:

- (1) The minimum staff-to-client ratio shall be not less than two staff for up to 12 clients.
- (2) There shall be not more than three clients incapable of self-preservation.
- (3) The staff-to-client ratio shall be permitted to be modified by the authority having jurisdiction where safeguards in addition to those specified by Section 17.6 are provided.

17.6.2 Means of Escape Requirements.

17.6.2.1 General. Means of escape shall comply with Section 24.2.

17.6.2.2 Reserved.**17.6.2.3 Reserved.**

17.6.2.4 Number of Means of Escape. The number of means of escape shall comply with Section 24.2 and 17.6.2.4.1 through 17.6.2.4.4.

17.6.2.4.1 In group day-care homes, every story occupied by clients shall have not less than two remotely located means of escape.

17.6.2.4.2 Every room used for sleeping, living, or dining purposes shall comply with the following:

- (1) There shall be not less than two means of escape, not less than one of which shall be a door or stairway providing a means of unobstructed travel to the outside of the building at street or ground level.
- (2) The second means of escape shall be permitted to be a window in accordance with 17.2.11.1.
- (3) No room or space that is accessible only by a ladder or folding stairs or through a trap door shall be occupied for living or sleeping purposes.

17.6.2.4.3 In group day-care homes where spaces on the story above the level of exit discharge are used by clients, not less than one means of escape shall be an exit discharging directly to the outside, and the second means of escape shall be permitted to be a window in accordance with 17.2.11.1.

17.6.2.4.4 Where clients occupy a story below the level of exit discharge, not less than one means of escape shall be an exit discharging directly to the outside, the vertical travel to ground level shall not exceed 2440 mm (96 in.), and the second means of escape shall be permitted to be a window in accordance with 17.2.11.1.

17.6.2.5 Arrangement of Means of Egress.

17.6.2.5.1 A story used above or below the level of exit discharge shall be in accordance with 17.6.2.4.3 or 17.6.2.4.4.

17.6.2.5.2 For group day-care homes, means of egress shall be arranged in accordance with Section 7.5.

17.6.2.5.3 No dead-end corridor shall exceed 6100 mm (240 in.), other than in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, in which case dead-end corridors shall not exceed 15 m (50 ft).

17.6.2.6 Travel Distance.

17.6.2.6.1 Travel distance shall meet the following criteria unless otherwise permitted by 17.6.2.6.2:

- (1) The travel distance between any room door intended as an exit access and an exit shall not exceed 30 m (100 ft).
- (2) The travel distance between any point in a room and an exit shall not exceed 46 m (150 ft).
- (3) The travel distance between any point in a sleeping room and an exit access to that room shall not exceed 15 m (50 ft).

17.6.2.6.2 The travel distance required by 17.6.2.6.1(1) and 17.6.2.6.1(2) shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

17.6.2.7 Discharge from Exits. See 17.6.2.4.

17.6.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

17.6.2.9 Emergency Lighting. (No requirements.)

17.6.2.10 Marking of Means of Egress. (No requirements.)

17.6.3 Protection.

17.6.3.1 Protection of Vertical Openings.

17.6.3.1.1 For group day-care homes, the doorway between the level of exit discharge and any story below shall be equipped with a fire door assembly having a 20-minute fire protection rating.

17.6.3.1.2 Where the story above the level of exit discharge is used for sleeping purposes, there shall be a fire door assembly having a 20-minute fire protection rating at the top or bottom of each stairway unless otherwise permitted by 17.6.3.1.3.

17.6.3.1.3 Approved existing self-closing 44-mm (1¾-in.) thick, solid-bonded wood doors without rated frames shall be permitted to continue in use.

17.6.3.2 Protection from Hazards. (No requirements.)

17.6.3.3 Interior Finish.

17.6.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

17.6.3.3.2 Interior Wall and Ceiling Finish.

17.6.3.3.2.1 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in exits.

17.6.3.3.2.2 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A, Class B, or Class C in occupied spaces.

17.6.3.3.3 Interior Floor Finish. (No requirements.)

17.6.3.4 Detection, Alarm, and Communications Systems.

17.6.3.4.1 Smoke alarms shall be installed within day-care homes in accordance with 9.6.2.10.

17.6.3.4.2 Where a day-care home is located within a building of another occupancy, such as in an apartment building or office building, any corridors serving the day-care home shall be provided with a smoke detection system in accordance with Section 9.6.

17.6.3.4.3 One of the following shall be provided in all rooms used for sleeping:

- (1) Single-station or multiple-station smoke alarms in accordance with 9.6.2.10 that are powered by the building electrical system

- (2) System detectors with integral sounding devices in accordance with 9.6.1.3

17.6.3.4.4 Approved existing battery-powered smoke alarms, rather than house electrical service-powered smoke alarms required by 17.6.3.4.3, shall be permitted where the facility has testing, maintenance, and battery replacement programs that ensure reliability of power to the smoke alarms.

17.6.3.5 Extinguishment Requirements. Any required sprinkler systems shall be in accordance with Section 9.7 and, other than approved existing systems, shall be installed in accordance with 9.7.1.1(1), 9.7.1.1(2), or 9.7.1.1(3), as appropriate with respect to the scope of the installation standard.

17.7 Operating Features.

17.7.1* Emergency Plans. Emergency plans shall be provided in accordance with Section 4.8.

17.7.2 Emergency Egress and Relocation Drills.

17.7.2.1* Emergency egress and relocation drills shall be conducted in accordance with Section 4.7 and the applicable provisions of 17.7.2.2.

17.7.2.2 Emergency egress and relocation drills shall be conducted as follows:

- (1) Not less than one emergency egress and relocation drill shall be conducted every month the facility is in session, unless both of the following criteria are met:
 - (a) In climates where the weather is severe, the monthly emergency egress and relocation drills shall be permitted to be deferred.
 - (b) The required number of emergency egress and relocation drills shall be conducted, and not less than four shall be conducted before the drills are deferred.
- (2) All occupants of the building shall participate in the drill.
- (3) One additional emergency egress and relocation drill, other than for day-care occupancies that are open on a year-round basis, shall be required within the first 30 days of operation.

17.7.3 Inspections.

17.7.3.1 Fire prevention inspections shall be conducted monthly by a trained senior member of the staff, after which a copy of the latest inspection report shall be posted in a conspicuous place in the day-care facility.

17.7.3.2* It shall be the duty of site administrators and staff members to inspect all exit facilities daily to ensure that all stairways, doors, and other exits are in proper condition.

17.7.3.3 Open plan buildings shall require extra surveillance to ensure that exit paths are maintained clear of obstruction and are obvious.

17.7.4 Furnishings and Decorations.

17.7.4.1 Draperies, curtains, and other similar furnishings and decorations in day-care occupancies shall be in accordance with the provisions of 10.3.1.

17.7.4.2 Clothing and personal effects shall not be stored in corridors, unless otherwise permitted by the following:

- (1) This requirement shall not apply to corridors protected by an automatic sprinkler system in accordance with Section 9.7.

- (2) This requirement shall not apply to corridor areas protected by a smoke detection system in accordance with Section 9.6.
- (3) This requirement shall not apply to storage in metal lockers, provided that the required egress width is maintained.

17.7.4.3 Artwork and teaching materials shall be permitted to be attached directly to the walls in accordance with the following:

- (1) The artwork and teaching materials shall not exceed 20 percent of the wall area in a building that is not protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.
- (2) The artwork and teaching materials shall not exceed 50 percent of the wall area in a building that is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

17.7.5* Day-Care Staff. Adequate adult staff shall be on duty, alert, awake, and in the facility at all times where clients are present.

Chapter 18 New Health Care Occupancies

18.1 General Requirements.

18.1.1 Application.

18.1.1.1 General.

18.1.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as health care occupancies (*see 1.3.1*)
- (2) Additions made to, or used as, a health care occupancy (*see 4.6.7 and 18.1.1.4*), unless all of the following criteria are met:
 - (a) The addition is classified as other than a health care occupancy.
 - (b) The addition is separated from the health care occupancy in accordance with 18.1.2.2(2).
 - (c) The addition conforms to the requirements for the specific occupancy in accordance with Chapter 12 through Chapter 17 and Chapter 20 through Chapter 42, as appropriate.
- (3) Alterations, modernizations, or renovations of existing health care occupancies (*see 4.6.8 and 18.1.1.4*)
- (4)*Existing buildings or portions thereof upon change of occupancy to a health care occupancy (*see 4.6.12*), unless the authority having jurisdiction has determined equivalent safety has been provided in accordance with Section 1.4.

18.1.1.1.2 The requirements established by this chapter shall apply to the design of all new hospitals, nursing homes, and limited care facilities. The term *hospital*, wherever used in this *Code*, shall include general hospitals, psychiatric hospitals, and specialty hospitals. The term *nursing home*, wherever used in this *Code*, shall include nursing and convalescent homes, skilled nursing facilities, intermediate care facilities, and infirmaries in homes for the aged. Where requirements vary, the specific subclass of health care occupancy is named in the paragraph pertaining thereto. The requirements established by Chapter 20 shall apply to all new ambulatory health care

facilities. The operating feature requirements established by Section 18.7 shall apply to all health care occupancies.

18.1.1.1.3 The health care facilities regulated by this chapter shall be those that provide sleeping accommodations for their occupants and are occupied by persons who are mostly incapable of self-preservation because of age, because of physical or mental disability, or because of security measures not under the occupants' control.

18.1.1.1.4 Buildings, or sections of buildings, that primarily house patients who, in the opinion of the governing body of the facility and the governmental agency having jurisdiction, are capable of exercising judgment and appropriate physical action for self-preservation under emergency conditions shall be permitted to comply with chapters of this *Code* other than Chapter 18.

18.1.1.1.5 It shall be recognized that, in buildings housing certain types of patients or having detention rooms or a security section, it might be necessary to lock doors and bar windows to confine and protect building inhabitants. In such instances, the authority having jurisdiction shall make appropriate modifications to those sections of this *Code* that would otherwise require means of egress to be kept unlocked.

18.1.1.1.6 Buildings, or sections of buildings, that house older persons and that provide activities that foster continued independence but that do not include services distinctive to health care occupancies (*see 18.1.3*) as defined in 3.3.152.7 shall be permitted to comply with the requirements of other chapters of this *Code*, such as Chapter 30 or Chapter 32.

18.1.1.1.7 Facilities that do not provide housing on a 24-hour basis for their occupants shall be classified as other occupancies and shall be covered by other chapters of this *Code*.

18.1.1.1.8* The requirements of this chapter are based on the assumption that staff is available in all patient-occupied areas to perform certain fire safety functions as required in other paragraphs of this chapter.

18.1.1.2* Goals and Objectives. The goals and objectives of Section 4.1 and Section 4.2 shall be met with due consideration for functional requirements, which are accomplished by limiting the development and spread of a fire emergency to the room of fire origin and reducing the need for occupant evacuation, except from the room of fire origin.

18.1.1.3 Total Concept.

18.1.1.3.1 All health care facilities shall be designed, constructed, maintained, and operated to minimize the possibility of a fire emergency requiring the evacuation of occupants.

18.1.1.3.2 Because the safety of health care occupants cannot be ensured adequately by dependence on evacuation of the building, their protection from fire shall be provided by appropriate arrangement of facilities, adequate, trained staff, and development of operating and maintenance procedures composed of the following:

- (1) Design, construction, and compartmentation
- (2) Provision for detection, alarm, and extinguishment
- (3) Fire prevention procedures and the planning, training, and drilling programs for the isolation of fire, transfer of occupants to areas of refuge, or evacuation of the building

18.1.1.4 Additions, Conversions, Modernization, Renovation, and Construction Operations.

18.1.1.4.1 Additions. Additions shall be separated from any existing structure not conforming to the provisions within Chapter 19 by a fire barrier having not less than a 2-hour fire resistance rating and constructed of materials as required for the addition. (See 4.6.12 and 4.6.7.)

18.1.1.4.2 Communicating openings in dividing fire barriers required by 18.1.1.4.1 shall be permitted only in corridors and shall be protected by approved self-closing fire door assemblies. (See also Section 8.3.)

18.1.1.4.3 Doors in barriers required by 18.1.1.4.1 shall normally be kept closed unless otherwise permitted by 18.1.1.4.4.

18.1.1.4.4 Doors shall be permitted to be held open if they meet the requirements of 18.2.2.2.6.

18.1.1.4.5 Changes of Occupancy. Changes of occupancy shall comply with 4.6.12, and the following also shall apply:

- (1) A change from one health care occupancy subclassification to another shall require compliance with the requirements for new construction.
- (2) A change from a hospital to a nursing home or from a nursing home to a hospital shall not be considered a change in occupancy or occupancy subclassification.
- (3) A change from a hospital or nursing home to a limited care facility shall not be considered a change in occupancy or occupancy subclassification.
- (4) A change from a hospital or nursing home to an ambulatory health care facility shall not be considered a change in occupancy or occupancy subclassification.

18.1.1.4.6 Rehabilitation.

18.1.1.4.6.1 For purposes of the provisions of this chapter, the following shall apply:

- (1) A major rehabilitation shall involve the modification of more than 50 percent, or more than 420 m² (4500 ft²), of the area of the smoke compartment.
- (2) A minor rehabilitation shall involve the modification of not more than 50 percent, and not more than 420 m² (4500 ft²), of the area of the smoke compartment.

18.1.1.4.6.2 Work that is exclusively plumbing, mechanical, fire protection system, electrical, medical gas, or medical equipment shall not be included in the computation of the modification area within the smoke compartment.

18.1.1.4.6.3* Where major rehabilitation is made in a non-sprinklered smoke compartment, the automatic sprinkler requirements of 18.3.5.1 shall apply to the smoke compartment undergoing the rehabilitation, and, in cases where the building is not protected throughout by an approved automatic sprinkler system, the requirements of 18.4.3.2 and 18.4.3.3(2) shall also apply.

18.1.1.4.6.4* Where minor rehabilitation is done in a non-sprinklered smoke compartment, the requirements of 18.3.5.1 shall not apply, but, in such cases, the rehabilitation shall not reduce life safety below the level that previously existed or below the level of requirements of 18.4.3 for nonsprinklered smoke compartment rehabilitation. (See 4.6.8.)

18.1.1.4.7 Construction, Repair, and Improvement Operations. (See 4.6.11.)

18.1.2 Multiple Occupancies.

18.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

18.1.2.2* Sections of health care facilities shall be permitted to be classified as other occupancies, provided that they meet all of the following conditions:

- (1) They are not intended to serve health care occupants for purposes of housing, treatment, or customary access by patients incapable of self-preservation.
- (2) They are separated from areas of health care occupancies by construction having a fire resistance rating of not less than 2 hours.

18.1.2.3* Ambulatory care facilities, medical clinics, and similar facilities that are contiguous to health care occupancies but are primarily intended to provide outpatient services shall be permitted to be classified as business occupancies or ambulatory health care facilities, provided that the facilities are separated from the health care occupancy by not less than 2-hour fire resistance-rated construction and the facility is not intended to provide services simultaneously for four or more in-patients who are litterborne.

18.1.2.4 All means of egress from health care occupancies that traverse non-health care spaces shall conform to the requirements of this *Code* for health care occupancies, unless otherwise permitted by 18.1.2.5.

18.1.2.5 Exit through a horizontal exit into other contiguous occupancies that do not conform to health care egress provisions, but that do comply with requirements set forth in the appropriate occupancy chapter of this *Code*, shall be permitted, provided that both of the following criteria apply:

- (1) The occupancy does not contain high hazard contents.
- (2) The horizontal exit complies with the requirements of 18.2.2.5.

18.1.2.6 Egress provisions for areas of health care facilities that correspond to other occupancies shall meet the corresponding requirements of this *Code* for such occupancies, and, where the clinical needs of the occupant necessitate the locking of means of egress, staff shall be present for the supervised release of occupants during all times of use.

18.1.2.7 Auditoriums, chapels, staff residential areas, or other occupancies provided in connection with health care facilities shall have means of egress provided in accordance with other applicable sections of this *Code*.

18.1.2.8 Any area with a hazard of contents classified higher than that of the health care occupancy and located in the same building shall be protected as required by 18.3.2.

18.1.2.9 Non-health care-related occupancies classified as containing high hazard contents shall not be permitted in buildings housing health care occupancies.

18.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Ambulatory Health Care Occupancy.** See 3.3.152.1.
- (2) **Hospital.** See 3.3.112.
- (3) **Limited Care Facility.** See 3.3.69.2.
- (4) **Nursing Home.** See 3.3.110.2.

18.1.4 Classification of Occupancy. See 18.1.3.

18.1.5 Classification of Hazard of Contents. The classification of hazard of contents shall be as defined in Section 6.2.

18.1.6 Minimum Construction Requirements.

18.1.6.1 For the purpose of 18.1.6, the number of stories shall be counted starting with the primary level of exit discharge and ending with the highest occupiable level.

18.1.6.2 For the purposes of 18.1.6.1, the primary level of exit discharge of a building shall be the lowest story whose floor is level with or above finished grade on the exterior wall line for 50 percent or more of its perimeter.

18.1.6.3 For the purposes of 18.1.6.2, building levels below the primary level shall not be counted as a story.

18.1.6.4 Health care occupancies shall be limited to the types of building construction shown in Table 18.1.6.4, unless otherwise permitted by 18.1.6.5. (See 8.2.1.)

Table 18.1.6.4 Construction Type Limitations

Construction Type	Stories			
	1	2	3	4 or More
I(443)	X	X	X	X
I(332)	X	X	X	X
II(222)	X	X	X	X
II(111)	X	X	X	NP
II(000)	X	NP	NP	NP
III(211)	X	NP	NP	NP
III(200)	NP	NP	NP	NP
IV(2HH)	X	NP	NP	NP
V(111)	X	NP	NP	NP
V(000)	NP	NP	NP	NP

X: Permitted type of construction.

NP: Not permitted.

18.1.6.5 Any building of Type I(443), Type I(332), Type II(222), or Type II(111) construction shall be permitted to include roofing systems involving combustible supports, decking, or roofing, provided that the following criteria are met:

- (1) The roof covering shall meet Class A requirements in accordance with NFPA 256, *Standard Methods of Fire Tests of Roof Coverings*.
- (2) The roof shall be separated from all occupied portions of the building by a noncombustible floor assembly having not less than a 2-hour fire resistance rating that includes not less than 63 mm (2½ in.) of concrete or gypsum fill.
- (3) The structural elements supporting the 2-hour fire resistance-rated floor assembly specified in 18.1.6.5(2) shall be required to have only the fire resistance rating required of the building.

18.1.6.6 All interior walls and partitions in buildings of Type I or Type II construction shall be of noncombustible or limited-combustible materials.

18.1.6.7 Fire-retardant-treated wood that serves as supports for the installation of fixtures and equipment shall be permitted to be installed behind noncombustible or limited-combustible sheathing.

18.1.6.8 All buildings with more than one level below the level of exit discharge shall have all such lower levels separated

from the level of exit discharge by not less than Type II(111) construction.

18.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, either shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

18.2 Means of Egress Requirements.

18.2.1 General. Every aisle, passageway, corridor, exit discharge, exit location, and access shall be in accordance with Chapter 7, unless otherwise modified by 18.2.2 through 18.2.11.

18.2.2* Means of Egress Components.

18.2.2.1 Components of means of egress shall be limited to the types described in 18.2.2.2 through 18.2.2.10.

18.2.2.2 Doors.

18.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

18.2.2.2.2 Locks shall not be permitted on patient sleeping room doors, unless otherwise permitted by the following:

- (1) Key-locking devices that restrict access to the room from the corridor and that are operable only by staff from the corridor side shall be permitted, provided that such devices do not restrict egress from the room.
- (2) Door-locking arrangements shall be permitted in health care occupancies, or portions of health care occupancies, where the clinical needs of the patients require specialized security measures for their safety, provided that keys are carried by staff at all times.

18.2.2.2.3 Doors not located in a required means of egress shall be permitted to be subject to locking.

18.2.2.2.4 Doors within a required means of egress shall not be equipped with a latch or lock that requires the use of a tool or key from the egress side, unless otherwise permitted by the following:

- (1) Door-locking arrangements without delayed egress shall be permitted in health care occupancies, or portions of health care occupancies, where the clinical needs of the patients require specialized security measures for their safety, provided that staff can readily unlock such doors at all times. (See 18.1.1.1.5 and 18.2.2.2.5.)
- (2)*Delayed-egress locks complying with 7.2.1.6.1 shall be permitted, provided that not more than one such device is located in any egress path.
- (3) Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

18.2.2.2.5 Doors that are located in the means of egress and are permitted to be locked under other provisions of this chapter shall have provisions made for the rapid removal of occupants by means such as the following:

- (1) Remote control of locks
- (2) Keying of all locks to keys carried by staff at all times
- (3) Other such reliable means available to the staff at all times

18.2.2.2.5.1 Only one locking device as specified in 18.2.2.2.5 shall be permitted on each door.

18.2.2.2.5.2 Locks in accordance with 18.2.2.2.4(2) and 18.2.2.2.4(3) shall be permitted.

18.2.2.2.6* Any door in an exit passageway, stairway enclosure, horizontal exit, smoke barrier, or hazardous area enclosure (except boiler rooms, heater rooms, and mechanical equipment rooms) shall be permitted to be held open only by an automatic release device that complies with 7.2.1.8.2. The automatic sprinkler system and the fire alarm system, and the systems required by 7.2.1.8.2, shall be arranged to initiate the closing action of all such doors throughout the smoke compartment or throughout the entire facility.

18.2.2.2.7 Where doors in a stair enclosure are held open by an automatic release device as permitted in 18.2.2.2.6, initiation of a door-closing action on any level shall cause all doors at all levels in the stair enclosure to close.

18.2.2.2.8 High-rise health care occupancies shall comply with the re-entry provisions of 7.2.1.5.7.

18.2.2.2.9 Horizontal sliding doors, as permitted by 7.2.1.14, that are not automatic-closing shall be limited to a single leaf and shall have a latch or other mechanism that ensures that doors will not rebound into a partially open position if forcefully closed in an emergency.

18.2.2.3 Stairs. Stairs complying with 7.2.2 shall be permitted.

18.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

18.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 and the modifications of 18.2.2.5.1 through 18.2.2.5.6 shall be permitted.

18.2.2.5.1 Accumulation space shall be provided in accordance with 18.2.2.5.1.1 and 18.2.2.5.1.2.

18.2.2.5.1.1 Not less than 2.8 net m² (30 net ft²) per patient in a hospital or nursing home, or not less than 1.4 net m² (15 net ft²) per resident in a limited care facility, shall be provided within the aggregated area of corridors, patient rooms, treatment rooms, lounge or dining areas, and other similar areas on each side of the horizontal exit.

18.2.2.5.1.2 On stories not housing bed or litterborne patients, not less than 0.56 net m² (6 net ft²) per occupant shall be provided on each side of the horizontal exit for the total number of occupants in adjoining compartments.

18.2.2.5.2 The total egress capacity of the other exits (stairs, ramps, doors leading outside the building) shall not be reduced below one-third of that required for the entire area of the building.

18.2.2.5.3 A single door shall be permitted in a horizontal exit if the following conditions apply:

- (1) The exit serves one direction only.
- (2) Such door is a swinging door or a horizontal sliding door complying with 7.2.1.14.
- (3) The door is not less than 1055 mm (41½ in.) in clear width.

18.2.2.5.4 A horizontal exit involving a corridor 2440 mm (96 in.) or more in width and serving as a means of egress from both sides of the doorway shall have the opening protected by a pair of swinging doors arranged to swing in opposite directions from each other, with each door having a clear width of not less than 1055 mm (41½ in.), or by a horizontal sliding door that complies with 7.2.1.14 and provides a clear width of not less than 2110 mm (83 in.).

18.2.2.5.5 A horizontal exit involving a corridor 1830 mm (72 in.) or more in width and serving as a means of egress from both sides of the doorway shall have the opening protected by a pair of swinging doors, arranged to swing in opposite directions from each other, with each door having a clear width of not less than 810 mm (32 in.), or by a horizontal sliding door that complies with 7.2.1.14 and provides a clear width of not less than 1625 mm (64 in.).

18.2.2.5.6 An approved vision panel shall be required in each horizontal exit.

18.2.2.5.7 Center mullions shall be prohibited in horizontal exit door openings.

18.2.2.6 Ramps.

18.2.2.6.1 Ramps complying with 7.2.5 shall be permitted.

18.2.2.6.2 Ramps enclosed as exits shall be of sufficient width to provide egress capacity in accordance with 18.2.3.

18.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

18.2.2.8 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

18.2.2.9 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

18.2.2.10 Areas of Refuge. Areas of refuge used as part of a required accessible means of egress shall comply with 7.2.12.

18.2.3 Capacity of Means of Egress.

18.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

18.2.3.2 Reserved.

18.2.3.3 Reserved.

18.2.3.4* Aisles, corridors, and ramps required for exit access in a hospital or nursing home shall be not less than 2440 mm (96 in.) in clear and unobstructed width, unless otherwise permitted by the following:

- (1)*Aisles, corridors, and ramps in adjunct areas not intended for the housing, treatment, or use of inpatients shall be not less than 1120 mm (44 in.) in clear and unobstructed width.
- (2)*Exit access within a room or suite of rooms complying with the requirements of 18.2.5 shall be permitted.

18.2.3.5 Aisles, corridors, and ramps required for exit access in a limited care facility or hospital for psychiatric care shall be not less than 1830 mm (72 in.) in clear and unobstructed width, unless otherwise permitted by the following:

- (1)*Aisles, corridors, and ramps in adjunct areas not intended for the housing, treatment, or use of inpatients shall be not less than 1120 mm (44 in.) in clear and unobstructed width.
- (2)*Exit access within a room or suite of rooms complying with the requirements of 18.2.5 shall be permitted.

18.2.3.6 The minimum clear width for doors in the means of egress from sleeping rooms; diagnostic and treatment areas, such as x-ray, surgery, or physical therapy; and nursery rooms shall be as follows:

- (1) Hospitals and nursing homes — 1055 mm (41½ in.)
- (2) Psychiatric hospitals and limited care facilities — 810 mm (32 in.)

18.2.3.7 The requirements of 18.2.3.6 shall not apply where otherwise permitted by the following:

- (1) Doors that are located so as not to be subject to use by any health care occupant shall be not less than 810 mm (32 in.) in clear width.
- (2) Doors in exit stair enclosures shall be not less than 810 mm (32 in.) in clear width.
- (3) Doors serving newborn nurseries shall be not less than 810 mm (32 in.) in clear width.
- (4) Where a pair of doors is provided, the following criteria shall be met:
 - (a) Not less than one of the doors shall provide not less than a 810 mm (32 in.) clear width opening.
 - (b) A rabbet, bevel, or astragal shall be provided at the meeting edge.
 - (c) The inactive door leaf shall have an automatic flush bolt to provide positive latching.

18.2.4 Number of Exits.

18.2.4.1 Not less than two exits of the types described in 18.2.2.2 through 18.2.2.10, remotely located from each other, shall be provided for each floor or fire section of the building.

18.2.4.2 Not less than one exit from each floor or fire section shall be one of the following:

- (1) A door leading directly outside the building
- (2) A stair
- (3) A smokeproof enclosure
- (4) A ramp
- (5) An exit passageway

18.2.4.3 Any fire section not meeting the requirements of 18.2.4.2 shall be considered part of an adjoining zone through which egress shall not require return through the zone of fire origin.

18.2.4.4* Not less than two exits of the types described in 18.2.2.2 through 18.2.2.10 shall be accessible from each smoke compartment, and egress shall be permitted through an adjacent compartment(s) but shall not require return through the compartment of fire origin.

18.2.5 Arrangement of Means of Egress.

18.2.5.1 Every habitable room shall have an exit access door leading directly to an exit access corridor, unless otherwise permitted by the following:

- (1) The requirement of 18.2.5.1 shall not apply if there is an exit door opening directly to the outside from the room at ground level.
- (2) Exit access from a patient sleeping room with not more than eight patient beds shall be permitted to pass through one intervening room to reach the exit access corridor.
- (3) Exit access from a sleeping or nursing suite shall be permitted to pass through one intervening room to reach the exit access corridor where the arrangement allows for direct and constant visual supervision by nursing personnel.
- (4) Exit access from a suite of rooms, other than patient sleeping rooms, shall be permitted to pass through not more than two adjacent rooms to reach the exit access corridor where the travel distance within the suite is in accordance with 18.2.5.8.

18.2.5.2 Any patient sleeping room, or any suite that includes patient sleeping rooms, of more than 93 m² (1000 ft²) shall

have not less than two exit access doors remotely located from each other.

18.2.5.3 Any room or any suite of rooms, other than patient sleeping rooms, of more than 232 m² (2500 ft²) shall have not less than two exit access doors remotely located from each other.

18.2.5.4 Any suite of rooms that complies with the requirements of 18.2.5 shall be permitted to be subdivided with non-fire-rated, noncombustible, or limited-combustible partitions.

18.2.5.5 Intervening rooms shall not be hazardous areas as defined by 18.3.2.

18.2.5.6 Suites of sleeping rooms shall not exceed 465 m² (5000 ft²).

18.2.5.7 Suites of rooms, other than patient sleeping rooms, shall not exceed 929 m² (10,000 ft²).

18.2.5.8 Suites of rooms, other than patient sleeping rooms, shall be permitted to have one intervening room if the travel distance within the suite to the exit access door does not exceed 30 m (100 ft) and shall be permitted to have two intervening rooms where the travel distance within the suite to the exit access door does not exceed 15 m (50 ft).

18.2.5.9 Every corridor shall provide access to not less than two approved exits in accordance with Section 7.4 and Section 7.5 without passing through any intervening rooms or spaces other than corridors or lobbies.

18.2.5.10 Every exit or exit access shall be arranged so that no corridor, aisle, or passageway has a pocket or dead end exceeding 9140 mm (360 in.).

18.2.6 Travel Distance to Exits.

18.2.6.1 Travel distance shall be measured in accordance with Section 7.6.

18.2.6.2 Travel distance shall comply with 18.2.6.2.1 through 18.2.6.2.6.

18.2.6.2.1 The travel distance between any room door required as an exit access and an exit shall not exceed 46 m (150 ft).

18.2.6.2.2 Reserved.

18.2.6.2.3 The travel distance between any point in a room and an exit shall not exceed 61 m (200 ft).

18.2.6.2.4 Reserved.

18.2.6.2.5 The travel distance between any point in a health care sleeping room and an exit access door in that room shall not exceed 15 m (50 ft).

18.2.6.2.6 The travel distance between any point in a suite of sleeping rooms as permitted by 18.2.5 and an exit access door of that suite shall not exceed 30 m (100 ft) and shall meet the requirements of 18.2.6.2.3.

18.2.7 Discharge from Exits. Discharge from exits shall be arranged in accordance with Section 7.7.

18.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

18.2.9 Emergency Lighting.

18.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9.

18.2.9.2 Buildings equipped with, or in which patients require the use of, life-support systems (*see 18.5.1.3*) shall have emergency lighting equipment supplied by the life safety branch of the electrical system as described in NFPA 99, *Standard for Health Care Facilities*.

18.2.10 Marking of Means of Egress.

18.2.10.1 Means of egress shall have signs in accordance with Section 7.10.

18.2.10.2 Illumination of required exit and directional signs in buildings equipped with, or in which patients use, life-support systems (*see 18.5.1.3*) shall be provided as follows:

- (1) Illumination shall be supplied by the life safety branch of the electrical system as described in NFPA 99, *Standard for Health Care Facilities*.
- (2) Self-luminous exit signs complying with 7.10.4 shall be permitted.

18.2.11 Special Means of Egress Features. (Reserved)

18.3 Protection.

18.3.1 Protection of Vertical Openings. Any vertical opening shall be enclosed or protected in accordance with Section 8.6, unless otherwise modified by 18.3.1.1 through 18.3.1.8.

18.3.1.1 Reserved.

18.3.1.2 Unprotected vertical openings in accordance with 8.6.8.2 shall be permitted.

18.3.1.3 Subparagraph 8.6.7(1)(b) shall not apply to patient sleeping and treatment rooms.

18.3.1.4 Multilevel patient sleeping areas in psychiatric facilities shall be permitted without enclosure protection between levels, provided that all of the following conditions are met:

- (1) The entire normally occupied area, including all communicating floor levels, is sufficiently open and unobstructed so that a fire or other dangerous condition in any part is obvious to the occupants or supervisory personnel in the area.
- (2) The egress capacity provides simultaneously for all the occupants of all communicating levels and areas, with all communicating levels in the same fire area being considered as a single floor area for purposes of determination of required egress capacity.
- (3) The height between the highest and lowest finished floor levels does not exceed 3960 mm (156 in.), and the number of levels is permitted to be unrestricted.

18.3.1.5 Unprotected openings in accordance with 8.6.6 shall not be permitted.

18.3.1.6 Reserved.

18.3.1.7 A door in a stair enclosure shall be self-closing and shall normally be kept in the closed position, unless otherwise permitted by 18.3.1.8.

18.3.1.8 Doors in stair enclosures shall be permitted to be held open under the conditions specified by 18.2.2.2.6 and 18.2.2.2.7.

18.3.2 Protection from Hazards.

18.3.2.1* Hazardous Areas. Any hazardous areas shall be protected in accordance with Section 8.7, and the areas described in Table 18.3.2.1 shall be protected as indicated.

Table 18.3.2.1 Hazardous Area Protection

Hazardous Area Description	Separation/Protection
Boiler and fuel-fired heater rooms	1 hour
Central/bulk laundries larger than 9.3 m ² (100 ft ²)	1 hour
Laboratories employing flammable or combustible materials in quantities less than those that would be considered a severe hazard	See 18.3.6.3.9
Laboratories that use hazardous materials that would be classified as a severe hazard in accordance with NFPA 99, <i>Standard for Health Care Facilities</i>	1 hour
Paint shops employing hazardous substances and materials in quantities less than those that would be classified as a severe hazard	1 hour
Physical plant maintenance shops	1 hour
Soiled linen rooms	1 hour
Storage rooms larger than 4.6 m ² (50 ft ²) but not exceeding 9.3 m ² (100 ft ²) and storing combustible material	See 18.3.6.3.9
Storage rooms larger than 9.3 m ² (100 ft ²) and storing combustible material	1 hour
Trash collection rooms	1 hour

18.3.2.2* Laboratories. Laboratories employing quantities of flammable, combustible, or hazardous materials that are considered as a severe hazard shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

18.3.2.3 Anesthetizing Locations. Anesthetizing locations shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

18.3.2.4 Medical Gas. Medical gas storage and administration areas shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

18.3.2.5 Cooking Facilities.

18.3.2.5.1 Cooking facilities shall be protected in accordance with 9.2.3, unless otherwise permitted by 18.3.2.5.2.

18.3.2.5.2* Where domestic cooking equipment is used for food-warming or limited cooking, protection or separation of food preparation facilities shall not be required.

18.3.2.6 Heliports. Buildings that house health care occupancies, as indicated in 18.1.1.1.2, and have rooftop heliports shall be protected in accordance with NFPA 418, *Standard for Heliports*.

18.3.3 Interior Finish.

18.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

18.3.3.2* Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be permitted throughout if Class A except as indicated in 18.3.3.2.1 or 18.3.3.2.2.

18.3.3.2.1 Walls and ceilings shall be permitted to have Class A or Class B interior finish in individual rooms having a capacity not exceeding four persons.

18.3.3.2.2 Corridor wall finish not exceeding 1220 mm (48 in.) in height that is restricted to the lower half of the wall shall be permitted to be Class A or Class B.

18.3.3.3 Interior Floor Finish. (No requirements.)

18.3.4 Detection, Alarm, and Communications Systems.

18.3.4.1 General. Health care occupancies shall be provided with a fire alarm system in accordance with Section 9.6.

18.3.4.2* Initiation.

18.3.4.2.1 Initiation of the required fire alarm systems shall be by manual means in accordance with 9.6.2 and by means of any required sprinkler system waterflow alarms, detection devices, or detection systems, unless otherwise permitted by 18.3.4.2.2.

18.3.4.2.2 Manual fire alarm boxes in patient sleeping areas shall not be required at exits if located at all nurses' control stations or other continuously attended staff location, provided that both of the following criteria are met:

- (1) Such manual fire alarm boxes are visible and continuously accessible.
- (2) Travel distances required by 9.6.2.4 are not exceeded

18.3.4.3 Notification.

18.3.4.3.1 Occupant Notification. Occupant notification shall be accomplished automatically in accordance with 9.6.3, unless otherwise modified by the following:

- (1) Paragraph 9.6.3.2.3 shall not be permitted to be used.
- (2)*In lieu of audible alarm signals, visible alarm-indicating appliances shall be permitted to be used in critical care areas.

18.3.4.3.2 Emergency Forces Notification.

18.3.4.3.2.1 Fire department notification shall be accomplished in accordance with 9.6.4.

18.3.4.3.2.2 Smoke detection devices, or smoke detection systems, equipped with reconfirmation features shall not be required to automatically notify the fire department unless the alarm condition is reconfirmed after a period not exceeding 120 seconds.

18.3.4.3.3 Alarm Annunciation.

18.3.4.3.3.1 Alarm annunciation shall be provided in accordance with 9.6.7, unless otherwise permitted by 18.3.4.3.3.2.

18.3.4.3.3.2 The alarm zone shall be permitted to coincide with the permitted area for smoke compartments.

18.3.4.4 Emergency Control. Operation of any activating device in the required fire alarm system shall be arranged to accomplish automatically any control functions to be performed by that device. (See 9.6.5.)

18.3.4.5 Detection.

18.3.4.5.1 Detection systems, where required, shall be in accordance with Section 9.6.

18.3.4.5.2 Detection in Spaces Open to Corridors. See 18.3.6.1.

18.3.4.5.3* Nursing Homes. An approved automatic smoke detection system shall be installed in corridors throughout smoke compartments containing patient sleeping rooms and in spaces open to corridors as permitted in nursing homes by 18.3.6.1, unless otherwise permitted by the following:

- (1) Corridor systems shall not be required where each patient sleeping room is protected by an approved smoke detection system.
- (2) Corridor systems shall not be required where patient room doors are equipped with automatic door-closing devices with integral smoke detectors on the room side installed in accordance with their listing, provided that the integral detectors provide occupant notification.

18.3.5 Extinguishment Requirements.

18.3.5.1* Buildings containing health care occupancies shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, unless otherwise permitted by 18.3.5.3.

18.3.5.2 The sprinkler system required by 18.3.5.1 shall be installed in accordance with 9.7.1.1(1).

18.3.5.3 In Type I and Type II construction, alternative protection measures shall be permitted to be substituted for sprinkler protection, without causing a building to be classified as nonsprinklered, in specified areas where the authority having jurisdiction has prohibited sprinklers.

18.3.5.4* Listed quick-response or listed residential sprinklers shall be used throughout smoke compartments containing patient sleeping rooms.

18.3.5.5 Reserved.

18.3.5.6* Sprinklers in areas where cubicle curtains are installed shall be in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

18.3.5.7 Portable fire extinguishers shall be provided in all health care occupancies in accordance with 9.7.4.1.

18.3.6 Corridors.

18.3.6.1 Corridors shall be separated from all other areas by partitions complying with 18.3.6.2 through 18.3.6.5 (see also 18.2.5.9), unless otherwise permitted by the following:

- (1) Spaces shall be permitted to be unlimited in area and open to the corridor, provided that the following criteria are met:
 - (a) The spaces are not used for patient sleeping rooms, treatment rooms, or hazardous areas.
 - (b) The corridors onto which the spaces open in the same smoke compartment are protected by an electrically supervised automatic smoke detection system in accordance with 18.3.4, or the smoke compartment in which the space is located is protected throughout by quick-response sprinklers.
 - (c) The open space is protected by an electrically supervised automatic smoke detection system in accordance with 18.3.4, or the entire space is arranged and located to allow direct supervision by the facility staff from a nurses' station or similar space.
 - (d) The space does not obstruct access to required exits.

- (2) Waiting areas shall be permitted to be open to the corridor, provided that the following criteria are met:
 - (a) The aggregate waiting area in each smoke compartment does not exceed 55.7 m² (600 ft²).
 - (b) Each area is protected by an electrically supervised automatic smoke detection system in accordance with 18.3.4, or each area is arranged and located to allow direct supervision by the facility staff from a nursing station or similar space.
 - (c) The area does not obstruct access to required exits.
- (3)*This requirement shall not apply to spaces for nurses' stations.
- (4) Gift shops not exceeding 46.4 m² (500 ft²) shall be permitted to be open to the corridor or lobby, provided the building is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.
- (5) In a limited care facility, group meeting or multipurpose therapeutic spaces shall be permitted to open to the corridor, provided that the following criteria are met:
 - (a) The space is not a hazardous area.
 - (b) The space is protected by an electrically supervised automatic smoke detection system in accordance with 18.3.4, or the space is arranged and located to allow direct supervision by the facility staff from the nurses' station or similar location.
 - (c) The space does not obstruct access to required exits.

18.3.6.2* Construction of Corridor Walls.

18.3.6.2.1 Corridor walls shall form a barrier to limit the transfer of smoke.

18.3.6.2.2 Corridor walls shall be permitted to terminate at the ceiling where the ceiling is constructed to limit the transfer of smoke.

18.3.6.2.3 No fire resistance rating is required for corridor walls.

18.3.6.3* Corridor Doors.

18.3.6.3.1* Doors protecting corridor openings shall be constructed to resist the passage of smoke, and the following also shall apply.

- (1) Compliance with NFPA 80, *Standard for Fire Doors and Fire Windows*, shall not be required.
- (2) Clearance between the bottom of the door and the floor covering not exceeding 25 mm (1 in.) shall be permitted for corridor doors.
- (3) Doors to toilet rooms, bathrooms, shower rooms, sink closets, and similar auxiliary spaces that do not contain flammable or combustible material shall not be required to be constructed to resist the passage of smoke.

18.3.6.3.2 Reserved.

18.3.6.3.3 Reserved.

18.3.6.3.4 Reserved.

18.3.6.3.5 Doors shall be provided with positive latching hardware.

18.3.6.3.6 Doors to toilet rooms, bathrooms, shower rooms, sink closets, and similar auxiliary spaces that do not contain flammable or combustible materials shall not be required to be provided with positive latching hardware.

18.3.6.3.7 Roller latches shall be prohibited.

18.3.6.3.8* Doors shall not be held open by devices other than those that release when the door is pushed or pulled.

18.3.6.3.9 Door-closing devices shall not be required on doors in corridor wall openings other than those serving required exits, smoke barriers, or enclosures of vertical openings and hazardous areas.

18.3.6.3.10* Nonrated, factory- or field-applied protective plates extending not more than 1220 mm (48 in.) above the bottom of the door shall be permitted.

18.3.6.3.11 Dutch doors shall be permitted where they conform to 18.3.6.3 and meet the following criteria:

- (1) Both the upper leaf and lower leaf are equipped with a latching device.
- (2) The meeting edges of the upper and lower leaves are equipped with an astragal, a rabbet, or a bevel.
- (3) Where protecting openings in enclosures around hazardous areas, the doors comply with NFPA 80, *Standard for Fire Doors and Fire Windows*.

18.3.6.4 Transfer Grilles.

18.3.6.4.1 Transfer grilles, regardless of whether they are protected by fusible link-operated dampers, shall not be used in corridor walls or doors, unless otherwise permitted by 18.3.6.4.2.

18.3.6.4.2 Doors to toilet rooms, bathrooms, shower rooms, sink closets, and similar auxiliary spaces that do not contain flammable or combustible materials shall be permitted to have ventilating louvers or to be undercut.

18.3.6.5 Openings. In other than smoke compartments containing patient bedrooms, miscellaneous openings such as mail slots, pharmacy pass-through windows, laboratory pass-through windows, and cashier pass-through windows shall be permitted to be installed in vision panels or doors without special protection, provided that both of the following criteria are met:

- (1) The aggregate area of openings per room does not exceed 0.05 m² (0.55 ft²).
- (2) The openings are installed at or below half the distance from the floor to the room ceiling.

18.3.7* Subdivision of Building Spaces.

18.3.7.1 Buildings containing health care facilities shall be subdivided by smoke barriers, unless otherwise permitted by 18.3.7.2, as follows:

- (1) To divide every story used by inpatients for sleeping or treatment into not less than two smoke compartments
- (2) To divide every story having an occupant load of 50 or more persons, regardless of use, into not less than two smoke compartments
- (3) To limit the size of each smoke compartment required by (1) and (2) to an area not exceeding 2100 m² (22,500 ft²), unless the area is an atrium separated in accordance with 8.6.7, in which case no limitation in size is required
- (4) To limit the travel distance from any point to reach a door in the required smoke barrier to a distance not exceeding 61 m (200 ft)

18.3.7.2 The smoke barrier subdivision requirement of 18.3.7.1 shall not apply to the following:

- (1) Stories that do not contain a health care occupancy, located totally above the health care occupancy

- (2) Areas that do not contain a health care occupancy and that are separated from the health care occupancy by a fire barrier complying with 7.2.4.3
- (3) Stories that do not contain a health care occupancy and that are more than one story below the health care occupancy
- (4) Open-air parking structures protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7

18.3.7.3 Smoke barriers shall be provided on stories that are usable but unoccupied.

18.3.7.4 Any required smoke barrier shall be constructed in accordance with Section 8.5 and shall have a fire resistance rating of not less than 1 hour, unless otherwise permitted by the following:

- (1) This requirement shall not apply where an atrium is used, provided that both of the following criteria are met:
 - (a) Smoke barriers shall be permitted to terminate at an atrium wall constructed in accordance with 8.6.7(1)(c).
 - (b) Not less than two separate smoke compartments shall be provided on each floor.
- (2)*Smoke dampers shall not be required in duct penetrations of smoke barriers in fully ducted heating, ventilating, and air conditioning systems.

18.3.7.5 Materials and methods of construction used for required smoke barriers shall not reduce the required fire resistance rating.

18.3.7.6 Accumulation space shall be provided in accordance with 18.3.7.6.1 and 18.3.7.6.2.

18.3.7.6.1 Not less than 2.8 net m² (30 net ft²) per patient in a hospital or nursing home, or not less than 1.4 net m² (15 net ft²) per resident in a limited care facility, shall be provided within the aggregate area of corridors, patient rooms, treatment rooms, lounge or dining areas, and other low hazard areas on each side of the smoke barrier.

18.3.7.6.2 On stories not housing bed or litterborne patients, not less than 0.56 net m² (6 net ft²) per occupant shall be provided on each side of the smoke barrier for the total number of occupants in adjoining compartments.

18.3.7.7* Doors in smoke barriers shall be substantial doors, such as 44-mm (1¾-in.) thick, solid-bonded wood core doors, or shall be of construction that resists fire for not less than 20 minutes, and shall meet the following requirements:

- (1) Nonrated factory- or field-applied protective plates extending not more than 1220 mm (48 in.) above the bottom of the door shall be permitted.
- (2) Cross-corridor openings in smoke barriers shall be protected by a pair of swinging doors or a horizontal sliding door complying with 7.2.1.14.
- (3) Swinging doors shall be arranged so that each door swings in a direction opposite from the other.
- (4) The minimum clear width for swinging doors shall be as follows:
 - (a) Hospitals and nursing homes — 1055 mm (41½ in.)
 - (b) Psychiatric hospitals and limited care facilities — 810 mm (32 in.)
- (5) The minimum clear width opening for horizontal sliding doors shall be as follows:

- (a) Hospitals and nursing homes — 2110 mm (83 in.)
- (b) Psychiatric hospitals and limited care facilities — 1625 mm (64 in.)

18.3.7.8* Doors in smoke barriers shall comply with 8.3.4 and shall be self-closing or automatic-closing in accordance with 18.2.2.2.6.

18.3.7.9* Vision panels consisting of fire-rated glazing or wire glass panels in approved frames shall be provided in each cross-corridor swinging door and at each cross-corridor horizontal sliding door in a smoke barrier.

18.3.7.10 Rabbets, bevels, or astragals shall be required at the meeting edges, and stops shall be required at the head and sides of door frames in smoke barriers. Positive latching hardware shall not be required. Center mullions shall be prohibited.

18.3.8* Special Protection Features — Outside Window or Door.

18.3.8.1 Every patient sleeping room shall have an outside window or outside door.

- (1) This requirement shall not apply to newborn nurseries and rooms intended for occupancy for less than 24 hours, such as those housing obstetrical labor beds, recovery beds, and observation beds in the emergency department.
- (2) Windows in atrium walls shall be considered outside windows for the purposes of this requirement.

18.3.8.2 Where windows are required by 18.3.8.1, the allowable sill height shall not exceed 915 mm (36 in.) above the floor, unless otherwise permitted by the following:

- (1) The window sill in special nursing care areas, such as those housing ICU, CCU, hemodialysis, and neonatal patients, shall not exceed 1525 mm (60 in.) above the floor.
- (2) The window sill in limited care facilities shall not exceed 1120 mm (44 in.) above the floor.

18.4 Special Provisions.

18.4.1 Limited Access Buildings. Limited access buildings or limited access portions of buildings shall not be used for patient sleeping rooms and shall comply with Section 11.7.

18.4.2 High-Rise Buildings. High-rise buildings shall comply with Section 11.8.

18.4.3 Nonsprinklered Existing Smoke Compartment Rehabilitation.

18.4.3.1* General. Where a modification in a nonsprinklered smoke compartment is exempted by the provisions of 18.1.1.4.6.4 from the sprinkler requirement of 18.3.5.1, the requirements of 18.4.3.2 through 18.4.3.8 shall apply.

18.4.3.2 Minimum Construction Requirements (Nonsprinklered Smoke Compartment Rehabilitation). Health care occupancies in buildings not protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.2 shall be limited to the types of construction permitted by Table 18.4.3.2.

18.4.3.3 Capacity of Means of Egress (Nonsprinklered Smoke Compartment Rehabilitation). The capacity of the means of egress serving the modification area shall be as follows:

- (1) 13 mm (½ in.) per person for horizontal travel, without stairs, by means such as doors, ramps, or level floor surfaces
- (2) 15 mm (0.6 in.) per person for travel by means of stairs

Table 18.4.3.2 Construction Type Limitations (Nonsprinklered Buildings)

Construction Type	Stories			
	1	2	3	4 or more
I(443)	X	X	X	X
I(332)	X	X	X	X
II(222)	X	X	X	X
II(111)	X	NP	NP	NP
II(000)	NP	NP	NP	NP
III(211)	NP	NP	NP	NP
III(200)	NP	NP	NP	NP
IV(2HH)	NP	NP	NP	NP
V(111)	NP	NP	NP	NP
V(000)	NP	NP	NP	NP

X: Permitted type of construction.

NP: Not permitted.

18.4.3.4 Travel Distance (Nonsprinklered Smoke Compartment Rehabilitation).

18.4.3.4.1 The travel distance between any room door required as an exit access and an exit shall not exceed the following:

- (1) 46 m (150 ft) where the travel is wholly within smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.2
- (2) 30 m (100 ft) where the travel is not wholly within smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.2

18.4.3.4.2 The travel distance between any point in a room and an exit shall not exceed the following:

- (1) 61 m (200 ft) where the travel is wholly within smoke compartments protected throughout by an approved, supervised sprinkler system in accordance with 19.3.5.2
- (2) 46 m (150 ft) where the travel is not wholly within smoke compartments protected throughout by an approved, supervised sprinkler system in accordance with 19.3.5.2

18.4.3.5 Hazardous Area Protection (Nonsprinklered Smoke Compartment Rehabilitation). Where a new hazardous area is formed in an existing nonsprinklered smoke compartment, the hazardous area itself shall be protected as indicated in Table 18.4.3.5.

18.4.3.6 Interior Finish (Nonsprinklered Smoke Compartment Rehabilitation).

18.4.3.6.1 General. Interior finish within the modification area shall be in accordance with Section 10.2.

18.4.3.6.2 Interior Wall and Ceiling Finish. Newly installed interior wall and ceiling finish materials complying with Section 10.2 shall be permitted throughout nonsprinklered smoke compartments if the materials are Class A, except as otherwise permitted in 18.4.3.6.2.1 or 18.4.3.6.2.2.

18.4.3.6.2.1 Walls and ceilings shall be permitted to have Class A or Class B interior finish in individual rooms having a capacity not exceeding four persons.

Table 18.4.3.5 Hazardous Area Protection (Nonsprinklered Buildings)

Hazardous Area Description	Separation/Protection
Boiler and fuel-fired heater rooms	1 hour and sprinklers
Central/bulk laundries larger than 9.3 m ² (100 ft ²)	1 hour and sprinklers
Laboratories employing flammable or combustible materials in quantities less than those that would be considered a severe hazard	1 hour or sprinklers (Also see 18.4.3.7.2.2)
Laboratories that use hazardous materials that would be classified as a severe hazard in accordance with NFPA 99, <i>Standard for Health Care Facilities</i>	1 hour and sprinklers
Paint shops employing hazardous substances and materials in quantities less than those that would be classified as a severe hazard	1 hour and sprinklers
Physical plant maintenance shops	1 hour and sprinklers
Soiled linen rooms	1 hour and sprinklers
Storage rooms larger than 4.6 m ² (50 ft ²) but not exceeding 9.3 m ² (100 ft ²) and storing combustible material	1 hour or sprinklers (Also see 18.4.3.7.2.2)
Storage rooms larger than 9.3 m ² (100 ft ²) and storing combustible material	1 hour and sprinklers
Trash collection rooms	1 hour and sprinklers

18.4.3.6.2.2 Corridor wall finish not exceeding 1220 mm (48 in.) in height and restricted to the lower half of the wall shall be permitted to be Class A or Class B.

18.4.3.6.3 Interior Floor Finish.

18.4.3.6.3.1 Newly installed interior floor finish shall comply with Section 10.2.

18.4.3.6.3.2 The requirements for newly installed interior floor finish in exit enclosures and corridors not separated from them by walls complying with 19.3.6 shall be as follows:

- (1) Be unrestricted in smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.2
- (2) Be not less than Class I in smoke compartments not protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.2

18.4.3.7 Corridors (Nonsprinklered Smoke Compartment Rehabilitation).**18.4.3.7.1 Construction of Corridor Walls.**

18.4.3.7.1.1 Where the smoke compartment being modified is not protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.2, corridor walls shall comply with the following, as modified by 18.4.3.7.1.2:

- (1) Have a fire resistance rating of not less than ½ hour

- (2) Be continuous from the floor to the underside of the floor or roof deck above
- (3) Resist the passage of smoke

18.4.3.7.1.2 The requirements of 18.4.3.7.1.1 shall be permitted to be modified for conditions permitted by 19.3.6.1(3), 19.3.6.1(4), 19.3.6.1(6), 19.3.6.1(7), and 19.3.6.1(8).

18.4.3.7.2 Corridor Doors.

18.4.3.7.2.1 Where the smoke compartment being modified is not protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.2, the following shall apply:

- (1) Doors protecting corridor openings shall be constructed of 44-mm (1¾-in.) thick, solid-bonded core wood or of construction that resists the passage of fire for not less than 20 minutes.
- (2) Door frames shall be labeled or of steel construction.
- (3) Existing roller latches demonstrated to keep the door closed against a force of 22 N (5 lbf) shall be permitted.

18.4.3.7.2.2 Door-closing devices shall be required on doors in corridor wall openings serving smoke barriers or enclosures of exits, hazardous contents areas, or vertical openings.

18.4.3.8 Subdivision of Building Space (Nonsprinklered Smoke Compartment Rehabilitation). Subparagraph 18.3.7.4(2) shall be permitted only where adjacent smoke compartments are protected throughout by an approved, supervised automatic sprinkler system in accordance with 18.3.5.1 and 18.3.5.2.

18.5 Building Services.

18.5.1 Utilities.

18.5.1.1 Utilities shall comply with the provisions of Section 9.1.

18.5.1.2 Power for alarms, emergency communications systems, and illumination of generator set locations shall be in accordance with the essential electrical system requirements of NFPA 99, *Standard for Health Care Facilities*.

18.5.1.3 Any health care occupancy, as indicated in 18.1.1.1.2, that normally uses life-support devices shall have electrical systems designed and installed in accordance with NFPA 99, *Standard for Health Care Facilities*, unless the facility uses life-support equipment for emergency purposes only.

18.5.2 Heating, Ventilating, and Air Conditioning.

18.5.2.1 Heating, ventilating, and air conditioning shall comply with the provisions of Section 9.2 and shall be installed in accordance with the manufacturer's specifications, unless otherwise modified by 18.5.2.2.

18.5.2.2* Any heating device other than a central heating plant shall be designed and installed so that combustible material cannot be ignited by the device or its appurtenances, and the following requirements shall also apply.

- (1) If fuel-fired, such heating devices shall comply with the following:
 - (a) They shall be chimney connected or vent connected.
 - (b) They shall take air for combustion directly from outside.
 - (c) They shall be designed and installed to provide for complete separation of the combustion system from the atmosphere of the occupied area.

- (2) Any heating device shall have safety features to immediately stop the flow of fuel and shut down the equipment in case of either excessive temperatures or ignition failure.

18.5.2.3 The requirements of 18.5.2.2 shall not apply where otherwise permitted by the following:

- (1) Approved, suspended unit heaters shall be permitted in locations other than means of egress and patient sleeping areas, provided that both of the following criteria are met:
 - (a) Such heaters are located high enough to be out of the reach of persons using the area.
 - (b) Such heaters are equipped with the safety features required by 18.5.2.2.
- (2) Fireplaces shall be permitted and used only in areas other than patient sleeping areas, provided that all of the following criteria are met:
 - (a) Such areas are separated from patient sleeping spaces by construction having not less than a 1-hour fire resistance rating.
 - (b) Such fireplaces comply with the provisions of 9.2.2.
 - (c) The fireplace is equipped with the following:
 - i. A hearth that is raised not less than 100 mm (4 in.)
 - ii. A fireplace enclosure guaranteed against breakage up to a temperature of 343°C (650°F) and constructed of heat-tempered glass or other approved material
- (3) If, in the opinion of the authority having jurisdiction, special hazards are present, a lock on the enclosure specified in 18.5.2.3(2)(c)(ii) and other safety precautions shall be permitted to be required.

18.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

18.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes.

18.5.4.1 Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

18.5.4.2 Any rubbish chute or linen chute, including pneumatic rubbish and linen systems, shall be provided with automatic extinguishing protection in accordance with Section 9.7. (See Section 9.5.)

18.5.4.3 Any trash chute shall discharge into a trash collection room used for no other purpose and protected in accordance with Section 8.7.

18.5.4.4 Incinerators shall not be directly flue-fed, nor shall any floor-charging chute directly connect with the combustion chamber.

18.6 Reserved.

18.7* Operating Features.

18.7.1 Evacuation and Relocation Plan and Fire Drills.

18.7.1.1 The administration of every health care occupancy shall have, in effect and available to all supervisory personnel, written copies of a plan for the protection of all persons in the event of fire, for their evacuation to areas of refuge, and for their evacuation from the building when necessary.

18.7.1.2 All employees shall be periodically instructed and kept informed with respect to their duties under the plan required by 18.7.1.1.

18.7.1.3 A copy of the plan required by 18.7.1.1 shall be readily available at all times in the telephone operator's location or at the security center.

18.7.1.4* Fire drills in health care occupancies shall include the transmission of a fire alarm signal and simulation of emergency fire conditions.

18.7.1.5 Infirm or bedridden patients shall not be required to be moved during drills to safe areas or to the exterior of the building.

18.7.1.6 Drills shall be conducted quarterly on each shift to familiarize facility personnel (nurses, interns, maintenance engineers, and administrative staff) with the signals and emergency action required under varied conditions.

18.7.1.7 When drills are conducted between 9:00 p.m. (2100 hours) and 6:00 a.m. (0600 hours), a coded announcement shall be permitted to be used instead of audible alarms.

18.7.1.8 Employees of health care occupancies shall be instructed in life safety procedures and devices.

18.7.2 Procedure in Case of Fire.

18.7.2.1* Protection of Patients.

18.7.2.1.1 For health care occupancies, the proper protection of patients shall require the prompt and effective response of health care personnel.

18.7.2.1.2 The basic response required of staff shall include the following:

- (1) Removal of all occupants directly involved with the fire emergency
- (2) Transmission of an appropriate fire alarm signal to warn other building occupants and summon staff
- (3) Confinement of the effects of the fire by closing doors to isolate the fire area
- (4) Relocation of patients as detailed in the health care occupancy's fire safety plan

18.7.2.2 Fire Safety Plan. A written health care occupancy fire safety plan shall provide for the following:

- (1) Use of alarms
- (2) Transmission of alarm to fire department
- (3) Emergency phone call to fire department
- (4) Response to alarms
- (5) Isolation of fire
- (6) Evacuation of immediate area
- (7) Evacuation of smoke compartment
- (8) Preparation of floors and building for evacuation
- (9) Extinguishment of fire

18.7.2.3 Staff Response.

18.7.2.3.1 All health care occupancy personnel shall be instructed in the use of and response to fire alarms.

18.7.2.3.2 All health care occupancy personnel shall be instructed in the use of the code phrase to ensure transmission of an alarm under the following conditions:

- (1) When the individual who discovers a fire must immediately go to the aid of an endangered person
- (2) During a malfunction of the building fire alarm system

18.7.2.3.3 Personnel hearing the code announced shall first activate the building fire alarm using the nearest manual fire

alarm box, then shall execute immediately their duties as outlined in the fire safety plan.

18.7.3 Maintenance of Exits.

18.7.3.1 Proper maintenance shall be provided to ensure the dependability of the method of evacuation selected.

18.7.3.2 Health care occupancies that find it necessary to lock exits shall, at all times, maintain an adequate staff qualified to release locks and direct occupants from the immediate danger area to a place of safety in case of fire or other emergency.

18.7.4* Smoking. Smoking regulations shall be adopted and shall include not less than the following provisions:

- (1) Smoking shall be prohibited in any room, ward, or compartment where flammable liquids, combustible gases, or oxygen is used or stored and in any other hazardous location, and such areas shall be posted with signs that read NO SMOKING or shall be posted with the international symbol for no smoking.
- (2) In health care occupancies where smoking is prohibited and signs are prominently placed at all major entrances, secondary signs with language that prohibits smoking shall not be required.
- (3) Smoking by patients classified as not responsible shall be prohibited.
- (4) The requirement of 18.7.4(3) shall not apply where the patient is under direct supervision.
- (5) Ashtrays of noncombustible material and safe design shall be provided in all areas where smoking is permitted.
- (6) Metal containers with self-closing cover devices into which ashtrays can be emptied shall be readily available to all areas where smoking is permitted.

18.7.5 Furnishings, Bedding, and Decorations.

18.7.5.1* Draperies, curtains, and other loosely hanging fabrics and films serving as furnishings or decorations in health care occupancies shall be in accordance with the provisions of 10.3.1 (*see 18.3.5.6*), and the following also shall apply:

- (1) Such curtains shall include cubicle curtains.
- (2) Such curtains shall not include curtains at showers.

18.7.5.2 Newly introduced upholstered furniture within health care occupancies shall meet the criteria specified when tested in accordance with the methods cited in 10.3.2(2) and 10.3.3.

18.7.5.3 Reserved.

18.7.5.4 Newly introduced mattresses within health care occupancies shall meet the criteria specified when tested in accordance with the methods cited in 10.3.2(3) and 10.3.4.

18.7.5.5 Reserved.

18.7.5.6 Combustible decorations shall be prohibited in any health care occupancy unless one of the following criteria is met:

- (1) They are flame-retardant.
- (2) They are decorations, such as photographs and paintings, in such limited quantities that a hazard of fire development or spread is not present.

18.7.5.7 Soiled linen or trash collection receptacles shall not exceed 121 L (32 gal) in capacity and shall meet the following requirements:

- (1) The average density of container capacity in a room or space shall not exceed 20.4 L/m² (0.5 gal/ft²).

- (2) A capacity of 121 L (32 gal) shall not be exceeded within any 16-m² (64-ft²) area.
- (3) Mobile soiled linen or trash collection receptacles with capacities greater than 121 L (32 gal) shall be located in a room protected as a hazardous area when not attended.
- (4) Container size and density shall not be limited in hazardous areas.

18.7.6 Maintenance and Testing. See 4.6.13.

18.7.7* Engineered Smoke Control Systems.

18.7.7.1 New engineered smoke control systems shall be tested in accordance with established engineering principles and shall meet the performance requirements of such testing prior to acceptance.

18.7.7.2 Following acceptance, all engineered smoke control systems shall be tested periodically in accordance with recognized engineering principles.

18.7.7.3 Test documentation shall be maintained on the premises at all times.

18.7.8 Portable Space-Heating Devices. Portable space-heating devices shall be prohibited in all health care occupancies, unless both of the following criteria are met:

- (1) Such devices are permitted to be used only in nonsleeping staff and employee areas.
- (2) The heating elements of such devices do not exceed 100°C (212°F).

18.7.9 Construction, Repair, and Improvement Operations.

18.7.9.1 Construction, repair, and improvement operations shall comply with 4.6.11.

18.7.9.2 The means of egress in any area undergoing construction, repair, or improvements shall be inspected daily for compliance with 7.1.10.1 and shall also comply with NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*.

Chapter 19 Existing Health Care Occupancies

19.1 General Requirements.

19.1.1 Application.

19.1.1.1 General.

19.1.1.1.1* The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as health care occupancies, unless the authority having jurisdiction has determined equivalent safety has been provided in accordance with Section 1.4. (See also 18.1.1.1.1.)

19.1.1.1.2 The requirements established by this chapter shall apply to all existing hospitals, nursing homes, and limited care facilities. The term *hospital*, wherever used in this *Code*, shall include general hospitals, psychiatric hospitals, and specialty hospitals. The term *nursing home*, wherever used in this *Code*, shall include nursing and convalescent homes, skilled nursing facilities, intermediate care facilities, and infirmaries in homes for the aged. Where requirements vary, the specific subclass of health care occupancy is named in the paragraph pertaining thereto. The requirements established by Chapter 21 shall apply to all existing ambulatory health care facilities. The oper-

ating features requirements established by Section 19.7 shall apply to all health care occupancies.

19.1.1.1.3 The health care facilities regulated by this chapter shall be those that provide sleeping accommodations for their occupants and are occupied by persons who are mostly incapable of self-preservation because of age, because of physical or mental disability, or because of security measures not under the occupants' control.

19.1.1.1.4 Buildings, or sections of buildings, that primarily house patients who, in the opinion of the governing body of the facility and the governmental agency having jurisdiction, are capable of exercising judgment and appropriate physical action for self-preservation under emergency conditions shall be permitted to comply with chapters of the *Code* other than Chapter 19.

19.1.1.1.5 It shall be recognized that, in buildings housing certain types of patients or having detention rooms or a security section, it might be necessary to lock doors and bar windows to confine and protect building inhabitants. In such instances, the authority having jurisdiction shall make appropriate modifications to those sections of this *Code* that would otherwise require means of egress to be kept unlocked.

19.1.1.1.6 Buildings, or sections of buildings, that house older persons and that provide activities that foster continued independence but do not include services distinctive to health care occupancies (see 19.1.3) as defined in 3.3.152.7 shall be permitted to comply with the requirements of other chapters of this *Code*, such as Chapter 31 or Chapter 33.

19.1.1.1.7 Facilities that do not provide housing on a 24-hour basis for their occupants shall be classified as other occupancies and shall be covered by other chapters of this *Code*.

19.1.1.1.8* The requirements of this chapter are based on the assumption that staff is available in all patient-occupied areas to perform certain fire safety functions as required in other paragraphs of this chapter.

19.1.1.2* Goals and Objectives. The goals and objectives of Section 4.1 and Section 4.2 shall be met with due consideration for functional requirements, which are accomplished by limiting the development and spread of a fire emergency to the room of fire origin and reducing the need for occupant evacuation, except from the room of fire origin.

19.1.1.3 Total Concept.

19.1.1.3.1 All health care facilities shall be designed, constructed, maintained, and operated to minimize the possibility of a fire emergency requiring the evacuation of occupants.

19.1.1.3.2 Because the safety of health care occupants cannot be ensured adequately by dependence on evacuation of the building, their protection from fire shall be provided by appropriate arrangement of facilities, adequate staffing, and development of operating and maintenance procedures composed of the following:

- (1) Design, construction, and compartmentation
- (2) Provision for detection, alarm, and extinguishment
- (3) Fire prevention procedures and the planning, training, and drilling programs for the isolation of fire, transfer of occupants to areas of refuge, or evacuation of the building

19.1.1.4 Additions, Conversions, Modernization, Renovation, and Construction Operations.

19.1.1.4.1 Additions. Additions shall be separated from any existing structure not conforming to the provisions within Chapter 19 by a fire barrier having not less than a 2-hour fire resistance rating and constructed of materials as required for the addition. (See 4.6.12 and 4.6.7.)

19.1.1.4.2 Communicating openings in dividing fire barriers required by 19.1.1.4.1 shall be permitted only in corridors and shall be protected by approved self-closing fire door assemblies. (See also Section 8.3.)

19.1.1.4.3 Doors in barriers required by 19.1.1.4.1 shall normally be kept closed unless otherwise permitted by 19.1.1.4.4.

19.1.1.4.4 Doors shall be permitted to be held open if they meet the requirements of 19.2.2.2.6.

19.1.1.4.5 Changes of Occupancy. Changes of occupancy shall comply with 4.6.12, and the following also shall apply:

- (1) A change from one health care occupancy subclassification to another shall require compliance with the requirements for new construction.
- (2) A change from a hospital to a nursing home or from a nursing home to a hospital shall not be considered a change in occupancy or occupancy subclassification.
- (3) A change from a hospital or nursing home to a limited care facility shall not be considered a change in occupancy or occupancy subclassification.
- (4) A change from a hospital or nursing home to an ambulatory health care facility shall not be considered a change in occupancy or occupancy subclassification.

19.1.1.4.6 Rehabilitation.

19.1.1.4.6.1 For purposes of the provisions of this chapter, the following shall apply:

- (1) A major rehabilitation shall involve the modification of more than 50 percent, or more than 420 m² (4500 ft²), of the area of the smoke compartment.
- (2) A minor rehabilitation shall involve the modification of not more than 50 percent, and not more than 420 m² (4500 ft²), of the area of the smoke compartment.

19.1.1.4.6.2 Work that is exclusively plumbing, mechanical, fire protection system, electrical, medical gas, or medical equipment shall not be included in the computation of the modification area within the smoke compartment.

19.1.1.4.6.3* Where major rehabilitation is made in a non-sprinklered smoke compartment, the automatic sprinkler requirements of Chapter 18 shall apply to the smoke compartment undergoing the rehabilitation, and, in cases where the building is not protected throughout by an approved automatic sprinkler system, the requirements of 18.4.3.2 and 18.4.3.3(2) shall also apply.

19.1.1.4.6.4* Where minor rehabilitation is done in a non-sprinklered smoke compartment, the requirements of 18.3.5.1 shall not apply but, in such cases, the rehabilitation shall not reduce life safety below the level that previously existed or below the level of requirements of 18.4.3 for nonsprinklered smoke compartment rehabilitation. (See 4.6.8.)

19.1.1.4.7 Construction, Repair, and Improvement Operations. See 4.6.11.

19.1.2 Multiple Occupancies.

19.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

19.1.2.2* Sections of health care facilities shall be permitted to be classified as other occupancies, provided that they meet all of the following conditions:

- (1) They are not intended to serve health care occupants for purposes of housing, treatment, or customary access by patients incapable of self-preservation.
- (2) They are separated from areas of health care occupancies by construction having a fire resistance rating of not less than 2 hours.

19.1.2.3* Ambulatory care facilities, medical clinics, and similar facilities that are contiguous to health care occupancies but are primarily intended to provide outpatient services shall be permitted to be classified as business occupancies or ambulatory health care facilities, provided that the facilities are separated from the health care occupancy by not less than 2-hour fire resistance-rated construction and the facility is not intended to provide services simultaneously for four or more inpatients who are litterborne.

19.1.2.4 All means of egress from health care occupancies that traverse non-health care spaces shall conform to the requirements of this *Code* for health care occupancies, unless otherwise permitted by 19.1.2.5.

19.1.2.5 Exit through a horizontal exit into other contiguous occupancies that do not conform to health care egress provisions but that do comply with requirements set forth in the appropriate occupancy chapter of this *Code* shall be permitted, provided that both of the following criteria apply:

- (1) The occupancy does not contain high hazard contents.
- (2) The horizontal exit complies with the requirements of 19.2.2.5.

19.1.2.6 Egress provisions for areas of health care facilities that correspond to other occupancies shall meet the corresponding requirements of this *Code* for such occupancies, and, where the clinical needs of the occupant necessitate the locking of means of egress, staff shall be present for the supervised release of occupants during all times of use.

19.1.2.7 Auditoriums, chapels, staff residential areas, or other occupancies provided in connection with health care facilities shall have means of egress provided in accordance with other applicable sections of this *Code*.

19.1.2.8 Any area with a hazard of contents classified higher than that of the health care occupancy and located in the same building shall be protected as required by 19.3.2.

19.1.2.9 Non-health care-related occupancies classified as containing high hazard contents shall not be permitted in buildings housing health care occupancies.

19.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Ambulatory Health Care Occupancy.** See 3.3.152.1.
- (2) **Hospital.** See 3.3.112.
- (3) **Limited Care Facility.** See 3.3.69.2.
- (4) **Nursing Home.** See 3.3.110.2.

19.1.4 Classification of Occupancy. See 19.1.3.

19.1.5 Classification of Hazard of Contents. The classification of hazard of contents shall be as defined in Section 6.2.

19.1.6 Minimum Construction Requirements.

19.1.6.1 For the purpose of 19.1.6, the number of stories shall be counted starting with the primary level of exit discharge and ending with the highest occupiable level.

19.1.6.2 For the purposes of 19.1.6.1, the primary level of exit discharge of a building shall be the lowest story whose floor is level with or above finished grade on the exterior wall line for 50 percent or more of its perimeter.

19.1.6.3 For the purposes of 19.1.6.2, building levels below the primary level shall not be counted as a story.

19.1.6.4 Health care occupancies shall be limited to the types of building construction shown in Table 19.1.6.4, unless otherwise permitted by 19.1.6.5. (See 8.2.1.)

Table 19.1.6.4 Construction Type Limitations

Construction Type	Stories			
	1	2	3	4 or More
I(443)	X	X	X	X
I(332)	X	X	X	X
II(222)	X	X	X	X
II(111)	X	X*	X*	NP
II(000)	X*	X*	NP	NP
III(211)	X*	X*	NP	NP
III(200)	X*	NP	NP	NP
IV(2HH)	X*	X*	NP	NP
V(111)	X*	X*	NP	NP
V(000)	X*	NP	NP	NP

X: Permitted type of construction.

NP: Not permitted.

*Building requires automatic sprinkler protection. (See 19.3.5.1.)

19.1.6.5* Any building of Type I(443), Type I(332), Type II(222), or Type II(111) construction shall be permitted to include roofing systems involving combustible supports, decking, or roofing, provided that the following criteria are met:

- (1) The roof covering shall meet Class C requirements in accordance with NFPA 256, *Standard Methods of Fire Tests of Roof Coverings*.
- (2) The roof shall be separated from all occupied portions of the building by a noncombustible floor assembly that includes not less than 63 mm (2½ in.) of concrete or gypsum fill.
- (3) The attic or other space shall be either unoccupied or protected throughout by an approved automatic sprinkler system.

19.1.6.6 All interior walls and partitions in buildings of Type I or Type II construction shall be of noncombustible or limited-combustible materials, unless otherwise permitted by 19.1.6.7.

19.1.6.7* Listed, fire-retardant-treated wood studs shall be permitted within non-load-bearing 1-hour fire-rated partitions.

19.1.6.8 Each exterior wall of frame construction and all interior stud partitions shall be firestopped to cut off all concealed draft openings, both horizontal and vertical, between any cellar or basement and the first floor, and such firestop-

ping shall consist of wood not less than 51 mm (2 in.) (nominal) thick or shall be of noncombustible material.

19.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, either shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

19.2 Means of Egress Requirements.

19.2.1 General. Every aisle, passageway, corridor, exit discharge, exit location, and access shall be in accordance with Chapter 7, unless otherwise modified by 19.2.2 through 19.2.11.

19.2.2 Means of Egress Components.

19.2.2.1 Components of means of egress shall be limited to the types described in 19.2.2.2 through 19.2.2.10.

19.2.2.2 Doors.

19.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

19.2.2.2.2 Locks shall not be permitted on patient sleeping room doors, unless otherwise permitted by the following:

- (1) Key-locking devices that restrict access to the room from the corridor and that are operable only by staff from the corridor side shall be permitted, provided that such devices do not restrict egress from the room.
- (2) Door-locking arrangements shall be permitted in health care occupancies, or portions of health care occupancies, where the clinical needs of the patients require specialized security measures for their safety, provided that keys are carried by staff at all times.

19.2.2.2.3 Doors not located in a required means of egress shall be permitted to be subject to locking.

19.2.2.2.4 Doors within a required means of egress shall not be equipped with a latch or lock that requires the use of a tool or key from the egress side, unless otherwise permitted by the following:

- (1) Door-locking arrangements without delayed egress shall be permitted in health care occupancies, or portions of health care occupancies, where the clinical needs of the patients require specialized security measures for their safety, provided that staff can readily unlock such doors at all times. (See 19.1.1.1.5 and 19.2.2.2.5.)
- (2)*Delayed-egress locks complying with 7.2.1.6.1 shall be permitted, provided that not more than one such device is located in any egress path.
- (3) Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

19.2.2.2.5 Doors that are located in the means of egress and are permitted to be locked under other provisions of this chapter shall have adequate provisions made for the rapid removal of occupants by means such as the following:

- (1) Remote control of locks
- (2) Keying of all locks to keys carried by staff at all times
- (3) Other such reliable means available to the staff at all times

19.2.2.2.5.1 Only one such locking device as specified in 19.2.2.2.5 shall be permitted on each door.

19.2.2.2.5.2 Locks in accordance with 19.2.2.2.4(2) and 19.2.2.2.4(3) shall be permitted.

19.2.2.2.5.3 More than one lock shall be permitted on each door, subject to approval of the authority having jurisdiction.

19.2.2.2.6* Any door in an exit passageway, stairway enclosure, horizontal exit, smoke barrier, or hazardous area enclosure shall be permitted to be held open only by an automatic release device that complies with 7.2.1.8.2. The automatic sprinkler system, if provided, and the fire alarm system, and the systems required by 7.2.1.8.2 shall be arranged to initiate the closing action of all such doors throughout the smoke compartment or throughout the entire facility.

19.2.2.2.7 Where doors in a stair enclosure are held open by an automatic release device as permitted in 19.2.2.2.6, initiation of a door-closing action on any level shall cause all doors at all levels in the stair enclosure to close.

19.2.2.2.8* Existing health care occupancies shall be exempt from the re-entry provisions of 7.2.1.5.7.

19.2.2.2.9 Horizontal sliding doors, as permitted by 7.2.1.14, that are not automatic-closing shall be limited to a single leaf and shall have a latch or other mechanism that ensures that doors will not rebound into a partially open position if forcefully closed in an emergency.

19.2.2.3 Stairs. Stairs complying with 7.2.2 shall be permitted.

19.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

19.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 and the modifications of 19.2.2.5.1 through 19.2.2.5.4 shall be permitted.

19.2.2.5.1 Accumulation space shall be provided in accordance with 19.2.2.5.1.1 and 19.2.2.5.1.2.

19.2.2.5.1.1 Not less than 2.8 net m² (30 net ft²) per patient in a hospital or nursing home, or not less than 1.4 net m² (15 net ft²) per resident in a limited care facility, shall be provided within the aggregated area of corridors, patient rooms, treatment rooms, lounge or dining areas, and other similar areas on each side of the horizontal exit.

19.2.2.5.1.2 On stories not housing bed or litterborne patients, not less than 0.56 net m² (6 net ft²) per occupant shall be provided on each side of the horizontal exit for the total number of occupants in adjoining compartments.

19.2.2.5.2 The total egress capacity of the other exits (stairs, ramps, doors leading outside the building) shall not be reduced below one-third of that required for the entire area of the building.

19.2.2.5.3* A door in a horizontal exit shall not be required to swing with egress travel as specified in 7.2.4.3.7(1).

19.2.2.5.4 Door openings in horizontal exits shall be protected by one of the following methods:

- (1) Such door openings shall be protected by a swinging door providing a clear width of not less than 810 mm (32 in.).
- (2) Such door openings shall be protected by a horizontal sliding door that complies with 7.2.1.14 and provides a clear width of not less than 810 mm (32 in.).
- (3) Such door openings shall be protected by an existing 865-mm (34-in.) swinging door.

19.2.2.6 Ramps.

19.2.2.6.1 Ramps complying with 7.2.5 shall be permitted.

19.2.2.6.2 Ramps enclosed as exits shall be of sufficient width to provide egress capacity in accordance with 19.2.3.

19.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

19.2.2.8 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

19.2.2.9 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

19.2.2.10 Areas of Refuge. Areas of refuge used as part of a required accessible means of egress shall comply with 7.2.12.

19.2.3 Capacity of Means of Egress.

19.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

19.2.3.2 The capacity of means of egress providing travel by means of stairs shall be 15 mm (0.6 in.) per person, and the capacity of means of egress providing horizontal travel (without stairs) by means such as doors, ramps, or horizontal exits shall be 13 mm (½ in.) per person, unless otherwise permitted by 19.2.3.3.

19.2.3.3 The capacity of means of egress in health care occupancies protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.2 shall be 7.6 mm (0.3 in.) per person for travel by means of stairs and 5 mm (0.2 in.) per person for horizontal travel without stairs.

19.2.3.4* Any required aisle, corridor, or ramp shall be not less than 1220 mm (48 in.) in clear width where serving as means of egress from patient sleeping rooms, unless otherwise permitted by the following:

- (1) Aisles, corridors, and ramps in adjunct areas not intended for the housing, treatment, or use of inpatients shall be not less than 1120 mm (44 in.) in clear and unobstructed width.
- (2) Exit access within a room or suite of rooms complying with the requirements of 19.2.5 shall be permitted.

19.2.3.5 The aisle, corridor, or ramp shall be arranged to avoid any obstructions to the convenient removal of nonambulatory persons carried on stretchers or on mattresses serving as stretchers.

19.2.3.6 The minimum clear width for doors in the means of egress from hospitals; nursing homes; limited care facilities; psychiatric hospital sleeping rooms; and diagnostic and treatment areas, such as x-ray, surgery, or physical therapy, shall be not less than 810 mm (32 in.) wide.

19.2.3.7 The requirement of 19.2.3.6 shall not apply where otherwise permitted by the following:

- (1) Existing 865-mm (34-in.) doors shall be permitted.
- (2) Existing 710-mm (28-in.) corridor doors in facilities where the fire plans do not require evacuation by bed, gurney, or wheelchair shall be permitted.

19.2.4 Number of Exits.

19.2.4.1 Not less than two exits of the types described in 19.2.2.2 through 19.2.2.10, remotely located from each other, shall be provided for each floor or fire section of the building.

19.2.4.2 Not less than one exit from each floor or fire section shall be one of the following:

- (1) A door leading directly outside the building
- (2) A stair
- (3) A smokeproof enclosure
- (4) A ramp
- (5) An exit passageway

19.2.4.3 Any fire section not meeting the requirements of 19.2.4.2 shall be considered part of an adjoining zone through which egress shall not require return through the zone of fire origin.

19.2.4.4* Not less than two exits of the types described in 19.2.2.2 through 19.2.2.10 shall be accessible from each smoke compartment, and egress shall be permitted through an adjacent compartment(s) but shall not require return through the compartment of fire origin.

19.2.5 Arrangement of Means of Egress.

19.2.5.1 Every habitable room shall have an exit access door leading directly to an exit access corridor, unless otherwise permitted by the following:

- (1) The requirement of 19.2.5.1 shall not apply if there is an exit door opening directly to the outside from the room at ground level.
- (2) Exit access from a patient sleeping room with not more than eight patient beds shall be permitted to pass through one intervening room to reach the exit access corridor.
- (3) Exit access from a sleeping or nursing suite shall be permitted to pass through one intervening room to reach the exit access corridor where the arrangement allows for direct and constant visual supervision by nursing personnel.
- (4) Exit access from a suite of rooms, other than patient sleeping rooms, shall be permitted to pass through not more than two adjacent rooms to reach the exit access corridor where the travel distance within the suite is in accordance with 19.2.5.8.

19.2.5.2 Any patient sleeping room, or any suite that includes patient sleeping rooms, of more than 93 m² (1000 ft²) shall have not less than two exit access doors remotely located from each other.

19.2.5.3 Any room or any suite of rooms, other than patient sleeping rooms, of more than 232 m² (2500 ft²) shall have not less than two exit access doors remotely located from each other.

19.2.5.4 Any suite of rooms that complies with the requirements of 19.2.5 shall be permitted to be subdivided with non-fire-rated, noncombustible, or limited-combustible partitions.

19.2.5.5 Intervening rooms shall not be hazardous areas as defined by 19.3.2.

19.2.5.6 Suites of sleeping rooms shall not exceed 465 m² (5000 ft²).

19.2.5.7 Suites of rooms, other than patient sleeping rooms, shall not exceed 929 m² (10,000 ft²).

19.2.5.8 Suites of rooms, other than patient sleeping rooms, shall be permitted to have one intervening room if the travel distance within the suite to the exit access door does not exceed 30 m (100 ft) and shall be permitted to have two intervening rooms where the travel distance within the suite to the exit access door does not exceed 15 m (50 ft).

19.2.5.9 Every corridor shall provide access to not less than two approved exits in accordance with Section 7.4 and Section 7.5 without passing through any intervening rooms or spaces other than corridors or lobbies.

19.2.5.10* Existing dead-end corridors shall be permitted to continue in use if it is impractical and unfeasible to alter them so that exits are accessible in not less than two different directions from all points in aisles, passageways, and corridors.

19.2.6 Travel Distance to Exits.

19.2.6.1 Travel distance shall be measured in accordance with Section 7.6.

19.2.6.2 Travel distance shall comply with 19.2.6.2.1 through 19.2.6.2.6.

19.2.6.2.1 The travel distance between any room door required as an exit access and an exit shall not exceed 30 m (100 ft), unless otherwise permitted by 19.2.6.2.2.

19.2.6.2.2 The maximum travel distance specified in 19.2.6.2.1 shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3.

19.2.6.2.3 The travel distance between any point in a room and an exit shall not exceed 46 m (150 ft), unless otherwise permitted by 19.2.6.2.4.

19.2.6.2.4 The maximum travel distance specified in 19.2.6.2.3 shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3.

19.2.6.2.5 The travel distance between any point in a health care sleeping room and an exit access door in that room shall not exceed 15 m (50 ft).

19.2.6.2.6 The travel distance between any point in a suite of sleeping rooms as permitted by 19.2.5 and an exit access door of that suite shall not exceed 30 m (100 ft) and shall meet the requirements of 19.2.6.2.3 and 19.2.6.2.4.

19.2.7 Discharge from Exits. Discharge from exits shall be arranged in accordance with Section 7.7.

19.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

19.2.9 Emergency Lighting.

19.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9.

19.2.10 Marking of Means of Egress.

19.2.10.1 Means of egress shall have signs in accordance with Section 7.10, unless otherwise permitted by 19.2.10.2.

19.2.10.2 Where the path of egress travel is obvious, signs shall not be required in one-story buildings with an occupant load of fewer than 30 persons.

19.2.11 Special Means of Egress Features. (Reserved)

19.3 Protection.

19.3.1 Protection of Vertical Openings. Any vertical opening shall be enclosed or protected in accordance with Section 8.6, unless otherwise modified by 19.3.1.1 through 19.3.1.8.

19.3.1.1 Where enclosure is provided, the construction shall have not less than a 1-hour fire resistance rating.

19.3.1.2 Unprotected vertical openings in accordance with 8.6.8.2 shall be permitted.

19.3.1.3 Subparagraph 8.6.7(1)(b) shall not apply to patient sleeping and treatment rooms.

19.3.1.4 Multilevel patient sleeping areas in psychiatric facilities shall be permitted without enclosure protection between levels, provided that all of the following conditions are met:

- (1) The entire normally occupied area, including all communicating floor levels, is sufficiently open and unobstructed so that a fire or other dangerous condition in any part is obvious to the occupants or supervisory personnel in the area.
- (2) The egress capacity provides simultaneously for all the occupants of all communicating levels and areas, with all communicating levels in the same fire area being considered as a single floor area for purposes of determination of required egress capacity.
- (3) The height between the highest and lowest finished floor levels does not exceed 3960 mm (156 in.) and the number of levels is permitted to be unrestricted.

19.3.1.5 Unprotected openings in accordance with 8.6.6 shall not be permitted.

19.3.1.6 Where a full enclosure of a stairway that is not a required exit is impracticable, the required enclosure shall be permitted to be limited to that necessary to prevent a fire originating in any story from spreading to any other story.

19.3.1.7 A door in a stair enclosure shall be self-closing and shall normally be kept in the closed position, unless otherwise permitted by 19.3.1.8.

19.3.1.8 Doors in stair enclosures shall be permitted to be held open under the conditions specified by 19.2.2.2.6 and 19.2.2.2.7.

19.3.2 Protection from Hazards.

19.3.2.1 **Hazardous Areas.** Any hazardous areas shall be safeguarded by a fire barrier having a 1-hour fire resistance rating or shall be provided with an automatic extinguishing system in accordance with 8.7.1.

19.3.2.1.1 An automatic extinguishing system, where used in hazardous areas, shall be permitted to be in accordance with 19.3.5.5.

19.3.2.1.2 Where the sprinkler option of 19.3.2.1 is used, the areas shall be separated from other spaces by smoke-resisting partitions and doors.

19.3.2.1.3 The doors shall be self-closing or automatic-closing.

19.3.2.1.4 Doors in rated enclosures shall be permitted to have nonrated, factory- or field-applied protective plates extending not more than 1220 mm (48 in.) above the bottom of the door.

19.3.2.1.5 Hazardous areas shall include, but shall not be restricted to, the following:

- (1) Boiler and fuel-fired heater rooms
- (2) Central/bulk laundries larger than 9.3 m² (100 ft²)
- (3) Paint shops
- (4) Repair shops
- (5) Soiled linen rooms
- (6) Trash collection rooms

(7) Rooms or spaces larger than 4.6 m² (50 ft²), including repair shops, used for storage of combustible supplies and equipment in quantities deemed hazardous by the authority having jurisdiction

(8) Laboratories employing flammable or combustible materials in quantities less than those that would be considered a severe hazard

19.3.2.2* **Laboratories.** Laboratories employing quantities of flammable, combustible, or hazardous materials that are considered as a severe hazard shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

19.3.2.3 **Anesthetizing Locations.** Anesthetizing locations shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

19.3.2.4 **Medical Gas.** Medical gas storage and administration areas shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

19.3.2.5 Cooking Facilities.

19.3.2.5.1 Cooking facilities shall be protected in accordance with 9.2.3, unless otherwise permitted by 19.3.2.5.2.

19.3.2.5.2* Where domestic cooking equipment is used for food-warming or limited cooking, protection or separation of food preparation facilities shall not be required.

19.3.3 Interior Finish.

19.3.3.1 **General.** Interior finish shall be in accordance with Section 10.2.

19.3.3.2* **Interior Wall and Ceiling Finish.** Existing interior wall and ceiling finish materials complying with Section 10.2 shall be permitted to be Class A or Class B.

19.3.3.3 **Interior Floor Finish.** No restrictions shall apply to existing interior floor finish.

19.3.4 Detection, Alarm, and Communications Systems.

19.3.4.1 **General.** Health care occupancies shall be provided with a fire alarm system in accordance with Section 9.6.

19.3.4.2* Initiation.

19.3.4.2.1 Initiation of the required fire alarm systems shall be by manual means in accordance with 9.6.2 and by means of any required sprinkler system waterflow alarms, detection devices, or detection systems, unless otherwise permitted by 19.3.4.2.2 through 19.3.4.2.4.

19.3.4.2.2 Manual fire alarm boxes in patient sleeping areas shall not be required at exits if located at all nurses' control stations or other continuously attended staff location, provided that both of the following criteria are met:

- (1) Such manual fire alarm boxes are visible and continuously accessible.
- (2) Travel distances required by 9.6.2.4 are not exceeded.

19.3.4.2.3 Fixed extinguishing systems protecting commercial cooking equipment in kitchens that are protected by a complete automatic sprinkler system shall not be required to initiate the fire alarm system.

19.3.4.2.4 Detectors required by 19.7.5.3 and 19.7.5.5 shall not be required to initiate the fire alarm system.

19.3.4.3 Notification.

19.3.4.3.1 Occupant Notification. Occupant notification shall be accomplished automatically in accordance with 9.6.3, unless otherwise modified by the following:

- (1)*In lieu of audible alarm signals, visible alarm-indicating appliances shall be permitted to be used in critical care areas.
- (2) Where visual devices have been installed in patient sleeping areas in place of an audible alarm, they shall be permitted where approved by the authority having jurisdiction.

19.3.4.3.2 Emergency Forces Notification.

19.3.4.3.2.1 Fire department notification shall be accomplished in accordance with 9.6.4.

19.3.4.3.2.2 Smoke detection devices or smoke detection systems equipped with reconfirmation features shall not be required to automatically notify the fire department unless the alarm condition is reconfirmed after a period not exceeding 120 seconds.

19.3.4.4 Emergency Control. Operation of any activating device in the required fire alarm system shall be arranged to accomplish automatically any control functions to be performed by that device. (See 9.6.5.)

19.3.4.5 Detection.

19.3.4.5.1 Corridors. An approved automatic smoke detection system in accordance with Section 9.6 shall be installed in all corridors of limited care facilities, unless otherwise permitted by the following:

- (1) Where each patient sleeping room is protected by an approved smoke detection system, and a smoke detector is provided at smoke barriers and horizontal exits in accordance with Section 9.6, the corridor smoke detection system shall not be required on the patient sleeping room floors.
- (2) Smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3 shall be permitted.

19.3.4.5.2 Detection in Spaces Open to Corridors. See 19.3.6.1.

19.3.5 Extinguishment Requirements.

19.3.5.1 Where required by 19.1.6, health care facilities shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, unless otherwise permitted by 19.3.5.3.

19.3.5.2 In Type I and Type II construction, alternative protection measures shall be permitted to be substituted for sprinkler protection, without causing a building to be classified as nonsprinklered, in specified areas where the authority having jurisdiction has prohibited sprinklers.

19.3.5.3* Where this *Code* permits exceptions for fully sprinklered buildings or smoke compartments, the sprinkler system shall meet the following criteria:

- (1) It shall be in accordance with Section 9.7.
- (2) It shall be installed in accordance with 9.7.1.1(1) unless it is an approved existing system.
- (3) It shall be electrically connected to the fire alarm system.
- (4) It shall be fully supervised.

- (5) In Type I and Type II construction, where the authority having jurisdiction has prohibited sprinklers, approved alternative protection measures shall be permitted to be substituted for sprinkler protection in specified areas without causing a building to be classified as nonsprinklered.

19.3.5.4* Where this *Code* permits exceptions for fully sprinklered buildings or smoke compartments and specifically references this paragraph, the sprinkler system shall meet the following criteria:

- (1) It shall be installed throughout the building in accordance with Section 9.7.
- (2) It shall be installed in accordance with 9.7.1.1(1) unless it is an approved existing system.
- (3) It shall be electrically connected to the fire alarm system.
- (4) It shall be fully supervised.
- (5) It shall be equipped with listed quick-response or listed residential sprinklers throughout all smoke compartments containing patient sleeping rooms.
- (6) Standard response sprinklers shall be permitted to be continued to be used in approved existing sprinkler systems where quick-response and residential sprinklers were not listed for use in such locations at the time of installation.
- (7) Standard response sprinklers shall be permitted for use in hazardous areas protected in accordance with 19.3.2.1.

19.3.5.5 Isolated hazardous areas shall be permitted to be protected in accordance with 9.7.1.2. For new installations in existing health care occupancies, where more than two sprinklers are installed in a single area, waterflow detection shall be provided to sound the building fire alarm, or to notify by a signal any constantly attended location, such as PBX, security, or emergency room, at which the necessary corrective action shall be taken.

19.3.5.6* Newly introduced cubicle curtains in sprinklered areas shall be installed in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

19.3.5.7 Portable fire extinguishers shall be provided in all health care occupancies in accordance with 9.7.4.1.

19.3.6 Corridors.

19.3.6.1 Corridors shall be separated from all other areas by partitions complying with 19.3.6.2 through 19.3.6.5 (see also 19.2.5.9), unless otherwise permitted by the following:

- (1) Smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3 shall be permitted to have spaces that are unlimited in size and open to the corridor, provided that the following criteria are met:
 - (a) The spaces are not used for patient sleeping rooms, treatment rooms, or hazardous areas.
 - (b) The corridors onto which the spaces open in the same smoke compartment are protected by an electrically supervised automatic smoke detection system in accordance with 19.3.4, or the smoke compartment in which the space is located is protected throughout by quick-response sprinklers.
 - (c) The open space is protected by an electrically supervised automatic smoke detection system in accordance with 19.3.4, or the entire space is arranged and located to allow direct supervision by the facility staff from a nurses' station or similar space.
 - (d) The space does not obstruct access to required exits.

- (2) In smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3, waiting areas shall be permitted to be open to the corridor, provided that the following criteria are met:
 - (a) The aggregate waiting area in each smoke compartment does not exceed 55.7 m² (600 ft²).
 - (b) Each area is protected by an electrically supervised automatic smoke detection system in accordance with 19.3.4, or each area is arranged and located to allow direct supervision by the facility staff from a nursing station or similar space.
 - (c) The area does not obstruct access to required exits.
- (3)*This requirement shall not apply to spaces for nurses' stations.
- (4) Gift shops not exceeding 46.4 m² (500 ft²) shall be permitted to be open to the corridor or lobby, provided that one of the following is met:
 - (a) The building is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7
 - (b) The gift shop is protected throughout by an approved automatic sprinkler system in accordance with Section 9.7 and storage is separately protected.
- (5) Limited care facilities in smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3 shall be permitted to have group meeting or multipurpose therapeutic spaces open to the corridor, provided that the following criteria are met:
 - (a) The space is not a hazardous area.
 - (b) The space is protected by an electrically supervised automatic smoke detection system in accordance with 19.3.4, or the space is arranged and located to allow direct supervision by the facility staff from the nurses' station or similar location.
 - (c) The space does not obstruct access to required exits.
- (6) Spaces other than patient sleeping rooms, treatment rooms, and hazardous areas shall be permitted to be open to the corridor and unlimited in area, provided that the following criteria are met:
 - (a) The space and the corridors onto which it opens, where located in the same smoke compartment, are protected by an electrically supervised automatic smoke detection system in accordance with 19.3.4.
 - (b)*Each space is protected by automatic sprinklers, or the furnishings and furniture, in combination with all other combustibles within the area, are of such minimum quantity and arrangement that a fully developed fire is unlikely to occur.
 - (c) The space does not obstruct access to required exits.
- (7)*Waiting areas shall be permitted to be open to the corridor, provided that the following criteria are met:
 - (a) Each area does not exceed 55.7 m² (600 ft²).
 - (b) The area is equipped with an electrically supervised automatic smoke detection system in accordance with 19.3.4.
 - (c) The area does not obstruct any access to required exits.
- (8) Group meeting or multipurpose therapeutic spaces, other than hazardous areas, that are under continuous supervision by facility staff shall be permitted to be

open to the corridor, provided that the following criteria are met:

- (a) Each area does not exceed 139 m² (1500 ft²).
- (b) Not more than one such space is permitted per smoke compartment.
- (c) The area is equipped with an electrically supervised automatic smoke detection system in accordance with 19.3.4.
- (d) The area does not obstruct access to required exits.

19.3.6.2 Construction of Corridor Walls.

19.3.6.2.1 Corridor walls shall be continuous from the floor to the underside of the floor or roof deck above, through any concealed spaces, such as those above suspended ceilings, and through interstitial structural and mechanical spaces, unless otherwise permitted by 19.3.6.2.3 through 19.3.6.2.5.

19.3.6.2.2* Corridor walls shall have a fire resistance rating of not less than ½ hour.

19.3.6.2.3* In smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3, a corridor shall be permitted to be separated from all other areas by non-fire-rated partitions and shall be permitted to terminate at the ceiling where the ceiling is constructed to limit the transfer of smoke.

19.3.6.2.4 Existing corridor partitions shall be permitted to terminate at ceilings that are not an integral part of a floor construction if 1525 mm (5 ft) or more of space exists between the top of the ceiling subsystem and the bottom of the floor or roof above, provided that the following criteria are met:

- (1) The ceiling is part of a fire-rated assembly tested to have a fire resistance rating of not less than 1 hour in compliance with the provisions of Section 8.3.
- (2) The corridor partitions form smoketight joints with the ceilings (joint filler, if used, shall be noncombustible).
- (3) Each compartment of interstitial space that constitutes a separate smoke area is vented, in a smoke emergency, to the outside by mechanical means having the capacity to provide not less than two air changes per hour but, in no case, a capacity less than 2.35 m³/s (5000 ft³/min).
- (4) The interstitial space is not used for storage.
- (5) The space is not used as a plenum for supply, exhaust, or return air, except as noted in 19.3.6.2.4(3).

19.3.6.2.5* Existing corridor partitions shall be permitted to terminate at monolithic ceilings that resist the passage of smoke where there is a smoketight joint between the top of the partition and the bottom of the ceiling.

19.3.6.2.6* Corridor walls shall form a barrier to limit the transfer of smoke.

19.3.6.2.7 Fixed fire window assemblies in accordance with Section 8.3 shall be permitted in corridor walls, unless otherwise permitted in 19.3.6.2.8.

19.3.6.2.8 There shall be no restrictions in area and fire resistance of glass and frames in smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3.

19.3.6.3 Corridor Doors.

19.3.6.3.1* Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous

areas shall be doors constructed to resist the passage of smoke and shall be constructed of materials such as the following:

- (1) 44-mm (1¾-in.) thick, solid-bonded core wood
- (2) Construction that resists fire for not less than 20 minutes

19.3.6.3.2 The requirements of 19.3.6.3.1 shall not apply where otherwise permitted by the following:

- (1) Doors to toilet rooms, bathrooms, shower rooms, sink closets, and similar auxiliary spaces that do not contain flammable or combustible materials shall not be required to comply with 19.3.6.3.1.
- (2) In smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3, the door construction requirements of 19.3.6.3.1 shall not be mandatory, but the doors shall be constructed to resist the passage of smoke.

19.3.6.3.3 Compliance with NFPA 80, *Standard for Fire Doors and Fire Windows*, shall not be required.

19.3.6.3.4 Clearance between the bottom of the door and the floor covering not exceeding 25 mm (1 in.) shall be permitted for corridor doors.

19.3.6.3.5* Doors shall be provided with a means for keeping the door closed that is acceptable to the authority having jurisdiction, and the following requirements also shall apply:

- (1) The device used shall be capable of keeping the door fully closed if a force of 22 N (5 lbf) is applied at the latch edge of the door.
- (2) Roller latches shall be prohibited on corridor doors in buildings not fully protected by an approved automatic sprinkler system in accordance with 19.3.5.3.

19.3.6.3.6 The requirements of 19.3.6.3.5 shall not apply where otherwise permitted by the following:

- (1) Doors to toilet rooms, bathrooms, shower rooms, sink closets, and similar auxiliary spaces that do not contain flammable or combustible materials shall not be required to comply with 19.3.6.3.5.
- (2) Existing roller latches demonstrated to keep the door closed against a force of 22 N (5 lbf) shall be permitted to be kept in service.

19.3.6.3.7 Reserved.

19.3.6.3.8* Doors shall not be held open by devices other than those that release when the door is pushed or pulled.

19.3.6.3.9 Door-closing devices shall not be required on doors in corridor wall openings other than those serving required exits, smoke barriers, or enclosures of vertical openings and hazardous areas.

19.3.6.3.10* Nonrated, factory- or field-applied protective plates extending not more than 1220 mm (48 in.) above the bottom of the door shall be permitted.

19.3.6.3.11 Dutch doors shall be permitted where they conform to 19.3.6.3 and meet the following criteria:

- (1) Both the upper leaf and lower leaf are equipped with a latching device.
- (2) The meeting edges of the upper and lower leaves are equipped with an astragal, a rabbet, or a bevel.
- (3) Where protecting openings in enclosures around hazardous areas, the doors comply with NFPA 80, *Standard for Fire Doors and Fire Windows*.

19.3.6.3.12 Door frames shall be labeled, shall be of steel construction, or shall be of other materials in compliance with the provisions of Section 8.3, unless otherwise permitted by 19.3.6.3.13.

19.3.6.3.13 Door frames in smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3 shall not be required to comply with 19.3.6.3.12.

19.3.6.3.14 Fixed fire window assemblies in accordance with Section 8.3 shall be permitted in corridor doors.

19.3.6.3.15 Restrictions in area and fire resistance of glass and frames required by Section 8.3 shall not apply in smoke compartments protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3.

19.3.6.4 Transfer Grilles.

19.3.6.4.1 Transfer grilles, regardless of whether they are protected by fusible link-operated dampers, shall not be used in corridor walls or doors.

19.3.6.4.2 Doors to toilet rooms, bathrooms, shower rooms, sink closets, and similar auxiliary spaces that do not contain flammable or combustible materials shall be permitted to have ventilating louvers or to be undercut.

19.3.6.5 Openings.

19.3.6.5.1 Miscellaneous openings such as mail slots, pharmacy pass-through windows, laboratory pass-through windows, and cashier pass-through windows shall be permitted to be installed in vision panels or doors without special protection, provided that both of the following criteria are met:

- (1) The aggregate area of openings per room does not exceed 0.015 m² (0.14 ft²).
- (2) The openings are installed at or below half the distance from the floor to the room ceiling.

19.3.6.5.2 The alternative requirements of 19.3.6.5.1 shall not apply where otherwise modified by the following:

- (1) Openings in smoke compartments containing patient bedrooms shall not be permitted to be installed in vision panels or doors without special protection.
- (2) For rooms protected throughout by an approved, supervised automatic sprinkler system in accordance with 19.3.5.3, the aggregate area of openings per room shall not exceed 0.05 m² (0.55 ft²).

19.3.7 Subdivision of Building Spaces.

19.3.7.1 Smoke barriers shall be provided to divide every story used for sleeping rooms for more than 30 patients into not less than two smoke compartments, and the following also shall apply:

- (1) The size of any such smoke compartment shall not exceed 2100 m² (22,500 ft²), and the travel distance from any point to reach a door in the required smoke barrier shall not exceed 61 m (200 ft).
- (2) Where neither the length nor width of the smoke compartment exceeds 46 m (150 ft), the travel distance to reach the smoke barrier door shall not be limited.
- (3) The area of an atrium separated in accordance with 8.6.7 shall not be limited in size.

19.3.7.2 For purposes of the requirements of 19.3.7, the number of health care occupants shall be determined by actual count of patient bed capacity.

19.3.7.3 Any required smoke barrier shall be constructed in accordance with Section 8.5 and shall have a fire resistance rating of not less than ½ hour, unless otherwise permitted by the following:

- (1) This requirement shall not apply where an atrium is used, provided that both of the following criteria are met:
 - (a) Smoke barriers shall be permitted to terminate at an atrium wall constructed in accordance with 8.6.7(1)(c).
 - (b) Not less than two separate smoke compartments shall be provided on each floor.
- (2)*Smoke dampers shall not be required in duct penetrations of smoke barriers in fully ducted heating, ventilating, and air conditioning systems where an approved, supervised automatic sprinkler system in accordance with 19.3.5.4 has been provided for smoke compartments adjacent to the smoke barrier.

19.3.7.4 Accumulation space shall be provided in accordance with 19.3.7.4.1 and 19.3.7.4.2.

19.3.7.4.1 Not less than 2.8 net m² (30 net ft²) per patient in a hospital or nursing home, or not less than 1.4 net m² (15 net ft²) per resident in a limited care facility, shall be provided within the aggregate area of corridors, patient rooms, treatment rooms, lounge or dining areas, and other low hazard areas on each side of the smoke barrier.

19.3.7.4.2 On stories not housing bed or litterborne patients, not less than 0.56 net m² (6 net ft²) per occupant shall be provided on each side of the smoke barrier for the total number of occupants in adjoining compartments.

19.3.7.5 Openings in smoke barriers shall be protected using one of the following methods:

- (1) They shall be protected by fire-rated glazing.
- (2) They shall be protected by wired glass panels and steel frames.
- (3) They shall be protected by doors, such as 44-mm (1¾-in.) thick, solid-bonded wood core doors.
- (4) They shall be protected by construction that resists fire for not less than 20 minutes.

19.3.7.5.1* Nonrated factory- or field-applied protective plates extending not more than 1220 mm (48 in.) above the bottom of the door shall be permitted.

19.3.7.5.2 Doors shall be permitted to have fixed fire window assemblies in accordance with Section 8.3.

19.3.7.6* Doors in smoke barriers shall comply with Section 8.3 and shall be self-closing or automatic-closing in accordance with 19.2.2.2.6. Such doors in smoke barriers shall not be required to swing with egress travel. Positive latching hardware shall not be required.

19.3.7.7 Door openings in smoke barriers shall be protected using one of the following methods:

- (1) A swinging door providing a clear width of not less than 810 mm (32 in.)
- (2) A horizontal sliding door complying with 7.2.1.14 and providing a clear width of not less than 810 mm (32 in.)

19.3.7.8 The requirement of 19.3.7.7 shall not apply to existing 865-mm (34-in.) doors.

19.3.8* Special Protection Features — Outside Window or Door. Every patient sleeping room shall have an outside window or outside door, unless otherwise permitted by the following:

- (1) This requirement shall not apply to newborn nurseries and rooms intended for occupancy for less than 24 hours, such as those housing obstetrical labor beds, recovery beds, and observation beds in the emergency department.
- (2) Windows in atrium walls shall be considered outside windows for the purposes of this requirement.

19.4 Special Provisions.

19.4.1 Limited Access Buildings. See Section 11.7 for requirements for limited access buildings.

19.4.2 High-Rise Buildings. (Reserved)

19.5 Building Services.

19.5.1 Utilities.

19.5.1.1 Utilities shall comply with the provisions of Section 9.1.

19.5.1.2 Existing installations shall be permitted to be continued in service, provided that the systems do not present a serious hazard to life.

19.5.2 Heating, Ventilating, and Air Conditioning.

19.5.2.1 Heating, ventilating, and air conditioning shall comply with the provisions of Section 9.2 and shall be installed in accordance with the manufacturer's specifications, unless otherwise modified by 19.5.2.2.

19.5.2.2* Any heating device other than a central heating plant shall be designed and installed so that combustible material cannot be ignited by the device or its appurtenances, and the following requirements also shall apply:

- (1) If fuel-fired, such heating devices shall comply with the following:
 - (a) They shall be chimney connected or vent connected.
 - (b) They shall take air for combustion directly from the outside.
 - (c) They shall be designed and installed to provide for complete separation of the combustion system from the atmosphere of the occupied area.
- (2) Any heating device shall have safety features to immediately stop the flow of fuel and shut down the equipment in case of either excessive temperature or ignition failure.

19.5.2.3 The requirements of 19.5.2.2 shall not apply where otherwise permitted by the following:

- (1) Approved, suspended unit heaters shall be permitted in locations other than means of egress and patient sleeping areas, provided that both of the following criteria are met:
 - (a) Such heaters are located high enough to be out of the reach of persons using the area.
 - (b) Such heaters are equipped with the safety features required by 19.5.2.2.
- (2) Fireplaces shall be permitted and used only in areas other than patient sleeping areas, provided that all of the following criteria are met:
 - (a) Such areas are separated from patient sleeping spaces by construction having not less than a 1-hour fire resistance rating.
 - (b) Such fireplaces comply with the provisions of 9.2.2.
 - (c) The fireplace is equipped with a fireplace enclosure guaranteed against breakage up to a temperature of 343°C (650°F) and constructed of heat-tempered glass or other approved material.

- (3) If, in the opinion of the authority having jurisdiction, special hazards are present, a lock on the enclosure specified in 19.5.2.3(2)(c) and other safety precautions shall be permitted to be required.

19.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

19.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes.

19.5.4.1 Any existing linen and trash chute, including pneumatic rubbish and linen systems, that opens directly onto any corridor shall be sealed by fire-resistive construction to prevent further use or shall be provided with a fire door assembly having a fire protection rating of 1 hour. All new chutes shall comply with Section 9.5.

19.5.4.2 Any rubbish chute or linen chute, including pneumatic rubbish and linen systems, shall be provided with automatic extinguishing protection in accordance with Section 9.7. (See Section 9.5.)

19.5.4.3 Any trash chute shall discharge into a trash collection room used for no other purpose and protected in accordance with Section 8.7.

19.5.4.4 Existing flue-fed incinerators shall be sealed by fire-resistive construction to prevent further use.

19.6 Reserved.

19.7* Operating Features.

19.7.1 Evacuation and Relocation Plan and Fire Drills.

19.7.1.1 The administration of every health care occupancy shall have, in effect and available to all supervisory personnel, written copies of a plan for the protection of all persons in the event of fire, for their evacuation to areas of refuge, and for their evacuation from the building when necessary.

19.7.1.2 All employees shall be periodically instructed and kept informed with respect to their duties under the plan required by 19.7.1.1.

19.7.1.3 A copy of the plan required by 19.7.1.1 shall be readily available at all times in the telephone operator's location or at the security center.

19.7.1.4* Fire drills in health care occupancies shall include the transmission of a fire alarm signal and simulation of emergency fire conditions.

19.7.1.5 Infirm or bedridden patients shall not be required to be moved during drills to safe areas or to the exterior of the building.

19.7.1.6 Drills shall be conducted quarterly on each shift to familiarize facility personnel (nurses, interns, maintenance engineers, and administrative staff) with the signals and emergency action required under varied conditions.

19.7.1.7 When drills are conducted between 9:00 p.m. (2100 hours) and 6:00 a.m. (0600 hours), a coded announcement shall be permitted to be used instead of audible alarms.

19.7.1.8 Employees of health care occupancies shall be instructed in life safety procedures and devices.

19.7.2 Procedure in Case of Fire.

19.7.2.1* Protection of Patients.

19.7.2.1.1 For health care occupancies, the proper protection of patients shall require the prompt and effective response of health care personnel.

19.7.2.1.2 The basic response required of staff shall include the following:

- (1) Removal of all occupants directly involved with the fire emergency
- (2) Transmission of an appropriate fire alarm signal to warn other building occupants and summon staff
- (3) Confinement of the effects of the fire by closing doors to isolate the fire area
- (4) Relocation of patients as detailed in the health care occupancy's fire safety plan

19.7.2.2 Fire Safety Plan. A written health care occupancy fire safety plan shall provide for the following:

- (1) Use of alarms
- (2) Transmission of alarm to fire department
- (3) Emergency phone call to fire department
- (4) Response to alarms
- (5) Isolation of fire
- (6) Evacuation of immediate area
- (7) Evacuation of smoke compartment
- (8) Preparation of floors and building for evacuation
- (9) Extinguishment of fire

19.7.2.3 Staff Response.

19.7.2.3.1 All health care occupancy personnel shall be instructed in the use of and response to fire alarms.

19.7.2.3.2 All health care occupancy personnel shall be instructed in the use of the code phrase to ensure transmission of an alarm under the following conditions:

- (1) When the individual who discovers a fire must immediately go to the aid of an endangered person
- (2) During a malfunction of the building fire alarm system

19.7.2.3.3 Personnel hearing the code announced shall first activate the building fire alarm using the nearest manual fire alarm box, then shall execute immediately their duties as outlined in the fire safety plan.

19.7.3 Maintenance of Exits.

19.7.3.1 Proper maintenance shall be provided to ensure the dependability of the method of evacuation selected.

19.7.3.2 Health care occupancies that find it necessary to lock exits shall, at all times, maintain an adequate staff qualified to release locks and direct occupants from the immediate danger area to a place of safety in case of fire or other emergency.

19.7.4* Smoking. Smoking regulations shall be adopted and shall include not less than the following provisions:

- (1) Smoking shall be prohibited in any room, ward, or compartment where flammable liquids, combustible gases, or oxygen is used or stored and in any other hazardous location, and such areas shall be posted with signs that read NO SMOKING or shall be posted with the international symbol for no smoking.
- (2) In health care occupancies where smoking is prohibited and signs are prominently placed at all major entrances, secondary signs with language that prohibits smoking shall not be required.
- (3) Smoking by patients classified as not responsible shall be prohibited.
- (4) The requirement of 19.7.4(3) shall not apply where the patient is under direct supervision.

- (5) Ashtrays of noncombustible material and safe design shall be provided in all areas where smoking is permitted.
- (6) Metal containers with self-closing cover devices into which ashtrays can be emptied shall be readily available to all areas where smoking is permitted.

19.7.5 Furnishings, Bedding, and Decorations.

19.7.5.1* Draperies, curtains, and other loosely hanging fabrics and films serving as furnishings or decorations in health care occupancies shall be in accordance with the provisions of 10.3.1 (*see 19.3.5.6*), and the following also shall apply:

- (1) Such curtains shall include cubicle curtains.
- (2) Such curtains shall not include curtains at showers.

19.7.5.2 Newly introduced upholstered furniture within health care occupancies shall meet the criteria specified when tested in accordance with the methods cited in 10.3.2(2) and 10.3.3.

19.7.5.3 The requirement of 19.7.5.2 shall not apply to upholstered furniture belonging to the patient in sleeping rooms of nursing homes where the following criteria are met:

- (1) A smoke detector shall be installed in such rooms.
- (2) Battery-powered single-station smoke detectors shall be permitted.

19.7.5.4 Newly introduced mattresses within health care occupancies shall meet the criteria specified when tested in accordance with the methods cited in 10.3.2(3) and 10.3.4.

19.7.5.5 The requirement of 19.7.5.4 shall not apply to mattresses belonging to the patient in sleeping rooms of nursing homes where the following criteria are met:

- (1) A smoke detector shall be installed in such rooms.
- (2) Battery-powered, single-station smoke detectors shall be permitted.

19.7.5.6 Combustible decorations shall be prohibited in any health care occupancy unless one of the following criteria is met:

- (1) They are flame-retardant.
- (2) They are decorations such as photographs and paintings in such limited quantities that a hazard of fire development or spread is not present.

19.7.5.7 Soiled linen or trash collection receptacles shall not exceed 121 L (32 gal) in capacity, and the following also shall apply:

- (1) The average density of container capacity in a room or space shall not exceed 20.4 L/m² (0.5 gal/ft²).
- (2) A capacity of 121 L (32 gal) shall not be exceeded within any 6-m² (64-ft²) area.
- (3) Mobile soiled linen or trash collection receptacles with capacities greater than 121 L (32 gal) shall be located in a room protected as a hazardous area when not attended.
- (4) Container size and density shall not be limited in hazardous areas.

19.7.6 Maintenance and Testing. (*See 4.6.13.*)

19.7.7* Engineered Smoke Control Systems.

19.7.7.1 Existing engineered smoke control systems, unless specifically exempted by the authority having jurisdiction, shall be tested in accordance with established engineering principles.

19.7.7.2 Systems not meeting the performance requirements of such testing shall be continued in operation only with the specific approval of the authority having jurisdiction.

19.7.8 Portable Space-Heating Devices. Portable space-heating devices shall be prohibited in all health care occupancies, unless both of the following criteria are met:

- (1) Such devices are used only in nonsleeping staff and employee areas.
- (2) The heating elements of such devices do not exceed 100°C (212°F).

19.7.9 Construction, Repair, and Improvement Operations.

19.7.9.1 Construction, repair, and improvement operations shall comply with 4.6.11.

19.7.9.2 The means of egress in any area undergoing construction, repair, or improvements shall be inspected daily for compliance with 7.1.10.1 and shall also comply with NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*.

Chapter 20 New Ambulatory Health Care Occupancies

20.1 General Requirements.

20.1.1 Application.

20.1.1.1 General.

20.1.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as ambulatory health care occupancies (*see 1.3.1*)
- (2) Additions made to, or used as, an ambulatory health care occupancy (*see 4.6.7 and 20.1.1.4*), unless all of the following criteria are met:
 - (a) The addition is classified as an occupancy other than an ambulatory health care occupancy.
 - (b) The addition is separated from the ambulatory health care occupancy in accordance with 20.1.2.2.
 - (c) The addition conforms to the requirements for the specific occupancy.
- (3) Alterations, modernizations, or renovations of existing ambulatory health care occupancies (*see 4.6.8 and 20.1.1.4*)
- (4) Existing buildings or portions thereof upon change of occupancy to an ambulatory health care occupancy (*see 4.6.12*)

20.1.1.1.2 Ambulatory health care facilities shall comply with the provisions of Chapter 38 and this chapter, whichever is more stringent.

20.1.1.1.3 This chapter establishes life safety requirements, in addition to those required in Chapter 38, for the design of all ambulatory health care occupancies as defined in 3.3.152.1.

20.1.1.1.4 Buildings, or sections of buildings, that primarily house patients who, in the opinion of the governing body of the facility and the governmental agency having jurisdiction, are capable of exercising judgment and appropriate physical action for self-preservation under emergency conditions shall

be permitted to comply with chapters of this *Code* other than Chapter 20.

20.1.1.1.5 It shall be recognized that, in buildings providing treatment for certain types of patients or having detention rooms or a security section, it might be necessary to lock doors and bar windows to confine and protect building inhabitants. In such instances, the authority having jurisdiction shall make appropriate modifications to those sections of this *Code* that would otherwise require means of egress to be kept unlocked.

20.1.1.1.6* The requirements of this chapter are based on the assumption that staff is available in all patient-occupied areas to perform certain fire safety functions as required in other paragraphs of this chapter.

20.1.1.2* Goals and Objectives. The goals and objectives of Section 4.1 and Section 4.2 shall be met with due consideration for functional requirements, which are accomplished by limiting the development and spread of a fire emergency to the room of fire origin and reducing the need for occupant evacuation, except from the room of fire origin.

20.1.1.3 Total Concept.

20.1.1.3.1 All ambulatory health care facilities shall be designed, constructed, maintained, and operated to minimize the possibility of a fire emergency requiring the evacuation of occupants.

20.1.1.3.2 Because the safety of ambulatory health care occupants cannot be ensured adequately by dependence on evacuation of the building, their protection from fire shall be provided by appropriate arrangement of facilities, adequate, trained staff, and development of operating and maintenance procedures composed of the following:

- (1) Design, construction, and compartmentation
- (2) Provision for detection, alarm, and extinguishment
- (3) Fire prevention and the planning, training, and drilling programs for the isolation of fire, transfer of occupants to areas of refuge, or evacuation of the building

20.1.1.4 Additions, Conversions, Modernization, Renovation, and Construction Operations.

20.1.1.4.1 Additions.

20.1.1.4.1.1 Additions shall be separated from any existing structure not conforming to the provisions within Chapter 21 by a fire barrier having not less than a 2-hour fire resistance rating and constructed of materials as required for the addition. (See 4.6.4 and 4.6.7.)

20.1.1.4.1.2 Doors in barriers required by 20.1.1.4.1.1 shall normally be kept closed, unless otherwise permitted by 20.1.1.4.1.3.

20.1.1.4.1.3 Doors shall be permitted to be held open if they meet the requirements of 20.2.2.3.

20.1.1.4.2 Changes of Occupancy. A change from a hospital or nursing home to an ambulatory health care occupancy shall not be considered a change in occupancy or occupancy subclassification.

20.1.1.4.3 Renovations, Alterations, and Modernizations. (See 4.6.8.)

20.1.1.4.4 Construction, Repair, and Improvement Operations. (See 4.6.11.)

20.1.2 Multiple Occupancies.

20.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

20.1.2.2* Sections of ambulatory health care facilities shall be permitted to be classified as other occupancies, provided that they meet all of the following conditions:

- (1) They are not intended to serve ambulatory health care occupants for purposes of treatment or customary access by patients incapable of self-preservation.
- (2) They are separated from areas of ambulatory health care occupancies by construction having a fire resistance rating of not less than 1 hour.

20.1.2.3 All means of egress from ambulatory health care occupancies that traverse nonambulatory health care spaces shall conform to requirements of this *Code* for ambulatory health care occupancies, unless otherwise permitted by 20.1.2.4.

20.1.2.4 Exit through a horizontal exit into other contiguous occupancies that do not conform to ambulatory health care egress provisions but that do comply with requirements set forth in the appropriate occupancy chapter of this *Code* shall be permitted, provided that the occupancy does not contain high hazard contents.

20.1.2.5 Egress provisions for areas of ambulatory health care facilities that correspond to other occupancies shall meet the corresponding requirements of this *Code* for such occupancies, and, where the clinical needs of the occupant necessitate the locking of means of egress, staff shall be present for the supervised release of occupants during all times of use.

20.1.2.6 Any area with a hazard of contents classified higher than that of the ambulatory health care occupancy and located in the same building shall be protected as required in 20.3.2.

20.1.2.7 Non-health care-related occupancies classified as containing high hazard contents shall not be permitted in buildings housing ambulatory health care occupancies.

20.1.3 Definition: Ambulatory Health Care Occupancy. See 3.3.152.1.

20.1.4 Classification of Occupancy. (See 20.1.3.)

20.1.5 Classification of Hazard of Contents. The classification of hazard of contents shall be as defined in Section 6.2.

20.1.6 Minimum Construction Requirements.

20.1.6.1 For the purposes of 20.1.6, the number of stories shall be counted starting with the primary level of exit discharge and ending with the highest occupiable level used as an ambulatory health care facility.

20.1.6.2 For the purposes of 20.1.6.1, the primary level of exit discharge of a building shall be that floor that is level with or above finished grade of the exterior wall line for 50 percent or more of its perimeter.

20.1.6.3 Buildings of one story in height housing ambulatory health care facilities shall be of any construction type in accordance with NFPA 220, *Standard on Types of Building Construction*. (See 8.2.1.)

20.1.6.4 Buildings of two or more stories in height housing ambulatory health care facilities shall be of Type I(443), Type I(332), Type II(222), Type II(111), Type III(211), Type

IV(2HH), or Type V(111) construction (*see* 8.2.1), unless otherwise permitted by 20.1.6.5.

20.1.6.5 Buildings shall be permitted to be constructed of Type II(000), Type III(200), or Type V(000), if protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

20.1.6.6 Any level below the level of exit discharge shall be separated from the level of exit discharge by not less than Type II(111), Type III(211), or Type V(111) construction (*see* 8.2.1), unless both of the following criteria are met:

- (1) Such levels are under the control of the ambulatory health care facility.
- (2) Any hazardous spaces are protected in accordance with Section 8.4.

20.1.6.7 Where new ambulatory health care facilities are located in existing buildings, the authority having jurisdiction shall be permitted to accept construction systems of lesser fire resistance than that required by 20.1.6.3 through 20.1.6.6, provided that it can be demonstrated to the authority's satisfaction that prompt evacuation of the facility can be achieved in case of fire or that the exposing occupancies and materials of construction present no threat of fire penetration from such occupancy to the ambulatory health care facility or to the collapse of the structure.

20.1.6.8 All interior walls and partitions in buildings of Type I or Type II construction shall be of noncombustible or limited-combustible materials.

20.1.6.9 All buildings with more than one level below the level of exit discharge shall have all such lower levels separated from the level of exit discharge by not less than Type II(111) construction.

20.1.7 Occupant Load. (*See* 38.1.7.)

20.2 Means of Egress Requirements.

20.2.1 General. Every aisle, passageway, corridor, exit discharge, exit location, and access shall be in accordance with Chapter 7, unless otherwise modified by 20.2.2 through 20.2.11.

20.2.2 Means of Egress Components.

20.2.2.1 Components of means of egress shall be limited to the types described in 38.2.2.

20.2.2.2 Special locking arrangements complying with 7.2.1.6 shall be permitted.

20.2.2.3 Any door required to be self-closing shall be permitted to be held open only by an automatic release device that complies with 7.2.1.8.2. The required manual fire alarm system and the systems required by 7.2.1.8.2 shall be arranged to initiate the closing action of all such doors throughout the smoke compartment or throughout the entire facility.

20.2.2.4 Where doors in a stair enclosure are held open by an automatic release device as permitted in 20.2.2.3, initiation of a door-closing action on any level shall cause all doors at all levels in the stair enclosure to close.

20.2.3 Capacity of Means of Egress.

20.2.3.1 The capacity of any required means of egress shall be determined in accordance with the provisions of 38.2.3.

20.2.3.2 The clear width of any corridor or passageway required for exit access shall be not less than 1120 mm (44 in.).

20.2.3.3 Doors in the means of egress from diagnostic or treatment areas, such as x-ray, surgical, or physical therapy, shall provide a clear width of not less than 810 mm (32 in.).

20.2.4 Number of Exits.

20.2.4.1 Not less than two exits of the types described in 38.2.2 that are remotely located from each other shall be provided for each floor or fire section of the building.

20.2.4.2 Any room and any suite of rooms of more than 232 m² (2500 ft²) shall have not less than two exit access doors remotely located from each other.

20.2.4.3 Not less than two exits of the types described in 38.2.2 shall be accessible from each smoke compartment.

20.2.4.4 Egress from smoke compartments addressed in 20.2.4.3 shall be permitted through adjacent compartments but shall not require return through the compartment of fire origin.

20.2.5 Arrangement of Means of Egress. (*See* 38.2.5.)

20.2.6 Travel Distance to Exits.

20.2.6.1 Travel distance shall be measured in accordance with Section 7.6.

20.2.6.2 Travel distance shall be as follows:

- (1) The travel distance between any room door required as an exit access and an exit shall not exceed 30 m (100 ft).
- (2) The travel distance between any point in a room and an exit shall not exceed 46 m (150 ft).
- (3) The maximum travel distance in 20.2.6.2(1) or 20.2.6.2(2) shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

20.2.7 Discharge from Exits. (*See* 38.2.7.)

20.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

20.2.9 Emergency Lighting and Essential Electrical Systems.

20.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9.

20.2.9.2 Where general anesthesia or life-support equipment is used, each ambulatory health care facility shall be provided with an essential electrical system in accordance with NFPA 99, *Standard for Health Care Facilities*, unless otherwise permitted by the following:

- (1) Where battery-operated equipment is provided and acceptable to the authority having jurisdiction
- (2) Where a facility uses life-support equipment for emergency purposes only

20.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

20.2.11 Special Means of Egress Features. (Reserved)

20.3 Protection.

20.3.1 Protection of Vertical Openings. (*See* 38.3.1.)

20.3.2 Protection from Hazards. (See 38.3.2.)

20.3.2.1 Doors. Doors to hazardous areas shall be self-closing or automatic-closing in accordance with 20.2.2.3.

20.3.2.2 Laboratories. Laboratories employing quantities of flammable, combustible, or hazardous materials that are considered as a severe hazard shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

20.3.2.3 Anesthetizing Locations. Anesthetizing locations shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

20.3.2.4 Cooking Facilities. Cooking facilities shall be protected in accordance with 9.2.3 unless otherwise permitted by 20.3.2.5.

20.3.2.5 Domestic Cooking Equipment. Where domestic cooking equipment is used for food-warming or limited cooking, protection or separation of food preparation facilities shall not be required.

20.3.3 Interior Finish. (See 38.3.3.)**20.3.4 Detection, Alarm, and Communications Systems.**

20.3.4.1 General. Ambulatory health care facilities shall be provided with fire alarm systems in accordance with Section 9.6, except as modified by 20.3.4.2 through 20.3.4.5.

20.3.4.2 Initiation. Initiation of the required fire alarm systems shall be by manual means in accordance with 9.6.2 and by means of any detection devices or detection systems required.

20.3.4.3 Occupant Notification. Occupant notification shall be accomplished automatically, without delay, in accordance with 9.6.3 upon operation of any fire alarm activating device.

20.3.4.4 Emergency Forces Notification.

20.3.4.4.1 Fire department notification shall be accomplished in accordance with 9.6.4.

20.3.4.4.2 Smoke detection devices or smoke detection systems equipped with reconfirmation features shall not be required to automatically notify the fire department unless the alarm condition is reconfirmed after a period not exceeding 120 seconds.

20.3.4.5 Emergency Control Operation of any activating device in the required fire alarm system shall be arranged to accomplish automatically, without delay, any control functions required to be performed by that device. (See 9.6.5.)

20.3.5 Extinguishment Requirements. (See 38.3.5.)

20.3.5.1 Isolated hazardous areas shall be permitted to be protected in accordance with 9.7.1.2.

20.3.5.2 Where more than two sprinklers are installed in a single area for protection in accordance with 9.7.1.2, water-flow detection shall be provided to sound the building fire alarm or to notify, by a signal, any constantly attended location, such as PBX, security, or emergency room, at which the necessary corrective action shall be taken.

20.3.5.3 Portable fire extinguishers shall be provided in ambulatory health care facilities in accordance with 9.7.4.1.

20.3.6 Corridors.**20.3.6.1 General.** (See 38.3.6.)**20.3.6.2 Openings.**

20.3.6.2.1 Miscellaneous openings such as mail slots, pharmacy pass-through windows, laboratory pass-through windows, and cashier pass-through windows shall be permitted to be installed in vision panels or doors without special protection, provided that both of the following criteria are met:

- (1) The aggregate area of openings per room does not exceed 0.015 m^2 (0.14 ft^2).
- (2) The openings are installed at or below half the distance from the floor to the room ceiling.

20.3.6.2.2 For rooms protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7, the aggregate area of openings per room shall not exceed 0.05 m^2 (0.55 ft^2).

20.3.7 Subdivision of Building Space.

20.3.7.1 Ambulatory health care facilities shall be separated from other tenants and occupancies and shall meet the following requirements:

- (1) Walls shall have not less than a 1-hour fire resistance rating and shall extend from the floor slab below to the floor or roof slab above.
- (2) Doors shall be constructed of not less than 44-mm ($1\frac{3}{4}$ -in.) thick, solid-bonded wood core or the equivalent and shall be equipped with positive latches.
- (3) Doors shall be self-closing and shall be kept in the closed position except when in use.
- (4) Any windows in these barriers shall be of fixed fire window assemblies in accordance with Section 8.3.

20.3.7.2 Every story of an ambulatory health care facility shall be divided into not less than two smoke compartments, unless otherwise permitted by the following:

- (1) This requirement shall not apply to facilities of less than 465 m^2 (5000 ft^2) that are protected by an approved automatic smoke detection system.
- (2) This requirement shall not apply to facilities of less than 929 m^2 ($10,000 \text{ ft}^2$) that are protected throughout by an approved, supervised automatic sprinkler system installed in accordance with Section 9.7.
- (3) An area in an adjoining occupancy shall be permitted to serve as a smoke compartment for an ambulatory health care facility if the following criteria are met:
 - (a) The separating wall and both compartments meet the requirements of 20.3.7.
 - (b) The ambulatory health care facility is less than 2100 m^2 ($22,500 \text{ ft}^2$).
 - (c) Access from the ambulatory health care facility to the other occupancy is unrestricted.

20.3.7.3 Smoke compartments shall not exceed an area of 2100 m^2 ($22,500 \text{ ft}^2$) and the travel distance from any point to reach a door in a smoke barrier shall not exceed 61 m (200 ft).

20.3.7.4 The area of an atrium separated in accordance with 8.6.7 shall not be limited in size.

20.3.7.5 Any required smoke barrier shall be constructed in accordance with Section 8.5 and shall have a fire resistance rating of not less than 1 hour, unless otherwise permitted by 20.3.7.6.

20.3.7.6 Smoke dampers shall not be required in duct penetrations of smoke barriers in fully ducted heating, ventilating,

and air conditioning systems for buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

20.3.7.7 Windows in the smoke barrier shall be of fixed fire window assemblies in accordance with Section 8.3.

20.3.7.8 Not less than 1.4 net m² (15 net ft²) per ambulatory health care facility occupant shall be provided within the aggregate area of corridors, patient rooms, treatment rooms, lounges, and other low hazard areas on each side of the smoke compartment for the total number of occupants in adjoining compartments.

20.3.7.9* Doors in smoke barriers shall be not less than 44-mm (1¾-in.) thick, solid-bonded wood core or the equivalent and shall be self-closing or automatic-closing in accordance with 20.2.2.3.

20.3.7.10 Positive latching hardware shall not be required on smoke barrier cross-corridor doors.

20.3.7.11 A vision panel of fire-rated glazing or wire glass panels shall be required in smoke barrier cross-corridor doors.

20.3.7.12 Rabbits, bevels, or astragals shall be required at the meeting edges, and stops shall be required at the head and sides of door frames in smoke barriers.

20.3.7.13 Center mullions shall be prohibited in smoke barrier door openings.

20.4 Special Provisions. (See Section 38.4.)

20.5 Building Services.

20.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

20.5.2 Heating, Ventilating, and Air Conditioning.

20.5.2.1 Heating, ventilating, and air conditioning shall comply with the provisions of Section 9.2 and shall be installed in accordance with the manufacturer's specifications, unless otherwise modified by 20.5.2.2.

20.5.2.2 If fuel-fired, such heating devices shall comply with the following:

- (1) They shall be chimney connected or vent connected.
- (2) They shall take air for combustion directly from the outside.
- (3) They shall be designed and installed to provide for complete separation of the combustion system from the atmosphere of the occupied area.

20.5.2.2.1 Any heating device shall have safety features to immediately stop the flow of fuel and shut down the equipment in case of either excessive temperature or ignition failure.

20.5.2.2.2 Approved, suspended unit heaters shall be permitted in locations other than means of egress and patient treatment areas, provided that both of the following criteria are met:

- (1) Such heaters are located high enough to be out of the reach of persons using the area.
- (2) Such heaters are equipped with the safety features required by 20.5.2.2.1.

20.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

20.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

20.6 Reserved.

20.7* Operating Features.

20.7.1 Evacuation and Relocation Plan and Fire Drills.

20.7.1.1 The administration of every ambulatory health care facility shall have, in effect and available to all supervisory personnel, written copies of a plan for the protection of all persons in the event of fire, for their evacuation to areas of refuge, and for their evacuation from the building when necessary.

20.7.1.2 All employees shall be periodically instructed and kept informed with respect to their duties under the plan required by 20.7.1.1.

20.7.1.3 A copy of the plan required by 20.7.1.1 shall be readily available at all times in the telephone operator's location or at the security center.

20.7.1.4* Fire drills in ambulatory health care facilities shall include the transmission of a fire alarm signal and simulation of emergency fire conditions.

20.7.1.5 Patients shall not be required to be moved during drills to safe areas or to the exterior of the building.

20.7.1.6 Drills shall be conducted quarterly on each shift to familiarize facility personnel (nurses, interns, maintenance engineers, and administrative staff) with the signals and emergency action required under varied conditions.

20.7.1.7 When drills are conducted between 9:00 p.m. (2100 hours) and 6:00 a.m. (0600 hours), a coded announcement shall be permitted to be used instead of audible alarms.

20.7.1.8 Employees of ambulatory health care facilities shall be instructed in life safety procedures and devices.

20.7.2 Procedure in Case of Fire.

20.7.2.1* Protection of Patients.

20.7.2.1.1 For ambulatory health care facilities, the proper protection of patients shall require the prompt and effective response of ambulatory health care personnel.

20.7.2.1.2 The basic response required of staff shall include the following:

- (1) Removal of all occupants directly involved with the fire emergency
- (2) Transmission of an appropriate fire alarm signal to warn other building occupants and summon staff
- (3) Confinement of the effects of the fire by closing doors to isolate the fire area
- (4) Relocation of patients as detailed in the facility's fire safety plan

20.7.2.2 Fire Safety Plan. A written fire safety plan shall provide for the following:

- (1) Use of alarms
- (2) Transmission of alarm to fire department
- (3) Response to alarms
- (4) Isolation of fire
- (5) Evacuation of immediate area
- (6) Evacuation of smoke compartment
- (7) Preparation of floors and building for evacuation
- (8) Extinguishment of fire

20.7.2.3 Staff Response.

20.7.2.3.1 All personnel shall be instructed in the use of and response to fire alarms.

20.7.2.3.2 All health care personnel shall be instructed in the use of the code phrase to ensure transmission of an alarm under the following conditions:

- (1) When the individual who discovers a fire must immediately go to the aid of an endangered person
- (2) During a malfunction of the building fire alarm system

20.7.2.3.3 Personnel hearing the code announced shall first activate the building fire alarm using the nearest fire alarm box, then shall execute immediately their duties as outlined in the fire safety plan.

20.7.3 Maintenance of Exits.

20.7.3.1 Proper maintenance shall be provided to ensure the dependability of the method of evacuation selected.

20.7.3.2 Ambulatory health care occupancies that find it necessary to lock exits shall, at all times, maintain an adequate staff qualified to release locks and direct occupants from the immediate danger area to a place of safety in case of fire or other emergency.

20.7.4* Smoking. Smoking regulations shall be adopted and shall include not less than the following provisions:

- (1) Smoking shall be prohibited in any room, ward, or compartment where flammable liquids, combustible gases, or oxygen is used or stored and in any other hazardous location, and such areas shall be posted with signs that read NO SMOKING or shall be posted with the international symbol for no smoking.
- (2) In ambulatory health care facilities where smoking is prohibited and signs are placed at all major entrances, secondary signs with language that prohibits smoking shall not be required.
- (3) Smoking by patients classified as not responsible shall be prohibited.
- (4) The requirement of 20.7.4(3) shall not apply where the patient is under direct supervision.
- (5) Ashtrays of noncombustible material and safe design shall be provided in all areas where smoking is permitted.
- (6) Metal containers with self-closing cover devices into which ashtrays can be emptied shall be readily available to all areas where smoking is permitted.

20.7.5 Furnishings, Bedding, and Decorations.

20.7.5.1* Draperies, curtains, and other loosely hanging fabrics and films serving as furnishings or decorations in ambulatory health care occupancies shall be in accordance with the provisions of 10.3.1, and the following also shall apply:

- (1) Such curtains shall include cubicle curtains.
- (2) Such curtains shall not include curtains at showers.

20.7.5.2 Newly introduced upholstered furniture shall meet the criteria specified when tested in accordance with the methods cited in 10.3.2(2) and 10.3.3.

20.7.5.3 Newly introduced mattresses shall meet the criteria specified when tested in accordance with the methods cited in 10.3.2(3) and 10.3.4.

20.7.5.4 Combustible decorations shall be prohibited unless one of the following criteria is met:

- (1) They are flame-retardant.
- (2) They are decorations, such as photographs and paintings, in such limited quantities that a hazard of fire development or spread is not present.

20.7.5.5 Soiled linen or trash collection receptacles shall not exceed 121 L (32 gal) in capacity, and the following also shall apply:

- (1) The average density of container capacity in a room or space shall not exceed 20.4 L/m² (0.5 gal/ft²).
- (2) A capacity of 121 L (32 gal) shall not be exceeded within any 6-m² (64-ft²) area.
- (3) Mobile soiled linen or trash collection receptacles with capacities greater than 121 L (32 gal) shall be located in a room protected as a hazardous area when not attended.
- (4) Container size and density shall not be limited in hazardous areas.

20.7.6 Maintenance and Testing. (See 4.6.13.)**20.7.7* Engineered Smoke Control Systems.**

20.7.7.1 New engineered smoke control systems shall be tested in accordance with established engineering principles and shall meet the performance requirements of such testing prior to acceptance.

20.7.7.2 Following acceptance, all engineered smoke control systems shall be tested periodically in accordance with recognized engineering principles.

20.7.7.3 Test documentation shall be maintained on the premises at all times.

20.7.8 Portable Space-Heating Devices. Portable space-heating devices shall be prohibited in all ambulatory health care occupancies unless both of the following criteria are met:

- (1) Such devices are used only in nonsleeping staff and employee areas.
- (2) The heating elements of such devices do not exceed 100°C (212°F).

20.7.9 Construction, Repair, and Improvement Operations.

20.7.9.1 Construction, repair, and improvement operations shall comply with 4.6.11.

20.7.9.2 The means of egress in any area undergoing construction, repair, or improvements shall be inspected daily for compliance with 7.1.10.1 and shall also comply with NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*.

Chapter 21 Existing Ambulatory Health Care Occupancies

21.1 General Requirements.**21.1.1 Application.****21.1.1.1 General.**

21.1.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as an ambulatory health care occupancy. (See also 20.1.1.1.1.)

21.1.1.1.2 Ambulatory health care facilities shall comply with the provisions of Chapter 39 and this chapter, whichever is more stringent.

21.1.1.1.3 This chapter establishes life safety requirements, in addition to those required in Chapter 39, for the design of all ambulatory health care occupancies as defined in 3.3.152.1.

21.1.1.1.4 Buildings, or sections of buildings, that primarily house patients who, in the opinion of the governing body of the facility and the governmental agency having jurisdiction, are capable of exercising judgment and appropriate physical action for self-preservation under emergency conditions shall be permitted to comply with chapters of this *Code* other than Chapter 21.

21.1.1.1.5 It shall be recognized that, in buildings providing treatment for certain types of patients or having detention rooms or a security section, it might be necessary to lock doors and bar windows to confine and protect building inhabitants. In such instances, the authority having jurisdiction shall make appropriate modifications to those sections of this *Code* that would otherwise require means of egress to be kept unlocked.

21.1.1.1.6* The requirements of this chapter are based on the assumption that staff is available in all patient-occupied areas to perform certain fire safety functions as required in other paragraphs of this chapter.

21.1.1.2* Goals and Objectives. The goals and objectives of Section 4.1 and Section 4.2 shall be met with due consideration for functional requirements, which are accomplished by limiting the development and spread of a fire emergency to the room of fire origin and reducing the need for occupant evacuation, except from the room of fire origin.

21.1.1.3 Total Concept.

21.1.1.3.1 All ambulatory health care facilities shall be designed, constructed, maintained, and operated to minimize the possibility of a fire emergency requiring the evacuation of occupants.

21.1.1.3.2 Because the safety of ambulatory health care occupants cannot be ensured adequately by dependence on evacuation of the building, their protection from fire shall be provided by appropriate arrangement of facilities, adequate, trained staff, and development of operating and maintenance procedures composed of the following:

- (1) Design, construction, and compartmentation
- (2) Provision for detection, alarm, and extinguishment
- (3) Fire prevention and the planning, training, and drilling programs for the isolation of fire, transfer of occupants to areas of refuge, or evacuation of the building

21.1.1.4 Additions, Conversions, Modernization, Renovation, and Construction Operations.

21.1.1.4.1 Additions.

21.1.1.4.1.1 Additions shall be separated from any existing structure not conforming to the provisions within Chapter 21 by a fire barrier having not less than a 2-hour fire resistance rating and constructed of materials as required for the addition. (See 4.6.4 and 4.6.7.)

21.1.1.4.1.2 Doors in barriers required by 21.1.1.4.1.1 shall normally be kept closed, unless otherwise permitted by 21.1.1.4.1.3.

21.1.1.4.1.3 Doors shall be permitted to be held open if they meet the requirements of 21.2.2.3.

21.1.1.4.2 Changes of Occupancy. A change from a hospital or nursing home to an ambulatory health care occupancy shall not be considered a change in occupancy or occupancy subclassification.

21.1.1.4.3 Renovations, Alterations, and Modernizations. (See 4.6.8.)

21.1.1.4.4 Construction, Repair, and Improvement Operations. (See 4.6.11.)

21.1.2 Multiple Occupancies.

21.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

21.1.2.2* Sections of ambulatory health care facilities shall be permitted to be classified as other occupancies, provided that they meet all of the following conditions:

- (1) They are not intended to serve ambulatory health care occupants for purposes of treatment or customary access by patients incapable of self-preservation.
- (2) They are separated from areas of ambulatory health care occupancies by construction having a fire resistance rating of not less than 1 hour.

21.1.2.3 All means of egress from ambulatory health care occupancies that traverse nonambulatory health care spaces shall conform to the requirements of this *Code* for ambulatory health care occupancies, unless otherwise permitted by 21.1.2.4.

21.1.2.4 Exit through a horizontal exit into other contiguous occupancies that do not conform with ambulatory health care egress provisions but that do comply with requirements set forth in the appropriate occupancy chapter of this *Code* shall be permitted, provided that the occupancy does not contain high hazard contents.

21.1.2.5 Egress provisions for areas of ambulatory health care facilities that correspond to other occupancies shall meet the corresponding requirements of this *Code* for such occupancies, and where the clinical needs of the occupant necessitate the locking of means of egress, staff shall be present for the supervised release of occupants during all times of use.

21.1.2.6 Any area with a hazard of contents classified higher than that of the ambulatory health care occupancy and located in the same building shall be protected as required in 21.3.2.

21.1.2.7 Non-health-care-related occupancies classified as containing high hazard contents shall not be permitted in buildings housing ambulatory health care occupancies.

21.1.3 Definition: Ambulatory Health Care Occupancy. See 3.3.152.1.

21.1.4 Classification of Occupancy. (See 21.1.3.)

21.1.5 Classification of Hazard of Contents. The classification of hazard of contents shall be as defined in Section 6.2.

21.1.6 Minimum Construction Requirements.

21.1.6.1 For the purposes of 21.1.6, the number of stories shall be counted starting with the primary level of exit discharge and ending with the highest occupiable level used as an ambulatory health care facility.

21.1.6.2 For the purposes of 21.1.6.1, the primary level of exit discharge of a building shall be that floor that is level with or

above finished grade of the exterior wall line for 50 percent or more of its perimeter.

21.1.6.3 Buildings of one story in height housing ambulatory health care facilities shall be of any construction type in accordance with NFPA 220, *Standard on Types of Building Construction*. (See 8.2.1.)

21.1.6.4 Buildings of two or more stories in height housing ambulatory health care facilities shall be of Type I(443), Type I(332), Type II(222), Type II(111), Type III(211), Type IV(2HH), or Type V(111) construction (see 8.2.1), unless otherwise permitted by 21.1.6.5.

21.1.6.5 Buildings shall be permitted to be constructed of Type II(000), Type III(200), or Type V(000), if protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

21.1.6.6 Any level below the level of exit discharge shall be separated from the level of exit discharge by not less than Type II(111), Type III(211), or Type V(111) construction (see 8.2.1), unless both of the following criteria are met:

- (1) Such levels are under the control of the ambulatory health care facility.
- (2) Any hazardous spaces are protected in accordance with Section 8.7.

21.1.6.7 In existing buildings, the authority having jurisdiction shall be permitted to accept construction systems of lesser fire resistance than that required by 21.1.6.3 through 21.1.6.6, provided that it can be demonstrated to the authority's satisfaction that prompt evacuation of the facility can be achieved in case of fire or that the exposing occupancies and materials of construction present no threat of fire penetration from such occupancy to the ambulatory health care facility or to the collapse of the structure.

21.1.6.8 All interior walls and partitions in buildings of Type I or Type II construction shall be of noncombustible or limited-combustible materials.

21.1.6.9 All buildings with more than one level below the level of exit discharge shall have all such lower levels separated from the level of exit discharge by not less than Type II(111) construction.

21.1.7 Occupant Load. (See 39.1.7.)

21.2 Means of Egress Requirements.

21.2.1 General. Every aisle, passageway, corridor, exit discharge, exit location, and access shall be in accordance with Chapter 7, unless otherwise modified by 21.2.2 through 21.2.11.

21.2.2 Means of Egress Components.

21.2.2.1 Components of means of egress shall be limited to the types described in 39.2.2.

21.2.2.2 Special locking arrangements complying with 7.2.1.6 shall be permitted.

21.2.2.3 Any door required to be self-closing shall be permitted to be held open only by an automatic release device that complies with 7.2.1.8.2. The required manual fire alarm system and the systems required by 7.2.1.8.2 shall be arranged to initiate the closing action of all such doors throughout the smoke compartment or throughout the entire facility.

21.2.2.4 Where doors in a stair enclosure are held open by an automatic release device as permitted in 21.2.2.3, initiation of a door-closing action on any level shall cause all doors at all levels in the stair enclosure to close.

21.2.3 Capacity of Means of Egress.

21.2.3.1 The capacity of any required means of egress shall be determined in accordance with the provisions of 39.2.3.

21.2.3.2 The clear width of any corridor or passageway required for exit access shall be not less than 1120 mm (44 in.).

21.2.3.3 Doors in the means of egress from diagnostic or treatment areas, such as x-ray, surgical, or physical therapy, shall provide a clear width of not less than 810 mm (32 in.), unless such doors are existing 865-mm (34-in.) doors.

21.2.4 Number of Exits.

21.2.4.1 Not less than two exits of the types described in 39.2.2 that are remotely located from each other shall be provided for each floor or fire section of the building.

21.2.4.2 Any room and any suite of rooms of more than 232 m² (2500 ft²) shall have not less than two exit access doors remotely located from each other.

21.2.4.3 Not less than two exits of the types described in 39.2.2 shall be accessible from each smoke compartment.

21.2.4.4 Egress from smoke compartments addressed in 21.2.4.3 shall be permitted through adjacent compartments but shall not require return through the compartment of fire origin.

21.2.5 Arrangement of Means of Egress. (See 39.2.5.)

21.2.6 Travel Distance to Exits.

21.2.6.1 Travel distance shall be measured in accordance with Section 7.6.

21.2.6.2 Travel distance shall be as follows:

- (1) The travel distance between any room door required as an exit access and an exit shall not exceed 30 m (100 ft).
- (2) The travel distance between any point in a room and an exit shall not exceed 46 m (150 ft).
- (3) The maximum travel distance in 21.2.6.2(1) or 21.2.6.2(2) shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved automatic sprinkler system in accordance with Section 9.7.

21.2.7 Discharge from Exits. (See 39.2.7.)

21.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

21.2.9 Emergency Lighting and Essential Electrical Systems.

21.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9.

21.2.9.2 Where general anesthesia or life-support equipment is used, each ambulatory health care facility shall be provided with an essential electrical system in accordance with NFPA 99, *Standard for Health Care Facilities*, unless otherwise permitted by the following:

- (1) Where battery-operated equipment is provided and acceptable to the authority having jurisdiction
- (2) Where a facility uses life-support equipment for emergency purposes only

21.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

21.2.11 Special Means of Egress Features. (Reserved)

21.3 Protection.

21.3.1 Protection of Vertical Openings. (See 39.3.1.)

21.3.2 Protection from Hazards. (See 39.3.2.)

21.3.2.1 Doors. Doors to hazardous areas shall be self-closing or automatic-closing in accordance with 21.2.2.3.

21.3.2.2 Laboratories. Laboratories employing quantities of flammable, combustible, or hazardous materials that are considered as a severe hazard shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

21.3.2.3 Anesthetizing Locations. Anesthetizing locations shall be protected in accordance with NFPA 99, *Standard for Health Care Facilities*.

21.3.2.4 Cooking Facilities. Cooking facilities shall be protected in accordance with 9.2.3 unless otherwise permitted by 21.3.2.5.

21.3.2.5 Domestic Cooking Equipment. Where domestic cooking equipment is used for food-warming or limited cooking, protection or separation of food preparation facilities shall not be required.

21.3.3 Interior Finish. (See 39.3.3.)

21.3.4 Detection, Alarm, and Communications Systems.

21.3.4.1 General. Ambulatory health care facilities shall be provided with fire alarm systems in accordance with Section 9.6, except as modified by 21.3.4.2 through 21.3.4.5.

21.3.4.2 Initiation. Initiation of the required fire alarm systems shall be by manual means in accordance with 9.6.2 and by means of any detection devices or detection systems required.

21.3.4.3 Occupant Notification. Occupant notification shall be accomplished automatically, without delay, in accordance with 9.6.3, upon operation of any fire alarm activating device.

21.3.4.4 Emergency Forces Notification.

21.3.4.4.1 Fire department notification shall be accomplished in accordance with 9.6.4.

21.3.4.4.2 Smoke detection devices or smoke detection systems equipped with reconfirmation features shall not be required to automatically notify the fire department unless the alarm condition is reconfirmed after a period not exceeding 120 seconds.

21.3.4.5 Emergency Control. Operation of any activating device in the required fire alarm system shall be arranged to accomplish automatically, without delay, any control functions required to be performed by that device. (See 9.6.5.)

21.3.5 Extinguishment Requirements. (See 39.3.5.)

21.3.5.1 Isolated hazardous areas shall be permitted to be protected in accordance with 9.7.1.2.

21.3.5.2 For new installations in existing ambulatory health care facilities, where more than two sprinklers are installed in a single area for protection in accordance with 9.7.1.2, water-flow detection shall be provided to sound the building fire alarm or to notify, by a signal, any constantly attended loca-

tion, such as PBX, security, or emergency room, at which the necessary corrective action shall be taken.

21.3.5.3 Portable fire extinguishers shall be provided in ambulatory health care facilities in accordance with 9.7.4.1.

21.3.6 Corridors. (No requirements.)

21.3.7 Subdivision of Building Space.

21.3.7.1 Ambulatory health care facilities shall be separated from other tenants and occupancies and shall meet the following requirements:

- (1) Walls shall have not less than a 1-hour fire resistance rating and shall extend from the floor slab below to the floor or roof slab above.
- (2) Doors shall be constructed of not less than 44-mm (1¾-in.) thick, solid-bonded wood core or the equivalent and shall be equipped with positive latches.
- (3) Doors shall be self-closing and shall be kept in the closed position except when in use.
- (4) Any windows in these barriers shall be of fixed fire window assemblies in accordance with Section 8.3.

21.3.7.2 Every story of an ambulatory health care facility shall be divided into not less than two smoke compartments, unless otherwise permitted by the following:

- (1) This requirement shall not apply to facilities of less than 465 m² (5000 ft²) that are protected by an approved automatic smoke detection system.
- (2) This requirement shall not apply to facilities of less than 929 m² (10,000 ft²) that are protected throughout by an approved, supervised automatic sprinkler system installed in accordance with Section 9.7.
- (3) An area in an adjoining occupancy shall be permitted to serve as a smoke compartment for an ambulatory health care facility if the following criteria are met:
 - (a) The separating wall and both compartments meet the requirements of 21.3.7.
 - (b) The ambulatory health care facility is less than 2100 m² (22,500 ft²).
 - (c) Access from the ambulatory health care facility to the other occupancy is unrestricted.

21.3.7.3 Reserved.

21.3.7.4 Reserved.

21.3.7.5 Any required smoke barrier shall be constructed in accordance with Section 8.5 and shall have a fire resistance rating of not less than 1 hour, unless otherwise permitted by 21.3.7.6.

21.3.7.6 Smoke dampers shall not be required in duct penetrations of smoke barriers in fully ducted heating, ventilating, and air conditioning systems for buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.

21.3.7.7 Windows in the smoke barrier shall be of fixed fire window assemblies in accordance with Section 8.3.

21.3.7.8 Reserved.

21.3.7.9* Doors in smoke barriers shall be not less than 44-mm (1¾-in.) thick, solid-bonded wood core or the equivalent and shall be self-closing or automatic-closing in accordance with 20.2.2.3.

21.3.7.10 Positive latching hardware shall not be required on smoke barrier cross-corridor doors.

21.3.7.11 A vision panel of fire-rated glazing or wire glass panels shall be required in smoke barrier cross-corridor doors.

21.3.7.12 Reserved.

21.3.7.13 Reserved.

21.4 Special Provisions. (See Section 39.4.)

21.5 Building Services.

21.5.1 Utilities.

21.5.1.1 Utilities shall comply with the provisions of Section 9.1.

21.5.1.2 Existing installations shall be permitted to be continued in service, provided that the systems do not present a serious hazard to life.

21.5.2 Heating, Ventilating, and Air Conditioning.

21.5.2.1 Heating, ventilating, and air conditioning shall comply with the provisions of Section 9.2 and shall be in accordance with the manufacturer's specifications, unless otherwise modified by 21.5.2.2.

21.5.2.2 If fuel-fired, heating devices shall comply with the following:

- (1) They shall be chimney connected or vent connected.
- (2) They shall take air for combustion directly from the outside.
- (3) They shall be designed and installed to provide for complete separation of the combustion system from the atmosphere of the occupied area.

21.5.2.2.1 Any heating device shall have safety features to immediately stop the flow of fuel and shut down the equipment in case of either excessive temperature or ignition failure.

21.5.2.2.2 Approved, suspended unit heaters shall be permitted in locations other than means of egress and patient treatment areas, provided that both of the following criteria are met:

- (1) Such heaters are located high enough to be out of the reach of persons using the area.
- (2) Such heaters are equipped with the safety features required by 21.5.2.2.1.

21.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

21.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

21.6 Reserved.

21.7* Operating Features.

21.7.1 Evacuation and Relocation Plan and Fire Drills.

21.7.1.1 The administration of every ambulatory health care facility shall have, in effect and available to all supervisory personnel, written copies of a plan for the protection of all persons in the event of fire, for their evacuation to areas of refuge, and for their evacuation from the building when necessary.

21.7.1.2 All employees shall be periodically instructed and kept informed with respect to their duties under the plan required by 21.7.1.1.

21.7.1.3 A copy of the plan required by 21.7.1.1 shall be readily available at all times in the telephone operator's location or at the security center.

21.7.1.4* Fire drills in ambulatory health care facilities shall include the transmission of a fire alarm signal and simulation of emergency fire conditions.

21.7.1.5 Patients shall not be required to be moved during drills to safe areas or to the exterior of the building.

21.7.1.6 Drills shall be conducted quarterly on each shift to familiarize facility personnel (nurses, interns, maintenance engineers, and administrative staff) with the signals and emergency action required under varied conditions.

21.7.1.7 When drills are conducted between 9:00 p.m. (2100 hours) and 6:00 a.m. (0600 hours), a coded announcement shall be permitted to be used instead of audible alarms.

21.7.1.8 Employees of ambulatory health care facilities shall be instructed in life safety procedures and devices.

21.7.2 Procedure in Case of Fire.

21.7.2.1* Protection of Patients.

21.7.2.1.1 For ambulatory health care facilities, the proper protection of patients shall require the prompt and effective response of ambulatory health care personnel.

21.7.2.1.2 The basic response required of staff shall include the following:

- (1) Removal of all occupants directly involved with the fire emergency
- (2) Transmission of an appropriate fire alarm signal to warn other building occupants and summon staff
- (3) Confinement of the effects of the fire by closing doors to isolate the fire area
- (4) Relocation of patients as detailed in the facility's fire safety plan

21.7.2.2 Fire Safety Plan. A written fire safety plan shall provide for the following:

- (1) Use of alarms
- (2) Transmission of alarm to fire department
- (3) Response to alarms
- (4) Isolation of fire
- (5) Evacuation of immediate area
- (6) Evacuation of smoke compartment
- (7) Preparation of floors and building for evacuation
- (8) Extinguishment of fire

21.7.2.3 Staff Response.

21.7.2.3.1 All personnel shall be instructed in the use of and response to fire alarms.

21.7.2.3.2 All health care personnel shall be instructed in the use of the code phrase to ensure transmission of an alarm under the following conditions:

- (1) When the individual who discovers a fire must immediately go to the aid of an endangered person
- (2) During a malfunction of the building fire alarm system

21.7.2.3.3 Personnel hearing the code announced shall first activate the building fire alarm using the nearest fire alarm

box and then shall execute immediately their duties as outlined in the fire safety plan.

21.7.3 Maintenance of Exits.

21.7.3.1 Proper maintenance shall be provided to ensure the dependability of the method of evacuation selected.

21.7.3.2 Ambulatory health care occupancies that find it necessary to lock exits shall, at all times, maintain an adequate staff qualified to release locks and direct occupants from the immediate danger area to a place of safety in case of fire or other emergency.

21.7.4* Smoking. Smoking regulations shall be adopted and shall include not less than the following provisions:

- (1) Smoking shall be prohibited in any room, ward, or compartment where flammable liquids, combustible gases, or oxygen is used or stored and in any other hazardous location, and such areas shall be posted with signs that read NO SMOKING or shall be posted with the international symbol for no smoking.
- (2) In ambulatory health care facilities where smoking is prohibited and signs are placed at all major entrances, secondary signs with language that prohibits smoking shall not be required.
- (3) Smoking by patients classified as not responsible shall be prohibited.
- (4) The requirement of 21.7.4(3) shall not apply where the patient is under direct supervision.
- (5) Ashtrays of noncombustible material and safe design shall be provided in all areas where smoking is permitted.
- (6) Metal containers with self-closing cover devices into which ashtrays can be emptied shall be readily available to all areas where smoking is permitted.

21.7.5 Furnishings, Bedding, and Decorations.

21.7.5.1* Draperies, curtains and other loosely hanging fabrics and films serving as furnishings or decorations in ambulatory health care occupancies shall be in accordance with the provisions of 10.3.1, and the following also shall apply:

- (1) Such curtains shall include cubicle curtains.
- (2) Such curtains shall not include curtains at showers.

21.7.5.2 Newly introduced upholstered furniture shall meet the criteria specified when tested in accordance with the methods cited in 10.3.2(2) and 10.3.3.

21.7.5.3 Newly introduced mattresses shall meet the criteria specified when tested in accordance with the methods cited in 10.3.2(3) and 10.3.4.

21.7.5.4 Combustible decorations shall be prohibited unless one of the following criteria is met:

- (1) They are flame-retardant.
- (2) They are decorations, such as photographs and paintings, in such limited quantities that a hazard of fire development or spread is not present.

21.7.5.5 Soiled linen or trash collection receptacles shall not exceed 121 L (32 gal) in capacity, and the following also shall apply:

- (1) The average density of container capacity in a room or space shall not exceed 20.4 L/m² (0.5 gal/ft²).
- (2) A capacity of 121 L (32 gal) shall not be exceeded within any 6-m² (64-ft²) area.

- (3) Mobile soiled linen or trash collection receptacles with capacities greater than 121 L (32 gal) shall be located in a room protected as a hazardous area when not attended.
- (4) Container size and density shall not be limited in hazardous areas.

21.7.6 Maintenance and Testing. (See 4.6.13.)

21.7.7* Engineered Smoke Control Systems.

21.7.7.1 New engineered smoke control systems shall be tested in accordance with established engineering principles and shall meet the performance requirements of such testing prior to acceptance.

21.7.7.2 Following acceptance, all engineered smoke control systems shall be tested periodically in accordance with recognized engineering principles.

21.7.7.3 Test documentation shall be maintained on the premises at all times.

21.7.8 Portable Space-Heating Devices. Portable space-heating devices shall be prohibited in all ambulatory health care occupancies unless both of the following criteria are met:

- (1) Such devices are used only in nonsleeping staff and employee areas.
- (2) The heating elements of such devices do not exceed 100°C (212°F).

21.7.9 Construction, Repair, and Improvement Operations.

21.7.9.1 Construction, repair, and improvement operations shall comply with 4.6.11.

21.7.9.2 The means of egress in any area undergoing construction, repair, or improvements shall be inspected daily for compliance with 7.1.10.1 and shall also comply with NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*.

Chapter 22 New Detention and Correctional Occupancies

22.1 General Requirements.

22.1.1 Application.

22.1.1.1 General.

22.1.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as detention or correctional occupancies (*see 1.3.1*)
- (2) Additions made to, or used as, a detention or correctional occupancy (*see 4.6.7 and 22.1.1.3*)
- (3) Alterations, modernizations, or renovations of existing detention or correctional occupancies (*see 4.6.8 and 22.1.1.4*)
- (4) Existing buildings or portions thereof upon change of occupancy to a detention or correctional occupancy (*see 4.6.12*)

22.1.1.1.2 This chapter establishes life safety requirements for the design of all new detention and correctional facilities, other than the following:

- (1) Use Condition I facilities protected as residential occupancies in accordance with 22.1.4.3
- (2)*Facilities determined to have equivalent safety provided in accordance with Section 1.4.

22.1.1.1.3 Detention and correctional occupancies shall include those used for purposes such as correctional institutions, detention facilities, community residential centers, training schools, work camps, and substance abuse centers where occupants are confined or housed under some degree of restraint or security.

22.1.1.1.4 Detention and correctional occupancies shall include those that provide sleeping facilities for four or more residents and are occupied by persons who are generally prevented from taking self-preservation action because of security measures not under the occupants' control.

22.1.1.2 Total Concept.

22.1.1.2.1 All detention and correctional facilities shall be designed, constructed, maintained, and operated to minimize the possibility of a fire emergency.

22.1.1.2.2 Because the safety of all occupants in detention and correctional facilities cannot be adequately ensured solely by dependence on evacuation of the building, their protection from fire shall be provided by appropriate arrangement of facilities; adequate, trained staff; and development of operating, security, and maintenance procedures composed of the following:

- (1) Design, construction, and compartmentation
- (2) Provision for detection, alarm, and extinguishment
- (3) Fire prevention and planning, training, and drilling programs for the isolation of fire and the transfer of occupants to areas of refuge, for evacuation of the building, or for protection of the occupants in place
- (4) Provision of security to the degree necessary for the safety of the public and the occupants of the facility

22.1.1.3 Additions. Additions shall be separated from any existing structure not conforming with the provisions of Chapter 23 by a fire barrier having not less than a 2-hour fire resistance rating constructed to the requirements of the addition, and the following also shall apply:

- (1) Doors in such partitions shall normally be kept closed.
- (2) Doors in such partitions shall be permitted to be held open if they meet the requirements of 7.2.1.8.2.

22.1.1.4 Modernizations or Renovations.

22.1.1.4.1 Modernizations and renovations shall be in accordance with 4.6.8, unless otherwise permitted by 22.1.1.4.2.

22.1.1.4.2 In nonsprinklered existing buildings, modernizations or renovations shall be permitted to comply with the nonsprinklered options contained in 22.4.4 in lieu of the sprinkler requirement of 22.3.5.2.

22.1.2* Multiple Occupancies.

22.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

22.1.2.2 Egress provisions for areas of detention and correctional facilities that correspond to other occupancies shall meet the corresponding requirements of this *Code* for such occupancies as modified by 22.1.2.2.1 and 22.1.2.2.2.

22.1.2.2.1 Where security operations necessitate the locking of required means of egress, staff in the building shall be provided with a means for the supervised release of occupants during all times of use.

22.1.2.2.2* Where security operations necessitate the locking of required means of egress, the following shall apply:

- (1) Detention grade hardware, meeting ASTM F1577, *Standard Test Method for Detention Locks for Swinging Doors*, shall be provided on swinging doors within the required means of egress.
- (2) Sliding doors within the required means of egress shall be designed and engineered for detention and correctional use, and lock cylinders shall meet the cylinder test requirements of ASTM F 1577.

22.1.2.3 Sections of detention and correctional facilities shall be permitted to be classified as other occupancies, provided that they meet all of the following conditions:

- (1) They are not intended to serve residents for sleeping purposes.
- (2) They are separated from areas of detention or correctional occupancies by construction having not less than a 2-hour fire resistance rating.

22.1.2.4 All means of egress from detention and correctional occupancies that traverse other use areas shall, as a minimum, conform to the requirements of this *Code* for detention and correctional occupancies, unless otherwise permitted by 22.1.2.5.

22.1.2.5 Egress through a horizontal exit into other contiguous occupancies that do not conform with detention and correctional occupancy egress provisions but that do comply with requirements set forth in the appropriate occupancy chapter of this *Code* shall be permitted, provided that both of the following criteria apply:

- (1) The occupancy shall not contain high hazard contents.
- (2) The horizontal exit shall comply with the requirements of 22.2.2.5.

22.1.2.6 Any area with a hazard of contents classified higher than that of the detention or correctional occupancy and located in the same building shall be protected as required in 22.3.2.

22.1.2.7 Nondetention- or noncorrectional-related occupancies classified as containing high hazard contents shall not be permitted in buildings housing detention or correctional occupancies.

22.1.3 Definitions. The following terms are used in this chapter:

- (1) **Detention and Correctional Residential Housing Area.** See 3.3.16.1.
- (2) **Sally Port (Security Vestibule).** See 3.3.187.

22.1.4 Classification of Occupancy.

22.1.4.1* For application of the life safety requirements of this chapter, the resident user category shall be divided into the following five groups:

- (1) *Use Condition I — Free Egress.* Free movement is allowed from sleeping areas and other spaces where access or occupancy is permitted to the exterior via means of egress that meet the requirements of the *Code*.
- (2) *Use Condition II — Zoned Egress.* Free movement is allowed from sleeping areas and any other occupied smoke compartment to one or more other smoke compartments.
- (3) *Use Condition III — Zoned Impeded Egress.* Free movement is allowed within individual smoke compartments, such as

within a residential unit comprised of individual sleeping rooms and a group activity space, with egress impeded by remote-controlled release of means of egress from such a smoke compartment to another smoke compartment.

- (4) *Use Condition IV — Impeded Egress.* Free movement is restricted from an occupied space. Remote-controlled release is provided to allow movement from all sleeping rooms, activity spaces, and other occupied areas within the smoke compartment to another smoke compartment.
- (5) *Use Condition V — Contained.* Free movement is restricted from an occupied space. Staff-controlled manual release at each door is provided to allow movement from all sleeping rooms, activity spaces, and other occupied areas within the smoke compartment to another smoke compartment.

22.1.4.2* To be classified as Use Condition III or Use Condition IV, the arrangement, accessibility, and security of the release mechanism(s) used for emergency egress shall be such that the minimum available staff, at any time, can promptly release the locks.

22.1.4.3 Areas housing occupancies corresponding to Use Condition I shall conform to one of the following:

- (1) The requirements of residential occupancies under this Code.
- (2)*The requirements of this chapter for Use Condition II facilities, provided that the staffing requirements of Section 22.7 are met.

22.1.5 Classification of Hazard of Contents. The classification of hazard of contents shall be as defined in Section 6.2.

22.1.6 Minimum Construction Requirements.

22.1.6.1 For the purposes of 22.1.6, the number of stories shall be counted starting with the primary level of exit discharge.

22.1.6.2 For the purposes of 22.1.6.1, the primary level of exit discharge of a building shall be that floor that is level with or above finished grade on the exterior wall line for 50 percent or more of its perimeter.

22.1.6.3 For the purposes of 22.1.6.2, building levels below the primary level shall not be counted as a story in determining the height of the building.

22.1.6.4 Reserved.

22.1.6.5 Detention and correctional occupancies shall be limited to the types of building construction permitted by Table 22.1.6.5. (See 8.2.1.)

22.1.6.6 All interior walls and partitions in Type I or Type II construction shall be of noncombustible or limited-combustible materials.

22.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, either shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

22.2 Means of Egress Requirements.

22.2.1 General. Means of egress shall comply with Chapter 7, unless otherwise provided or modified by Section 22.2.

22.2.2 Means of Egress Components.

22.2.2.1 General. Components of means of egress shall be limited to the types described in 22.2.2.2 through 22.2.2.11.

22.2.2.2 Doors. Doors complying with 7.2.1 shall be permitted, unless otherwise provided by 22.2.11.

22.2.2.3 Stairs.

22.2.2.3.1 Stairs shall be permitted as follows:

- (1) Stairs complying with 7.2.2 shall be permitted.
- (2) Noncombustible grated stair treads and landing floors shall be permitted.

22.2.2.3.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted for access to and between staff locations.

22.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

22.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 and the modifications of 22.2.2.5.1 and 22.2.2.5.2 shall be permitted.

Table 22.1.6.5 Construction Type Limitations

Type of Construction	1 Story with Basement	1 Story without Basement	2 Stories	3 Stories	>3 Stories and Not High-Rise	High-Rise
I(443)	X	X	X	X	X	X
I(332)	X	X	X	X	X	X
II(222)	X	X	X	X	X	X
II(111)	X	X	X	NP	NP	NP
III(211)	X	X	X	NP	NP	NP
IV(2HH)	X	X	X	NP	NP	NP
V(111)	X	X	X	NP	NP	NP
II(000)	X	X	X	NP	NP	NP
III(200)	X	X	X	NP	NP	NP
V(000)	X	X	X	NP	NP	NP

X: Permitted types of construction.

NP: Not permitted.

22.2.2.5.1 Not less than 0.55 m² (6 ft²) of accessible space per occupant shall be provided on each side of the horizontal exit for the total number of people in adjoining compartments.

22.2.2.5.2* Horizontal exits shall be permitted to comprise 100 percent of the exits required, provided that an exit, other than a horizontal exit, located in another (not necessarily adjacent) fire compartment is accessible without returning through the compartment of fire origin.

22.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

22.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

22.2.2.8 Reserved.

22.2.2.9 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

22.2.2.10 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

22.2.2.11 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

22.2.3 Capacity of Means of Egress.

22.2.3.1 The capacity of any required means of egress shall be in accordance with Section 7.3.

22.2.3.2 Aisles, corridors, and ramps required for egress shall be not less than 1220 mm (48 in.) in width.

22.2.3.3 For residents' sleeping room door widths, see 22.2.11.3.

22.2.4 Number of Exits. (See also Section 7.4.)

22.2.4.1 Not less than two separate exits shall meet the following criteria:

- (1) They shall be provided on every story.
- (2) They shall be accessible from every part of every story, fire compartment, or smoke compartment; however, exit access travel shall be permitted to be common for the distances permitted as common path of travel by 22.2.5.3.

22.2.4.2 Not less than one approved exit shall be accessible from each fire compartment and each required smoke compartment into which residents are potentially moved in a fire emergency, with the exits arranged so that egress is possible without returning through the zone of fire origin.

22.2.5 Arrangement of Means of Egress. (See also Section 7.5.)

22.2.5.1 Every sleeping room shall have a door leading directly to an exit access corridor, unless otherwise permitted by the following:

- (1) The requirement of 22.2.5.1 shall not apply if there is an exit door opening directly to the outside from the room at ground level.
- (2) One adjacent room, such as a day room, group activity space, or other common space shall be permitted to intervene, and the following also shall apply:
 - (a) Where sleeping rooms directly adjoin a day room or group activity space that is used for access to an exit, such sleeping rooms shall be permitted to open directly to the day room or space.

- (b) Sleeping rooms permitted to open directly to the day room or space shall be permitted to be separated in elevation by a one-half or full story height. (See 22.4.4.6.)

22.2.5.2 No exit or exit access shall contain a corridor, hallway, or aisle having a pocket or dead end exceeding 15 m (50 ft) for Use Condition II, Use Condition III, or Use Condition IV and 6100 mm (240 in.) for Use Condition V.

22.2.5.3 A common path of travel shall not exceed 30 m (100 ft).

22.2.5.4 A sally port shall be permitted in a means of egress where there are provisions for continuous and unobstructed travel through the sally port during an emergency egress condition.

22.2.6 Travel Distance to Exits. Travel distance shall comply with 22.2.6.1 through 22.2.6.6.

22.2.6.1 The travel distance between any room door required as an exit access and an exit shall not exceed 46 m (150 ft).

22.2.6.2 Reserved.

22.2.6.3 The travel distance between any point in a room and an exit shall not exceed 61 m (200 ft).

22.2.6.4 Reserved.

22.2.6.5 The travel distance between any point in a sleeping room to the door in that room shall not exceed 15 m (50 ft), unless otherwise permitted by 22.2.6.6.

22.2.6.6 The maximum travel distance limitation of 22.2.6.5 shall be permitted to be increased to 30 m (100 ft) in open dormitories, provided the following criteria are met:

- (1) The enclosing walls of the dormitory space shall be of smoketight construction.
- (2) Not less than two exit access doors remotely located from each other shall be provided where travel distance to the exit access door from any point within the dormitory exceeds 15 m (50 ft).

22.2.7 Discharge from Exits.

22.2.7.1 Exits shall be permitted to discharge into a fenced or walled courtyard, provided that not more than two walls of the courtyard are the building walls from which egress is being made.

22.2.7.2 Enclosed yards or courts used for exit discharge in accordance with 22.2.7.1 shall be of sufficient size to accommodate all occupants at a distance of not less than 15 m (50 ft) from the building while providing a net area of 1.4 m² (15 ft²) per person.

22.2.7.3 All exits shall be permitted to discharge through the level of exit discharge.

22.2.7.4 The requirements of 7.7.2 shall be waived, provided that not more than 50 percent of the exits discharge into a single fire compartment separated from other compartments by construction having not less than a 1-hour fire resistance rating.

22.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

22.2.9 Emergency Lighting. Emergency lighting shall be provided in accordance with Section 7.9.

22.2.10 Marking of Means of Egress. Exit marking shall be provided as follows:

- (1) Exit signs shall be provided in areas accessible to the public in accordance with Section 7.10.
- (2) Exit signs shall not be required in detention and correctional residential housing areas. (*See Detention and Correctional Residential Housing Area in 3.3.16.1.*)

22.2.11 Special Features.

22.2.11.1 Doors within means of egress shall be in accordance with Chapter 7, unless otherwise provided in 22.2.11.2 through 22.2.11.11.

22.2.11.2 Doors shall be permitted to be locked in accordance with the applicable use condition.

22.2.11.3* Doors to resident sleeping rooms shall be not less than 710 mm (28 in.) in clear width.

22.2.11.4 Reserved.

22.2.11.5 Doors in a means of egress shall be permitted to be of the horizontal sliding type, provided that the force necessary to slide the door to its fully open position does not exceed 222 N (50 lbf) where a force of 222 N (50 lbf) is simultaneously applied perpendicular to the door.

22.2.11.6 Doors from areas of refuge to the exterior shall be permitted to be locked with key locks in lieu of locking methods described in 22.2.11.7, and the keys to unlock such doors shall be maintained and available at the facility at all times, and the locks shall be operable from the outside.

22.2.11.7* Any remote-control release used in a means of egress shall be provided with a reliable means of operation to release locks on all doors and shall be remotely located from the resident living areas, unless otherwise permitted by 22.2.11.7.2.

22.2.11.7.1 The remote location of a remote-control release used in a means of egress shall provide sight and sound supervision of the resident living areas.

22.2.11.7.2 Remote-control locking and unlocking of occupied rooms in Use Condition IV shall not be required, provided that both of the following criteria are met:

- (1) Not more than 10 locks need to be unlocked to relocate all occupants from one smoke compartment to an area of refuge as promptly as is required where remote-control unlocking is used. (*See 22.3.7.9 for requirements for smoke barrier doors.*)
- (2) Unlocking of all necessary locks shall be accomplished with not more than two separate keys.

22.2.11.8 All remote-control release-operated doors shall be provided with a redundant means of operation as follows:

- (1) Power-operated sliding doors or power-operated locks shall be constructed so that, in the event of power failure, a manual mechanical means to release and open the doors is provided at each door, and either emergency power arranged in accordance with 7.9.2.2 is provided for the power operation or a remote-control manual mechanical release is provided.
- (2) Mechanically operated sliding doors or mechanically operated locks shall be provided with a manual mechanical means at each door to release and open the door.

22.2.11.9 The provisions of 7.2.1.5.7 for stairway re-entry shall not apply.

22.2.11.10 Doors unlocked by means of remote control under emergency conditions shall not automatically relock when closed unless specific action is taken at the remote-control location to enable doors to relock.

22.2.11.11 Emergency power shall be provided for all electrically power-operated sliding doors and power-operated locks, unless otherwise permitted by 22.2.11.11.2.

22.2.11.11.1 The emergency power shall be arranged to automatically operate within 10 seconds upon failure of normal power and to maintain the necessary power source for not less than 1½ hours.

22.2.11.11.2 The emergency power specified in 22.2.11.11 shall not be required in facilities with 10 or fewer locks complying with 22.2.11.7.2.

22.3 Protection.

22.3.1 Protection of Vertical Openings. Any vertical opening shall be enclosed or protected in accordance with Section 8.6, unless otherwise permitted by the following:

- (1) Unprotected vertical openings in accordance with 8.6.8.2 shall be permitted.
- (2)*In residential housing area smoke compartments, unprotected vertical openings shall be permitted in accordance with the conditions of 8.6.6, provided that the height between the lowest and highest finished floor levels does not exceed 7010 mm (276 in.), and the following also shall be permitted:
 - (a) The number of levels shall not be restricted.
 - (b) Residential housing areas subdivided in accordance with 22.3.8 shall be permitted to be considered as part of the communicating space.
 - (c) The separation shall not be required to have a fire resistance rating. [*See 8.6.6(4)(b).*]

22.3.2 Protection from Hazards.

22.3.2.1* Any hazardous area shall be protected in accordance with Section 8.7. The areas described in Table 22.3.2.1 shall be protected as indicated.

22.3.2.2 Hazardous areas determined by the authority having jurisdiction as not incidental to residents' housing shall be separated by 2-hour fire resistance-rated barriers in conjunction with automatic sprinkler protection.

22.3.2.3 Where cooking facilities are protected in accordance with 9.2.3, kitchens shall not be required to be provided with roomwide protection.

22.3.3 Interior Finish.

22.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

22.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in corridors, in exits, and in any space not separated from corridors and exits by partitions capable of retarding the passage of smoke; and Class A, Class B, or Class C in all other areas. The provisions of 10.2.8.2 shall not apply.

22.3.3.3 Interior Floor Finish.

22.3.3.3.1 Interior floor finish shall comply with Section 10.2.

22.3.3.3.2 Interior floor finish in exit enclosures and exit access corridors shall be not less than Class II. The provisions of 10.2.8.1 shall not apply.

Table 22.3.2.1 Hazardous Area Protection

Hazardous Area Description	Separation/Protection
Areas not incidental to resident housing	2 hours
Boiler and fuel-fired heater rooms	1 hour
Central or bulk laundries >9.3 m ² (>100 ft ²)	1 hour
Commercial cooking equipment	In accordance with 9.2.3
Commissaries	Smoke resistant
Employee locker rooms	Smoke resistant
Hobby/handicraft shops	Smoke resistant
Maintenance shops	Smoke resistant
Padded cells	1 hour
Soiled linen rooms	1 hour
Storage rooms >4.6 m ² (>50 ft ²) in area but ≤9.3 m ² (≤100 ft ²) in area storing combustible material	Smoke resistant
Storage rooms >9.3 m ² (>100 ft ²) storing combustible materials	1 hour
Trash collection rooms	1 hour

22.3.3.3.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

22.3.4 Detection, Alarm, and Communications Systems.

22.3.4.1 General.

22.3.4.1.1 Detention and correctional occupancies shall be provided with a fire alarm system in accordance with Section 9.6, except as modified by 22.3.4.1.3 through 22.3.4.4.3.

22.3.4.1.2 Reserved.

22.3.4.1.3 All fire alarm systems and detection systems required in 22.3.4 shall be provided with a secondary power supply, and the installation shall be in accordance with *NFPA 72, National Fire Alarm Code*.

22.3.4.2 Initiation. Initiation of the required fire alarm system shall be by manual means in accordance with 9.6.2, by means of any required detection devices or detection systems, and by means of waterflow alarm in the sprinkler system required by 22.3.5.2, unless otherwise permitted by the following:

- (1) Manual fire alarm boxes shall be permitted to be locked, provided that staff is present within the area when it is occupied and staff has keys readily available to unlock the boxes.
- (2) Manual fire alarm boxes shall be permitted to be located in a staff location, provided that both of the following criteria are met:
 - (a) The staff location is attended when the building is occupied.
 - (b) The staff attendant has direct supervision of the sleeping area.

22.3.4.3 Notification.

22.3.4.3.1 Occupant Notification. Occupant notification shall be accomplished automatically in accordance with 9.6.3, and the following also shall apply:

- (1) A positive alarm sequence shall be permitted in accordance with 9.6.3.4.
- (2)*Any smoke detectors required by this chapter shall be permitted to be arranged to alarm at a constantly attended location only and shall not be required to accomplish general occupant notification.

22.3.4.3.2 Emergency Forces Notification.

22.3.4.3.2.1 Fire department notification shall be accomplished in accordance with 9.6.4, unless otherwise permitted by the following:

- (1) A positive alarm sequence shall be permitted in accordance with 9.6.3.4.
- (2) Any smoke detectors required by this chapter shall not be required to transmit an alarm to the fire department.
- (3) This requirement shall not apply where staff is provided at a constantly attended location that meets one of the following criteria:
 - (a) It has the capability to promptly notify the fire department.
 - (b) It has direct communication with a control room having direct access to the fire department.

22.3.4.3.2.2 Where the provision of 22.3.4.3.2.1 (3) is utilized, the fire plan, as required by 22.7.1.3, shall include procedures for logging of alarms and immediate notification of the fire department.

22.3.4.4* Detection. An approved automatic smoke detection system shall be in accordance with Section 9.6, as modified by 22.3.4.4.1 through 22.3.4.4.3, throughout all resident sleeping areas and adjacent day rooms, activity rooms, or contiguous common spaces.

22.3.4.4.1 Smoke detectors shall not be required in sleeping rooms with four or fewer occupants.

22.3.4.4.2 Other arrangements and positioning of smoke detectors shall be permitted to prevent damage or tampering, or for other purposes.

22.3.4.4.2.1 Such arrangements shall be capable of detecting any fire, and the placement of detectors shall be such that the speed of detection is equivalent to that provided by the spacing and arrangements required by the installation standards referenced in Section 9.6.

22.3.4.4.2.2 Detectors shall be permitted to be located in exhaust ducts from cells, behind grilles, or in other locations.

22.3.4.4.2.3 The equivalent performance of the design, however, shall be acceptable to the authority having jurisdiction in accordance with the equivalency concepts specified in Section 1.4.

22.3.4.4.3* Smoke detectors shall not be required in Use Condition II open dormitories where staff is present within the dormitory whenever the dormitory is occupied.

22.3.5 Extinguishment Requirements.

22.3.5.1 High-rise buildings shall comply with 22.4.3.

22.3.5.2 All buildings classified as Use Condition II, Use Condition III, Use Condition IV, or Use Condition V shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 22.3.5.3.

22.3.5.3 The automatic sprinkler system required by 22.3.5.2 shall be as follows:

- (1) In accordance with Section 7.7
- (2) Installed in accordance with 9.7.1.1(1).
- (3) Electrically connected to the fire alarm system
- (4) Fully supervised

22.3.5.4 Portable fire extinguishers shall be provided in accordance with 9.7.4.1, unless otherwise permitted by the following:

- (1)*Access to portable fire extinguishers shall be permitted to be locked.
- (2) Portable fire extinguishers shall be permitted to be located at staff locations only.

22.3.5.5 Standpipe and hose systems shall be provided in accordance with 9.7.4.2 as follows, unless otherwise permitted by 22.3.5.6:

- (1) Class I standpipe systems shall be provided for any building over two stories in height.
- (2) Class III standpipe and hose systems shall be provided for all nonsprinklered buildings over two stories in height.

22.3.5.6 The requirements of 22.3.5.5 shall not apply where otherwise permitted by the following:

- (1) Formed hose, 25 mm (1 in.) in diameter, on hose reels shall be permitted to provide Class II service.
- (2) Separate Class I and Class II systems shall be permitted in lieu of a Class III system.

22.3.6 Corridors. (See 22.3.8.)

22.3.7 Subdivision of Building Spaces.

22.3.7.1 Smoke barriers shall be provided to divide every story used for sleeping by residents, or any other story having an occupant load of 50 or more persons, into not less than two compartments, unless otherwise permitted by the following:

- (1) Protection shall be permitted to be accomplished using horizontal exits. (See 7.2.4.)
- (2)*The requirement for subdivision of building space shall be permitted to be fulfilled by one of the following:
 - (a) Smoke compartments having exit to a public way where such exit serves only one area and has no openings to other areas
 - (b) A building separated from the resident housing area by a 2-hour fire resistance rating or 15 m (50 ft) of open space
 - (c) A secured, open area having a holding space located 15 m (50 ft) from the housing area that provides 1.4 m² (15 ft²) or more of refuge area for each person (resident, staff, visitors) potentially present at the time of a fire

22.3.7.2 Doors used to access the areas specified in 22.3.7.1(2)(a), 22.3.7.1(2)(b), and 22.3.7.1(2)(c) shall meet the requirements for doors at smoke barriers for the applicable use condition.

22.3.7.3 Where smoke barriers are required by 22.3.7.1, they shall be provided as follows:

- (1) They shall limit the occupant load to not more than 200 residents in any smoke compartment.
- (2) They shall limit the travel distance to a door in a smoke barrier as follows:

- (a) The distance from any room door required as exit access shall not exceed 46 m (150 ft).
- (b) The distance from any point in a room shall not exceed 61 m (200 ft).

22.3.7.4 Reserved.

22.3.7.5* Any required smoke barrier shall be constructed in accordance with Section 8.5, shall be of substantial construction, and shall have structural fire resistance.

22.3.7.6 Openings in smoke barriers shall be protected in accordance with Section 8.5, unless otherwise permitted by the following:

- (1)*The total number of vision panels in any barrier shall not be restricted.
- (2) Sliding doors in smoke barriers that are designed to normally be kept closed and are remotely operated from a continuously attended location shall not be required to be self-closing.

22.3.7.7 Not less than 0.55 net m² (6 net ft²) per occupant shall be provided on each side of the smoke barrier for the total number of occupants in adjoining compartments, and this space shall be readily available wherever occupants are moved across the smoke barrier in a fire emergency.

22.3.7.8 Doors shall provide resistance to the passage of smoke. Swinging doors shall be self-latching, or the opening resistance of the door shall be not less than 22 N (5 lbf).

22.3.7.9 Doors in smoke barriers shall conform with the requirements for doors in means of egress as specified in Section 22.2 and shall have locking and release arrangements according to the applicable use condition. The provisions of 22.2.11.7.2 shall not be used for smoke barrier doors serving a smoke compartment containing more than 20 persons.

22.3.7.10 Vision panels shall be provided in smoke barriers at points where the barrier crosses an exit access corridor.

22.3.7.11 Smoke dampers shall be provided in accordance with 8.5.4, unless otherwise permitted by 22.3.7.12.

22.3.7.12 Arrangements and positioning of smoke detectors required by 22.3.7.11 shall be permitted to prevent damage or tampering, or for other purposes, provided that the following criteria are met:

- (1) Such arrangements shall be capable of detecting any fire.
- (2) The placement of detectors shall be such that the speed of detection is equivalent to that provided by the spacing and arrangement required by *NFPA 72, National Fire Alarm Code*, as referenced in 8.5.4.7.1.

22.3.8* Special Protection Features — Subdivision of Resident Housing Spaces. Subdivision of facility spaces shall comply with Table 22.3.8.

22.4 Special Provisions.

22.4.1 Limited Access Structures. The provisions of Section 11.7 for limited access structures shall not apply.

22.4.2 Underground Buildings. See Section 11.7 for requirements for underground buildings.

22.4.3 High-Rise Buildings. High-rise buildings shall comply with 11.8.2.

Table 22.3.8 Subdivision of Resident Housing Spaces

Feature	Use Condition			
	II	III	IV	V
Room to room separation	NR	NR	NR	SR
Room face to corridor separation	NR	NR	NR	SR
Room face to common space separation	NR	NR SR ≤15 m >15 m (≤50 ft) [†] (>50 ft) [†]	NR SR ≤15 m >15 m (≤50 ft) [†] (>50 ft) [†]	SR
Common space to corridor separation	NR	NR	NR	SR
Total openings in solid room face where room face is required to be smoke resistant or fire rated [‡]	0.08 m ² (0.85 ft ²)	0.08 m ² (0.85 ft ²)	0.08 m ² (0.85 ft ²)	0.08 m ² (0.85 ft ²) where meeting one of the following: (1) kept in closed position except when in use by staff, (2) closable from the inside, (3) with smoke control

NR: No requirement.

SR: Smoke resistant.

Notes:

1. Doors in openings in partitions required to be smoke resistant (SR) in accordance with Table 22.3.8 shall be substantial doors of construction that resists the passage of smoke. Latches and door closers shall not be required on cell doors.

2. Under Use Condition II, Use Condition III, or Use Condition IV, a space subdivided by open construction (any combination of grating doors and grating walls or solid walls) shall be permitted to be considered one room if housing not more than 16 persons. The perimeter walls of such space shall be of smoke-resistant construction. Smoke detection shall be provided in such space. Under Use Condition IV, common walls between sleeping areas within the space shall be smoke resistant, and grating doors and fronts shall be permitted to be used. Under Use Condition II and Use Condition III, open dormitories shall be permitted to house more than 16 persons as permitted by other sections of this chapter.

3. Where barriers are required to be smoke resistant (SR), the provisions of Section 8.5 shall not apply.

[†]Travel distance through the common space to the exit access corridor.

[‡]"Total openings in solid room face" includes all openings (for example, undercuts, food passes, grilles), the total of which shall not exceed 0.08 m² (0.85 ft²). All openings shall be 915 mm (36 in.) or less above the floor.

22.4.4 Nonsprinklered Existing Building Renovations.

22.4.4.1 General. Modernizations or renovations of nonsprinklered existing buildings shall be permitted to meet the requirements of this chapter as modified by 22.4.4.2 through 22.4.4.13 in lieu of the sprinkler requirement of 22.3.5.2.

22.4.4.2 Minimum Construction Requirements (Nonsprinklered Buildings).

22.4.4.2.1 Detention and correctional occupancies in nonsprinklered buildings shall be limited to the types of building construction permitted by Table 22.4.4.2.1. (See 8.2.1.)

22.4.4.2.2 A residential housing area complying with 22.4.4.6 shall be considered as a one-story building for purposes of applying Table 22.4.4.2.1.

22.4.4.3* Horizontal Exit Duct Penetrations (Nonsprinklered Buildings). Ducts shall be permitted to penetrate horizontal exits in accordance with 7.2.4.3.4(3) if protected by combina-

tion fire dampers/smoke leakage-rated dampers that meet the smoke damper actuation requirements of 8.5.4.

22.4.4.4 Common Path of Travel (Nonsprinklered Buildings). A common path of travel shall not exceed 15 m (50 ft).

22.4.4.5 Travel Distance to Exits (Nonsprinklered Buildings).

22.4.4.5.1 The travel distance between any room door required as an exit access and an exit shall not exceed 30 m (100 ft).

22.4.4.5.2 The travel distance between any point in a room and an exit shall not exceed 46 m (150 ft).

22.4.4.6 Protection of Vertical Openings (Nonsprinklered Buildings).

22.4.4.6.1 Multilevel residential housing areas without enclosure protection between levels shall be permitted, provided that the conditions of 22.4.4.6.2 through 22.4.4.6.4 are met.

Table 22.4.4.2.1 Construction Type Limitations — Nonsprinklered Buildings

Type of Construction	1 Story with Basement	1 Story without Basement	2 Stories	3 Stories	>3 Stories and Not High-Rise	High-Rise
I(443)	X	X	X	X	X	NP
I(332)	X	X	X	X	X	NP
II(222)	X	X	X	X	X	NP
II(111)	X*	X	X*	NP	NP	NP
III(211)	X*	X*	X*	NP	NP	NP
IV(2HH)	X*	X*	X*	NP	NP	NP
V(111)	X*	X*	X*	NP	NP	NP
II(000)	NP	NP	NP	NP	NP	NP
III(200)	NP	NP	NP	NP	NP	NP
V(000)	NP	NP	NP	NP	NP	NP

X: Permitted types of construction.

NP: Not permitted.

*Permitted for other than Use Condition V.

22.4.4.6.2* The entire normally occupied area, including all communicating floor levels, shall be sufficiently open and unobstructed so that a fire or other dangerous condition in any part is obvious to the occupants or supervisory personnel in the area.

22.4.4.6.3 Egress capacity shall simultaneously accommodate all occupants of all communicating levels and areas, with all communicating levels in the same fire area considered as a single floor area for purposes of determining required egress capacity.

22.4.4.6.4* The height between the highest and lowest finished floor levels shall not exceed 3960 mm (156 in.). The number of levels shall not be restricted.

22.4.4.7 Hazardous Areas (Nonsprinklered Buildings). Any hazardous area shall be protected in accordance with Section 8.7. The areas described in the Table 22.4.4.7 shall be protected as indicated.

22.4.4.8 Interior Finish (Nonsprinklered Buildings).

22.4.4.8.1 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A in corridors, in exits, and in any space not separated from corridors and exits by partitions capable of retarding the passage of smoke; and Class A, Class B, or Class C in all other areas.

22.4.4.8.2 Interior Floor Finish.

22.4.4.8.2.1 Interior floor finish shall comply with Section 10.2.

22.4.4.8.2.2 Interior floor finish in exit enclosures and exit access corridors shall be not less than Class I.

22.4.4.8.2.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

22.4.4.9 Detection, Alarm, and Communications Systems (Nonsprinklered Buildings).

22.4.4.9.1 Initiation. Initiation of the fire alarm system required by 22.3.4.1.1 shall be by manual means in accordance with 9.6.2 and by means of any required detection devices or detection systems, unless otherwise permitted by the following:

Table 22.4.4.7 Hazardous Area Protection — Nonsprinklered Buildings

Hazardous Area Description	Separation/Protection
Areas not incidental to resident housing	2 hours
Boiler and fuel-fired heater rooms	2 hours or 1 hour and sprinklers
Central or bulk laundries >9.3 m ² (>100 ft ²)	2 hours or 1 hour and sprinklers
Commercial cooking equipment	In accordance with 9.2.3
Commissaries	1 hour or sprinklers
Employee locker rooms	1 hour or sprinklers
Hobby/handicraft shops	1 hour or sprinklers
Maintenance shops	1 hour or sprinklers
Padded cells	2 hours or 1 hour and sprinklers
Soiled linen rooms	2 hours or 1 hour and sprinklers
Storage rooms >4.6 m ² (>50 ft ²) in area but ≤9.3 m ² (≤100 ft ²) in area storing combustible material	1 hour or sprinklers
Storage rooms >9.3 m ² (>100 ft ²) storing combustible materials	2 hours or 1 hour and sprinklers
Trash collection rooms	2 hours or 1 hour and sprinklers

- (1) Manual fire alarm boxes shall be permitted to be locked, provided that staff is present within the area when it is occupied and staff has keys readily available to unlock the boxes.
- (2) Manual fire alarm boxes shall be permitted to be located in a staff location, provided that both of the following criteria are met:
 - (a) The staff location is attended when the building is occupied
 - (b) The staff attendant has direct supervision of the sleeping area.

22.4.4.9.2 Detection. An approved automatic smoke detection system shall be in accordance with Section 9.6, as modified by 22.4.4.9.2.1 and 22.4.4.9.2.2, throughout all resident sleeping areas and adjacent day rooms, activity rooms, or contiguous common spaces.

22.4.4.9.2.1 Smoke detectors shall not be required in sleeping rooms with four or fewer occupants in Use Condition II or Use Condition III.

22.4.4.9.2.2 Other arrangements and positioning of smoke detectors shall be permitted to prevent damage or tampering, or for other purposes. Such arrangements shall be capable of detecting any fire, and the placement of detectors shall be such that the speed of detection is equivalent to that provided by the spacing and arrangements required by the installation standards referenced in Section 9.6. Detectors shall be permitted to be located in exhaust ducts from cells, behind grilles, or in other locations. The equivalent performance of the design, however, shall be acceptable to the authority having jurisdiction in accordance with the equivalency concepts specified in Section 1.4.

22.4.4.10 Subdivision of Building Spaces (Nonsprinklered Buildings). Where smoke barriers are required by 22.3.7.1, they shall be provided as follows:

- (1) They shall limit the occupant load to not more than 200 residents in any smoke compartment.
- (2) They shall limit the travel distance to a door in a smoke barrier as follows:
 - (a) The distance from any room door required as exit access shall not exceed 30 m (100 ft).
 - (b) The distance from any point in a room shall not exceed 46 m (150 ft).

22.4.4.11* Subdivision of Resident Housing Spaces (Nonsprinklered Buildings). Subdivision of facility spaces shall comply with Table 22.4.4.11.

22.4.4.12 Limited Access Structures (Nonsprinklered Buildings).

22.4.4.12.1 Limited access structures used as detention and correctional occupancies shall comply with 22.4.4.12.2. The provisions of Section 11.7 for limited access structures shall not apply.

22.4.4.12.2 Any one of the following means shall be provided to evacuate smoke from the smoke compartment of fire origin:

- (1) Operable windows on not less than two sides of the building, spaced not more than 9140 mm (360 in.) apart, that provide openings with dimensions of not less than 560 mm (22 in.) in width and 610 mm (24 in.) in height
- (2)*Manual or automatic smoke vents
- (3) Engineered smoke control system
- (4) Mechanical exhaust system providing not less than 6 air changes per hour
- (5) Other method acceptable to the authority having jurisdiction

22.4.4.13* Furnishings, Bedding, and Decorations (Nonsprinklered Buildings).

22.4.4.13.1 Newly introduced upholstered furniture within detention and correctional occupancies shall be tested in accordance with the provisions of 10.3.2(2) and 10.3.3.

22.4.4.13.2* Newly introduced mattresses within detention and correctional occupancies shall be tested in accordance with the provisions of 10.3.2(3) and 10.3.4.

22.5 Building Services.

22.5.1 Utilities.

22.5.1.1 Utilities shall comply with the provisions of Section 9.1.

22.5.1.2 Alarms, emergency communication systems, and the illumination of generator set locations shall be provided with emergency power in accordance with NFPA 70, *National Electrical Code*.

22.5.2 Heating, Ventilating, and Air Conditioning.

22.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2 and shall be installed in accordance with the manufacturer's specifications, unless otherwise modified by 22.5.2.2.

22.5.2.2 Portable space-heating devices shall be prohibited, unless otherwise permitted by 22.5.2.4.

22.5.2.3 Any heating device other than a central heating plant shall be designed and installed so that combustible material cannot be ignited by the device or its appurtenances, and the following requirements also shall apply:

- (1) If fuel-fired, such heating devices shall comply with the following:
 - (a) They shall be chimney connected or vent connected.
 - (b) They shall take air for combustion directly from outside.
 - (c) They shall be designed and installed to provide for complete separation of the combustion system from the atmosphere of the occupied area.
- (2) The heating system shall have safety devices to immediately stop the flow of fuel and shut down the equipment in case of either excessive temperatures or ignition failure.

22.5.2.4 Approved, suspended unit heaters shall be permitted in locations other than means of egress and sleeping areas, provided that both of the following criteria are met:

- (1) Such heaters are located high enough to be out of the reach of persons using the area.
- (2) Such heaters are vent connected and equipped with the safety devices required by 22.5.2.3.

22.5.2.5 Combustion and ventilation air for boiler, incinerator, or heater rooms shall be taken directly from and discharged directly to the outside.

22.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

22.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes.

22.5.4.1 Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

22.5.4.2 Rubbish chutes and linen chutes, including pneumatic rubbish and linen systems, shall be provided with automatic extinguishing protection in accordance with Section 9.7.

22.5.4.3 Trash chutes shall discharge into a trash collection room used for no other purpose and protected in accordance with Section 8.7.

22.5.4.4 Incinerators shall not be directly flue-fed, and floor chutes shall not directly connect with the combustion chamber.

Table 22.4.4.11 Subdivision of Resident Housing Spaces — Nonsprinklered Buildings

Feature	Use Condition			
	II	III	IV	V
Room to room separation	NR	NR	SR	FR(½)
Room face to corridor separation	SR	SR	SR	FR
Room face to common space separation	NR	NR SR ≤15 m >15 m (≤50 ft) [†] (>50 ft) [†]	SR	FR
Common space to corridor separation	FR	FR	FR	FR
Total openings in solid room face where room face is required to be smoke resistant or fire rated [‡]	0.08 m ² (0.85 ft ²)	0.08 m ² (0.85 ft ²)	0.08 m ² (0.85 ft ²)	0.08 m ² (0.85 ft ²) where meeting one of the following: (1) kept in closed position except when in use by staff, (2) closable from the inside, (3) with smoke control

NR: No requirement.

SR: Smoke resistant.

FR(½): Fire rated — ½ hour.

FR: Fire rated — 1 hour.

Notes:

1. Doors in openings in partitions required to be fire rated (FR(½), FR) in accordance with Table 22.4.4.11 in other than required enclosures of exits or hazardous areas shall be substantial doors of construction that resists fire for not less than 20 minutes. Vision panels with wired glass or glass with not less than 45-minute fire-rated glazing shall be permitted. Latches and door closers shall not be required on cell doors.

2. Doors in openings in partitions required to be smoke resistant (SR) in accordance with Table 22.4.4.11 shall be substantial doors of construction that resists the passage of smoke. Latches and door closers shall not be required on cell doors.

3. Under Use Condition II, Use Condition III, or Use Condition IV, a space subdivided by open construction (any combination of grating doors and grating walls or solid walls) shall be permitted to be considered one room if housing not more than 16 persons. The perimeter walls of such space shall be of smoke-resistant construction. Smoke detection shall be provided in such space. Under Use Condition IV, common walls between sleeping areas within the space shall be smoke resistant, and grating doors and fronts shall be permitted to be used. In Use Condition II and Use Condition III, open dormitories shall be permitted to house more than 16 persons as permitted by other sections of this chapter.

4. Where barriers are required to be smoke resistant (SR), the provisions of Section 8.5 shall not apply.

[†]Travel distance through the common space to the exit access corridor.

[‡]"Total openings in solid room face" includes all openings (for example, undercuts, food passes, grilles), the total of which shall not exceed 0.08 m² (0.85 ft²). All openings shall be 915 mm (36 in.) or less above the floor.

22.6 Reserved.

22.7 Operating Features.

22.7.1 Attendants, Evacuation Plan, Fire Drills.

22.7.1.1 Detention and correctional facilities, or those portions of facilities having such occupancy, shall be provided with 24-hour staffing, and the following requirements also shall apply:

- (1) Staff shall be within three floors or a 91-m (300-ft) horizontal distance of the access door of each resident housing area.
- (2) In addition, for Use Condition III, Use Condition IV, and Use Condition V, the arrangement shall be such that the staff involved starts the release of locks necessary for emergency evacuation or rescue and initiates other necessary emergency actions within 2 minutes of alarm.

(3) The following shall apply to areas in which all locks are unlocked remotely in compliance with 22.2.11.7:

- (a) Staff shall not be required to be within three floors or 91 m (300 ft) of the access door.
- (b) The 10-lock, manual key exemption of 22.2.11.7.2 shall not be permitted to be used in conjunction with this alternative requirement.

22.7.1.2* Provisions shall be made so that residents in Use Condition III, Use Condition IV, and Use Condition V shall be able to notify staff of an emergency.

22.7.1.3* The administration of every detention or correctional facility shall have, in effect and available to all supervisory personnel, written copies of a plan for the protection of all persons in the event of fire, for their evacuation to areas of refuge, and for evacuation from the building when necessary.

22.7.1.3.1 All employees shall be instructed and drilled with respect to their duties under the plan.

22.7.1.3.2 The plan shall be coordinated with and reviewed by the fire department legally committed to serve the facility.

22.7.1.4 Employees of detention and correctional occupancies shall be instructed in the proper use of portable fire extinguishers and other manual fire suppression equipment.

22.7.1.4.1 Such training shall be provided to new staff promptly upon commencement of duty.

22.7.1.4.2 Refresher training shall be provided to existing staff at not less than annual intervals.

22.7.2 Combustible Personal Property. Books, clothing, and other combustible personal property allowed in sleeping rooms shall be stored in closable metal lockers or an approved fire-resistant container.

22.7.3 Heat-Producing Appliances. The number of heat-producing appliances, such as toasters and hot plates, and the overall use of electrical power within a sleeping room shall be controlled by facility administration.

22.7.4* Furnishings, Bedding, and Decorations.

22.7.4.1 Draperies and curtains, including privacy curtains, in detention and correctional occupancies, shall be in accordance with the provisions of 10.3.1.

22.7.4.2 Reserved.

22.7.4.3 Reserved.

22.7.4.4 Combustible decorations shall be prohibited in any detention or correctional occupancy unless flame-retardant.

22.7.4.5 Wastebaskets and other waste containers shall be of noncombustible or other approved materials. Waste containers with a capacity exceeding 76 L (20 gal) shall be provided with a noncombustible lid or lid of other approved material.

22.7.5 Keys. All keys necessary for unlocking doors installed in a means of egress shall be individually identified by both touch and sight.

22.7.6 Portable Space-Heating Devices. Portable space-heating devices shall be prohibited in all detention and correctional occupancies.

Chapter 23 Existing Detention and Correctional Occupancies

23.1 General Requirements.

23.1.1 Application.

23.1.1.1 General.

23.1.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as detention or correctional occupancies. (*See also 22.1.1.1.*)

23.1.1.1.2 This chapter establishes life safety requirements for all existing detention and correctional facilities, other than the following:

- (1) Use Condition I facilities protected as residential occupancies in accordance with 23.1.4.3
- (2)*Facilities determined to have equivalent safety provided in accordance with Section 1.4

23.1.1.1.3 Detention and correctional occupancies shall include those used for purposes such as correctional institutions, detention facilities, community residential centers, training schools, work camps, and substance abuse centers where occupants are confined or housed under some degree of restraint or security.

23.1.1.1.4 Detention and correctional occupancies shall include those that provide sleeping facilities for four or more residents and are occupied by persons who are generally prevented from taking self-preservation action because of security measures not under the occupants' control.

23.1.1.2 Total Concept.

23.1.1.2.1 All detention and correctional facilities shall be designed, constructed, maintained, and operated to minimize the possibility of a fire emergency.

23.1.1.2.2 Because the safety of all occupants in detention and correctional facilities cannot be adequately ensured solely by dependence on evacuation of the building, their protection from fire shall be provided by appropriate arrangement of facilities; adequate, trained staff; and development of operating, security, and maintenance procedures composed of the following:

- (1) Design, construction, and compartmentation
- (2) Provision for detection, alarm, and extinguishment
- (3) Fire prevention and planning, training, and drilling programs for the isolation of fire and the transfer of occupants to areas of refuge, for evacuation of the building, or for protection of the occupants in place
- (4) Provision of security to the degree necessary for the safety of the public and the occupants of the facility

23.1.1.3 Additions. Additions shall be separated from any existing structure not conforming with the provisions of this chapter by a fire barrier having not less than a 2-hour fire resistance rating constructed to the requirements of the addition, and the following also shall apply:

- (1) Doors in such partitions shall normally be kept closed.
- (2) Doors shall be permitted to be held open if they meet the requirements of 7.2.1.8.2.

23.1.1.4 Modernizations or Renovations.

23.1.1.4.1 Modernizations and renovations shall be in accordance with 4.6.8, unless otherwise permitted by 23.1.1.4.2.

23.1.1.4.2 In nonsprinklered existing buildings, modernizations or renovations shall be permitted to comply with the nonsprinklered options contained in 22.4.4 in lieu of the sprinkler requirement of 22.3.5.2.

23.1.2* Multiple Occupancies.

23.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

23.1.2.2 Egress provisions for areas of detention and correctional facilities that correspond to other occupancies shall meet the corresponding requirements of this *Code* for such occupancies as modified by 23.1.2.2.1.

23.1.2.2.1* Where security operations necessitate the locking of required means of egress, staff in the building shall be provided with the means for the supervised release of occupants during all times of use.

23.1.2.2.2 Reserved.

23.1.2.3 Sections of detention and correctional facilities shall be permitted to be classified as other occupancies, provided that they meet all of the following conditions:

- (1) They are not intended to serve residents for sleeping purposes.
- (2) They are separated from areas of detention or correctional occupancies by construction having not less than a 2-hour fire resistance rating.

23.1.2.4 All means of egress from detention and correctional occupancies that traverse other use areas shall, as a minimum, conform to the requirements of this *Code* for detention and correctional occupancies, unless otherwise permitted by 23.1.2.5.

23.1.2.5 Egress through a horizontal exit into other contiguous occupancies that do not conform to detention and correctional occupancy egress provisions but that do comply with requirements set forth in the appropriate occupancy chapter of this *Code* shall be permitted, provided that both of the following criteria apply:

- (1) The occupancy shall not contain high hazard contents.
- (2) The horizontal exit shall comply with the requirements of 23.2.2.5.

23.1.2.6 Any area with a hazard of contents classified higher than that of the detention or correctional occupancy and located in the same building shall be protected as required in 23.3.2.

23.1.2.7 Nondetention- or noncorrectional-related occupancies classified as containing high hazard contents shall not be permitted in buildings housing detention or correctional occupancies.

23.1.3 Definitions. The following terms are used in this chapter:

- (1) **Detention and Correctional Residential Housing Area.** See 3.3.16.1.
- (2) **Sally Port (Security Vestibule).** See 3.3.187.

23.1.4 Classification of Occupancy.

23.1.4.1* For application of the life safety requirements that follow, the resident user category shall be divided into the following five groups:

- (1) *Use Condition I — Free Egress.* Free movement is allowed from sleeping areas and other spaces where access or occupancy is permitted to the exterior via means of egress meeting the requirements of this *Code*.
- (2) *Use Condition II — Zoned Egress.* Free movement is allowed from sleeping areas and any other occupied smoke compartment to one or more other smoke compartments.
- (3) *Use Condition III — Zoned Impeded Egress.* Free movement is allowed within individual smoke compartments, such as within a residential unit comprised of individual sleeping rooms and a group activity space, with egress impeded by remote-controlled release of means of egress from such a smoke compartment to another smoke compartment.
- (4) *Use Condition IV — Impeded Egress.* Free movement is restricted from an occupied space. Remote-controlled release is provided to allow movement from all sleeping rooms, activity spaces, and other occupied areas within the smoke compartment to another smoke compartment.
- (5) *Use Condition V — Contained.* Free movement is restricted from an occupied space. Staff-controlled manual release at each door is provided to allow movement from all sleeping rooms, activity spaces, and other occupied areas within the smoke compartment to another smoke compartment.

23.1.4.2* To be classified as Use Condition III or Use Condition IV, the arrangement, accessibility, and security of the release mechanism(s) used for emergency egress shall be such that the minimum available staff, at any time, can promptly release the locks.

23.1.4.3 Areas housing occupancies corresponding to Use Condition I shall conform to one of the following:

- (1) The requirements of residential occupancies under this *Code*.
- (2)*The requirements of this chapter for Use Condition II facilities, provided that the staffing requirements of Section 23.7 are met.

23.1.5 Classification of Hazard of Contents. The classification of hazard of contents shall be as defined in Section 6.2.

23.1.6 Minimum Construction Requirements.

23.1.6.1 For the purposes of 23.1.6, the number of stories shall be counted starting with the primary level of exit discharge.

23.1.6.2 For the purposes of 23.1.6.1, the primary level of exit discharge of a building shall be that floor that is level with or above finished grade on the exterior wall line for 50 percent or more of its perimeter.

23.1.6.3 For the purposes of 23.1.6.2 building levels below the primary level shall not be counted as a story in determining the height of the building.

23.1.6.4 A residential housing area complying with 23.3.1.2 shall be considered as a one-story building for purposes of applying 23.1.6.5.

23.1.6.5 Detention and correctional occupancies shall be limited to the types of building construction permitted by Table 23.1.6.5. (*see 8.2.1*), unless otherwise permitted by the following:

- (1) Any building of Type I, Type II(222), or Type II(111) construction shall be permitted to include roofing systems

Table 23.1.6.5 Construction Type Limitations

Type of Construction	1 Story with Basement	1 Story without Basement	2 Stories	3 Stories	>3 Stories and Not High-Rise	High-Rise
I(443)	X	X	X	X	X	X ¹
I(332)	X	X	X	X	X	X ¹
II(222)	X	X	X	X	X	X ¹
II(111)	X ²	X	X ²	X ¹	X ¹	X ¹
III(211)	X ²	X	X ²	X ¹	X ¹	X ¹
IV(2HH)	X ²	X	X ²	X ¹	X ¹	X ¹
V(111)	X ²	X	X ²	X ¹	X ¹	X ¹
II(000)	X ²	X ²	X ¹	X ¹	X ¹	X ¹
III(200)	X ²	X ²	X ¹	X ¹	X ¹	X ¹
V(000)	X ²	X ²	X ¹	X ¹	X ¹	X ¹

X: Permitted types of construction.

¹Permitted if the entire building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 23.3.5.3.

²Where Use Condition V is used, permitted if the entire building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 23.3.5.3.

involving combustible or steel supports, decking, or roofing, provided that the following criteria are met:

(a) The roof covering shall meet not less than Class C requirements in accordance with NFPA 256, *Standard Methods of Fire Tests of Roof Coverings*.

(b) The roof shall be separated from all occupied portions of the building by a noncombustible floor assembly that includes not less than 63 mm (2½ in.) of concrete or gypsum fill and the attic or other space so developed shall meet one of the following requirements:

- i. It shall be unoccupied.
- ii. It shall be protected throughout by an approved automatic sprinkler system.

(2) In determining building construction type, exposed steel roof members located 4875 mm (192 in.) or more above the floor of the highest cell shall be permitted to be disregarded.

23.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, either shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

23.2 Means of Egress Requirements.

23.2.1 General. Means of egress shall comply with Chapter 7, unless otherwise provided or modified by Section 23.2.

23.2.2 Means of Egress Components.

23.2.2.1 General. Components of means of egress shall be limited to the types described in 23.2.2.2 through 23.2.2.11.

23.2.2.2 Doors. Doors complying with 7.2.1 shall be permitted, unless otherwise provided in 23.2.11.

23.2.2.3 Stairs.

23.2.2.3.1 Stairs shall be permitted as follows:

- (1) Stairs complying with 7.2.2 shall be permitted.

- (2) Noncombustible grated stair treads and landing floors shall be permitted.

23.2.2.3.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted for access to and between staff locations.

23.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

23.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 and the modifications of 23.2.2.5.1 through 23.2.2.5.4 shall be permitted.

23.2.2.5.1 Not less than 0.55 m² (6 ft²) of accessible space per occupant shall be provided on each side of the horizontal exit for the total number of people in adjoining compartments.

23.2.2.5.2* Horizontal exits shall be permitted to comprise 100 percent of the exits required, provided that an exit, other than a horizontal exit, located in another (not necessarily adjacent) fire compartment is accessible without returning through the compartment of fire origin.

23.2.2.5.3* Ducts shall be permitted to penetrate horizontal exits in accordance with 7.2.4.3.4(3) if protected by combination fire dampers/smoke leakage-rated dampers that meet the smoke damper actuation requirements of 8.5.4.

23.2.2.5.4 A door in a horizontal exit shall not be required to swing with egress travel as specified in 7.2.4.3.7(1).

23.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

23.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

23.2.2.8 Fire Escape Stairs. Fire escape stairs complying with 7.2.8 shall be permitted.

23.2.2.9 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

23.2.2.10 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

23.2.2.11 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

23.2.3 Capacity of Means of Egress.

23.2.3.1 The capacity of any required means of egress shall be in accordance with Section 7.3.

23.2.3.2 Aisles, corridors, and ramps required for egress shall be not less than 915 mm (36 in.) in width.

23.2.3.3 For residents' sleeping room door widths, see 23.2.11.3.

23.2.4 Number of Exits. See also Section 7.4.

23.2.4.1* Not less than two separate exits shall meet the following criteria:

- (1) They shall be provided on every story.
- (2) They shall be accessible from every part of every story, fire compartment, or smoke compartment; however, exit access travel shall be permitted to be common for the distances permitted as common path of travel by 23.2.5.3.

23.2.4.2* Not less than one approved exit shall be accessible from each fire compartment and each required smoke compartment into which residents are potentially moved in a fire emergency, with the exits arranged so that egress is possible without returning through the zone of fire origin.

23.2.5 Arrangement of Means of Egress. See also Section 7.5.

23.2.5.1 Every sleeping room shall have a door leading directly to an exit access corridor, unless otherwise permitted by the following:

- (1) The requirement of 23.2.5.1 shall not apply if there is an exit door opening directly to the outside from the room at the ground level.
- (2) One adjacent room, such as a day room, group activity space, or other common space, shall be permitted to intervene, and the following also shall apply:
 - (a) Where sleeping rooms directly adjoin a day room or group activity space that is used for access to an exit, such sleeping rooms shall be permitted to open directly to the day room or space.
 - (b) Sleeping rooms permitted to open directly to the day room or space shall be permitted to be separated in elevation by a one-half or full story height. (See 23.3.1.1.)

23.2.5.2* Existing dead-end corridors are undesirable and shall be altered wherever possible so that exits are accessible in not less than two different directions from all points in aisles, passageways, and corridors.

23.2.5.3 A common path of travel shall not exceed 15 m (50 ft), unless otherwise permitted by the following:

- (1) A common path of travel shall be permitted for the first 30 m (100 ft) in smoke compartments protected throughout by an approved automatic sprinkler system in accordance with 23.3.5.3.
- (2) A common path of travel shall be permitted to exceed 15 m (50 ft) in multilevel residential housing units in which each floor level, considered separately, has not less than one-half of its individual required egress capacity accessible by exit access leading directly out of that level without traversing another communicating floor level.
- (3)*Approved existing common paths of travel that exceed 15 m (50 ft) shall be permitted to continue to be used.

23.2.5.4 A sally port shall be permitted in a means of egress where there are provisions for continuous and unobstructed travel through the sally port during an emergency egress condition.

23.2.6 Travel Distance to Exits. Travel distance shall comply with 23.2.6.1 through 23.2.6.6.

23.2.6.1 The travel distance between any room door required as an exit access and an exit or smoke barrier shall not exceed 30 m (100 ft), unless otherwise permitted by 23.2.6.2.

23.2.6.2 The maximum travel distance limitations of 23.2.6.1 shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved automatic sprinkler system in accordance with 23.3.5.3 or a smoke control system.

23.2.6.3 The travel distance between any point in a room and an exit or smoke barrier shall not exceed 46 m (150 ft), unless otherwise permitted by 23.2.6.4.

23.2.6.4 The maximum travel distance limitations of 23.2.6.3 shall be permitted to be increased by 15 m (50 ft) in buildings protected throughout by an approved automatic sprinkler system in accordance with 23.3.5.3 or a smoke control system.

23.2.6.5 The travel distance between any point in a sleeping room to the door of that room shall not exceed 15 m (50 ft), unless otherwise permitted by 23.2.6.6.

23.2.6.6 The maximum travel distance limitations of 23.2.6.5 shall be permitted to be increased to 30 m (100 ft) in open dormitories, provided the following criteria are met:

- (1) The enclosing walls of the dormitory space shall be of smoketight construction.
- (2) Not less than two exit access doors remotely located from each other shall be provided where travel distance to the exit access door from any point within the dormitory exceeds 15 m (50 ft).

23.2.7 Discharge from Exits.

23.2.7.1 Exits shall be permitted to discharge into a fenced or walled courtyard, provided that not more than two walls of the courtyard are the building walls from which egress is being made.

23.2.7.2 Enclosed yards or courts used for exit discharge in accordance with 23.2.7.1 shall be of sufficient size to accommodate all occupants at a distance of not less than 15 m (50 ft) from the building while providing a net area of 1.4 m² (15 ft²) per person.

23.2.7.3 All exits shall be permitted to discharge through the level of exit discharge.

23.2.7.4 The requirements of 7.7.2 shall be waived, provided that not more than 50 percent of the exits discharge into a single fire compartment separated from other compartments by construction having not less than a 1-hour fire resistance rating.

23.2.7.5 Where all exits are permitted to discharge through areas on the level of discharge, the following criteria shall be met:

- (1) A smoke barrier shall be provided to divide that level into not less than two compartments with not less than one exit discharging into each compartment
- (2) Each smoke compartment shall have an exit discharge to the building exterior.
- (3) The level of discharge shall be provided with automatic sprinkler protection.
- (4) Any other portion of the level of discharge with access to the discharge area shall be provided with automatic sprinkler protection or shall be separated from the discharge area in accordance with the requirements for the enclosure of exits. (See 7.1.3.2.1.)

23.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

23.2.9 Emergency Lighting.

23.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9, unless otherwise permitted by 23.2.9.2.

23.2.9.2 Emergency lighting of not less than a 1-hour duration shall be permitted to be provided.

23.2.10 Marking of Means of Egress. Exit marking shall be provided as follows:

- (1) Exit signs shall be provided in areas accessible to the public in accordance with Section 7.10.
- (2) Exit signs shall not be required in detention and correctional residential housing areas. (See *Detention and Correctional Residential Housing Area* in 3.3.16.1.)

23.2.11 Special Features.

23.2.11.1 Doors within means of egress shall be in accordance with Chapter 7, unless otherwise provided in 23.2.11.2 through 23.2.11.9.

23.2.11.2 Doors shall be permitted to be locked in accordance with the applicable use condition.

23.2.11.3* Doors to resident sleeping rooms shall be not less than 710 mm (28 in.) in clear width.

23.2.11.4 Existing doors to resident sleeping rooms housing four or fewer residents shall be permitted to be not less than 485 mm (19 in.) in clear width.

23.2.11.5 Doors in a means of egress shall be permitted to be of the horizontal sliding type, provided that the force necessary to slide the door to its fully open position does not exceed 222 N (50 lbf) where a force of 222 N (50 lbf) is simultaneously applied perpendicular to the door.

23.2.11.6 Doors from areas of refuge to the exterior shall be permitted to be locked with key locks in lieu of locking methods described in 23.2.11.7, and the keys to unlock such doors shall be maintained and available at the facility at all times, and the locks shall be operable from the outside.

23.2.11.7* Any remote-control release used in a means of egress shall be provided with a reliable means of operation to release locks on all doors and shall be remotely located from the resident living area, unless otherwise permitted by 23.2.11.7.2.

23.2.11.7.1 The remote location of a remote-control release used in a means of egress shall provide sight and sound supervision of the resident living areas.

23.2.11.7.2 Remote-control locking and unlocking of occupied rooms in Use Condition IV shall not be required, provided that both of the following criteria are met:

- (1) Not more than 10 locks need to be unlocked to relocate all occupants from one smoke compartment to an area of refuge as promptly as is required where remote-control unlocking is used. *(See 23.3.7.9 for requirements for smoke barrier doors.)*
- (2) Unlocking of all necessary locks shall be accomplished with not more than two separate keys.

23.2.11.8 All remote-control release-operated doors shall be provided with a redundant means of operation as follows:

- (1) Power-operated sliding doors or power-operated locks shall be constructed so that, in the event of power failure, a manual mechanical means to release and open the doors is provided at each door, and either emergency power arranged in accordance with 7.9.2.2 is provided for the power operation or a remote-control manual mechanical release is provided.
- (2) A combination of the emergency power-operated release of selected individual doors and remote-control manual mechanical ganged release specified in 23.2.11.8(1) shall be permitted without mechanical release means at each door.
- (3) Mechanically operated sliding doors or mechanically operated locks shall be provided with a manual mechanical means at each door to release and open the door.

23.2.11.9 The provisions of 7.2.1.5.7 for stairway re-entry shall not apply.

23.3 Protection.

23.3.1 Protection of Vertical Openings.

23.3.1.1 Any vertical opening shall be enclosed or protected in accordance with Section 8.6, unless otherwise permitted by the following:

- (1) Unprotected vertical openings in accordance with 8.6.8.2 shall be permitted.
- (2) In residential housing area smoke compartments protected throughout by an approved automatic sprinkler system in accordance with 23.3.5.3, unprotected vertical openings shall be permitted in accordance with the conditions of 8.6.6, provided that the height between the lowest and highest finished floor levels does not exceed 7010 mm (276 in.) and the following also shall be permitted
 - (a) The number of levels shall not be restricted.
 - (b) Residential housing areas subdivided in accordance with 23.3.8 shall be permitted to be considered as part of the communicating space.
 - (c) The separation shall not be required to have a fire resistance rating. *[(See 8.6.6(4)(b).)]*
- (3) The requirement of 23.3.1.1 shall not apply to multilevel residential housing areas in accordance with 23.3.1.2.
- (4) Where full enclosure is impractical, the required enclosure shall be permitted to be limited to that necessary to prevent a fire originating in any story from spreading to any other story.
- (5) The fire resistance rating of enclosures in detention and correctional occupancies protected throughout by an approved automatic sprinkler system in accordance with 23.3.5.3 shall be not less than 1 hour.

23.3.1.2 Multilevel residential housing areas without enclosure protection between levels shall be permitted, provided that the conditions of 23.3.1.2.1 through 23.3.1.2.3 are met.

23.3.1.2.1* The entire normally occupied area, including all communicating floor levels, shall be sufficiently open and unobstructed so that a fire or other dangerous condition in any part is obvious to the occupants or supervisory personnel in the area.

23.3.1.2.2 Egress capacity shall simultaneously accommodate all occupants of all communicating levels and areas, with all communicating levels in the same fire area considered as a single floor area for purposes of determining required egress capacity.

23.3.1.2.3* The height between the highest and lowest finished floor levels shall not exceed 3960 mm (156 in.). The number of levels shall not be restricted.

23.3.1.3* A multitiered, open cell block shall be considered as a single-story building, where one of the following criteria is met:

- (1) A smoke control system is provided *(see recommended design criteria in A.23.3.1.3)* to maintain the level of smoke from potential cell fires at not less than 1525 mm (60 in.) above the floor level of any occupied tier involving space that is classified as follows:
 - (a) Use Condition IV or Use Condition V
 - (b) Use Condition III, unless all persons housed in such space can pass through a free access smoke barrier or freely pass below the calculated smoke level with not more than 15 m (50 ft) of travel from their cells
- (2) The entire building, including cells, is provided with complete automatic sprinkler protection in accordance with 23.3.5.3.

23.3.2 Protection from Hazards.

23.3.2.1* Any hazardous area shall be protected in accordance with Section 8.7. The areas described in Table 23.3.2.1 shall be protected as indicated.

Table 23.3.2.1 Hazardous Area Protection

Hazardous Area Description	Separation/Protection
Areas not incidental to resident housing	2 hours
Boiler and fuel-fired heater rooms	1 hour or sprinklers
Central or bulk laundries >9.3 m ² (>100 ft ²)	1 hour or sprinklers
Commercial cooking equipment	In accordance with 9.2.3
Commissaries	1 hour or sprinklers
Employee locker rooms	1 hour or sprinklers
Hobby/handicraft shops	1 hour or sprinklers
Maintenance shops	1 hour or sprinklers
Padded cells	1 hour and sprinklers
Soiled linen rooms	1 hour or sprinklers
Storage rooms >4.6 m ² (>50 ft ²) in area storing combustible material	1 hour or sprinklers
Trash collection rooms	1 hour or sprinklers

23.3.2.2 Hazardous areas determined by the authority having jurisdiction as not incidental to residents' housing shall be separated by 2-hour fire resistance-rated barriers in conjunction with automatic sprinkler protection.

23.3.2.3 Where cooking facilities are protected in accordance with 9.2.3, kitchens shall not be required to be provided with roomwide protection.

23.3.3 Interior Finish.

23.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

23.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in corridors, in exits, and in any space not separated from corridors and exits by partitions capable of retarding the passage of smoke; and Class A, Class B, or Class C in all other areas.

23.3.3.3 Interior Floor Finish.

23.3.3.3.1 Interior floor finish complying with Section 10.2 shall be Class I or Class II in corridors and exits.

23.3.3.3.2 Existing floor finish material of Class A or Class B in nonsprinklered smoke compartments and Class A, Class B, or Class C in sprinklered smoke compartments shall be permitted to be continued to be used, provided that it has been evaluated based on tests performed in accordance with 10.2.7.

23.3.4 Detection, Alarm, and Communications Systems.**23.3.4.1 General.**

23.3.4.1.1 Detention and correctional occupancies shall be provided with a fire alarm system in accordance with Section 9.6, except as modified by 23.3.4.1.2 through 23.3.4.4.4.

23.3.4.1.2 Existing systems lacking the monitoring of wiring required by 9.6.1.5 shall be permitted to be continued in use in buildings protected by a complete automatic extinguishing system.

23.3.4.1.3 All fire alarm systems and detection systems required in 23.3.4 shall be provided with a secondary power supply, and the installation shall be in accordance with *NFPA 72*[®], *National Fire Alarm Code*[®].

23.3.4.2 Initiation. Initiation of the required fire alarm system shall be by manual means in accordance with 9.6.2 and by means of any required detection devices or detection systems, unless otherwise permitted by the following:

- (1) Manual fire alarm boxes shall be permitted to be locked, provided that staff is present within the area when it is occupied and staff has keys readily available to unlock the boxes.
- (2) Manual fire alarm boxes shall be permitted to be located in a staff location, provided that both of the following criteria are met:
 - (a) The staff location is attended when the building is occupied.
 - (b) The staff attendant has direct supervision of the sleeping area.

23.3.4.3 Notification.

23.3.4.3.1 Occupant Notification. Occupant notification shall be accomplished automatically in accordance with 9.6.3, and the following also shall apply:

- (1) A positive alarm sequence shall be permitted in accordance with 9.6.3.4.
- (2)*Any smoke detectors required by this chapter shall be permitted to be arranged to alarm at a constantly attended location only and shall not be required to accomplish general occupant notification.

23.3.4.3.2 Emergency Forces Notification.

23.3.4.3.2.1 Fire department notification shall be accomplished in accordance with 9.6.4, unless otherwise permitted by the following:

- (1) A positive alarm sequence shall be permitted in accordance with 9.6.3.4.
- (2) Any smoke detectors required by this chapter shall not be required to transmit an alarm to the fire department.
- (3) This requirement shall not apply where staff is provided at a constantly attended location that meets one of the following criteria:
 - (a) It has the capability to promptly notify the fire department.
 - (b) It has direct communication with a control room having direct access to the fire department.

23.3.4.3.2.2 Where the provision of 23.3.4.3.2.1(3) is utilized, the fire plan, as required by 23.7.1.3, shall include procedures for logging of alarms and immediate notification of the fire department.

23.3.4.4 Detection. An approved automatic smoke detection system shall be in accordance with Section 9.6, as modified by 23.3.4.4.1 through 23.3.4.4.4, throughout all resident housing areas.

23.3.4.4.1 Smoke detectors shall not be required in sleeping rooms with four or fewer occupants in Use Condition II or Use Condition III.

23.3.4.4.2 Other arrangements and positioning of smoke detectors shall be permitted to prevent damage or tampering, or for other purposes.

23.3.4.4.2.1 Such arrangements shall be capable of detecting any fire, and the placement of detectors shall be such that the speed of detection is equivalent to that provided by the spacing and arrangements required by the installation standards referenced in Section 9.6.

23.3.4.4.2.2 Detectors shall be permitted to be located in exhaust ducts from cells, behind grilles, or in other locations.

23.3.4.4.2.3 The equivalent performance of the design, however, shall be acceptable to the authority having jurisdiction in accordance with the equivalency concepts specified in Section 1.4.

23.3.4.4.3* Smoke detectors shall not be required in Use Condition II open dormitories where staff is present within the dormitory whenever the dormitory is occupied and the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 23.3.5.3.

23.3.4.4.4 In smoke compartments protected throughout by an approved automatic sprinkler system in accordance with 23.3.5.3, smoke detectors shall not be required, except in corridors, common spaces, and sleeping rooms with more than four occupants.

23.3.5 Extinguishment Requirements.

23.3.5.1 High-rise buildings shall comply with 23.4.3.

23.3.5.2* Where required by Table 23.1.6.5, facilities shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 23.3.5.3.

23.3.5.3 Where this *Code* permits exceptions for fully sprinklered detention and correctional occupancies or sprinklered smoke compartments, the sprinkler system shall be as follows:

- (1) In accordance with Section 9.7
- (2) Installed in accordance with 9.7.1.1(1).
- (3) Electrically connected to the fire alarm system
- (4) Fully supervised

23.3.5.4 Portable fire extinguishers shall be provided in accordance with 9.7.4.1, unless otherwise permitted by the following:

- (1)*Access to portable fire extinguishers shall be permitted to be locked.
- (2) Portable fire extinguishers shall be permitted to be located at staff locations only.

23.3.5.5 Standpipe and hose systems shall be provided in accordance with 9.7.4.2 as follows, unless otherwise permitted by 23.3.5.6:

- (1) Class I standpipe systems shall be provided for any building over two stories in height.
- (2) Class III standpipe and hose systems shall be provided for all nonsprinklered buildings over two stories in height.

23.3.5.6 The requirements of 23.3.5.5 shall not apply where otherwise permitted by the following:

- (1) Formed hose, 25 mm (1 in.) in diameter, on hose reels shall be permitted to provide Class II service.
- (2) Separate Class I and Class II systems shall be permitted in lieu of a Class III system.

23.3.6 Corridors. (See 23.3.8.)

23.3.7 Subdivision of Building Spaces.

23.3.7.1* Smoke barriers shall be provided to divide every story used for sleeping by 10 or more residents, or any other story having an occupant load of 50 or more persons, into not less than two compartments, unless otherwise permitted by the following:

- (1) Protection shall be permitted to be accomplished using horizontal exits. (See 7.2.4.)
- (2)*The requirement for subdivision of building space shall be permitted to be fulfilled by one of the following:
 - (a) Smoke compartments having exit to a public way where such exit serves only one area and has no openings to other areas
 - (b) A building separated from the resident housing area by a 2-hour fire resistance rating or 15 m (50 ft) of open space
 - (c) A secured, open area having a holding space located 15 m (50 ft) from the housing area that provides 1.4 m² (15 ft²) or more of refuge area for each person (resident, staff, visitors) potentially present at the time of a fire

23.3.7.2 Doors used to access the areas specified in 23.3.7.1(2)(a), 23.3.7.1(2)(b), and 23.3.7.1(2)(c) shall meet the requirements for doors at smoke barriers for the applicable use condition.

23.3.7.3 Where smoke barriers are required by 23.3.7.1, they shall be provided as follows:

- (1) They shall limit the occupant load to not more than 200 residents in any smoke compartment.
- (2)*They shall limit the travel distance to a door in a smoke barrier, unless otherwise permitted by 23.3.7.4, as follows:
 - (a) The distance from any room door required as exit access shall not exceed 30 m (100 ft).
 - (b) The distance from any point in a room shall not exceed 46 m (150 ft).

23.3.7.4 The maximum travel distance to a door in a smoke barrier shall be permitted to be increased by 15 m (50 ft) in smoke compartments protected throughout by an approved automatic sprinkler system in accordance with 23.3.5.3 or an automatic smoke control system.

23.3.7.5* Any required smoke barrier shall be constructed in accordance with Section 8.5, shall be of substantial construction, and shall have a structural fire resistance.

23.3.7.6 Openings in smoke barriers shall be protected in accordance with Section 8.5, unless otherwise permitted by the following:

- (1)*The total number of vision panels in any barrier shall not be restricted.
- (2) Sliding doors in smoke barriers that are designed to normally be kept closed and are remotely operated from a continuously attended location shall not be required to be self-closing.

23.3.7.7 Not less than 0.55 net m² (6 net ft²) per occupant shall be provided on each side of the smoke barrier for the total number of occupants in adjoining compartments, and this space shall be readily available wherever occupants are moved across the smoke barrier in a fire emergency.

23.3.7.8 Doors shall provide resistance to the passage of smoke. Swinging doors shall be self-latching, or the opening resistance of the door shall be not less than 22 N (5 lbf). Such doors shall not be required to swing in the direction of egress travel.

23.3.7.9 Doors in smoke barriers shall conform with the requirements for doors in means of egress as specified in Section 23.2 and shall have locking and release arrangements according to the applicable use condition. The provisions of 23.2.11.7.2 shall not be used for smoke barrier doors serving a smoke compartment containing more than 20 persons.

23.3.7.10 Vision panels shall be provided in smoke barriers at points where the barrier crosses an exit access corridor.

23.3.7.11 Smoke dampers shall be provided in accordance with 8.5.4, unless otherwise permitted by 23.3.7.12.

23.3.7.12 Arrangements and positioning of smoke detectors required by 23.3.7.11 shall be permitted to prevent damage or tampering, or for other purposes, provided that the following criteria are met:

- (1) Such arrangements shall be capable of detecting any fire.
- (2) The placement of detectors shall be such that the speed of detection is equivalent to that provided by the spacing and arrangement required by *NFPA 72®*, *National Fire Alarm Code®*, as referenced in 8.5.4.7.1.

23.3.8* Special Protection Features — Subdivision of Resident Housing Spaces. Subdivision of facility spaces shall comply with Table 23.3.8.

23.4 Special Provisions.

23.4.1 Limited Access Structures.

23.4.1.1 Limited access structures used as detention and correctional occupancies shall comply with 23.4.1.2, unless otherwise permitted by the following:

- (1) The provisions of Section 11.7 for limited access less structures shall not apply.
- (2) The requirement of 23.4.1.1 shall not apply to buildings protected throughout by an approved automatic sprinkler system in accordance with 23.3.5.3.

Table 23.3.8 Subdivision of Resident Housing Spaces

Feature	Use Condition							
	II		III				IV	
	NS	AS	NS	AS	NS	AS	NS	AS
Room to room separation	NR	NR	NR	NR	SR	NR	SR	SR†
Room face to corridor separation	NR	NR	SR‡	NR	SR‡	NR	FR‡	SR†
Room face to common space separation	NR	NR	NR	SR‡	SR‡	NR	SR‡	SR†
			≤15 m	>15 m	≤15 m	>15 m	≤15 m	>15 m
			(≤50 ft)§	(>50 ft)§	(≤50 ft)§	(>50 ft)§	(≤50 ft)§	(>50 ft)§
Common space to corridor separation	SR	NR	SR	NR	SR	NR	FR	SR†
Total openings in solid room face where room face is required to be smoke resistant or fire rated [#]	0.08 m ² (0.85 ft ²)		0.08 m ² (0.85 ft ²)				0.08 m ² (0.85 ft ²)	
							Where meeting one of the following: (1) kept in closed position except when in use by staff (2) closable from the inside (3) with smoke control	

NS: Not protected by automatic sprinklers.

AS: Protected by automatic sprinklers.

NR: No requirement.

SR: Smoke resistant.

FR: Fire rated — 1 hour.

Notes:

1. Doors in openings in partitions required to be fire rated (FR) in accordance with Table 23.3.8 in other than required enclosures of exits or hazardous areas shall be substantial doors of construction that resists fire for not less than 20 minutes. Vision panels with wired glass or glass with not less than 45-minute fire-rated glazing shall be permitted. Latches and door closers shall not be required on cell doors.

2. Doors in openings in partitions required to be smoke resistant (SR) in accordance with Table 23.3.8 shall be substantial doors of construction that resists the passage of smoke. Latches and door closers shall not be required on cell doors.

3. Under Use Condition II, Use Condition III, or Use Condition IV, a space subdivided by open construction (any combination of grating doors and grating walls or solid walls) shall be permitted to be considered one room if housing not more than 16 persons. The perimeter walls of such space shall be of smoke-resistant construction. Smoke detection shall be provided in such space. Under Use Condition IV, common walls between sleeping areas within the space shall be smoke resistant, and grating doors and fronts shall be permitted to be used. Under Use Condition II and Use Condition III, open dormitories shall be permitted to house more than 16 persons as permitted by other sections of this chapter.

4. Where barriers are required to be smoke resistant (SR), the provisions of Section 8.5 shall not apply.

†Might be no requirement (NR) where one of the following is provided:

(1) An approved automatic smoke detection system installed in all corridors and common spaces

(2) Multitiered cell blocks meeting the requirements of 23.3.1.3

‡Might be no requirement (NR) in multitiered, open cell blocks meeting the requirements of 23.3.1.3.

§Travel distance through the common space to the exit access corridor.

[#]Total openings in solid room face[†] includes all openings (for example, undercuts, food passes, grilles), the total of which shall not exceed 0.08 m² (0.85 ft²). All openings shall be 915 mm (36 in.) or less above the floor.

23.4.1.2 Any one of the following means shall be provided to evacuate smoke from the smoke compartment of fire origin:

- (1) Operable windows on not less than two sides of the building, spaced not more than 9140 mm (360 in.) apart, that provide openings with dimensions of not less than 560 mm (22 in.) in width and 610 mm (24 in.) in height
- (2)*Manual or automatic smoke vents
- (3) Engineered smoke control system
- (4) Mechanical exhaust system providing not less than 6 air changes per hour
- (5) Other method acceptable to the authority having jurisdiction

23.4.2 Underground Buildings. See Section 11.7 for requirements for underground buildings.

23.4.3 High-Rise Buildings. Existing high-rise buildings shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 23.3.5.3. A sprinkler control valve and a waterflow device shall be provided for each floor.

23.5 Building Services.

23.5.1 Utilities.

23.5.1.1 Utilities shall comply with the provisions of Section 9.1.

23.5.1.2 Alarms, emergency communication systems, and the illumination of generator set installations shall be provided with emergency power in accordance with NFPA 70, *National Electrical Code*[®], unless otherwise permitted by 23.5.1.3.

23.5.1.3 Systems complying with earlier editions of NFPA 70, *National Electrical Code*[®], and not presenting a life safety hazard shall be permitted to continue to be used.

23.5.2 Heating, Ventilating, and Air Conditioning.

23.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2 and shall be installed in accordance with the manufacturer's specifications, unless otherwise permitted by the following:

- (1) The requirement of 23.5.2.1 shall not apply where otherwise modified by 23.5.2.2.
- (2) Systems complying with earlier editions of the applicable codes and not presenting a life safety hazard shall be permitted to continue to be used.

23.5.2.2 Portable space-heating devices shall be prohibited, unless otherwise permitted by 23.5.2.4.

23.5.2.3 Any heating device other than a central heating plant shall be designed and installed so that combustible material cannot be ignited by the device or its appurtenances, and the following requirements also shall apply:

- (1) If fuel-fired, such heating devices shall comply with the following:
 - (a) They shall be chimney connected or vent connected.
 - (b) They shall take air for combustion directly from outside.
 - (c) They shall be designed and installed to provide for complete separation of the combustion system from the atmosphere of the occupied area.
- (2) The heating system shall have safety devices to immediately stop the flow of fuel and shut down the equipment in case of either excessive temperatures or ignition failure.

23.5.2.4 Approved, suspended unit heaters shall be permitted in locations other than means of egress and sleeping areas, provided that both of the following criteria are met:

- (1) Such heaters are located high enough to be out of the reach of persons using the area.
- (2) Such heaters are vent connected and equipped with the safety devices required by 23.5.2.3.

23.5.2.5 Combustion and ventilation air for boiler, incinerator, or heater rooms shall be taken directly from and discharged directly to the outside.

23.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

23.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes.

23.5.4.1 Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

23.5.4.2 Rubbish chutes and linen chutes, including pneumatic rubbish and linen systems, shall be provided with automatic extinguishing protection in accordance with Section 9.7.

23.5.4.3 Trash chutes shall discharge into a trash collection room used for no other purpose and protected in accordance with Section 8.7.

23.5.4.4 Incinerators shall not be directly flue-fed, and floor chutes shall not directly connect with the combustion chamber.

23.6 (Reserved)

23.7 Operating Features.

23.7.1 Attendants, Evacuation Plan, Fire Drills.

23.7.1.1 Detention and correctional facilities, or those portions of facilities having such occupancy, shall be provided with 24-hour staffing, and the following requirements also shall apply:

- (1) Staff shall be within three floors or a 91-m (300-ft) horizontal distance of the access door of each resident housing area.
- (2) In addition, for Use Condition III, Use Condition IV, and Use Condition V, the arrangement shall be such that the staff involved starts the release of locks necessary for emergency evacuation or rescue and initiates other necessary emergency actions within 2 minutes of alarm.
- (3) The following shall apply to areas in which all locks are unlocked remotely in compliance with 23.2.11.7.
 - (a) Staff shall not be required to be within three floors or 91 m (300 ft) of the access door.
 - (b) The 10-lock, manual key exemption of 23.2.11.7.2 shall not be permitted to be used in conjunction with this alternative requirement.

23.7.1.2* Provisions shall be made so that residents in Use Condition III, Use Condition IV, and Use Condition V shall be able to notify staff of an emergency.

23.7.1.3* The administration of every detention or correctional facility shall have, in effect and available to all supervisory personnel, written copies of a plan for the protection of all persons in the event of fire, for their evacuation to areas of refuge, and for evacuation from the building when necessary.

23.7.1.3.1 All employees shall be instructed and drilled with respect to their duties under the plan.

23.7.1.3.2 The plan shall be coordinated with and reviewed by the fire department legally committed to serve the facility.

23.7.1.4 Employees of detention and correctional occupancies shall be instructed in the proper use of portable fire extinguishers and other manual fire suppression equipment.

23.7.1.4.1 Such training shall be provided to new staff promptly upon commencement of duty.

23.7.1.4.2 Refresher training shall be provided to existing staff at not less than annual intervals.

23.7.2 Combustible Personal Property. Books, clothing, and other combustible personal property allowed in sleeping rooms shall be stored in closable metal lockers or an approved fire-resistant container.

23.7.3 Heat-Producing Appliances. The number of heat-producing appliances, such as toasters and hot plates, and the overall use of electrical power within a sleeping room shall be controlled by facility administration.

23.7.4* Furnishings, Bedding, and Decorations.

23.7.4.1 Draperies and curtains, including privacy curtains, in detention and correctional occupancies, shall be in accordance with the provisions of 10.3.1.

23.7.4.2 Newly introduced upholstered furniture within detention and correctional occupancies shall be tested in accordance with the provisions of 10.3.2(2) and 10.3.3.

23.7.4.3* Newly introduced mattresses within detention and correctional occupancies shall be tested in accordance with the provisions of 10.3.2(3) and 10.3.4.

23.7.4.4 Combustible decorations shall be prohibited in any detention or correctional occupancy unless flame-retardant.

23.7.4.5 Wastebaskets and other waste containers shall be of noncombustible or other approved materials. Waste containers with a capacity exceeding 76 L (20 gal) shall be provided with a noncombustible lid or lid of other approved material.

23.7.5 Keys. All keys necessary for unlocking doors installed in a means of egress shall be individually identified by both touch and sight.

23.7.6 Portable Space-Heating Devices. Portable space-heating devices shall be prohibited in all detention and correctional occupancies.

Chapter 24 One- and Two-Family Dwellings

24.1 General Requirements.

24.1.1 Application.

24.1.1.1* The requirements of this chapter shall apply to one- and two-family dwellings, which shall include those buildings containing not more than two dwelling units in which each dwelling unit is occupied by members of a single family with not more than three outsiders, if any, accommodated in rented rooms.

24.1.1.2 The requirements of this chapter shall apply to new buildings and to existing or modified buildings according to the provisions of 1.3.1 of this *Code*.

24.1.2 Multiple Occupancies.

24.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

24.1.2.2 No dwelling unit of a residential occupancy shall have its sole means of egress pass through any nonresidential occupancy in the same building.

24.1.2.3 Multiple dwelling units of a residential occupancy shall be permitted to be located above a nonresidential occupancy only where one of the following conditions exists:

- (1) Where the dwelling unit of the residential occupancy and exits therefrom are separated from the nonresidential occupancy by construction having a fire resistance rating of not less than 1 hour.
- (2) Where the nonresidential occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (3) Where the nonresidential occupancy is protected by an automatic fire detection system in accordance with Section 9.6.

24.1.3 Definitions. Terms applicable to this chapter are defined in Chapter 3 of this *Code*; where necessary, other terms are defined in the text.

24.1.4 Classification of Occupancy. See 24.1.1.1.

24.1.5 Classification of Hazard of Contents. The contents of residential occupancies shall be classified as ordinary hazard in accordance with 6.2.2.

24.1.6 Minimum Construction Requirements. (No special requirements.)

24.1.7 Occupant Load. (No requirements.)

24.2* Means of Escape Requirements.

24.2.1 General. The provisions of Chapter 7 shall not apply to means of escape unless specifically referenced in this chapter.

24.2.2 Number and Types of Means of Escape.

24.2.2.1 Number of Means of Escape.

24.2.2.1.1 In dwellings or dwelling units of two rooms or more, every sleeping room and every living area shall have not less than one primary means of escape and one secondary means of escape.

24.2.2.1.2 A secondary means of escape shall not be required where one of the following conditions are met:

- (1) The bedroom or living area has a door leading directly to the outside of the building at or to grade level.
- (2) The dwelling unit is protected throughout by an approved automatic sprinkler system in accordance with 24.3.5.

24.2.2.2 Primary Means of Escape. The primary means of escape shall be a door, stairway, or ramp providing a means of unobstructed travel to the outside of the dwelling unit at street or ground level.

24.2.2.3* Secondary Means of Escape. The secondary means of escape, other than existing approved means of escape, shall be one of the means specified in 24.2.2.3(A) through 24.2.2.3(C).

(A) It shall be a door, stairway, passage, or hall providing a way of unobstructed travel to the outside of the dwelling at

street or ground level that is independent of and remote from the primary means of escape.

(B) It shall be a passage through an adjacent nonlockable space, independent of and remote from the primary means of escape, to any approved means of escape.

(C)* It shall be an outside window or door operable from the inside without the use of tools, keys, or special effort and shall provide a clear opening of not less than 0.53 m^2 (5.7 ft^2). The width shall be not less than 510 mm (20 in.), and the height shall be not less than 610 mm (24 in.). The bottom of the opening shall be not more than 1120 mm (44 in.) above the floor. Such means of escape shall be acceptable where one of the following criteria are met:

- (1) The window shall be within 6100 mm (240 in.) of grade.
- (2) The window shall be directly accessible to fire department rescue apparatus as approved by the authority having jurisdiction.
- (3) The window or door shall open onto an exterior balcony.
- (4) Windows having a sill height below the adjacent ground level shall be provided with a window well meeting the following criteria:
 - (a) The window well shall have horizontal dimensions that allow the window to be fully opened.
 - (b) The window well shall have an accessible net clear opening of not less than 0.82 m^2 (9 ft^2) with a length and width of not less than 915 mm (36 in.).
 - (c) A window well with a vertical depth of more than 1120 mm (44 in.) shall be equipped with an approved permanently affixed ladder or with steps meeting the following criteria:
 - i. The ladder or steps shall not encroach more than 150 mm (6 in.) into the required dimensions of the window well.
 - ii. The ladder or steps shall not be obstructed by the window.

(D) Ladders or steps that comply with the requirements of 24.2.2.3(C)(4)(c) shall be exempt from the requirements of 7.2.2.

24.2.2.4 In buildings, other than existing buildings and other than those protected throughout by an approved, supervised automatic sprinkler system in accordance with 24.3.5, every story more than 185 m^2 (2000 ft^2) in area within the dwelling unit shall be provided with two primary means of escape remotely located from each other.

24.2.3 Arrangement of Means of Escape. Any required path of travel in a means of escape from any room to the outside shall not pass through another room or apartment not under the immediate control of the occupant of the first room or through a bathroom or other space subject to locking.

24.2.4 Doors.

24.2.4.1 Doors in the path of travel of a means of escape, other than bathroom doors in accordance with 24.2.4.2, shall be not less than 710 mm (28 in.) wide.

24.2.4.2 Bathroom doors shall be not less than 610 mm (24 in.) wide.

24.2.4.3 Doors shall be not less than 1980 mm (78 in.) in nominal height.

24.2.4.4 Every closet door latch shall be such that children can open the door from inside the closet.

24.2.4.5 Every bathroom door shall be designed to allow opening from the outside during an emergency when locked.

24.2.4.6 Doors shall be swinging or sliding.

24.2.4.7* No door in any means of escape shall be locked against egress when the building is occupied. All locking devices that impede or prohibit egress or that cannot be easily disengaged shall be prohibited.

24.2.4.8 Floor levels at doors in the primary means of escape shall comply with 7.2.1.3, unless otherwise permitted by the following:

- (1) Where the door discharges to the outside or to an exterior balcony or exterior exit access, the floor level outside the door shall be permitted to be one step lower than the inside, but shall not be in excess of 180 mm (7 in.).
- (2) A door at the top of a stair shall be permitted to open directly at a stair, provided that the door does not swing over the stair and the door serves an area with an occupant load of fewer than 50 persons.

24.2.4.9 Forces to open doors shall comply with 7.2.1.4.5.

24.2.4.10 Latching devices for doors shall comply with 7.2.1.5.9.

24.2.5 Stairs, Ramps and Guards.

24.2.5.1 Stairs, ramps, guards, and handrails shall be in accordance with 7.2.2 for stairs, 7.2.2.4 for guards, and 7.2.5 for ramps, as modified by 24.2.5.1.1 through 24.2.5.1.3.

24.2.5.1.1 The provisions of 7.2.2.5, 7.2.5.5, and 7.7.3 shall not apply.

24.2.5.1.2 If serving as a secondary means of escape, stairs complying with the fire escape requirements of Table 7.2.8.4.1(a) or Table 7.2.8.4.1(b) shall be permitted.

24.2.5.1.3 If serving as a secondary means of escape, ramps complying with the existing ramp requirements of Table 7.2.5.2(b) shall be permitted.

24.2.5.2 Interior stairways shall be provided with means capable of providing artificial light at the minimum level specified by 7.8.1.3 for exit stairs, measured at the center of treads and on landing surfaces within 610 mm (24 in.) of step nosings.

24.2.5.3 For interior stairways, manual lighting controls shall be reachable and operable without traversing any step of the stair.

24.2.5.4 The clear width of stairs, landings, ramps, balconies, and porches shall be not less than 910 mm (36 in.), measured in accordance with 7.3.2.

24.2.5.5 Spiral stairs and winders in accordance with 7.2.2.2.3 and 7.2.2.2.4 shall be permitted within a single dwelling unit.

24.2.5.6 No sleeping rooms or living areas shall be accessible only by a ladder, a stair ladder, an alternating tread device, or folding stairs or through a trap door.

24.2.6 Hallways.

24.2.6.1 The width of hallways, other than existing approved hallways which shall be permitted to be continued to be used, shall be not less than 910 mm (36 in.).

24.2.6.2 The height of hallways, other than existing approved hallways which shall be permitted to be continued to be used,

shall be not less than 2135 mm (84 in.) nominal, with clearance below projections from the ceiling of not less than 2030 mm (80 in.) nominal.

24.2.7 Bulkheads.

24.2.7.1 Bulkhead Enclosures. Where provided, bulkhead enclosures shall provide direct access to the basement from the exterior.

24.2.7.2 Bulkhead Enclosure Stairways. Stairways serving bulkhead enclosures that are not part of the required primary means of escape and that provide access from the outside grade level to the basement shall be exempt from the provisions of 24.2.5.1 when the maximum height from the basement finished floor level to grade adjacent to the stairway does not exceed 2348 mm (8 ft), and the grade level opening to the stairway is covered by a bulkhead enclosure with hinged doors or other approved means.

24.3 Protection.

24.3.1 Protection of Vertical Openings. (No requirements.)

24.3.2 Reserved.

24.3.3 Interior Finish.

24.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

24.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A, Class B, or Class C.

24.3.3.3 Interior Floor Finish. (No requirements.)

24.3.4 Detection, Alarm, and Communications Systems. Smoke alarms or a smoke detection system shall be provided in accordance with either 24.3.4.1 or 24.3.4.2, as modified by 24.3.4.3.

24.3.4.1 Smoke alarms shall be installed in accordance with 9.6.2.10 in the following locations:

- (1) All sleeping rooms in other than existing one- and two-family dwellings
- (2) Outside of each separate sleeping area, in the immediate vicinity of the sleeping rooms
- (3) On each level of the dwelling unit, including basements

24.3.4.2 Dwelling units shall be protected by an approved smoke detection system in accordance with Section 9.6 and equipped with an approved means of occupant notification.

24.3.4.3 In existing one- and two-family dwellings, approved smoke alarms powered by batteries shall be permitted.

24.3.5* Extinguishment Requirements.

24.3.5.1 Where an automatic sprinkler system is required or is used as an alternative method of protection, either for total or partial building coverage, the system shall be in accordance with Section 9.7.

24.3.5.2 In buildings up to and including four stories in height, systems in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, and with NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, shall also be permitted.

24.4 Reserved.

24.5 Building Services.

24.5.1 Heating, Ventilating, and Air Conditioning.

24.5.1.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

24.5.1.2 Unvented fuel-fired heaters shall not be used unless they are listed and approved.

Chapter 25 Reserved

Chapter 26 Lodging or Rooming Houses

26.1 General Requirements.

26.1.1 Application.

26.1.1.1* The requirements of this chapter shall apply to buildings that provide sleeping accommodations for 16 or fewer persons on either a transient or permanent basis, with or without meals, but without separate cooking facilities for individual occupants, except as provided in Chapter 24.

26.1.1.2 The requirements of this chapter shall apply to new buildings and to existing or modified buildings according to the provisions of 1.3.1 of this *Code*.

26.1.2 Multiple Occupancies.

26.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

26.1.2.2 No lodging or rooming house shall have its sole means of egress pass through any nonresidential occupancy in the same building.

26.1.2.3 Lodging or rooming houses shall be permitted to be located above a nonresidential occupancy only where one of the following conditions exists:

- (1) Where the lodging or rooming house and exits therefrom are separated from the nonresidential occupancy by construction having a fire resistance rating of not less than 1 hour.
- (2) Where the nonresidential occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7.
- (3) Where the lodging or rooming house is located above a nonresidential occupancy, and the nonresidential occupancy is protected by an automatic fire detection system in accordance with Section 9.6.

26.1.3 Definitions. Terms applicable to this chapter are defined in Chapter 3 of this *Code*, where necessary, other terms are defined in the text.

26.1.4 Classification of Occupancy. See 26.1.1.1.

26.1.5 Classification of Hazard of Contents. The contents of residential occupancies shall be classified as ordinary hazard in accordance with 6.2.2.

26.1.6 Minimum Construction Requirements. (No special requirements.)

26.1.7 Occupant Load. See 26.1.1.1.

26.2 Means of Escape Requirements.

26.2.1 Number and Types of Means of Escape.

26.2.1.1 Primary Means of Escape.

26.2.1.1.1 Every sleeping room and living area shall have access to a primary means of escape complying with Chapter 24 and located to provide a safe path of travel to the outside.

26.2.1.1.2 Where the sleeping room is above or below the level of exit discharge, the primary means of escape shall be an interior stair in accordance with 26.2.2, an exterior stair, a horizontal exit in accordance with 7.2.4, or an existing fire escape stair in accordance with 7.2.8.

26.2.1.2 Secondary Means of Escape. In addition to the primary route, each sleeping room and living area shall have a second means of escape in accordance with 24.2.2, unless the sleeping room or living area has a door leading directly outside the building with access to grade or to a stairway that meets the requirements for exterior stairs in 26.2.1.1.

26.2.1.3 Two Primary Means of Escape. In other than existing buildings and those protected throughout by an approved, supervised automatic sprinkler system in accordance with 26.3.5, every story more than 185 m² (2000 ft²) in area or with travel distance to the primary means of escape more than 23 m (75 ft) shall be provided with two primary means of escape remotely located from each other.

26.2.2 Stairways.

26.2.2.1 Interior stairways, other than those in accordance with 26.2.2.2 or 26.2.2.3, shall comply with 7.2.2.5.3 and shall be enclosed by ½-hour fire barriers with all openings protected with smoke-actuated automatic-closing or self-closing doors having a fire resistance comparable to that required for the enclosure.

26.2.2.2 Where an interior stair connects the street floor with the story next above or below only, but not with both, the interior stair shall be required to be enclosed only on the street floor.

26.2.2.3 Stairways shall be permitted to be unenclosed in accordance with 26.3.1.1.2 and 26.3.1.1.3.

26.2.2.4 Winders in accordance with 7.2.2.4 shall be permitted.

26.2.3 Doors.

26.2.3.1 Doors in a means of escape, other than bathroom doors in accordance with 26.2.3.2, and paths of travel in a means of escape shall be not less than 710 mm (28 in.) wide.

26.2.3.2 Bathroom doors shall be not less than 610 mm (24 in.) wide.

26.2.3.3 Every closet door latch shall be such that it can be readily opened from the inside in case of emergency.

26.2.3.4 Every bathroom door shall be designed to allow opening from the outside during an emergency when locked.

26.2.3.5 Door locking arrangements shall comply with either 26.2.3.5.1 or 26.2.3.5.2.

26.2.3.5.1* No door in any means of escape shall be locked against egress when the building is occupied.

26.2.3.5.2 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted, provided that not more than one such device is located in any one escape path.

26.2.3.6 Doors serving a single dwelling unit shall be permitted to be provided with a lock in accordance with 7.2.1.5.6.

26.3 Protection.

26.3.1 Protection of Vertical Openings.

26.3.1.1 Vertical openings shall comply with 26.3.1.1.1, 26.3.1.1.2, or 26.3.1.1.3.

26.3.1.1.1 Vertical openings shall be protected so that no primary escape route is exposed to an unprotected vertical opening.

26.3.1.1.1.1 The vertical opening shall be considered protected if the opening is cut off and enclosed in a manner that provides a smoke- and fire-resisting capability of not less than ½ hour.

26.3.1.1.1.2 Any doors or openings shall have a smoke- and fire-resisting capability equivalent to that of the enclosure and shall be automatic-closing on detection of smoke or shall be self-closing.

26.3.1.1.2 In buildings three or fewer stories in height that are protected throughout by an approved automatic sprinkler system in accordance with 26.3.5, unprotected vertical openings shall be permitted, provided that a primary means of escape from each sleeping area is provided that does not pass through a portion of a lower floor unless such portion is separated from all spaces on that floor by construction having a ½-hour fire resistance rating.

26.3.1.1.3 Stair enclosures shall not be required in buildings two or fewer stories in height where both of the following conditions exist:

- (1) The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 26.3.5.1.
- (2) The allowance of 24.2.2.1.2 to omit a secondary means of escape is not used.

26.3.1.2* Exterior stairs shall be protected against blockage caused by fire within the building.

26.3.2 Interior Finish.

26.3.2.1 General. Interior finish shall be in accordance with Section 10.2.

26.3.2.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A, Class B, or Class C.

26.3.2.3 Interior Floor Finish.

26.3.2.3.1 Newly installed interior floor finish shall comply with Section 10.2.

26.3.2.3.2 Newly installed interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

26.3.3 Detection, Alarm, and Communications Systems.

26.3.3.1 General.

26.3.3.1.1 Lodging and rooming houses, other than those meeting 26.3.3.1.2, shall be provided with a fire alarm system in accordance with Section 9.6.

26.3.3.1.2 A fire alarm system in accordance with Section 9.6 shall not be required in existing lodging and rooming houses that have an existing smoke detection system meeting or exceeding the requirements of 26.3.3.5.1 where that detection system includes not less than one manual fire alarm box per floor arranged to initiate the smoke detection alarm.

26.3.3.2 Initiation. Initiation of the required fire alarm system shall be by manual means in accordance with 9.6.2, or by alarm initiation in accordance with 9.6.2.1(3) in buildings protected throughout by an approved automatic sprinkler system in accordance with 26.3.5.

26.3.3.3 Notification. Occupant notification shall be provided automatically in accordance with 9.6.3, as modified by 26.3.3.3.1 and 26.3.3.3.2.

26.3.3.3.1* Visible signals for the hearing impaired shall not be required where the proprietor resides in the building and there are five or fewer rooms for rent.

26.3.3.3.2 Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.

26.3.3.4 Detection. (Reserved)

26.3.3.5 Smoke Alarms.

26.3.3.5.1 Approved single-station smoke alarms, other than existing smoke alarms meeting 26.3.3.5.3, shall be installed in accordance with 9.6.2.10 in every sleeping room.

26.3.3.5.2 The smoke alarms required by 26.3.3.5.1 shall not be required to be interconnected.

26.3.3.5.3 Existing battery-powered smoke alarms, rather than house electric-powered smoke alarms, shall be permitted where the facility has demonstrated to the authority having jurisdiction that the testing, maintenance, and battery replacement programs will ensure reliability of power to the smoke alarms.

26.3.4 Separation of Sleeping Rooms.

26.3.4.1 All sleeping rooms shall be separated from escape route corridors by smoke partitions in accordance with Section 8.4.

26.3.4.2 There shall be no louvers or operable transoms in corridor walls.

26.3.4.3 Air passages shall not penetrate corridor walls unless they are properly installed heating and utility installations other than transfer grilles.

26.3.4.4 Transfer grilles shall be prohibited in corridor walls.

26.3.4.5 Doors shall be provided with latches or other mechanisms suitable for keeping the doors closed.

26.3.4.6 Doors shall not be arranged to prevent the occupant from closing the door.

26.3.4.7 In buildings other than those protected throughout by an approved, automatic sprinkler system in accordance with 26.3.5, doors shall be self-closing or automatic-closing upon detection of smoke.

26.3.5 Extinguishment Requirements.

26.3.5.1 All new lodging or rooming houses, other than those meeting 26.3.5.2, shall be protected throughout by an approved automatic sprinkler system in accordance with 26.3.5.3.

26.3.5.2 An automatic sprinkler system shall not be required where every sleeping room has a door opening directly to the outside of the building at street or ground level, or has a door opening directly to the outside leading to an exterior stairway that meets the requirements of 26.2.1.1.

26.3.5.3 Where an automatic sprinkler system is required or is used as an alternative method of protection, either for total or partial building coverage, the system shall be in accordance with Section 9.7 and 26.3.5.3.1 through 26.3.5.3.6.

26.3.5.3.1 Activation of the automatic sprinkler system shall actuate the fire alarm system in accordance with Section 9.6.

26.3.5.3.2 Systems in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be permitted in buildings up to and including four stories in height.

26.3.5.3.3* Systems in accordance with NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, shall be permitted where the following requirements are met:

- (1) The lodging or rooming house shall not be part of a mixed occupancy.
- (2) Entrance foyers shall be sprinklered.
- (3) Lodging or rooming houses with sleeping accommodations for more than eight occupants shall be treated as two-family dwellings with regard to the water supply.

26.3.5.3.4 In buildings sprinklered in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, closets less than 1.1 m² (12 ft²) in area in individual dwelling units shall not be required to be sprinklered.

26.3.5.3.5 In buildings sprinklered in accordance with NFPA 13, closets that contain equipment such as washers, dryers, furnaces, or water heaters shall be sprinklered regardless of size.

26.3.5.3.6 In existing lodging or rooming houses, sprinkler installations shall not be required in closets not exceeding 2.2 m² (24 ft²) and in bathrooms not exceeding 5.1 m² (55 ft²).

26.4 Reserved.

26.5 Building Services.

26.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

26.5.2 Heating, Ventilating, and Air Conditioning.

26.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

26.5.2.2 Unvented fuel-fired heaters other than gas space heaters in compliance with NFPA 54, *National Fuel Gas Code*, shall not be used.

26.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

Chapter 27 Reserved

Chapter 28 New Hotels and Dormitories

28.1 General Requirements.

28.1.1 Application.

28.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as hotel or dormitory occupancies (see 1.3.1)
- (2) Additions made to, or used as, a hotel or dormitory occupancy (see 4.6.7)
- (3) Alterations, modernizations, or renovations of existing hotel or dormitory occupancies (see 4.6.8)
- (4) Buildings or portions thereof upon change of occupancy to a hotel or dormitory occupancy (see 4.6.12)

28.1.1.2 Any dormitory divided into suites of rooms, with one or more bedrooms opening into a living room or study that has a door opening into a common corridor serving a number of suites, shall be classified as an apartment building.

28.1.1.3 The term *hotel*, wherever used in this *Code*, shall include a hotel, inn, club, motel, bed and breakfast, or any other structure meeting the definition of *hotel*.

28.1.2 Multiple Occupancies.

28.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

28.1.2.2 No guest room or guest suite of a hotel or dormitory occupancy shall have its sole means of egress pass through any nonresidential occupancy in the same building.

28.1.3 Definitions. Terms applicable to this chapter are defined in Chapter 3 of this *Code* and include the terms in the list that follows:

- (1) **Dormitory.** See 3.3.48.
- (2) **Guest Room.** See 3.3.100.
- (3) **Guest Suite.** See 3.3.101.
- (4) **Hotel.** See 3.3.113.

28.1.4 Classification of Occupancy. See 28.1.3.

28.1.5 Classification of Hazard of Contents.

28.1.5.1 The contents of residential occupancies shall be classified as ordinary hazard in accordance with 6.2.2.

28.1.5.2 For the design of automatic sprinkler systems, the classification of contents in NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall apply.

28.1.6 Minimum Construction Requirements. (No special requirements.)

28.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

28.2 Means of Egress Requirements.

28.2.1 General.

28.2.1.1 Means of egress from guest rooms or guest suites to the outside of the building shall be in accordance with Chapter 7 and this chapter.

28.2.1.2 Means of escape within the guest room or guest suite shall comply with the provisions of Section 24.2 for one- and two-family dwellings.

28.2.1.3 For the purpose of application of the requirements of Chapter 24, the terms *guest room* and *guest suite* shall be synonymous with the terms *dwelling* or *living unit*.

28.2.2 Means of Egress Components.

28.2.2.1 General.

28.2.2.1.1 Components of means of egress shall be limited to the types described in 28.2.2.2 through 28.2.2.12.

28.2.2.1.2 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5, exit enclosures shall have a fire resistance rating of not less than 1 hour, and the fire protection rating of doors shall be not less than 1 hour.

28.2.2.2 Doors.

28.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

28.2.2.2.2 Door locking arrangements shall comply with 28.2.2.2.2.1, 28.2.2.2.2.2, or 28.2.2.2.2.3.

28.2.2.2.2.1 No door in any means of egress shall be locked against egress when the building is occupied.

28.2.2.2.2.2 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted, provided that not more than one such device is located in any one egress path.

28.2.2.2.2.3 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

28.2.2.2.3 Revolving doors complying with 7.2.1.10 shall be permitted.

28.2.2.2.4 Horizontal sliding doors, as permitted by 7.2.1.14, shall not be used across corridors.

28.2.2.3 Stairs. Stairs complying with 7.2.2 shall be permitted.

28.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

28.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

28.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

28.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

28.2.2.8 Reserved.

28.2.2.9 Reserved.

28.2.2.10 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

28.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

28.2.2.12 Areas of Refuge.

28.2.2.12.1 Areas of refuge complying with 7.2.12 shall be permitted, as modified by 28.2.2.12.2.

28.2.2.12.2* In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5, the two accessible rooms or spaces separated from each other by smoke-resistive partitions in accordance with the definition of area of refuge in 3.3.17 shall not be required.

28.2.3 Capacity of Means of Egress.

28.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

28.2.3.2 Street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs and ramps discharging onto the street floor.

28.2.3.3* Corridors, other than those within individual guest rooms or individual guest suites, shall be of sufficient width to accommodate the required occupant load, and shall be not less than 1120 mm (44 in.).

28.2.4 Number of Exits.

28.2.4.1 In buildings other than those complying with 28.2.4.2, not less than two separate exits shall be provided on each story. (See also Section 7.4.)

28.2.4.2 Buildings of four stories or less protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5, with not more than four guest rooms or guest suites per floor, shall be permitted to have a single exit under the following conditions:

- (1) The stairway is completely enclosed or separated by barriers having a fire resistance rating of not less than 1 hour, with self-closing 1-hour fire door assemblies protecting all openings between the stairway enclosure and the building.
- (2) The stairway does not serve more than one-half of a story below the level of exit discharge.
- (3) All corridors serving as access to exits have not less than a 1-hour fire resistance rating.
- (4) The travel distance from the entrance door of any guest room or guest suite to an exit does not exceed 10.7 m (35 ft).
- (5) Horizontal and vertical separation with a fire rating of not less than ½ hour is provided between guest rooms or guest suites.

28.2.5 Arrangement of Means of Egress.

28.2.5.1 Access to all required exits shall be in accordance with Section 7.5, as modified by 28.2.5.2.

28.2.5.2 The distance between exits addressed by 7.5.1.4 shall not apply to common nonlooped exit access corridors in buildings that have corridor doors from the guest room or guest suite that are arranged such that the exits are located in opposite directions from such doors.

28.2.5.3 In buildings not protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5, common paths of travel shall not exceed 10.7 m (35 ft); travel within a guest room or guest suite shall not be included when calculating common path of travel.

28.2.5.4 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5, common path of travel shall not exceed 15 m (50 ft); travel within a guest room or guest suite shall not be included when determining common path of travel.

28.2.5.5 In buildings not protected throughout by an approved, automatic sprinkler system in accordance with 28.3.5, dead-end corridors shall not exceed 10.7 m (35 ft).

28.2.5.6 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5, dead-end corridors shall not exceed 15 m (50 ft).

28.2.5.7 Any guest room or any guest suite of rooms in excess of 185 m² (2000 ft²) shall be provided with not less than two exit access doors remotely located from each other.

28.2.6 Travel Distance to Exits.

28.2.6.1 Travel distance within a guest room or guest suite to a corridor door shall not exceed 23 m (75 ft) in buildings not protected by an approved, supervised automatic sprinkler system in accordance with 28.3.5.

28.2.6.2 Travel distance within a guest room or guest suite to a corridor door shall not exceed 38 m (125 ft) in buildings protected by an approved, supervised automatic sprinkler system in accordance with 28.3.5.

28.2.6.3 Travel distance from the corridor door of any guest room or guest suite to the nearest exit shall comply with 28.2.6.3.1, 28.2.6.3.2, or 28.2.6.3.3.

28.2.6.3.1 Travel distance from the corridor door of any guest room or guest suite to the nearest exit, measured in accordance with Section 7.6, shall not exceed 30 m (100 ft).

28.2.6.3.2 Travel distance from the corridor door of any guest room or guest suite to the nearest exit, measured in accordance with Section 7.6, shall not exceed 61 m (200 ft) for exterior ways of exit access arranged in accordance with 7.5.3.

28.2.6.3.3 Travel distance from the corridor door of any guest room or guest suite to the nearest exit shall comply with 28.2.6.3.3.1 and 28.2.6.3.3.2.

28.2.6.3.3.1 Travel distance from the corridor door of any guest room or guest suite to the nearest exit shall be measured in accordance with Section 7.6 and shall not exceed 61 m (200 ft) where the exit access and any portion of the building that is tributary to the exit access are protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5.

28.2.6.3.3.2 The portion of the building in which the 61-m (200-ft) travel distance is permitted shall be separated from the remainder of the building by construction having a fire resistance rating of not less than 1 hour for buildings not more than three stories in height, and 2 hours for buildings more than three stories in height.

28.2.7 Discharge from Exits.

28.2.7.1 Exit discharge shall comply with Section 7.7.

28.2.7.2* Any required exit stair that is located so that it is necessary to pass through the lobby or other open space to reach the outside of the building shall be continuously enclosed down to a level of exit discharge or to a mezzanine within a lobby at a level of exit discharge.

28.2.7.3 The distance of travel from the termination of the exit enclosure to an exterior door leading to a public way shall not exceed 30 m (100 ft).

28.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

28.2.9 Emergency Lighting.

28.2.9.1 Emergency lighting in accordance with Section 7.9 shall be provided.

28.2.9.2 The requirement of 28.2.9.1 shall not apply where each guest room or guest suite has an exit direct to the outside of the building at street or ground level.

28.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

28.2.11 Special Means of Egress Features. (Reserved)

28.3 Protection.

28.3.1 Protection of Vertical Openings.

28.3.1.1 Vertical openings shall comply with 28.3.1.1.1, 28.3.1.1.2, or 28.3.1.1.3.

28.3.1.1.1 Vertical openings shall be enclosed or protected in accordance with Section 8.6.

28.3.1.1.2 Vertical openings in accordance with 8.6.8.2 shall be permitted.

28.3.1.1.3 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5, the fire resistance of walls enclosing vertical openings shall be not less than 1 hour and the fire protection rating of doors shall be not less than 1 hour.

28.3.1.2 No floor below the level of exit discharge used only for storage, heating equipment, or purposes other than residential occupancy shall have unprotected openings to floors used for residential purposes.

28.3.2 Protection from Hazards.

28.3.2.1 General. All rooms containing high-pressure boilers, refrigerating machinery, transformers, or other service equipment subject to possible explosion shall not be located directly under or directly adjacent to exits and shall be effectively cut off from other parts of the building as specified in Section 8.4.

28.3.2.2 Hazardous Areas.

28.3.2.2.1 Any hazardous area shall be protected in accordance with Section 8.4.

28.3.2.2.2 The areas described in Table 28.3.2.2.2 shall be protected as indicated.

Table 28.3.2.2.2 Hazardous Area Protection

Hazardous Area Description	Separation/Protection
Boiler and fuel-fired heater rooms serving more than a single guest room or guest suite	1 hour and sprinklers
Employee locker rooms	1 hour or sprinklers
Gift or retail shops	1 hour or sprinklers
Bulk laundries	1 hour and sprinklers
Guest laundries $\leq 9.3 \text{ m}^2$ ($\leq 100 \text{ ft}^2$) outside of guest rooms or guest suites	1 hour or sprinklers [†]
Guest laundries $> 9.3 \text{ m}^2$ ($> 100 \text{ ft}^2$) outside of guest rooms or guest suites	1 hour and sprinklers
Maintenance shops	1 hour and sprinklers
Storage rooms [‡]	1 hour or sprinklers
Trash collection rooms	1 hour and sprinklers

[†]Where automatic sprinkler protection is provided, no enclosure shall be required.

[‡]Where storage areas not exceeding 2.2 m^2 (24 ft^2) are directly accessible from the guest room or guest suite, no separation or protection shall be required.

28.3.2.2.3 Where sprinkler protection without fire-rated separation is used, areas shall be separated from other spaces by smoke partitions complying with Section 8.4.

28.3.3 Interior Finish.

28.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

28.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be permitted as follows:

- (1) Exit enclosures — Class A
- (2) Lobbies and corridors — Class A or Class B
- (3) Other spaces — Class A, Class B, or Class C

28.3.3.3 Interior Floor Finish.

28.3.3.3.1 Interior floor finish shall comply with Section 10.2.

28.3.3.3.2 Interior floor finish in exit enclosures and exit access corridors and spaces not separated from them by walls complying with 28.3.6.1 shall be not less than Class II.

28.3.3.3.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

28.3.3.4* Furnishings and Decorations. New draperies, curtains, and other similar loosely hanging furnishings and decorations in hotels and dormitories shall be in accordance with the provisions of 10.3.1.

28.3.4 Detection, Alarm, and Communications Systems.

28.3.4.1 General. A fire alarm system in accordance with Section 9.6, except as modified by 28.3.4.2 through 28.3.4.5, shall be provided.

28.3.4.2 Initiation. The required fire alarm system shall be initiated by each of the following:

- (1) Manual means in accordance with 9.6.2
- (2) A manual fire alarm box located at the hotel desk or other convenient central control point under continuous supervision by responsible employees
- (3) Any automatic sprinkler system
- (4) Any required automatic detection system other than sleeping room smoke detectors

28.3.4.3 Notification.

28.3.4.3.1* Occupant notification shall be provided automatically in accordance with 9.6.3.

28.3.4.3.2 Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.

28.3.4.3.3* Guest rooms and guest suites specifically required and equipped to accommodate hearing impaired individuals shall be provided with a visible notification appliance.

28.3.4.3.4 In occupiable areas, other than guest rooms and guest suites, visible notification appliances shall be provided.

28.3.4.3.5 Annunciation in accordance with 9.6.7 shall be provided in buildings exceeding two stories in height or having more than 50 guest rooms or guest suites.

28.3.4.3.6* Provisions shall be made for the immediate notification of the public fire department by telephone or other means in case of fire, and, where there is no public fire department, notification shall be made to the private fire brigade.

28.3.4.4 Detection. A corridor smoke detection system in accordance with Section 9.6 shall be provided in buildings other than those protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5.3.

28.3.4.5* Smoke Alarms. An approved single-station smoke alarm shall be installed in accordance with 9.6.2.10 in every guest room and every living area and sleeping room within a guest suite.

28.3.5 Extinguishment Requirements.

28.3.5.1 All buildings other than those complying with 28.3.5.2 shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5.3.

28.3.5.2 Automatic sprinkler protection shall not be required in buildings where all guest sleeping rooms or guest suites have a door opening directly to either of the following:

- (1) The outside at the street or grade level
- (2) Exterior exit access arranged in accordance with Section 7.5.3 in buildings up to and including three stories in height above grade.

28.3.5.3 Where an automatic sprinkler system is installed, either for total or partial building coverage, the system shall be in accordance with Section 9.7, as modified by 28.3.5.4; in buildings up to and including four stories in height above grade, systems in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be permitted.

28.3.5.4 The provisions for draft stops and closely spaced sprinklers in NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall not be required for openings complying with 8.6.8.2 where the opening is within the guest room or guest suite.

28.3.5.5 Listed quick-response or listed residential sprinklers shall be used throughout guest rooms and guest room suites.

28.3.5.6 Open parking structures that comply with NFPA 88A, *Standard for Parking Structures*, and are contiguous with hotels or dormitories shall be exempt from the sprinkler requirements of 28.3.5.1.

28.3.5.7 In buildings other than those protected throughout with an approved, supervised automatic sprinkler system in accordance with 28.3.5.3, portable fire extinguishers shall be provided as specified in 9.7.4.1 in hazardous areas addressed by 28.3.2.2.

28.3.6 Corridors.

28.3.6.1 Walls. Exit access corridor walls shall comply with 28.3.6.1.1 or 28.3.6.1.2.

28.3.6.1.1 In buildings not complying with 28.3.6.1.2, exit access corridor walls shall consist of fire barriers in accordance with Section 8.3 that have not less than a 1-hour fire resistance rating.

28.3.6.1.2 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5, corridor walls shall have not less than a ½-hour fire resistance rating.

28.3.6.2 Doors. Doors that open onto exit access corridors shall have not less than a 20-minute fire protection rating in accordance with Section 8.3.

28.3.6.3 Reserved.

28.3.6.4 Doors that open onto exit access corridors shall be self-closing and self-latching.

28.3.6.5 Unprotected openings, other than those from spaces complying with 28.3.6.6, shall be prohibited in exit access corridor walls and doors.

28.3.6.6 Spaces shall be permitted to be unlimited in area and open to the corridor, provided that the following criteria are met:

- (1) The spaces are not used for guest rooms or guest suites or hazardous areas.
- (2) The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 28.3.5.
- (3) The space does not obstruct access to required exits.

28.3.6.7 Transoms, louvers, or transfer grilles shall be prohibited in walls or doors of exit access corridors.

28.3.7 Subdivision of Building Spaces. Buildings shall be subdivided in accordance with 28.3.7.1 or 28.3.7.2.

28.3.7.1 In buildings not protected throughout by an approved, supervised automatic sprinkler system, each hotel guest room, including guest suites, and dormitory room shall be separated from other guest rooms or dormitory rooms by walls and floors constructed as fire barriers having fire resistance ratings of not less than one hour.

28.3.7.2 In buildings protected throughout by an approved, supervised automatic sprinkler system, each hotel guest room, including guest suites, and dormitory room shall be separated from other guest rooms or dormitory rooms by walls and floors constructed as fire barriers having fire resistance ratings of not less than ½ hour.

28.3.8 Special Protection Features. (Reserved)

28.4 Special Provisions.

28.4.1 High-Rise Buildings. High-rise buildings shall comply with Section 11.8.

28.5 Building Services.

28.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

28.5.2 Heating, Ventilating, and Air Conditioning.

28.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2, except as otherwise required in this chapter.

28.5.2.2 Unvented fuel-fired heaters, other than gas space heaters in compliance with NFPA 54, *National Fuel Gas Code*, shall not be used.

28.5.3 Elevators, Escalators, and Conveyors.

28.5.3.1 Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

28.5.3.2* In high-rise buildings, one elevator shall be provided with a protected power supply and shall be available for use by the fire department in case of emergency.

28.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

28.6 Reserved.

28.7 Operating Features.**28.7.1 Hotel Emergency Organization.**

28.7.1.1* Employees of hotels shall be instructed and drilled in the duties they are to perform in the event of fire, panic, or other emergency.

28.7.1.2* Drills of the emergency organization shall be held at quarterly intervals and shall cover such points as the operation and maintenance of the available first aid fire appliances, the testing of devices to alert guests, and a study of instructions for emergency duties.

28.7.2 Emergency Duties. Upon discovery of a fire, employees shall carry out the following duties:

- (1) Activate the facility fire protection signaling system, if provided
- (2) Notify the public fire department
- (3) Take other action as previously instructed

28.7.3 Drills in Dormitories. Emergency egress and relocation drills shall be regularly conducted in accordance with Section 4.7.

28.7.4 Emergency Instructions for Residents or Guests.

28.7.4.1* A floor diagram reflecting the actual floor arrangement, exit locations, and room identification shall be posted in a location and manner acceptable to the authority having jurisdiction on, or immediately adjacent to, every guest room door in hotels and in every resident room in dormitories.

28.7.4.2* Fire safety information shall be provided to allow guests to make the decision to evacuate to the outside, to evacuate to an area of refuge, to remain in place, or to employ any combination of the three options.

Chapter 29 Existing Hotels and Dormitories**29.1 General Requirements.****29.1.1 Application.**

29.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as hotel or dormitory occupancies, unless meeting 29.1.1.2. (*See also 28.1.1.*)

29.1.1.2 Any dormitory divided into suites of rooms, with one or more bedrooms opening into a living room or study that has a door opening into a common corridor serving a number of suites, shall be classified as an apartment building.

29.1.1.3 The term *hotel*, wherever used in this *Code*, shall include a hotel, inn, club, motel, bed and breakfast, or any other structure meeting the definition of *hotel*.

29.1.2 Multiple Occupancies.

29.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

29.1.2.2 No guest room or guest suite of a hotel or dormitory shall have its sole means of egress pass through any nonresidential occupancy in the same building.

29.1.3 Definitions. Terms applicable to this chapter are defined in Chapter 3 of this *Code* and include the terms in the list that follows:

- (1) **Dormitory.** See 3.3.48.
- (2) **Guest Room.** See 3.3.100.
- (3) **Guest Suite.** See 3.3.101.
- (4) **Hotel.** See 3.3.113.

29.1.4 Classification of Occupancy. See 29.1.3.

29.1.5 Classification of Hazard of Contents.

29.1.5.1 The contents of residential occupancies shall be classified as ordinary hazard in accordance with 6.2.2.

29.1.5.2 For the design of automatic sprinkler systems, the classification of contents in NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall apply.

29.1.6 Minimum Construction Requirements. (No special requirements.)

29.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

29.2 Means of Egress Requirements.**29.2.1 General.**

29.2.1.1 Means of egress from guest rooms or guest suites to the outside of the building shall be in accordance with Chapter 7 and this chapter.

29.2.1.2 Means of escape within the guest room or guest suite shall comply with the provisions of Section 24.2 for one- and two-family dwellings.

29.2.1.3 For the purpose of application of the requirements of Chapter 24, the terms *guest room* and *guest suite* shall be synonymous with the terms *dwelling* or *living unit*.

29.2.2 Means of Egress Components.**29.2.2.1 General.**

29.2.2.1.1 Components of means of egress shall be limited to the types described in 29.2.2.2 through 29.2.2.12.

29.2.2.1.2 In buildings protected throughout by an approved automatic sprinkler system in accordance with 29.3.5, exit enclosures shall have a fire resistance rating of not less than 1 hour, and the fire protection rating of doors shall be not less than 1 hour.

29.2.2.2 Doors.

29.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

29.2.2.2.2 Door locking arrangements shall comply with 29.2.2.2.2.1, 29.2.2.2.2.2, or 29.2.2.2.2.3.

29.2.2.2.2.1 No door in any means of egress shall be locked against egress when the building is occupied.

29.2.2.2.2.2 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted, provided that not more than one such device is located in any one egress path.

29.2.2.2.2.3 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

29.2.2.2.3 Revolving doors complying with 7.2.1.10 shall be permitted.

29.2.2.2.4 Horizontal sliding doors, as permitted by 7.2.1.14, shall not be used across corridors.

29.2.2.3 Stairs. Stairs complying with 7.2.2 shall be permitted.

29.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

29.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

29.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

29.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

29.2.2.8* Escalators. Escalators previously approved as a component in a means of egress shall be permitted to continue to be considered in compliance.

29.2.2.9 Fire Escape Stairs. Fire escape stairs complying with 7.2.8 shall be permitted.

29.2.2.10 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

29.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

29.2.2.12 Areas of Refuge.

29.2.2.12.1 Areas of refuge complying with 7.2.12 shall be permitted, as modified by 28.2.2.12.2.

29.2.2.12.2* In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 29.3.5, the two accessible rooms or spaces separated from each other by smoke-resistive partitions in accordance with the definition of area of refuge in 3.3.17 shall not be required.

29.2.3 Capacity of Means of Egress.

29.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

29.2.3.2 Street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs and ramps discharging onto the street floor.

29.2.4 Number of Exits.

29.2.4.1 In buildings other than those complying with 29.2.4.2, not less than two exits shall be accessible from every floor, including floors below the level of exit discharge and floors occupied for public purposes.

29.2.4.2 Buildings of four stories or less protected throughout by an approved, supervised automatic sprinkler system in accordance with 29.3.5, with not more than four guest rooms or guest suites per floor, shall be permitted to have a single exit under the following conditions:

- (1) The stairway is completely enclosed or separated by barriers having a fire resistance rating of not less than 1 hour, with self-closing 1-hour fire protection-rated doors protecting all openings between the stairway enclosure and the building.
- (2) The stairway does not serve more than one-half of a story below the level of exit discharge.
- (3) All corridors serving as access to exits have not less than a 1-hour fire resistance rating.

- (4) The travel distance from the entrance door of any guest room or guest suite to an exit does not exceed 10.7 m (35 ft).
- (5) Horizontal and vertical separation with a fire rating of not less than ½ hour is provided between guest rooms or guest suites.

29.2.5 Arrangement of Means of Egress.

29.2.5.1 Access to all required exits shall be in accordance with Section 7.5.

29.2.5.2 Reserved.

29.2.5.3 In buildings not protected throughout by an approved, supervised automatic sprinkler system in accordance with 29.3.5, common paths of travel shall not exceed 10.7 m (35 ft); travel within a guest room or guest suite shall not be included when calculating common path of travel.

29.2.5.4 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 29.3.5, common path of travel shall not exceed 15 m (50 ft); travel within a guest room or guest suite shall not be included when determining common path of travel.

29.2.5.5 Dead-end corridors shall not exceed 50 ft (15 m).

29.2.6 Travel Distance to Exits.

29.2.6.1 Travel distance within a guest room or guest suite to a corridor door shall not exceed 23 m (75 ft) in buildings not protected by an approved, supervised automatic sprinkler system in accordance with 29.3.5.

29.2.6.2 Travel distance within a guest room or guest suite to a corridor door shall not exceed 38 m (125 ft) in buildings protected by an approved, supervised automatic sprinkler system in accordance with 29.3.5.

29.2.6.3 Travel distance from the corridor door of any guest room or guest suite to the nearest exit shall comply with 29.2.6.3.1, 29.2.6.3.2, or 29.2.6.3.3.

29.2.6.3.1 Travel distance from the corridor door of any guest room or guest suite to the nearest exit, measured in accordance with Section 7.6, shall not exceed 30 (100 ft).

29.2.6.3.2 Travel distance from the corridor door of any guest room or guest suite to the nearest exit, measured in accordance with Section 7.6, shall not exceed 61 m (200 ft) for exterior ways of exit access arranged in accordance with 7.5.3.

29.2.6.3.3 Travel distance from the corridor door of any guest room or guest suite to the nearest exit, shall comply with 29.2.6.3.3.1 and 29.2.6.3.3.2.

29.2.6.3.3.1 Travel distance from the corridor door of any guest room or guest suite to the nearest exit shall be measured in accordance with Section 7.6, and shall not exceed 61 m (200 ft) where the exit access and any portion of the building that is tributary to the exit access are protected throughout by an approved, supervised automatic sprinkler system in accordance with 29.3.5.

29.2.6.3.3.2 The portion of the building in which the 61-m (200-ft) travel distance is permitted shall be separated from the remainder of the building by construction having a fire resistance rating of not less than 1 hour for buildings not more than three stories in height, and 2 hours for buildings more than three stories in height.

29.2.7 Discharge from Exits.

29.2.7.1 Exit discharge shall comply with Section 7.7.

29.2.7.2* Any required exit stair that is located so that it is necessary to pass through the lobby or other open space to reach the outside of the building shall be continuously enclosed down to a level of exit discharge or to a mezzanine within a lobby at a level of exit discharge.

29.2.7.3 The distance of travel from the termination of the exit enclosure to an exterior door leading to a public way shall not exceed 46 m (150 ft) in buildings protected throughout by an approved automatic sprinkler system in accordance with 29.3.5 and shall not exceed 30 m (100 ft) in all other buildings.

29.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

29.2.9 Emergency Lighting.

29.2.9.1 Emergency lighting in accordance with Section 7.9 shall be provided in all buildings with more than 25 rooms.

29.2.9.2 The requirement of 29.2.9.1 shall not apply where each guest room or guest suite has an exit direct to the outside of the building at street or ground level.

29.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

29.2.11 Special Means of Egress Features. (Reserved)**29.3 Protection.****29.3.1 Vertical Openings.**

29.3.1.1 Vertical openings shall comply with 29.3.1.1.1, 29.3.1.1.2, 29.3.1.1.3, or 29.3.1.1.4.

29.3.1.1.1 Vertical openings shall be enclosed or protected in accordance with Section 8.6.

29.3.1.1.2 Vertical openings in accordance with 8.6.8.2 shall be permitted.

29.3.1.1.3 In buildings protected throughout by an approved automatic sprinkler system in accordance with 29.3.5, and in which exits and required ways of travel thereto are adequately safeguarded against fire and smoke within the building, or where every individual room has direct access to an exterior exit without passing through any public corridor, the protection of vertical openings that are not part of required exits shall not be required where approved by the authority having jurisdiction and where such openings do not endanger required means of egress.

29.3.1.1.4 In buildings not more than two stories in height, unprotected openings shall be permitted by the authority having jurisdiction to continue to be used where the building is protected throughout by an approved automatic sprinkler system in accordance with 29.3.5.

29.3.1.2 No floor below the level of exit discharge used only for storage, heating equipment, or purposes other than residential occupancy shall have unprotected openings to floors used for residential purposes.

29.3.2 Protection from Hazards.

29.3.2.1 General. All rooms containing high-pressure boilers, refrigerating machinery, transformers, or other service equipment subject to possible explosion shall not be located directly

under or directly adjacent to exits and shall be effectively cut off from other parts of the building as specified in Section 8.4.

29.3.2.2 Hazardous Areas.

29.3.2.2.1 Any hazardous area shall be protected in accordance with Section 8.7.

29.3.2.2.2 The areas described in Table 29.3.2.2.2 shall be protected as indicated.

Table 29.3.2.2.2 Hazardous Area Protection

Hazardous Area Description	Separation/Protection
Boiler and fuel-fired heater rooms serving more than a single guest room or guest suite	1 hour or sprinklers
Employee locker rooms	1 hour or sprinklers
Gift or retail shops >9.3 m ² (>100 ft ²)	1 hour or sprinklers [†]
Bulk laundries	1 hour or sprinklers
Guest laundries >9.3 m ² (>100 ft ²) outside of guest rooms or guest suites	1 hour or sprinklers [†]
Maintenance shops	1 hour and sprinklers
Rooms or spaces used for storage of combustible supplies and equipment in quantities deemed hazardous by the authority having jurisdiction [†]	1 hour or sprinklers
Trash collection rooms	1 hour and sprinklers

[†]Where automatic sprinkler protection is provided, no enclosure shall be required.

[†]Where storage areas not exceeding 2.2 m² (24 ft²) are directly accessible from the guest room or guest suite, no separation or protection shall be required.

29.3.2.2.3 Where sprinkler protection without fire-rated separation is used, areas shall be separated from other spaces by smoke partitions complying with Section 8.4.

29.3.3 Interior Finish.

29.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

29.3.3.2 Interior-Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be permitted as follows:

- (1) Exit enclosures — Class A or Class B
- (2) Lobbies and corridors — Class A or Class B
- (3) Other spaces — Class A, Class B, or Class C

29.3.3.3 Interior Floor Finish. In nonsprinklered buildings, newly installed interior floor finish in exits and exit access corridors shall be not less than Class II in accordance with 10.2.7.

29.3.3.4* Furnishings and Decorations. New draperies, curtains, and other similar loosely hanging furnishings and decorations in hotels and dormitories shall be in accordance with the provisions of 10.3.1.

29.3.4 Detection, Alarm, and Communications Systems.

29.3.4.1 General. A fire alarm system in accordance with Section 9.6, except as modified by 29.3.4.2 through 29.3.4.5.2, shall be provided in buildings other than those where each guest room has exterior exit access in accordance with 7.5.3, and the building does not exceed three stories in height.

29.3.4.2 Initiation. The required fire alarm system shall be initiated by each of the following:

- (1) Manual means in accordance with 9.6.2, unless there are other effective means to activate the fire alarm system, such as complete automatic sprinkler or automatic detection systems. The manual fire alarm box in accordance with 29.3.4.2(2) shall be required.
- (2) A manual fire alarm box located at the hotel desk or other convenient central control point under continuous supervision by responsible employees
- (3) Any required automatic sprinkler system
- (4) Any required automatic detection system other than sleeping room smoke detectors.

29.3.4.3 Notification.

29.3.4.3.1 Occupant notification shall be provided automatically in accordance with 9.6.3.

29.3.4.3.2 Positive alarm sequence in accordance with 9.6.3.4, and a presignal system in accordance with 9.6.3.3, shall be permitted.

29.3.4.3.3 Reserved.**29.3.4.3.4 Reserved.****29.3.4.3.5 Reserved.**

29.3.4.3.6* Provisions shall be made for the immediate notification of the public fire department by telephone or other means in case of fire, and, where there is no public fire department, notification shall be made to the private fire brigade.

29.3.4.4 Detection. (Reserved)

29.3.4.5* Smoke Alarms. An approved single-station smoke alarm shall be installed in accordance with 9.6.2.10 in every guest room and every living area and sleeping room within a guest suite.

29.3.4.5.1 These alarms shall not be required to be interconnected.

29.3.4.5.2 Single-station smoke alarms without a secondary (standby) power source shall be permitted.

29.3.5 Extinguishment Requirements.

29.3.5.1 All high-rise buildings, other than those where each guest room or guest suite has exterior exit access in accordance with 7.5.3, shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 29.3.5.3.

29.3.5.2 Reserved.

29.3.5.3* Where an automatic sprinkler system is installed, either for total or partial building coverage, the system shall be in accordance with Section 9.7, as modified by 29.3.5.4, and 29.3.5.5; in buildings up to and including four stories in height above grade, systems in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be permitted.

29.3.5.4 The provisions for draft stops and closely spaced sprinklers in NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall not be required for openings complying with 8.6.8.2 where the opening is within the guest room or guest suite.

29.3.5.5 In guest rooms and in guest room suites, sprinkler installations shall not be required in closets not exceeding 2.2 m² (24 ft²) and in bathrooms not exceeding 5.1 m² (55 ft²).

29.3.5.6 Reserved.

29.3.5.7 In buildings other than those protected throughout with an approved, supervised automatic sprinkler system in accordance with 29.3.5.3, portable fire extinguishers shall be provided as specified in 9.7.4.1 in hazardous areas addressed by 29.3.2.2.

29.3.6 Corridors.

29.3.6.1 Walls. Exit access corridor walls shall comply with either 29.3.6.1.1 or 29.3.6.1.2.

29.3.6.1.1 In buildings not complying with 29.3.6.1.2, exit access corridor walls shall consist of fire barriers in accordance with 8.2.3 that have not less than a ½-hour fire resistance rating.

29.3.6.1.2 In buildings protected throughout by an approved, automatic sprinkler system in accordance with 29.3.5, no fire resistance rating shall be required but the walls and all openings therein shall resist the passage of smoke.

29.3.6.2 Doors. Doors that open onto exit access corridors, other than those complying with 8.3.4 or in buildings meeting 29.3.6.3, shall have not less than a 20-minute fire protection rating in accordance with Section 8.3.

29.3.6.3 Where automatic sprinkler protection is provided in the corridor in accordance with 31.3.5.6 through 31.3.5.9, doors shall not be required to have a fire protection rating but shall resist the passage of smoke and be equipped with latches to keep doors tightly closed.

29.3.6.4 Doors that open onto exit access corridors shall be self-closing and self-latching.

29.3.6.5 Unprotected openings, other than those from spaces complying with 29.3.6.6, shall be prohibited in exit access corridor walls and doors.

29.3.6.6 Spaces shall be permitted to be unlimited in area and open to the corridor, provided that the following criteria are met:

- (1) The spaces are not used for guest rooms or guest suites or hazardous areas.
- (2) The space is protected throughout by an approved automatic sprinkler system in accordance with 29.3.5.
- (3) The space does not obstruct access to required exits.

29.3.6.7 Transoms, louvers, or transfer grilles shall be prohibited in walls or doors of exit access corridors, unless meeting 29.3.6.7.1, 29.3.6.7.2, or 29.3.6.7.3.

29.3.6.7.1 Existing transoms shall be permitted but shall be fixed in the closed position and shall be covered or otherwise protected to provide a fire resistance rating not less than that of the wall in which they are installed.

29.3.6.7.2 The requirement of 29.3.6.7 shall not apply where a corridor smoke detection system is provided that, when sensing smoke, sounds the building alarm and shuts down return

or exhaust fans that draw air into the corridor from the guest rooms. The transfer grille or louver shall be located in the lower one-third of the wall or door height.

29.3.6.7.3 The requirement of 29.3.6.7 shall not apply to buildings protected throughout by an approved automatic sprinkler system complying with 29.3.5 or buildings with corridor sprinkler protection in accordance with 31.3.5.6 through 31.3.5.9. The transfer grille or louver shall be located in the lower one-third of the wall or door height.

29.3.7 Subdivision of Building Spaces. In buildings other than those meeting 29.3.7.1, 29.3.7.2, or 29.3.7.3, every guest room floor shall be divided into not less than two smoke compartments of approximately the same size by smoke barriers in accordance with Section 8.5.

29.3.7.1 Smoke barriers shall not be required in buildings protected throughout by an approved automatic sprinkler system in accordance with 29.3.5 or a corridor sprinkler system conforming to 31.3.5.6 through 31.3.5.9.

29.3.7.2 Smoke barriers shall not be required where each guest room is provided with exterior ways of exit access arranged in accordance with 7.5.3.

29.3.7.3 Smoke barriers shall not be required where the aggregate corridor length on each floor is not more than 46 m (150 ft).

29.3.7.4 Additional smoke barriers shall be provided so that the travel distance from a guest room corridor door to a smoke barrier shall not exceed 46 m (150 ft).

29.3.7.5 Smoke dampers shall not be required.

29.3.8 Special Protection Features. (Reserved)

29.4 Special Provisions.

29.4.1 High-Rise Buildings. High-rise buildings shall comply with 29.3.5.1.

29.5 Building Services.

29.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

29.5.2 Heating, Ventilating, and Air Conditioning.

29.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2, except as otherwise required in this chapter.

29.5.2.2 Unvented fuel-fired heaters, other than gas space heaters in compliance with NFPA 54, *National Fuel Gas Code*, shall not be used.

29.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

29.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

29.6 Reserved.

29.7 Operating Features.

29.7.1 Hotel Emergency Organization.

29.7.1.1* Employees of hotels shall be instructed and drilled in the duties they are to perform in the event of fire, panic, or other emergency.

29.7.1.2* Drills of the emergency organization shall be held at quarterly intervals and shall cover such points as the operation and maintenance of the available first aid fire appliances, the testing of devices to alert guests, and a study of instructions for emergency duties.

29.7.2 Emergency Duties. Upon discovery of a fire, employees shall carry out the following duties:

- (1) Activate the facility fire protection signaling system, if provided
- (2) Notify the public fire department
- (3) Take other action as previously instructed

29.7.3 Drills in Dormitories. Emergency egress and relocation drills shall be regularly conducted in accordance with Section 4.7.

29.7.4 Emergency Instructions for Residents or Guests.

29.7.4.1* A floor diagram reflecting the actual floor arrangement, exit locations, and room identification shall be posted in a location and manner acceptable to the authority having jurisdiction on, or immediately adjacent to, every guest room door in hotels and in every resident room in dormitories.

29.7.4.2* Fire safety information shall be provided to allow guests to make the decision to evacuate to the outside, to evacuate to an area of refuge, to remain in place, or to employ any combination of the three options.

Chapter 30 New Apartment Buildings

30.1 General Requirements.

30.1.1 Application.

30.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as apartment occupancies (*see 1.3.1*)
- (2) Additions made to, or used as, an apartment occupancy (*see 4.6.7*)
- (3) Alterations, modernizations, or renovations of existing apartment occupancies (*see 4.6.8*)
- (4) Buildings or portions thereof upon change of occupancy to an apartment occupancy (*see 4.6.12*)

30.1.1.2 The term *apartment building*, wherever used in this Code, shall include an apartment house, tenement, garden apartment, or any other structure meeting the definition of *apartment building*.

30.1.2 Multiple Occupancies.

30.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

30.1.2.2 No dwelling unit of a residential occupancy shall have its sole means of egress pass through any nonresidential occupancy in the same building.

30.1.2.3 Multiple dwelling units shall be permitted to be located above a nonresidential occupancy only where one of the following conditions exists:

- (1) Where the dwelling units of the residential occupancy and exits therefrom are separated from the nonresidential occupancy by construction having a fire resistance rating of not less than 1 hour

- (2) Where the nonresidential occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7

30.1.3 Definitions.

30.1.3.1 Terms applicable to this chapter are defined in Chapter 3 of this *Code*; where necessary, other terms are defined in the text.

30.1.3.2 **Apartment Building.** See 3.3.27.3.

30.1.4 **Classification of Occupancy.** See 30.1.3.

30.1.5 **Classification of Hazard of Contents.** The contents of residential occupancies shall be classified as ordinary hazard in accordance with 6.2.2.

30.1.6 **Minimum Construction Requirements.** (No special requirements.)

30.1.7 **Occupant Load.** The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

30.2 Means of Egress Requirements.

30.2.1 General.

30.2.1.1 Means of egress from dwelling units to the outside of the building shall be in accordance with Chapter 7 and this chapter.

30.2.1.2 Means of escape within the dwelling unit shall comply with the provisions of Section 24.2 for one- and two-family dwellings.

30.2.2 Means of Egress Components.

30.2.2.1 General.

30.2.2.1.1 Components of means of egress shall be limited to the types described in 30.2.2.2 through 30.2.2.12.

30.2.2.1.2 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 30.3.5, exit enclosures shall have a fire resistance rating of not less than 1 hour, and doors shall have a fire protection rating of not less than 1 hour.

30.2.2.2 Doors.

30.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

30.2.2.2.2 Door locking arrangements shall comply with 30.2.2.2.1, 30.2.2.2.2, or 30.2.2.2.3.

30.2.2.2.1* No door in any means of egress shall be locked against egress when the building is occupied.

30.2.2.2.2 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted, provided that not more than one such device is located in any one egress path.

30.2.2.2.3 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

30.2.2.2.3 Revolving doors complying with 7.2.1.10 shall be permitted.

30.2.2.2.4 Horizontal sliding doors, as permitted by 7.2.1.14, shall not be used across corridors.

30.2.2.2.5 Apartment occupancies shall be exempt from the re-entry provisions of 7.2.1.5.7 when the exit enclosure serves directly only one dwelling unit per floor and such exit is a smokeproof enclosure in accordance with 7.2.3.

30.2.2.3 Stairs.

30.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

30.2.2.3.2 Within any individual dwelling unit, unless protected by an approved automatic sprinkler system in accordance with 30.3.5, stairs more than one story above or below the entrance floor level of the dwelling unit shall not be permitted.

30.2.2.3.3 Spiral stairs complying with 7.2.2.2.3 shall be permitted within a single dwelling unit.

30.2.2.3.4 Winders complying with 7.2.2.2.4 shall be permitted within a single dwelling unit.

30.2.2.4 **Smokeproof Enclosures.** Smokeproof enclosures complying with 7.2.3 shall be permitted.

30.2.2.5 **Horizontal Exits.** Horizontal exits complying with 7.2.4 shall be permitted.

30.2.2.6 **Ramps.** Ramps complying with 7.2.5 shall be permitted.

30.2.2.7 **Exit Passageways.** Exit passageways complying with 7.2.6 shall be permitted.

30.2.2.8 **Reserved.**

30.2.2.9 **Reserved.**

30.2.2.10 **Fire Escape Ladders.** Fire escape ladders complying with 7.2.9 shall be permitted.

30.2.2.11 **Alternating Tread Devices.** Alternating tread devices complying with 7.2.11 shall be permitted.

30.2.2.12 Areas of Refuge.

30.2.2.12.1 Areas of refuge complying with 7.2.12 shall be permitted, as modified by 30.2.2.12.2.

30.2.2.12.2* In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 30.3.5, the two accessible rooms or spaces separated from each other by smoke-resistive partitions in accordance with the definition of area of refuge in 3.3.17 shall not be required.

30.2.3 Capacity of Means of Egress.

30.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

30.2.3.2 Street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs and ramps discharging onto the street floor.

30.2.3.3 Corridors with a required capacity of more than 50 persons as defined in Section 7.3 shall be of sufficient width to accommodate the required occupant load but have a width of not less than 1120 mm (44 in.).

30.2.3.4 Corridors with a required capacity of not more than 50 persons as defined in Section 7.3 shall be not less than 910 mm (36 in.) in width.

30.2.4 **Number of Exits.** The minimum number of exits shall comply with 30.2.4.1, 30.2.4.2, or 30.2.4.3. (See also Section 7.4.)

30.2.4.1 Every dwelling unit shall have access to at least two separate exits remotely located from each other as required by 7.5.1.

30.2.4.2 Any dwelling unit shall be permitted to have a single exit provided that one of the following criteria is met:

- (1) The dwelling unit has an exit door opening directly to the street or yard at ground level.
- (2) The dwelling unit has direct access to an outside stair that complies with 7.2.2 and serves a maximum of two units, both of which are located on the same floor.
- (3) The dwelling unit has direct access to an interior stair that serves only that unit and is separated from all other portions of the building by fire barriers having a minimum 1-hour fire resistance rating with no opening therein.

30.2.4.3 Any building that is protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5, has four or fewer stories, and has not more than four dwelling units per story shall be permitted to have a single exit, provided that all of the following conditions apply:

- (1) The stairway is separated from the rest of the building by barriers having not less than a 1-hour fire resistance rating, with self-closing 1-hour fire door assemblies protecting all openings between the stairway enclosure and the building.
- (2) The stairway does not serve more than one-half story below the level of exit discharge.
- (3) All corridors serving as access to exits have a minimum 1-hr fire resistance rating.
- (4) There is not more than 10.7 m (35 ft) of travel distance from the entrance door of any dwelling unit to an exit.
- (5) One-half-hour fire-rated horizontal and vertical separation between dwelling units is provided.

30.2.5 Arrangement of Means of Egress.

30.2.5.1 Access to all required exits shall be in accordance with Section 7.5, as modified by 30.2.5.3.

30.2.5.2 The distance between exits addressed by 7.5.1.3 shall not apply to nonlooped exit access corridors in buildings that have corridor doors from the dwelling units that are arranged such that the exits are located in opposite directions from such doors.

30.2.5.3 Common path of travel shall comply with 30.2.5.3.1 or 30.2.5.3.2.

30.2.5.3.1 No common path of travel shall exceed 10.7 m (35 ft) in buildings not protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5. Travel within a dwelling unit shall not be included when calculating common path of travel.

30.2.5.3.2 No common path of travel shall exceed 15 m (50 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5. Travel within a dwelling unit shall not be included when determining common path of travel.

30.2.5.4 Dead-end corridors shall be limited in accordance with either 30.2.5.4.1 or 30.2.5.4.2.

30.2.5.4.1 Dead-end corridors shall not exceed 10.7 m (35 ft) in buildings not protected throughout by an approved, automatic sprinkler system in accordance with 30.3.5.

30.2.5.4.2 Dead-end corridors shall not exceed 15 m (50 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 30.3.5.

30.2.6 Travel Distance to Exits.

30.2.6.1 Travel distance within a dwelling unit (apartment) to a corridor door shall not exceed 23 m (75 ft) in buildings not protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5.

30.2.6.2 Travel distance within a dwelling unit (apartment) to a corridor door shall not exceed 38 m (125 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5.

30.2.6.3 The travel distance from a dwelling unit (apartment) entrance door to the nearest exit shall be limited in accordance with 30.2.6.3.1, 30.2.6.3.2, or 30.2.6.3.3.

30.2.6.3.1 The travel distance from a dwelling unit (apartment) entrance door to the nearest exit shall not exceed 30 m (100 ft).

30.2.6.3.2 In buildings protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5, the travel distance from a dwelling unit (apartment) entrance door to the nearest exit shall not exceed 61 m (200 ft).

30.2.6.3.3 The travel distance from a dwelling unit (apartment) entrance door to the nearest exit shall not exceed 61 m (200 ft) for exterior ways of exit access arranged in accordance with 7.5.3.

30.2.6.4 The travel distance from areas other than those within living units to the exit measured in accordance with Section 7.6 shall not exceed 61 m (200 ft), or 83 m (250 ft) in buildings protected throughout by an approved, supervised, automatic sprinkler system installed in accordance with 30.3.5.6.

30.2.7 Discharge from Exits. Exit discharge shall comply with Section 7.7.

30.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

30.2.9 Emergency Lighting. Emergency lighting in accordance with Section 7.9 shall be provided in all buildings with more than 12 dwelling units or more than three stories in height, unless every dwelling unit has a direct exit to the outside of the building at grade level.

30.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10 in all buildings requiring more than one exit.

30.2.11 Special Means of Egress Features. (Reserved)

30.3 Protection.

30.3.1 Protection of Vertical Openings.

30.3.1.1 Vertical openings shall comply with 30.3.1.1.1, 30.3.1.1.2, or 30.3.1.1.3.

30.3.1.1.1 Vertical openings shall be enclosed or protected in accordance with Section 8.6.

30.3.1.1.2 Where the provisions of 8.6.6 are used, the requirements of 30.3.5.8 shall be met.

30.3.1.1.3 Vertical openings in accordance with 8.6.8.2 shall be permitted.

30.3.1.1.4 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance

with 30.3.5, the fire resistance of walls enclosing vertical openings shall be not less than 1 hour, and the fire protection rating of doors shall be not less than 1 hour.

30.3.1.2 No floor below the level of exit discharge used only for storage, heating equipment, or purposes other than residential occupancy open to the public shall have unprotected openings to floors used for residential purposes.

30.3.1.3 No unenclosed vertical opening shall be permitted in any building or fire section with only one exit.

30.3.2 Protection from Hazards.

30.3.2.1 Hazardous Areas. Any hazardous area shall be protected in accordance with Section 8.7.

30.3.2.1.1 The areas described in Table 30.3.2.1.1 shall be protected as indicated.

Table 30.3.2.1.1 Hazardous Area Protection

Hazardous Area Description	Separation/Protection
Boiler and fuel-fired heater rooms serving more than a single dwelling unit	1 hour and sprinklers
Employee locker rooms	1 hour or sprinklers
Gift or retail shops	1 hour or sprinklers
Bulk laundries	1 hour and sprinklers
Laundries $\leq 9.3 \text{ m}^2$ ($\leq 100 \text{ ft}^2$) outside of dwelling units	1 hour or sprinklers [†]
Laundries $> 9.3 \text{ m}^2$ ($> 100 \text{ ft}^2$) outside of dwelling units	1 hour and sprinklers
Maintenance shops	1 hour and sprinklers
Storage rooms outside of dwelling units	1 hour or sprinklers
Trash collection rooms	1 hour and sprinklers

[†]Where sprinklers are provided, separation shall not be required.

30.3.2.1.2 Where sprinkler protection without fire-rated separation is used, areas shall be separated from other spaces by smoke partitions complying with Section 8.4.

30.3.3 Interior Finish.

30.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

30.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be permitted as follows:

- (1) Exit enclosures — Class A
- (2) Lobbies and corridors — Class A or Class B
- (3) Other spaces — Class A, Class B, or Class C

30.3.3.3 Interior Floor Finish.

30.3.3.3.1 Interior floor finish shall comply with Section 10.2.

30.3.3.3.2 Interior floor finish in exit enclosures and exit access corridors and spaces not separated from them by walls complying with 30.3.6 shall be not less than Class II.

30.3.3.3.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

30.3.4 Detection, Alarm, and Communications Systems.

30.3.4.1 General.

30.3.4.1.1 Apartment buildings with more than three stories or with more than 11 dwelling units, other than those meeting 30.3.4.1.2 or 30.3.4.1.3, shall be provided with a fire alarm system in accordance with Section 9.6, except as modified by 30.3.4.2 through 30.3.4.5.2.

30.3.4.1.2 A fire alarm system shall not be required in buildings where each dwelling unit is separated from other contiguous dwelling units by fire barriers (see Section 8.3) having a fire resistance rating of not less than 1 hour, and where each dwelling unit has either its own independent exit or its own independent stairway or ramp discharging at grade.

30.3.4.1.3 A fire alarm system shall not be required in buildings that are protected throughout by an approved, automatic sprinkler system in accordance with 30.3.5.1, that do not exceed four stories in height, and that contain not more than 16 dwelling units.

30.3.4.2 Initiation.

30.3.4.2.1 Initiation of the required fire alarm system shall be by manual means in accordance with 9.6.2, unless the building complies with 30.3.4.2.2.

30.3.4.2.2 Initiation of the required fire alarm system by manual means shall not be required in buildings not exceeding four stories in height, containing not more than 16 dwelling units, and protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5.1.

30.3.4.2.3 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 30.3.5, required fire alarm systems shall be initiated upon operation of the automatic sprinkler system.

30.3.4.3 Notification.

30.3.4.3.1 Occupant notification shall be provided automatically in accordance with Section 9.6, and the following shall also apply:

- (1) Visible signals shall be installed in units designed for the hearing impaired.
- (2) Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.

30.3.4.3.2 Annunciation in accordance with 9.6.7 shall be provided unless the building complies with either 30.3.4.3.3 or 30.3.4.3.4.

30.3.4.3.3 Annunciation shall not be required in buildings not exceeding two stories in height and having not more than 50 rooms.

30.3.4.3.4 Annunciation shall not be required in buildings that are protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5.1, that do not exceed four stories in height, and that contain not more than 16 dwelling units.

30.3.4.3.5 Fire department notification shall be accomplished in accordance with 9.6.4.

30.3.4.4 Detection. (Reserved)

30.3.4.5 Smoke Alarms.

30.3.4.5.1* Approved single-station smoke alarms shall be installed in accordance with 9.6.2.10 outside every sleeping area in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements.

30.3.4.5.2 In buildings other than those protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5, approved single-station smoke alarms shall be installed in every sleeping room in accordance with 9.6.2.10.

30.3.5 Extinguishment Requirements.

30.3.5.1 All buildings, other than those complying with 30.3.5.2, shall be protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 30.3.5.3.

30.3.5.2 Sprinkler systems shall not be required in buildings where every dwelling unit complies with one of the following:

- (1) An exit door opening directly to the street or yard at ground level
- (2) Direct access to an outside stair that complies with 7.2.2 and serves a maximum of two units, both located on the same floor
- (3) Direct access to an interior stair serving only that unit and separated from all other portions of the building by fire barriers having a 1-hour fire resistance rating with no openings therein

30.3.5.3 Where an automatic sprinkler system is installed, either for total or partial building coverage, the system shall be installed in accordance with Section 9.7, as modified by 30.3.5.4 and 30.3.5.5. In buildings up to and including four stories in height above grade, systems in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be permitted.

30.3.5.4 In buildings sprinklered in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, closets less than 1.1 m² (12 ft²) in area in individual dwelling units shall not be required to be sprinklered. Closets that contain equipment such as washers, dryers, furnaces, or water heaters shall be sprinklered regardless of size.

30.3.5.5 The draft stop and closely spaced sprinkler requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall not be required for convenience openings complying with 8.6.8.2 where the convenience opening is within the dwelling unit.

30.3.5.6 Listed quick-response or listed residential sprinklers shall be used throughout all dwelling units.

30.3.5.7 Open parking structures complying with NFPA 88A, *Standard for Parking Structures*, that are contiguous with apartment buildings shall be exempt from the sprinkler requirements of 30.3.5.1.

30.3.5.8 Buildings with unprotected openings in accordance with 8.6.6 shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 30.3.5.

30.3.5.9 Reserved.

30.3.5.10 Reserved.

30.3.5.11 Portable fire extinguishers in accordance with 9.7.4.1 shall be provided in hazardous areas addressed by

30.3.2.1, unless the building is protected throughout with an approved, supervised automatic sprinkler system in accordance with 30.3.5.3.

30.3.6 Corridors.

30.3.6.1 Walls. Exit access corridor walls shall comply with 30.3.6.1.1 or 30.3.6.1.2.

30.3.6.1.1 In buildings not complying with 30.3.6.1.1, exit access corridor walls shall consist of fire barriers in accordance with Section 8.3 that have not less than a 1-hour fire resistance rating.

30.3.6.1.2 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 30.3.5.3, corridor walls shall have not less than a ½-hour fire resistance rating.

30.3.6.2 Doors Doors that open onto exit access corridors shall have not less than a 20-minute fire protection rating in accordance with Section 8.3.

30.3.6.3 Reserved.

30.3.6.4 Doors that open onto exit access corridors shall be self-closing and self-latching.

30.3.6.5 Unprotected openings, other than those from spaces complying with 30.3.6.5, shall be prohibited in exit access corridor walls and doors.

30.3.6.6 Spaces shall be permitted to be unlimited in area and open to the corridor, provided that the following criteria are met:

- (1) The spaces are not used for guest rooms or guest suites or hazardous areas.
- (2) The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 30.3.5.
- (3) The space does not obstruct access to required exits.

30.3.6.7 Transoms, louvers, or transfer grilles shall be prohibited in walls or doors of exit access corridors.

30.3.7 Subdivisions of Building Spaces. Buildings shall be subdivided in accordance with 30.3.7.1 or 30.3.7.2.

30.3.7.1 In buildings not meeting 30.3.7.2, dwelling units shall be separated from each other by walls and floors constructed as fire barriers having fire resistance ratings of not less than 1 hour.

30.3.7.2 In buildings protected throughout by an approved, supervised, automatic sprinkler system, dwelling units shall be separated from each other by walls and floors constructed as fire barriers having fire resistance ratings of not less than ½ hour.

30.3.8 Special Protection Features. (Reserved)**30.4 Special Provisions.**

30.4.1 High-Rise Buildings. High-rise buildings shall comply with Section 11.8. Subsections 30.3.5.4 and 30.3.5.5 shall be permitted.

30.5 Building Services.

30.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

30.5.2 Heating, Ventilating, and Air Conditioning.

30.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

30.5.2.2 Unvented fuel-fired heaters, other than gas space heater in compliance with NFPA 54, *National Fuel Gas Code*, shall not be used.

30.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

30.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

30.6 Reserved.

30.7 Operating Features: Emergency Instructions for Residents of Apartment Buildings. Emergency instructions shall be provided annually to each dwelling unit to indicate the location of alarms, egress paths, and actions to be taken, both in response to a fire in the dwelling unit and in response to the sounding of the alarm system.

Chapter 31 Existing Apartment Buildings**31.1* General Requirements.****31.1.1 Application.**

31.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as apartment occupancies (*see also 30.1.1*). In addition, the building shall meet the requirements of one of the following options:

- (1) Option 1 — Buildings without fire suppression or detection systems
- (2) Option 2 — Buildings provided with a complete automatic fire detection and notification system
- (3) Option 3 — Buildings provided with automatic sprinkler protection in selected areas
- (4) Option 4 — Buildings protected throughout by an approved automatic sprinkler system

31.1.1.2 The term *apartment building*, wherever used in this Code, shall include an apartment house, tenement, garden apartment, or any other structure meeting the definition of *apartment building*.

31.1.2 Multiple Occupancies.

31.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

31.1.2.2 No dwelling unit of a residential occupancy shall have its sole means of egress pass through any nonresidential occupancy in the same building.

31.1.2.3 Multiple dwelling units shall be permitted to be located above a nonresidential occupancy only where one of the following conditions exists:

- (1) Where the dwelling units of the residential occupancy and exits therefrom are separated from the nonresidential occupancy by construction having a fire resistance rating of not less than 1 hour
- (2) Where the nonresidential occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7

- (3) Where not more than two dwelling units are located above a nonresidential occupancy that is protected by an automatic fire detection system in accordance with Section 9.6

31.1.3 Definitions.

31.1.3.1 Terms applicable to this chapter are defined in Chapter 3 of this Code, where necessary, other terms are defined in the text.

31.1.3.2 Apartment Building. See 3.3.27.3.

31.1.4 Classification of Occupancy. See 31.1.3.

31.1.5 Classification of Hazard of Contents. The contents of residential occupancies shall be classified as ordinary hazard in accordance with 6.2.2.

31.1.6 Minimum Construction Requirements. (No special requirements.)

31.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

31.2 Means of Egress Requirements.**31.2.1 General.**

31.2.1.1 Means of egress from dwelling units to the outside of the building shall be in accordance with Chapter 7 and this chapter.

31.2.1.2 Means of escape within the dwelling unit shall comply with the provisions of Section 24.2 for one- and two-family dwellings.

31.2.2 Means of Egress Components.**31.2.2.1 General.**

31.2.2.1.1 Components of means of egress shall be limited to the types described in 31.2.2.2 through 31.2.2.12.

31.2.2.1.2 In buildings using Option 4, exit enclosures shall have a fire resistance rating of not less than 1 hour, and doors shall have a fire protection rating of not less than 1 hour.

31.2.2.1.3 In non-high-rise buildings using Option 2, Option 3, or Option 4, exit stair doors shall be permitted to be 44-mm (1¾-in.) thick, solid-bonded wood core doors, self-closing and self-latching, and in wood frames not less than 19 mm (¾ in.) thick.

31.2.2.1.4 In buildings using Option 3, sprinklers shall also be provided within the exit enclosure in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

31.2.2.2 Doors.

31.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

31.2.2.2.2 Door locking arrangements shall comply with 30.2.2.2.2.1, 30.2.2.2.2.2, or 30.2.2.2.2.3.

31.2.2.2.2.1 No door in any means of egress shall be locked against egress when the building is occupied.

31.2.2.2.2.2 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted, provided that not more than one such device is located in any one egress path.

31.2.2.2.2.3 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

31.2.2.2.3 Revolving doors complying with 7.2.1.10 shall be permitted.

31.2.2.2.4 Horizontal sliding doors, as permitted by 7.2.1.14, shall not be used across corridors.

31.2.2.2.5 Apartment occupancies protected throughout by an approved, supervised automatic sprinkler system shall be exempt from the re-entry provisions of 7.2.1.5.7 where the exit enclosure serves directly only one dwelling unit per floor and such exit is a smokeproof enclosure in accordance with 7.2.3.

31.2.2.3 Stairs.

31.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

31.2.2.3.2 Within any individual dwelling unit, unless protected by an approved automatic sprinkler system in accordance with 31.3.5, stairs more than one story above or below the entrance floor level of the dwelling unit shall not be permitted.

31.2.2.3.3 Spiral stairs complying with 7.2.2.2.3 shall be permitted within a single dwelling unit.

31.2.2.3.4 Winders complying with 7.2.2.2.4 shall be permitted.

31.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted. (See also 31.2.11.)

31.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

31.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

31.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

31.2.2.8* Escalators. Escalators previously approved as a component in the means of egress shall be permitted to continue to be considered as in compliance.

31.2.2.9 Fire Escape Stairs. Fire escape stairs complying with 7.2.8 shall be permitted.

31.2.2.10 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

31.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

31.2.2.12 Areas of Refuge.

31.2.2.12.1 Areas of refuge complying with 7.2.12 shall be permitted, as modified by 31.2.2.12.2.

31.2.2.12.2* In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 31.3.5, the two accessible rooms or spaces separated from each other by smoke-resistive partitions in accordance with the definition of area of refuge in 3.3.17 shall not be required.

31.2.3 Capacity of Means of Egress.

31.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

31.2.3.2 Street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs and ramps discharging onto the street floor.

31.2.4 Number of Exits. The minimum number of exits shall comply with 31.2.4.1, 31.2.4.2, 31.2.4.3, 31.2.4.4, or 31.2.4.5.

31.2.4.1 Every dwelling unit shall have access to not less than two separate exits remotely located from each other as required by 7.5.1. (See also Section 7.4)

31.2.4.2 Any dwelling unit shall be permitted to have a single exit, provided that one of the following criteria is met:

- (1) The dwelling unit has an exit door opening directly to the street or yard at ground level.
- (2) The dwelling unit has direct access to an outside stair that complies with 7.2.2 and serves not more than two units, both located on the same floor.
- (3) The dwelling unit has direct access to an interior stair that serves only that unit and is separated from all other portions of the building by fire barriers having not less than a 1-hour fire resistance rating with no opening therein.

31.2.4.3 Buildings of four stories or less protected throughout by an approved, supervised automatic sprinkler system in accordance with 31.3.5.3 shall be permitted to have a single exit, provided the following conditions are met:

- (1) The stairway is separated from the rest of the building by barriers having not less than a 1-hour fire resistance rating, with self-closing doors having not less than a 1-hour fire protection rating protecting all openings between the stairway enclosure and the building.
- (2) The stairway does not serve more than one-half of a story below the level of exit discharge.
- (3) All corridors serving as access to exits have not less than a ½-hour fire resistance rating.
- (4) There is not more than 10.7 m (35 ft) of travel distance from the entrance door of any dwelling unit to an exit.
- (5) One-half hour fire-rated horizontal and vertical separation between dwelling units is provided.

31.2.4.4 Any building of three stories or less in its entirety shall be permitted to have a single exit, provided the following conditions are met:

- (1) The stairway is separated from the rest of the building by barriers having not less than a 1-hour fire resistance rating, with self-closing doors having not less than a 1-hour fire protection rating protecting all openings between the stairway enclosure and the building.
- (2) The stairway does not serve more than one-half of a story below the level of exit discharge.
- (3) All corridors serving as access to exits have not less than a 20-minute fire resistance rating.
- (4) The travel distance from the entrance door of any dwelling unit to an exit does not exceed 10.7 m (35 ft).
- (5) Horizontal and vertical separation with a fire rating of not less than ½ hour is provided between dwelling units.

31.2.4.5 A building of any height, with not more than four dwelling units per floor, with a smokeproof enclosure or outside stair in accordance with the requirements of 7.2.3 as the exit, where such exit is immediately accessible to all dwelling units served thereby, shall be permitted to have a single exit. "Immediately accessible" means that the travel distance from the entrance door of any dwelling unit to an exit shall not exceed 6100 mm (240 in.).

31.2.5 Arrangement of Means of Egress.

31.2.5.1 Access to all required exits shall be in accordance with Section 7.5.

31.2.5.2 Reserved.

31.2.5.3 Common path of travel shall comply with 31.2.5.3.1 or 31.2.5.3.2.

31.2.5.3.1 No common path of travel shall exceed 10.7 m (35 ft) in buildings not protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 31.3.5. Travel within a dwelling unit shall not be included when calculating common path of travel.

31.2.5.3.2 No common path of travel shall exceed 15 m (50 ft) in buildings protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 31.3.5. Travel within a dwelling unit shall not be included when calculating common path of travel.

31.2.5.4 Dead-end corridors shall not exceed 15 m (50 ft).

31.2.6 Travel Distance to Exits.

31.2.6.1 Travel distance within a dwelling unit (apartment) to a corridor door shall not exceed the following limits:

- (1) For buildings using Option 1 or Option 3 — 23 m (75 ft)
- (2) For buildings using Option 2 or Option 4 — 38 m (125 ft)

31.2.6.2 The travel distance from a dwelling unit (apartment) entrance door to the nearest exit shall not exceed the following limits, as modified by 31.2.6.3:

- (1) For buildings using Option 1 — 30 m (100 ft)
- (2) For buildings using Option 2 or Option 3 — 46 m (150 ft)
- (3) For buildings using Option 4 — 61 m (200 ft)

31.2.6.3 Travel distance to exits shall not exceed 60 m (200 ft) for exterior ways of exit access arranged in accordance with 7.5.3.

31.2.7 Discharge from Exits.

31.2.7.1 Exit discharge shall comply with Section 7.7.

31.2.7.2 Any required exit stairway that is located so that it is necessary to pass through the lobby or other open space to reach the outside of the building shall be continuously enclosed to a level of exit discharge or to a mezzanine within a lobby at a level of exit discharge.

31.2.7.3 The distance of travel from the termination of the exit enclosure to an exterior door leading to a public way shall not exceed 46 m (150 ft) in buildings protected throughout by an approved automatic sprinkler system and shall not exceed 30 m (100 ft) in all other buildings.

31.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

31.2.9 Emergency Lighting. Emergency lighting in accordance with Section 7.9 shall be provided in all buildings with more than 12 dwelling units or more than three stories in height, unless every dwelling unit has a direct exit to the outside of the building at grade level.

31.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10 in all buildings requiring more than one exit.

31.2.11* Special Means of Egress Features. In high-rise buildings using Option 1, Option 2, or Option 3, smokeproof enclosures shall be provided in accordance with 7.2.3.

31.3 Protection.**31.3.1 Protection of Vertical Openings.**

31.3.1.1 Vertical openings shall comply with 31.3.1.1.1, 31.3.1.1.2, or 31.3.1.1.3.

31.3.1.1.1 Vertical openings shall be enclosed or protected in accordance with Section 8.6.

31.3.1.1.2 Reserved.

31.3.1.1.3 Vertical openings in accordance with 8.6.8.2 shall be permitted.

31.3.1.1.4 In buildings protected throughout by an approved, automatic sprinkler system in accordance with 31.3.5, and in which exits and required ways of travel thereto are adequately safeguarded against fire and smoke within the building, or where every individual room has direct access to an exterior exit without passing through any public corridor, the protection of vertical openings that are not part of required exits shall not be required.

31.3.1.2 No floor below the level of exit discharge used only for storage, heating equipment, or purposes other than residential occupancy open to the public shall have unprotected openings to floors used for residential purposes.

31.3.2 Protection from Hazards.

31.3.2.1 Hazardous Areas. Any hazardous area shall be protected in accordance with Section 8.7.

31.3.2.1.1 The areas described in Table 31.3.2.1.1 shall be protected as indicated.

Table 31.3.2.1.1 Hazardous Area Protection

Hazardous Area Description	Separation/Protection
Boiler and fuel-fired heater rooms serving more than a single dwelling unit	1 hour or sprinklers
Employee locker rooms	1 hour or sprinklers
Gift or retail shops >9.3 m ² (>100 ft ²)	1 hour or sprinklers [†]
Bulk laundries	1 hour or sprinklers
Laundries >9.3 m ² (>100 ft ²) outside of dwelling units	1 hour or sprinklers [†]
Maintenance shops	1 hour or sprinklers
Rooms or spaces used for storage of combustible supplies and equipment in quantities deemed hazardous by the authority having jurisdiction	1 hour or sprinklers
Trash collection rooms	1 hour or sprinklers

[†]Where sprinklers are provided, separation shall not be required.

31.3.2.1.2 Where sprinkler protection without fire-rated separation is used, areas shall be separated from other spaces by smoke partitions complying with Section 8.4.

31.3.3 Interior Finish.

31.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

31.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with 10.2 shall be permitted as follows:

- (1) Exit enclosures — Class A or Class B
- (2) Lobbies and corridors — Class A or Class B
- (3) Other spaces — Class A, Class B, or Class C

31.3.3.3 Interior Floor Finish. In buildings utilizing Option 1 or Option 2, newly installed interior floor finish in exits and exit access corridors shall be not less than Class II in accordance with 10.2.7.

31.3.4 Detection, Alarm, and Communications Systems.

31.3.4.1 General.

31.3.4.1.1 Apartment buildings with more than three stories or with more than 11 dwelling units, other than those meeting 31.3.4.1.2, shall be provided with a fire alarm system in accordance with Section 9.6, except as modified by 31.3.4.2 through 31.3.4.5.2.

31.3.4.1.2 A fire alarm system shall not be required where each dwelling unit is separated from other contiguous dwelling units by fire barriers (*see Section 8.3*) having a fire resistance rating of not less than ½ hour, and where each dwelling unit has either its own independent exit or its own independent stairway or ramp discharging at grade.

31.3.4.2 Initiation.

31.3.4.2.1 Initiation of the required fire alarm system shall be by manual means in accordance with 9.6.2 unless the building complies with 31.3.4.2.2.

31.3.4.2.2 Initiation of the required fire alarm system by manual means shall not be required in buildings not exceeding four stories in height, containing not more than 16 dwelling units, and protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 31.3.5.3.

31.3.4.2.3 In buildings using Option 2, the required fire alarm system shall be initiated by the automatic fire detection system in addition to the manual initiation means of 31.3.4.2.1.

31.3.4.2.4 In buildings using Option 3, the required fire alarm system shall be initiated upon operation of the automatic sprinkler system in addition to the manual initiation means of 31.3.4.2.1.

31.3.4.2.5 In buildings using Option 4, the required fire alarm system shall be initiated upon operation of the automatic sprinkler system in addition to the manual initiation means of 31.3.4.2.1.

31.3.4.3 Notification.

31.3.4.3.1 Occupant notification shall be provided automatically in accordance with Section 9.6, and the following shall also apply:

- (1) Visible signals shall be installed in units designed for the hearing impaired.
- (2) Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.
- (3) Existing approved presignal systems shall be permitted in accordance with 9.6.3.3.

31.3.4.3.2 An annunciator panel, whose location shall be approved by the authority having jurisdiction, connected with

the required fire alarm system shall be provided, unless the building meets 31.3.4.3.3 or 31.3.4.3.4.

31.3.4.3.3 Annunciation shall not be required in buildings not exceeding two stories in height and having not more than 50 rooms.

31.3.4.3.4 Annunciation shall not be required in buildings that are protected throughout by an approved, supervised automatic sprinkler system installed in accordance with 31.3.5.3, that do not exceed four stories in height, and that contain not more than 16 dwelling units.

31.3.4.3.5 Fire department notification shall be accomplished in accordance with 9.6.4.

31.3.4.4 Detection. In buildings using Option 2, a complete automatic fire detection system in accordance with 9.6.1.3 shall be required.

31.3.4.5 Smoke Alarms.

31.3.4.5.1 In buildings other than those equipped throughout with an existing, complete automatic smoke detection system, approved single-station smoke alarms shall be installed in accordance with 9.6.2.10, as modified by 31.3.4.5.2, outside every sleeping area in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements.

31.3.4.5.2 Single-station smoke alarms without a secondary (standby) power source shall be permitted.

31.3.5 Extinguishment Requirements.

31.3.5.1 Reserved.

31.3.5.2 Reserved.

31.3.5.3* Where an automatic sprinkler system is installed, either for total or partial building coverage, the system shall be installed in accordance with Section 9.7, as modified by 31.3.5.4 and 31.3.5.5. In buildings up to and including four stories in height above grade, systems in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be permitted.

31.3.5.4 In individual dwelling units, sprinkler installation shall not be required in closets not exceeding 2.2 m² (24 ft²) and in bathrooms not exceeding 5.1 m² (55 ft²). Closets that contain equipment such as washers, dryers, furnaces, or water heaters shall be sprinklered regardless of size.

31.3.5.5 The draft stop and closely spaced sprinkler requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall not be required for convenience openings complying with 8.6.8.2 where the convenience opening is within the dwelling unit.

31.3.5.6 Buildings using Option 3 shall be provided with the following:

- (1) Automatic sprinklers in the corridor along the corridor ceiling
- (2) An automatic sprinkler within any dwelling unit that has a door opening to the corridor, with such sprinkler positioned over the center of the door, unless the door to the dwelling unit has not less than a 20-minute fire protection rating and is self-closing

31.3.5.7 The sprinkler installation required in 31.3.5.6 shall meet the requirements of Section 9.7 in terms of workmanship and materials.

31.3.5.8 The installation of the corridor sprinklers required in 31.3.5.6 shall not exceed the maximum spacing and protection area requirements of the installation standards referenced in 31.3.5.3.

31.3.5.9 Buildings using Option 4 shall be protected throughout by an approved automatic sprinkler system in accordance with 31.3.5.3 and meeting the requirements of Section 9.7 for supervision for buildings more than six stories in height.

31.3.5.10 All high-rise buildings, other than those meeting 31.3.5.10.1 or 31.3.5.10.2, shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 31.3.5.3.

31.3.5.10.1 An automatic sprinkler system shall not be required where every dwelling unit has exterior exit access in accordance with 7.5.3.

31.3.5.10.2* An automatic sprinkler system shall not be required in buildings having an approved, engineered life safety system in accordance with 31.3.5.10.3.

31.3.5.10.3 Where required by 31.3.5.10.2, an engineered life safety system shall be developed by a registered professional engineer experienced in fire and life safety system design, approved by the authority having jurisdiction, and include any or all of the following:

- (1) Partial automatic sprinkler protection
- (2) Smoke detection systems
- (3) Smoke control systems
- (4) Compartmentation
- (5) Other approved systems

31.3.5.11 Portable fire extinguishers in accordance with 9.7.4.1 shall be provided in hazardous areas addressed by 31.3.2.1, unless the building is protected throughout with an approved, supervised automatic sprinkler system in accordance with 31.3.5.3.

31.3.6 Corridors.

31.3.6.1* Walls. Exit access corridor walls shall consist of fire barriers in accordance with Section 8.3 that have not less than a ½-hour fire resistance rating.

31.3.6.2 Doors. Doors that open onto exit access corridors, other than those complying with 8.3.4 and in buildings meeting 31.3.6.3, shall have not less than a 20-minute fire protection rating in accordance with Section 8.3.

31.3.6.3 In buildings using Option 3 or Option 4, doors shall be constructed to resist the passage of smoke.

31.3.6.4 Doors that open onto exit access corridors shall be self-closing and self-latching.

31.3.6.5 Unprotected openings, other than those from spaces complying with 31.3.6.6, shall be prohibited in exit access corridor walls and doors.

31.3.6.6 Spaces shall be permitted to be unlimited in area and open to the corridor, provided that the following criteria are met:

- (1) The spaces are not used for guest rooms or guest suites or hazardous areas.
- (2) The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 31.3.5.3.
- (3) The space does not obstruct access to required exits.

31.3.6.7 Transoms, louvers, or transfer grilles shall be prohibited in walls or doors of exit access corridors.

31.3.7 Subdivision of Building Spaces — Smoke Barriers. In buildings other than those meeting 31.3.7.1, 31.3.7.2, 31.3.7.3, 31.3.7.4, or 31.3.7.5, the following shall be met:

- (1) Smoke barriers in accordance with Section 8.5 shall be provided in exit access corridors to establish not less than two compartments approximately equal in size.
- (2) The length of each smoke compartment, measured along the corridor, shall not exceed 61 m (200 ft).
- (3) Smoke dampers shall not be required.

31.3.7.1 Smoke barriers shall not be required in buildings using Option 4.

31.3.7.2 Smoke barriers shall not be required in buildings having exterior exit access in accordance with 7.5.3 that provides access to two exits.

31.3.7.3 Smoke barriers shall not be required in buildings complying with 31.2.4.2, 31.2.4.3, 31.2.4.4, or 31.2.4.5.

31.3.7.4 Smoke barriers shall not be required in buildings with exits not more than 15 m (50 ft) apart.

31.3.7.5 Smoke barriers shall not be required where each dwelling unit has direct access to the exterior at grade.

31.3.8 Special Protection Features. (Reserved)

31.4 Special Provisions.

31.4.1 High-Rise Buildings. High-rise buildings shall comply with 31.2.11 and 31.3.5.10.

31.5 Building Services.

31.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

31.5.2 Heating, Ventilating, and Air Conditioning.

31.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

31.5.2.2 Unvented fuel-fired heaters, other than gas space heater in compliance with NFPA 54, *National Fuel Gas Code*, shall not be used.

31.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

31.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

31.6 Reserved.

31.7 Operating Features: Emergency Instructions for Residents of Apartment Buildings. Emergency instructions shall be provided annually to each dwelling unit to indicate the location of alarms, egress paths, and actions to be taken, both in response to a fire in the dwelling unit and in response to the sounding of the alarm system.

Chapter 32 New Residential Board and Care Occupancies

32.1 General Requirements.

32.1.1* Application.

32.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as residential board and care occupancies (*see 1.3.1*)
- (2) Additions made to, or used as, residential board and care occupancies (*see 4.6.7*)
- (3) Alterations, modernizations, or renovations of residential board and care occupancies (*see 4.6.8*)
- (4) Buildings or portions thereof upon change of occupancy to a residential board and care occupancy (*see 4.6.12*)

32.1.1.2 Reserved.

32.1.1.3 This chapter is divided into five sections as follows:

- (1) Section 32.1 — General Requirements
- (2) Section 32.2 — Small Facilities (that is, sleeping accommodations for not more than 16 residents)
- (3) Section 32.3 — Large Facilities (that is, sleeping accommodations for more than 16 residents)
- (4) Section 32.4 — Suitability of an Apartment Building to House a Board and Care Occupancy
- (5) Section 32.7 — Operating Features (*Sections 32.5 and 32.6 are reserved.*)

32.1.1.4 Conversion. For the purposes of this chapter, exceptions for conversions shall apply only for a change of occupancy from an existing residential or health care occupancy to a residential board and care occupancy.

32.1.2 Multiple Occupancies.

32.1.2.1 Multiple occupancies shall be in accordance with 6.1.14.

32.1.2.2 Reserved.

32.1.2.3 No board and care occupancy shall have its sole means of egress or means of escape pass through any nonresidential or non-health care occupancy in the same building.

32.1.2.4 No board and care occupancy shall be located above a nonresidential or non-health care occupancy unless the board and care occupancy and exits therefrom are separated from the nonresidential or non-health care occupancy by construction having a fire resistance rating of not less than 2 hours.

32.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Personal Care.** See 3.3.163.
- (2) **Point of Safety.** See 3.3.168.
- (3) **Residential Board and Care Occupancy.** See 3.3.152.13.
- (4) **Residential Board and Care Resident.** See 3.3.182.
- (5) **Staff (Residential Board and Care).** See 3.3.209.
- (6) **Thermal Barrier.** See 3.3.23.3.

32.1.4 Acceptability of Means of Egress or Escape. No means of escape or means of egress shall be considered as complying with the minimum criteria for acceptance unless emergency evacuation drills are regularly conducted using that route in accordance with the requirements of 32.7.3.

32.1.5* Fire resistance-rated assemblies shall comply with Section 8.3.

32.1.6 Reserved.

32.1.7 Reserved.

32.2 Small Facilities.

32.2.1 General.

32.2.1.1 Scope.

32.2.1.1.1 Section 32.2 shall apply to residential board and care occupancies providing sleeping accommodations for not more than 16 residents.

32.2.1.1.2 Where there are sleeping accommodations for more than 16 residents, the occupancy shall be classified as a large facility in accordance with Section 8.3.

32.2.1.2 Reserved.

32.2.1.3 Minimum construction requirements. (No requirements.)

32.2.2 Means of Escape.

32.2.2.1 Reserved.

32.2.2.2 Primary Means of Escape.

32.2.2.2.1 Every sleeping room and living area shall have access to a primary means of escape located to provide a safe path of travel to the outside.

32.2.2.2.2 Where sleeping rooms or living areas are above or below the level of exit discharge, the primary means of escape shall be an interior stair in accordance with 32.2.2.4, an exterior stair, a horizontal exit, or a fire escape stair.

32.2.2.3 Secondary Means of Escape.

32.2.2.3.1 Sleeping rooms, other than those complying with 32.2.2.3.2, and living areas in facilities without a sprinkler system installed in accordance with 32.2.3.5 shall have a second means of escape consisting of one of the following:

- (1) A door, stairway, passage, or hall providing a way of unobstructed travel to the outside of the dwelling at street or ground level that is independent of, and remotely located from, the primary means of escape
- (2) A passage through an adjacent nonlockable space, independent of, and remotely located from, the primary means of escape to any approved means of escape
- (3)*An outside window or door operable from the inside without the use of tools, keys, or special effort, and providing a clear opening of not less than 0.53 m² (5.7 ft²) with the width not less than 510 mm (20 in.) and the height not less than 610 mm (24 in.). The bottom of the opening shall be not more than 1120 mm (44 in.) above the floor. Such means of escape shall be acceptable if one of the following is met:
 - (a) The window is within 6100 mm (240 in.) of grade.
 - (b) The window is directly accessible to fire department rescue apparatus as approved by the authority having jurisdiction.
 - (c) The window or door opens onto an exterior balcony.

32.2.2.3.2 Sleeping rooms that have a door leading directly to the outside of the building with access to grade or to an exterior stairway meeting the requirements of 32.2.2.6.3 shall be considered as meeting all the requirements for a second means of escape.

32.2.2.4 Interior Stairs Used for Primary Means of Escape.

Interior stairs shall be protected in accordance with 32.2.2.4.1 through 32.2.2.4.4, unless they meet 32.2.2.4.5, 32.2.2.4.6, or 32.2.2.4.7.

32.2.2.4.1 Interior stairs shall be enclosed with ½-hour fire barriers in accordance with Section 8.3.

32.2.2.4.2 Stairs shall comply with 7.2.2.5.3.

32.2.2.4.3 The entire primary means of escape shall be arranged so that occupants are not required to pass through a portion of a lower story unless that route is separated from all

spaces on that story by construction having a minimum ½-hour fire resistance rating.

32.2.2.4.4 In buildings of construction other than Type II(000), Type III(200), or Type V(000), the supporting construction shall be protected to afford the required fire resistance rating of the supported wall.

32.2.2.4.5 Stairs that connect a story at street level to only one other story shall be permitted to be open to the story that is not the street level.

32.2.2.4.6 In buildings not exceeding three stories in height and protected by an approved, automatic sprinkler system in accordance with 32.2.3.5, stair enclosures shall not be required, provided there still remains a primary means of escape from each sleeping area that does not require occupants to pass through a portion of a lower floor, unless that route is separated from all spaces on that floor by construction having a ½-hour fire resistance rating.

32.2.2.4.7 Stairs serving a maximum of two stories in buildings protected with an approved automatic sprinkler system in accordance with 32.2.3.5 shall be permitted to be unenclosed.

32.2.2.5 Doors.

32.2.2.5.1 Doors, other than those meeting 32.2.2.5.1.1 and 32.2.2.5.1.2, and paths of travel to a means of escape shall be at least 810 mm (32 in.) wide.

32.2.2.5.1.1 Bathroom doors shall be at least 610 mm (24 in.) wide.

32.2.2.5.1.2 In conversions (*see* 32.1.1.3), 710-mm (28-in.) doors shall be permitted.

32.2.2.5.2 Reserved.

32.2.2.5.3 Doors shall be swinging or sliding.

32.2.2.5.4 Every closet door latch shall be readily opened from the inside.

32.2.2.5.5 Every bathroom door shall be designed to allow opening from the outside during an emergency when locked.

32.2.2.5.6 No door in any means of escape, other than those meeting 32.2.2.5.6.1 or 32.2.2.5.6.2, shall be locked against egress when the building is occupied.

32.2.2.5.6.1 Delayed egress locks complying with 7.2.1.6.1 shall be permitted on exterior doors only.

32.2.2.5.6.2 Access-controlled egress locks complying with 7.2.1.6.2 shall be permitted.

32.2.2.5.7 Forces to open doors shall comply with 7.2.1.4.5.

32.2.2.5.8 Door latching devices shall comply with 7.2.1.5.9.

32.2.2.5.9 Floor levels at doors shall comply with 7.2.1.3.

32.2.2.6 Stairs.

32.2.2.6.1 Stairs shall comply with 7.2.2 unless otherwise specified in this chapter.

32.2.2.6.2 Winders complying with 7.2.2.2.4 shall be permitted only in conversions.

32.2.2.6.3* Exterior stairs shall be protected against blockage caused by fire within the building.

32.2.3 Protection.

32.2.3.1 Protection of Vertical Openings.

32.2.3.1.1 Vertical openings, other than those meeting 32.2.3.1.3, shall be separated by smoke partitions in accordance with Section 8.4 that prevent the passage of smoke from one story to another story.

32.2.3.1.2 Smoke partitions described in 32.2.3.1.1 shall have a fire resistance rating of not less than ½ hour in accordance with Section 8.3.

32.2.3.1.3 Stairs shall be permitted to be open where complying with 32.2.2.4.6 or 32.2.2.4.7.

32.2.3.2 Hazardous Areas.

32.2.3.2.1* Any space where there is storage or activity having fuel conditions exceeding those of a one- or two-family dwelling and that possesses the potential for a fully involved fire shall be protected in accordance with 32.2.3.2.4 and 32.2.3.2.5.

32.2.3.2.2 Spaces requiring protection by 32.2.3.2.1 shall include, but shall not be limited to, areas for cartoned storage, food, or household maintenance items in wholesale or institutional-type quantities and concentrations, or mass storage of residents' belongings.

32.2.3.2.3 Reserved.

32.2.3.2.4 When the space is on the same floor as, and is in or abuts, a primary means of escape or a sleeping room, it shall be protected by one of the following means:

- (1) An enclosure with a fire resistance rating of at least 1 hour in accordance with 8.2.3, and protected by an automatic fire detection system connected to the fire alarm system provided in 32.2.3.4.1
- (2) An automatic sprinkler system in accordance with 32.2.3.5, and a smoke partition in accordance with Section 8.4, located between the space and the sleeping area or primary escape route. Any doors in such separation shall be self-closing or automatic-closing in accordance with 7.2.1.8.

32.2.3.2.5 Other spaces shall be protected by one of the following:

- (1) An enclosure having a fire resistance rating of at least ½ hour, with a self-closing or automatic-closing door in accordance with 7.2.1.8, equivalent to at least a 44-mm (1¾-in.) thick, solid bonded wood core construction and protected by an automatic fire detection system connected to the fire alarm system provided in 32.2.3.4.1
- (2) Automatic sprinkler protection in accordance with 32.2.3.5, regardless of enclosure

32.2.3.3 Interior Finish.

32.2.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

32.2.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A, Class B, or Class C.

32.2.3.3.3 Interior Floor Finish.

32.2.3.3.3.1 Interior floor finish shall comply with Section 10.2.

32.2.3.3.3.2 Reserved.

32.2.3.3.3.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2 as applicable.

32.2.3.4 Detection, Alarm, and Communication Systems.

32.2.3.4.1 Fire Alarm Systems. A manual fire alarm system shall be provided in accordance with Section 9.6.

32.2.3.4.2 Occupant Notification. Occupant notification shall be provided automatically, without delay, in accordance with 9.6.3.

32.2.3.4.3 Smoke Alarms.

32.2.3.4.3.1 Approved smoke alarms shall be provided in accordance with 9.6.2.10 on all levels, including basements, but excluding crawl spaces and unfinished attics.

32.2.3.4.3.2 Additional smoke alarms shall be installed in all living areas as defined in 3.3.16.5.

32.2.3.4.3.3 Each sleeping room shall be provided with an approved smoke alarm in accordance with 9.6.2.10.

32.2.3.5 Extinguishment Requirements.

32.2.3.5.1* All facilities, other than those meeting 32.2.3.5.2, shall be protected throughout by an approved, automatic sprinkler system installed in accordance with 32.2.3.5.3 using quick response or residential sprinklers.

32.2.3.5.2* In conversions, sprinklers shall not be required in small board and care homes, serving eight or fewer residents, when all occupants have the ability as a group to move reliably to a point of safety within 3 minutes.

32.2.3.5.3 Where an automatic sprinkler system is installed, for either total or partial building coverage, the following requirements shall be met:

- (1) The system shall be in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, and shall initiate the fire alarm system in accordance with 32.2.3.4.1.
- (2) The adequacy of the water supply shall be documented to the authority having jurisdiction.

32.2.3.5.3.1 An automatic sprinkler system in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be permitted in facilities up to and including four stories in height. All habitable areas and closets shall be sprinklered.

32.2.3.5.3.2* An automatic sprinkler system with a 30-minute water supply, and complying with the following requirements and with NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, shall be permitted.

- (1) All habitable areas and closets shall be sprinklered.
- (2) Facilities with more than eight residents shall be treated as two-family dwellings with regard to water supply.

32.2.3.5.4 Automatic sprinkler systems installed in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, and NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be provided with electrical supervision in accordance with 9.7.2.

32.2.3.5.5 Automatic sprinkler systems installed in accordance with NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, shall be provided with valve supervision by one of the following methods:

- (1) A single listed control valve that shuts off both domestic and sprinkler systems and a separate shutoff for the domestic system only
- (2) Electrical supervision in accordance with 9.7.2
- (3) Valve closure that causes the sounding of an audible signal in the facility

32.2.3.5.6 Sprinkler piping serving not more than six sprinklers for any isolated hazardous area shall be permitted to be installed in accordance with 9.7.1.2 and shall meet the following requirements:

- (1) In new installations, where more than two sprinklers are installed in a single area, water flow detection shall be provided to initiate the fire alarm system required by 32.2.3.4.1.
- (2) Duration of water supplies shall be as required by 32.2.3.5.3.2.

32.2.3.6 Construction of Corridor Walls.

32.2.3.6.1 Corridor walls, other than those meeting 32.2.3.6.2, shall meet the following requirements:

- (1) The separation walls of sleeping rooms shall be capable of resisting fire for at least ½ hour, which shall be considered to be achieved if the partitioning is finished on both sides with lath and plaster or material providing a 15-minute thermal barrier.
- (2) Sleeping room doors shall be substantial doors, such as those of 44-mm (1¾-in.) thick, solid bonded wood core construction or of other construction of equal or greater stability and fire integrity.
- (3) Any vision panels shall be fixed fire window assemblies in accordance with 8.3.4 or shall be wired glass not exceeding 0.84 m² (1296 in.²) each in area and installed in approved frames.

32.2.3.6.2 The requirements of 32.2.3.6.1 shall not apply to corridor walls that are smoke partitions in accordance with Section 8.4 where the facility is protected in accordance with 32.2.3.5, and the following shall also apply:

- (1) In such instances, there shall be no limitation on the type or size of glass panels.
- (2) Door closing shall comply with 32.2.3.6.4.

32.2.3.6.3 There shall be no louvers, operable transoms, or other air passages penetrating the wall other than properly installed heating and utility installations other than transfer grilles, which shall be prohibited.

32.2.3.6.4 Doors shall meet the following requirements:

- (1) Doors shall be provided with latches or other mechanisms suitable for keeping the doors closed.
- (2) No doors shall be arranged to prevent the occupant from closing the door.
- (3) Doors shall be self-closing or automatic-closing in accordance with 7.2.1.8 in buildings other than those protected throughout by an approved, automatic sprinkler system in accordance with 32.2.3.5.

32.2.4 Reserved.**32.2.5 Building Services.**

32.2.5.1 Utilities. Utilities shall comply with Section 9.1.

32.2.5.2 Heating, Ventilating, and Air Conditioning.

32.2.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with 9.2.1 and 9.2.2, unless otherwise required in this chapter.

32.2.5.2.2 No stove or combustion heater shall be located to block escape in case of fire caused by the malfunction of the stove or heater.

32.2.5.2.3 Unvented fuel-fired heaters shall not be used in any residential board and care facility.

32.2.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with Section 9.4.

32.3 Large Facilities.

32.3.1 General.

32.3.1.1 Scope.

32.3.1.1.1 Section 32.3 shall apply to residential board and care occupancies providing sleeping accommodations for more than 16 residents.

32.3.1.1.2 Facilities having sleeping accommodations for not more than 16 residents shall comply with Section 32.2.

32.3.1.2 Reserved.

32.3.1.3 Minimum Construction Requirements. Building construction shall be in accordance with Chapter 7 of *NFPA 5000™, Building Construction and Safety Code™*.

32.3.1.4 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space, or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

32.3.2 Means of Egress.

32.3.2.1 General. Means of egress shall be in accordance with Chapter 7.

32.3.2.2 Means of Egress Components.

32.3.2.2.1 General. Components of means of egress shall be limited to the types described in 32.3.2.2.2 through 32.3.2.2.10.

32.3.2.2.2 Doors. Doors in means of egress shall be as follows:

- (1) Doors complying with 7.2.1 shall be permitted.
- (2) Doors within individual rooms and suites of rooms shall be permitted to be swinging or sliding.
- (3) No door, other than those meeting (4) or (5), shall be equipped with a lock or latch that requires the use of a tool or key from the egress side.
- (4) Delayed egress locks in accordance with 7.2.1.6.1 shall be permitted, provided not more than one device is located in any egress path.
- (5) Access-controlled egress doors in accordance with 7.2.1.6.2 shall be permitted.
- (6) Doors located in the means of egress that are permitted to be locked under other provisions of Chapter 32, other than those meeting (4) or (5), shall have adequate provisions made for the rapid removal of occupants by means such as remote control of locks, keying of all locks to keys carried by staff at all times, or other such reliable means available to staff at all times.
- (7) Only one such locking device as described in (6) shall be permitted on each door.

32.3.2.2.3 Stairs. Stairs complying with 7.2.2 shall be permitted.

32.3.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

32.3.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

32.3.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

32.3.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

32.3.2.2.8 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

32.3.2.2.9 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

32.3.2.2.10 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

32.3.2.3 Capacity of Means of Egress.

32.3.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

32.3.2.3.2 Street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs and ramps discharging onto the street floor.

32.3.2.3.3 The width of corridors shall be sufficient for the occupant load served but shall not be less than 1525 mm (60 in.)

32.3.2.3.4 Number of Exits. The minimum number of exits as required by Section 7.4 shall be provided on every story.

32.3.2.5 Arrangement of Means of Egress.

32.3.2.5.1 Access to all required exits shall be in accordance with Section 7.5.

32.3.2.5.2 Common paths of travel shall not exceed 23 m (75 ft).

32.3.2.5.3 Reserved.

32.3.2.5.4 Dead-end corridors shall not exceed 9140 mm (360 in.).

32.3.2.5.5 Any room or any suite of rooms exceeding 185 m² (2000 ft²) shall be provided with not less than two exit access doors located remotely from each other.

32.3.2.6 Travel Distance to Exits. Travel distance from any point in a room to the nearest exit, measured in accordance with Section 7.6, shall not exceed 76 m (250 ft).

32.3.2.7 Discharge from Exits. Exit discharge shall comply with Section 7.7.

32.3.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

32.3.2.9 Emergency Lighting. Emergency lighting in accordance with Section 7.9 shall be provided unless each sleeping room has a direct exit to the outside at ground level.

32.3.2.10 Marking of Means of Egress. Means of egress shall be marked in accordance with Section 7.10.

32.3.2.11 Special Means of Egress Features. (Reserved)

32.3.3 Protection.**32.3.3.1 Protection of Vertical Openings.**

32.3.3.1.1 Vertical openings shall be enclosed or protected in accordance with Section 8.6.

32.3.3.1.2 Unenclosed vertical openings in accordance with 8.6.8.2 shall be permitted.

32.3.3.1.3 No floor below the level of exit discharge used only for storage, heating equipment, or purposes other than residential occupancy shall have unprotected openings to floors used for residential occupancy.

32.3.3.2 Protection from Hazards.

32.3.3.2.1 Hazardous areas shall be protected in accordance with Section 8.7.

32.3.3.2.2 The areas described in Table 32.3.3.2.2 shall be protected as indicated.

Table 32.3.3.2.2 Hazardous Area Protection

Hazardous Area Description	Separation/Protection
Boiler and fuel-fired heater rooms	1 hour
Central/bulk laundries larger than 9.3 m ² (100 ft ²)	1 hour
Paint shops employing hazardous substances and materials in quantities less than those that would be classified as a severe hazard	1 hour
Physical plant maintenance shops	1 hour
Soiled linen rooms	1 hour
Storage rooms larger than 4.6 m ² (50 ft ²) but not exceeding 9.3 m ² (100 ft ²) storing combustible material	Smoke partition
Storage rooms larger than 9.3 m ² (100 ft ²) storing combustible material	1 hour
Trash collection rooms	1 hour

32.3.3.3* Interior Finish.

32.3.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

32.3.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be in accordance with the following:

- (1) Exit enclosures — Class A
- (2) Lobbies and corridors — Class B
- (3) Rooms and enclosed spaces — Class B

32.3.3.3.3 Interior Floor Finish.

32.3.3.3.3.1 Interior floor finish shall comply with Section 10.2.

32.3.3.3.3.2 Interior floor finish in exit enclosures and exit access corridors and spaces not separated from them by walls complying with 32.3.6 shall be not less than Class II.

32.3.3.3.3.3 Interior floor finish shall comply with 10.2.7.1 or 10.2.7.2, as applicable.

32.3.3.4 Detection, Alarm, and Communications Systems.

32.3.3.4.1 General. A fire alarm system shall be provided in accordance with Section 9.6.

32.3.3.4.2 Initiation. The required fire alarm system shall be initiated by all of the following:

- (1) Manual means in accordance with 9.6.2
- (2) A manual fire alarm box located at a convenient central control point under continuous supervision of responsible employees
- (3) Any required automatic sprinkler system
- (4) Any required detection system

32.3.3.4.3 Annunciator Panel. An annunciator panel, whose location shall be approved by the authority having jurisdiction, shall be connected to the fire alarm system.

32.3.3.4.4 Occupant Notification. Occupant notification shall be provided automatically, without delay, in accordance with 9.6.3.

32.3.3.4.5 High-rise buildings shall be provided with an approved means of voice communication in accordance with 11.8.3 or with a public address system.

32.3.3.4.6 Emergency Forces Notification. Emergency forces notification shall meet the following requirements:

- (1) Fire department notification shall be accomplished in accordance with 9.6.4.
- (2) Smoke detection devices or smoke detection systems equipped with reconfirmation features shall not be required to automatically notify the fire department unless the alarm condition is reconfirmed after a period not exceeding 120 seconds.

32.3.3.4.7 Smoke Alarms. Approved smoke alarms shall be installed in accordance with 9.6.2.10 inside every sleeping room, outside every sleeping area in the immediate vicinity of the bedrooms, and on all levels within a resident unit.

32.3.3.4.8 Smoke Detection Systems.

32.3.3.4.8.1 Corridors and spaces open to the corridors, other than those meeting 32.3.3.4.8.2, shall be provided with smoke detectors that comply with *NFPA 72*[®], *National Fire Alarm Code*[®], and are arranged to initiate an alarm that is audible in all sleeping areas.

32.3.3.4.8.2 Smoke detection systems shall not be required in unenclosed corridors, passageways, balconies, colonnades, or other arrangements with one or more sides along the long dimension fully or extensively open to the exterior at all times.

32.3.3.5 Extinguishment Requirements.

32.3.3.5.1 All buildings shall be protected throughout by an approved automatic sprinkler system installed in accordance with 9.7.1.1(1) and provided with quick response or residential sprinklers throughout.

32.3.3.5.2 Reserved.**32.3.3.5.3 Reserved.**

32.3.3.5.4 Automatic sprinkler systems shall be provided with electrical supervision in accordance with 9.7.2.

32.3.3.5.5 Reserved.

32.3.3.5.6 Portable Fire Extinguishers. Portable fire extinguishers shall be provided in accordance with 9.7.4.1.

32.3.3.6* Corridors and Separation of Sleeping Rooms.

32.3.3.6.1 Access shall be provided from every resident use area to at least one means of egress that is separated from all sleeping rooms by walls complying with 32.3.3.6.3 through 32.3.3.6.6.

32.3.3.6.2 Sleeping rooms shall be separated from corridors, living areas, and kitchens by walls complying with 32.3.3.6.3 through 32.3.3.6.6.

32.3.3.6.3 Walls required by 32.3.3.6.1 or 32.3.3.6.2 shall be smoke partitions in accordance with Section 8.4.

32.3.3.6.4 Doors protecting corridor openings shall be constructed to resist the passage of smoke.

32.3.3.6.5 Door-closing devices shall not be required on doors in corridor wall openings other than those serving required exits, smoke barriers, or enclosures of vertical openings and hazardous areas.

32.3.3.6.6 No louvers, transfer grilles, operable transoms, or other air passages, other than properly installed heating and utility installations, shall penetrate such walls or doors.

32.3.3.7 Subdivision of Building Spaces. Buildings shall be subdivided by smoke barriers in accordance with 32.3.3.7.1 through 32.3.3.7.21.

32.3.3.7.1 Every story shall be divided into not less than two smoke compartments unless it meets 32.3.3.7.4, 32.3.3.7.5, 32.3.3.7.6, or 32.3.3.7.7.

32.3.3.7.2 Each smoke compartment shall have an area not exceeding 2100 m² (22,500 ft²).

32.3.3.7.3 The travel distance from any point to reach a door in the required smoke barrier shall be limited to a distance of 61 m (200 ft).

32.3.3.7.4 Smoke barriers shall not be required on stories that do not contain a board and care occupancy, located totally above the board and care occupancy.

32.3.3.7.5 Smoke barriers shall not be required in areas that do not contain a board and care occupancy and that are separated from the board and care occupancy by a fire barrier complying with Section 8.3.

32.3.3.7.6 Smoke barriers shall not be required on stories that do not contain a board and care occupancy and that are more than one story below the board and care occupancy.

32.3.3.7.7 Smoke barriers shall not be required in open parking structures protected throughout by an approved, supervised automatic sprinkler system in accordance with 32.3.3.5.

32.3.3.7.8 Smoke barriers shall be constructed in accordance with Section 8.3 and shall have a fire resistance rating of not less than 1 hour unless they meet 32.3.3.7.9 or 32.3.3.7.10.

32.3.3.7.9 Where an atrium is used, smoke barriers shall be permitted to terminate at an atrium wall constructed in accordance with 8.6.7(1)(c), in which case not less than two separate smoke compartments shall be provided on each floor.

32.3.3.7.10* Dampers shall not be required in duct penetrations of smoke barriers in fully ducted heating, ventilating, and air conditioning systems.

32.3.3.7.11 Not less than 1.4 net m² (15 net ft²) per resident shall be provided within the aggregate area of corridors, lounge or dining areas, and other low hazard areas on each side of the smoke barrier.

32.3.3.7.12 On stories not housing residents, not less than 0.56 net m² (6 net ft²) per occupant shall be provided on each side of the smoke barrier for the total number of occupants in adjoining compartments.

32.3.3.7.13* Doors in smoke barriers shall be substantial doors, such as 44-mm (1¾-in.) thick, solid-bonded wood core doors, or shall be of construction that resists fire for not less than 20 minutes.

32.3.3.7.14 Nonrated factory- or field-applied protective plates extending not more than 1220 mm (48 in.) above the bottom of the door shall be permitted.

32.3.3.7.15 Cross-corridor openings in smoke barriers shall be protected by a pair of swinging doors or a horizontal sliding door complying with 7.2.1.14.

32.3.3.7.16 Swinging doors shall be arranged so that each door swings in a direction opposite from the other.

32.3.3.7.17* Doors in smoke barriers shall comply with 8.5.3 and shall be self-closing or automatic-closing in accordance with 7.2.1.8.

32.3.3.7.18* Vision panels consisting of fire-rated glazing or wire glass panels in approved frames shall be provided in each cross-corridor swinging door and in each cross-corridor horizontal sliding door in a smoke barrier.

32.3.3.7.19 Rabbets, bevels, or astragals shall be required at the meeting edges, and stops shall be required at the head and sides of door frames in smoke barriers.

32.3.3.7.20 Positive latching hardware shall not be required.

32.3.3.7.21 Center mullions shall be prohibited.

32.3.3.8* Cooking Facilities. Cooking facilities, other than those within individual residential units, shall be protected in accordance with 9.2.3.

32.3.3.9 Standpipes.

32.3.3.9.1 General. Where required, standpipe and hose systems shall be installed and maintained in accordance with 9.7.4.2.

32.3.3.9.2 In High-Rise Buildings. Class I standpipe systems shall be installed throughout all high-rise buildings.

32.3.3.9.3 Roof Outlets. Roof outlets shall not be required on roofs having a slope of 3 in 12 or greater.

32.3.4 Special Provisions. (Reserved)**32.3.5 Reserved.****32.3.6 Building Services.**

32.3.6.1 Utilities. Utilities shall comply with Section 9.1.

32.3.6.2 Heating, Ventilating, and Air Conditioning.

32.3.6.2.1 Heating, ventilating, and air conditioning equipment shall comply with Section 9.2.

32.3.6.2.2 No stove or combustion heater shall be located such that it blocks escape in case of fire caused by the malfunction of the stove or heater.

32.3.6.2.3 Unvented fuel-fired heaters shall not be used in any board and care occupancy.

32.3.6.3 Elevators, Dumbwaiters, and Vertical Conveyors.

32.3.6.3.1 Elevators, dumbwaiters, and vertical conveyors shall comply with Section 9.4.

32.3.6.3.2* In high-rise buildings, one elevator shall be provided with a protected power supply and shall be available for use by the fire department in case of emergency.

32.3.6.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with Section 9.5.

32.4* Suitability of an Apartment Building to House a Board and Care Occupancy.

32.4.1 General.

32.4.1.1 Scope.

32.4.1.1.1 Section 32.4 shall apply to apartment buildings that have one or more individual apartments used as a board and care occupancy.

32.4.1.1.2 Section 32.4 determines the suitability of such buildings, other than those complying with 32.4.1.1.4, to house a residential board and care facility.

32.4.1.1.3 The suitability of such buildings for apartments not used for board and care occupancies is covered in Chapter 30.

32.4.1.1.4 If a new board and care occupancy is created in an existing apartment building, the suitability of such buildings for apartments not used for board and care occupancies shall be covered by Chapter 31.

32.4.1.2 Requirements for individual apartments used as residential board and care occupancies shall be as specified in Section 32.2. Egress from the apartment into the common building corridor shall be considered acceptable egress from the board and care facility.

32.4.1.3* Apartment buildings housing board and care facilities shall comply with the requirements of Chapter 30 and the additional requirements of Section 32.4, unless the authority having jurisdiction has determined that equivalent safety for housing a residential board and care facility is provided in accordance with Section 1.5.

32.4.1.4 Minimum Construction Requirements.

32.4.1.4.1 In addition to the requirements of Chapter 30, apartment buildings, other than those complying with 32.4.1.4.2, housing residential board and care facilities shall meet the construction requirements of 32.3.1.3.

32.4.1.4.2 If a new board and care occupancy is created in an existing apartment building, the construction requirements of 19.1.6 shall apply.

32.4.2 Means of Egress.

32.4.2.1 The requirements of Section 30.2 shall apply only to the parts of means of egress serving the apartment(s) used as a residential board and care occupancy, as modified by 32.4.2.2.

32.4.2.2 If a new board and care occupancy is created in an existing apartment building, the requirements of Section 31.2 shall apply to the parts of the means of egress serving the apartment(s) used as a residential board and care occupancy.

32.4.3 Protection.

32.4.3.1 Interior Finish.

32.4.3.1.1 The requirements of 30.3.3 shall apply only to the parts of means of egress serving the apartment(s) used as a residential board and care occupancy, as modified by 32.4.3.1.2.

32.4.3.1.2 If a new board and care occupancy is created in an existing apartment building, the requirements of 31.3.3 shall apply to the parts of the means of egress serving the apartment(s) used as a residential board and care occupancy.

32.4.3.2 Construction of Corridor Walls.

32.4.3.2.1 The requirements of 30.3.6 shall apply only to corridors serving the residential board and care facility, including that portion of the corridor wall separating the residential board and care facility from the common corridor, as modified by 32.4.3.2.1.

32.4.3.2.2 If a new board and care occupancy is created in an existing apartment building, the requirements of 31.3.6 shall apply to the corridor serving the residential board and care facility.

32.4.3.3 Subdivision of Building Spaces. (Reserved)

32.5 Reserved.

32.6 Reserved.

32.7 Operating Features.

32.7.1 Emergency Plan.

32.7.1.1 The administration of every residential board and care facility shall have, in effect and available to all supervisory personnel, written copies of a plan for protecting all persons in the event of fire, for keeping persons in place, for evacuating persons to areas of refuge, and for evacuating persons from the building when necessary.

32.7.1.2 The emergency plan shall include special staff response, including the fire protection procedures needed to ensure the safety of any resident, and shall be amended or revised whenever any resident with unusual needs is admitted to the home.

32.7.1.3 All employees shall be periodically instructed and kept informed with respect to their duties and responsibilities under the plan, and such instruction shall be reviewed by the staff not less than every 2 months.

32.7.1.4 A copy of the plan shall be readily available at all times within the facility.

32.7.2 Resident Training.

32.7.2.1 All residents participating in the emergency plan shall be trained in the proper actions to be taken in the event of fire.

32.7.2.2 The training required by 32.7.2.1 shall include actions to be taken if the primary escape route is blocked.

32.7.2.3 If a resident is given rehabilitation or habilitation training, training in fire prevention and the actions to be taken in the event of a fire shall be a part of the training program.

32.7.2.4 Residents shall be trained to assist each other in case of fire to the extent that their physical and mental abilities permit them to do so without additional personal risk.

32.7.3 Emergency Egress and Relocation Drills. Emergency egress and relocation drills shall be conducted in accordance with 32.7.3.1 through 32.7.3.6.

32.7.3.1 Emergency egress and relocation drills shall be conducted not less than six times per year on a bimonthly basis, with not less than two drills conducted during the night when residents are sleeping, as modified by 32.7.3.5 and 32.7.3.6.

32.7.3.2 The drills shall be permitted to be announced in advance to the residents.

32.7.3.3 The drills shall involve the actual evacuation of all residents to an assembly point as specified in the emergency plan and shall provide residents with experience in egressing through all exits and means of escape required by the *Code*.

32.7.3.4 Exits and means of escape not used in any drill shall not be credited in meeting the requirements of this *Code* for board and care facilities.

32.7.3.5 Actual exiting from windows shall not be required to comply with 32.7.3; opening the window and signaling for help shall be an acceptable alternative.

32.7.3.6 If the board and care facility has an evacuation capability classification of impractical, those residents who cannot meaningfully assist in their own evacuation or who have special health problems shall not be required to actively participate in the drill. Section 18.7 shall apply in such instances.

32.7.4 Smoking.

32.7.4.1* Smoking regulations shall be adopted by the administration of board and care occupancies.

32.7.4.2 Where smoking is permitted, noncombustible safety-type ashtrays or receptacles shall be provided in convenient locations.

32.7.5* Furnishings, Bedding, and Decorations.

32.7.5.1 New draperies, curtains, and other similar loosely hanging furnishings and decorations in board and care facilities shall be in accordance with the provisions of 10.3.1.

32.7.5.2* New upholstered furniture within board and care facilities shall comply with 32.7.5.2.1 or 32.7.5.2.2.

32.7.5.2.1 New upholstered furniture shall be tested in accordance with the provisions of 10.3.2(1) and 10.3.3.

32.7.5.2.2 Upholstered furniture belonging to residents in sleeping rooms shall not be required to be tested, provided that a smoke alarm is installed in such rooms; battery-powered single-station smoke alarms shall be permitted in such rooms.

32.7.5.3* New mattresses within board and care facilities shall comply with 32.7.5.3.1 or 32.7.5.3.2.

32.7.5.3.1 New upholstered furniture shall be tested in accordance with the provisions of 10.3.2(3) and 10.3.4.

32.7.5.3.2 Mattresses belonging to residents in sleeping rooms shall not be required to be tested, provided that a smoke alarm is installed in such rooms; battery-powered single-station smoke alarms shall be permitted in such rooms.

32.7.6 Staff. Staff shall be on duty and in the facility at all times when residents requiring evacuation assistance are present.

Chapter 33 Existing Residential Board and Care Occupancies

33.1 General Requirements.

33.1.1* Application.

33.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as residential board and care occupancies (*see also 32.1.1*).

33.1.1.2* Any facility meeting the requirements of Chapter 32 shall not be required to meet those of Chapter 33.

33.1.1.3 This chapter is divided into five sections as follows:

- (1) Section 33.1 — General Requirements
- (2) Section 33.2 — Small Facilities (that is, sleeping accommodations for not more than 16 residents)
- (3) Section 33.3 — Large Facilities (that is, sleeping accommodations for more than 16 residents)
- (4) Section 33.4 — Suitability of an Apartment Building to House a Board and Care Occupancy
- (5) Section 33.7 — Operating Features (*Sections 33.5 and 33.6 are reserved.*)

33.1.1.4 Conversion. For the purposes of this chapter, exceptions for conversions shall apply only for a change of occupancy from an existing residential or health care occupancy to a residential board and care occupancy.

33.1.2 Multiple Occupancies.

33.1.2.1 Multiple occupancies shall comply with 6.1.14 in buildings other than those meeting 33.1.2.2.

33.1.2.2 The requirement of 33.1.2.1 shall not apply to apartment buildings housing residential board and care occupancies in conformance with Section 33.4. In such facilities, any safeguards required by Section 33.4 that are more restrictive than those for other housed occupancies shall apply only to the extent prescribed by Section 33.4.

33.1.2.3 No board and care occupancy shall have its sole means of egress or means of escape pass through any nonresidential or non-health care occupancy in the same building.

33.1.2.4 No board and care occupancy shall be located above a nonresidential or non-health care occupancy unless one of the following conditions is met:

- (1) The board and care occupancy and exits therefrom are separated from the nonresidential or non-health care occupancy by construction having a fire resistance rating of not less than 2 hours.
- (2) The nonresidential or non-health care occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7 and is separated therefrom by construction with a fire-resistance rating of 1 hour.

33.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Evacuation Capability.** See 3.3.57.
- (2) **Impractical Evacuation Capability.** See 3.3.57.1.
- (3) **Personal Care.** See 3.3.163.
- (4) **Point of Safety.** See 3.3.168.
- (5) **Prompt Evacuation Capability.** See 3.3.57.2.
- (6) **Residential Board and Care Occupancy.** See 3.3.152.13.
- (7) **Residential Board and Care Resident.** See 3.3.182.
- (8) **Slow Evacuation Capability.** See 3.3.57.3.

(9) **Staff (Residential Board and Care).** See 3.3.209.

(10) **Thermal Barrier.** See 3.3.23.3.

33.1.4 Acceptability of Means of Egress or Escape. No means of escape or means of egress shall be considered as complying with the minimum criteria for acceptance unless emergency evacuation drills are regularly conducted using that route in accordance with the requirements of 33.7.3.

33.1.5* Fire resistance-rated assemblies shall comply with Section 8.3.

33.1.6 Changes in Facility Size. A change in facility size from small to large shall be considered a change in occupancy subclassification and shall require compliance with the provisions applicable to new construction.

33.1.7* Changes in Group Evacuation Capability. A change in evacuation capability to a slower level shall be permitted where the facility conforms to the requirements applicable to new construction, conversions, and the new evacuation capability.

33.2 Small Facilities.

33.2.1 General.

33.2.1.1 Scope.

33.2.1.1.1 Section 32.2 shall apply to residential board and care occupancies providing sleeping accommodations for not more than 16 residents.

33.2.1.1.2 Where there are sleeping accommodations for more than 16 residents, the occupancy shall be classified as a large facility in accordance with Section 33.3.

33.2.1.2 Requirements Based on Evacuation Capability.

33.2.1.2.1 Small facilities, other than those meeting 33.2.1.2.1.1 or 33.2.1.2.1.2, shall comply with the requirements of Section 33.2 as indicated for the appropriate evacuation capability; the ability of all occupants, residents, staff, and family members shall be considered in determining evacuation capability.

33.2.1.2.1.1* Facilities where the authority having jurisdiction has determined equivalent safety is provided in accordance with Section 1.4 shall not be required to comply with Section 33.2.

33.2.1.2.1.2 Facilities that were previously approved as complying with the requirements for a large facility having the same evacuation capability shall not be required to comply with Section 33.2.

33.2.1.2.2 Facility management shall furnish to the authority having jurisdiction, upon request, an evacuation capability determination using a procedure acceptable to the authority having jurisdiction; where such documentation is not furnished, the evacuation capability shall be classified as impractical.

33.2.1.3 Minimum Construction Requirements.

33.2.1.3.1 Prompt Evacuation Capability. (No special requirements.)

33.2.1.3.2 Slow Evacuation Capability.

33.2.1.3.2.1 The facility shall be housed in a building where the interior is fully sheathed with lath and plaster or other material providing a 15-minute thermal barrier, as modified by 33.2.1.3.2.3 through 33.2.1.3.2.7, including all portions of bearing walls, bearing partitions, floor construction, and roofs.

33.2.1.3.2.2 All columns, beams, girders, and trusses shall be similarly encased or otherwise shall provide not less than a ½-hour fire resistance rating.

33.2.1.3.2.3 Exposed steel or wood columns, girders, and beams (but not joists) located in the basement shall be permitted.

33.2.1.3.2.4 Buildings of Type I, Type II(222), Type II(111), Type III(211), Type IV, or Type V(111) construction shall not be required to meet 33.2.1.3.2. (See 8.2.1.)

33.2.1.3.2.5 Areas protected by approved automatic sprinkler systems in accordance with 33.2.3.5 shall not be required to meet 33.2.1.3.2.

33.2.1.3.2.6 Unfinished, unused, and essentially inaccessible loft, attic, or crawl spaces shall not be required to meet 33.2.1.3.2.

33.2.1.3.2.7 Where the facility can demonstrate to the authority having jurisdiction that the group is capable of evacuating the building in 8 minutes or less or achieves an E-score of three or less using the board and care occupancies evacuation capability determination methodology of NFPA 101A, *Guide on Alternative Approaches to Life Safety*, the requirements of 33.2.1.3.2 shall not apply.

33.2.1.3.3 Impractical Evacuation Capability. Nonsprinklered buildings shall be of any construction type in accordance with 8.2.1 other than Type II(000), Type III(200), or Type V(000) construction. Buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 33.2.3.5 shall be permitted to be of any type of construction.

33.2.2 Means of Escape.

33.2.2.1 Number of Means of Escape.

33.2.2.1.1 Each normally occupied story of the facility shall have not less than two remotely located means of escape that do not involve using windows, unless the facility meets 33.2.2.1.4 or 33.2.2.1.5.

33.2.2.1.2 Not less than one of these means of escape shall be in accordance with 33.2.2.2.

33.2.2.1.3 The provisions of Chapter 7 shall not apply to means of escape unless specifically referenced in this chapter.

33.2.2.1.4 In prompt evacuation capability facilities, one means of escape shall be permitted to involve windows complying with 33.2.2.3(3).

33.2.2.1.5 A second means of escape from each story shall not be required where the entire building is protected throughout by an approved automatic sprinkler system complying with 33.2.3.5 and the facility has two means of escape; this provision shall not be permitted to be used in conjunction with 33.2.2.3.2.

33.2.2.2 Primary Means of Escape.

33.2.2.2.1 Every sleeping room and living area shall have access to a primary means of escape located to provide a safe path of travel to the outside.

33.2.2.2.2 Where sleeping rooms or living areas are above or below the level of exit discharge, the primary means of escape shall be an interior stair in accordance with 33.2.2.4, an exterior stair, a horizontal exit, or a fire escape stair.

33.2.2.2.3 In slow and impractical evacuation capability facilities, the primary means of escape for each sleeping room shall

not be exposed to living areas and kitchens unless the building is protected by an approved automatic sprinkler system in accordance with 33.2.3.5 utilizing quick-response or residential sprinklers throughout.

33.2.2.2.4 Standard response sprinklers shall be permitted for use in hazardous areas in accordance with 33.2.3.2.

33.2.2.2.3 Secondary Means of Escape. In addition to the primary route, each sleeping room shall have a second means of escape that consists of one of the following, unless the provisions of 33.2.2.3.1, 33.2.2.3.2, or 33.2.2.3.3 are met.

- (1) A door, stairway, passage, or hall providing a way of unobstructed travel to the outside of the dwelling at street or ground level that is independent of, and remotely located from, the primary means of escape
- (2) A passage through an adjacent nonlockable space, independent of and remotely located from, the primary means of escape to any approved means of escape
- (3)*An outside window or door operable from the inside without the use of tools, keys, or special effort that provides a clear opening of not less than 0.53 m² (5.7 ft²). The width shall be not less than 510 mm (20 in.), and the height shall be not less than 610 mm (24 in.). The bottom of the opening shall be not more than 1120 mm (44 in.) above the floor. Such means of escape shall be acceptable where one of the following is met:
 - (a) The window shall be within 6100 mm (240 in.) of grade.
 - (b) The window shall be directly accessible to fire department rescue apparatus as approved by the authority having jurisdiction.
 - (c) The window or door shall open onto an exterior balcony.

33.2.2.3.1 Sleeping rooms that have a door leading directly to the outside of the building with access to grade or to a stairway that meets the requirements of exterior stairs in 33.2.2.2.2 shall be considered as meeting all the requirements for a second means of escape.

33.2.2.3.2 A second means of escape from each sleeping room shall not be required where the facility is protected throughout by an approved automatic sprinkler system in accordance with 33.2.3.5.

33.2.2.3.3 Existing approved means of escape shall be permitted to continue to be used.

33.2.2.4 Interior Stairs Used for Primary Means of Escape. Interior stairs used for primary means of escape shall comply with 33.2.2.4.1 through 33.2.2.4.6.

33.2.2.4.1 Interior stairs shall be enclosed with ½-hour fire barriers, in accordance with Section 8.3, and shall comply with 7.2.2.5.3.

33.2.2.4.2 The entire primary means of escape shall be arranged so that it is not necessary for occupants to pass through a portion of a lower story unless that route is separated from all spaces on that story by construction having not less than a ½-hour fire resistance rating.

33.2.2.4.3 In buildings of construction other than Type II(000), Type III(200), or Type V(000), the supporting construction shall be protected to afford the required fire resistance rating of the supported wall.

33.2.2.4.4 Stairs that connect a story at street level to only one other story shall be permitted to be open to the story that is not at street level.

33.2.2.4.5 Stair enclosures shall not be required in buildings, that are comprised of three or fewer stories, and that house prompt or slow evacuation capability facilities protected throughout by an approved automatic sprinkler system in accordance with 33.2.3.5 that uses quick-response or residential sprinklers, provided that a primary means of escape from each sleeping area still exists that does not pass through a portion of a lower floor, unless that route is separated from all spaces on that floor by construction having a ½-hour fire resistance rating.

33.2.2.4.6 Stair enclosures shall not be required in buildings that are comprised of two or fewer stories, that house prompt evacuation capability facilities with not more than eight residents, and are protected by an approved automatic sprinkler system in accordance with 33.2.3.5 that uses quick-response or residential sprinklers.

33.2.2.4.7 The provisions of 33.2.2.3.2, 33.2.3.4.3.5, or 33.2.3.4.3.6 shall not be used in conjunction with 33.2.2.4.6.

33.2.2.4.8 Stairs shall be permitted to be open at the topmost story only where all of the following are met:

- (1) The building shall have three or fewer stories.
- (2) The building shall house prompt or slow evacuation capability facilities.
- (3) The building shall be protected by an approved automatic sprinkler system in accordance with 33.2.3.5.
- (4) The entire primary means of escape of which the stairs are a part shall be separated from all portions of lower stories.

33.2.2.5 Doors.

33.2.2.5.1 Doors, other than bathroom doors addressed in 33.2.2.5.2, and paths of travel to a means of escape shall be not less than 710 mm (28 in.) wide.

33.2.2.5.2 Bathroom doors shall be not less than 610 mm (24 in.) wide.

33.2.2.5.3 Doors shall be swinging or sliding.

33.2.2.5.4 Every closet door latch shall be readily opened from the inside.

33.2.2.5.5 Every bathroom door shall be designed to allow opening from the outside during an emergency when locked.

33.2.2.5.6 No door in any means of escape, other than those meeting 33.2.2.5.6.1 or 33.2.2.5.6.2, shall be locked against egress when the building is occupied.

33.2.2.5.6.1 Delayed egress locks complying with 7.2.1.6.1 shall be permitted on exterior doors only.

33.2.2.5.6.2 Access-controlled egress locks complying with 7.2.1.6.2 shall be permitted.

33.2.2.5.7 Forces to open doors shall comply with 7.2.1.4.5.

33.2.2.5.8 Door latching devices shall comply with 7.2.1.5.4.

33.2.2.6 Stairs.

33.2.2.6.1 Stairs shall comply with 7.2.2, unless otherwise specified in this chapter.

33.2.2.6.2 Winders complying with 7.2.2.2.4 shall be permitted.

33.2.2.6.3* Exterior stairs shall be protected against blockage caused by fire within the building.

33.2.3 Protection.

33.2.3.1 Protection of Vertical Openings.

33.2.3.1.1 Vertical openings, other than stairs complying with 33.2.2.4.4, 33.2.2.4.5, or 33.2.2.4.6, shall be protected so as not to expose a primary means of escape.

33.2.3.1.2 Vertical openings required to be protected by 33.2.3.1.1 shall be considered protected if separated by smoke partitions in accordance with Section 8.4 that prevent the passage of smoke from one story to any primary means of escape on another story.

33.2.3.1.3 Smoke partitions used to protect vertical openings shall have a fire resistance rating of not less than ½ hour.

33.2.3.1.4 Any doors or openings to the protected vertical opening shall be capable of resisting fire for not less than 20 minutes.

33.2.3.2 Hazardous Areas.

33.2.3.2.1 Any space where there is storage or activity having fuel conditions exceeding those of a one- or two-family dwelling and that possesses the potential for a fully involved fire shall be protected in accordance with 33.2.3.2.4 and 33.2.3.2.5.

33.2.3.2.2 Spaces requiring protection by 33.2.3.2.1 shall include, but shall not be limited to, areas for cartoned storage, food or household maintenance items in wholesale or institutional-type quantities and concentrations, or mass storage of residents' belongings.

33.2.3.2.3 Areas containing approved, properly installed and maintained furnaces and heating equipment, furnace rooms, and cooking and laundry facilities shall not be classified as hazardous areas solely on the basis of such equipment.

33.2.3.2.4 Any hazardous area that is on the same floor as, and is in or abuts, a primary means of escape or a sleeping room shall be protected by one of the following means:

- (1) Protection shall be an enclosure with a fire resistance rating of not less than 1 hour, with a self-closing or automatic-closing fire door in accordance with 7.2.1.8 that has a fire protection rating of not less than ¾ hour.
- (2) Protection shall be automatic sprinkler protection, in accordance with 33.2.3.5, and a smoke partition, in accordance with Section 8.4, located between the hazardous area and the sleeping area or primary escape route. Any doors in such separation shall be self-closing or automatic-closing in accordance with 7.2.1.8.

33.2.3.2.5 Other hazardous areas shall be protected by one of the following:

- (1) An enclosure having a fire resistance rating of not less than ½ hour, with a self-closing or automatic-closing door in accordance with 7.2.1.8 that is equivalent to not less than a 440-mm (1¾-in.) thick, solid-bonded wood core construction
- (2) Automatic sprinkler protection in accordance with 33.2.3.5, regardless of enclosure

33.2.3.3 Interior Finish.

33.2.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

33.2.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be as follows:

- (1) Class A or Class B in facilities other than those having prompt evacuation capability
- (2) Class A, Class B, or Class C in facilities having prompt evacuation capability

33.2.3.3.3 Interior Floor Finish. No requirements.

33.2.3.4 Detection, Alarm, and Communications Systems.

33.2.3.4.1 Fire Alarm Systems. A manual fire alarm system shall be provided in accordance with Section 9.6, unless the provisions of 33.2.3.4.1.1 or 33.2.3.4.1.2 are met.

33.2.3.4.1.1 A fire alarm system shall not be required where there are interconnected smoke detectors meeting the requirements of 33.2.3.4.3 and there is not less than one manual fire alarm box per floor arranged to continuously sound the smoke detector alarms.

33.2.3.4.1.2 Other manually activated continuously sounding alarms acceptable to the authority having jurisdiction shall be permitted in lieu of a fire alarm system.

33.2.3.4.2 Occupant Notification. Occupant notification shall be in accordance with 9.6.3.

33.2.3.4.3* Smoke Alarms.

33.2.3.4.3.1 Approved smoke alarms shall be provided in accordance with 9.6.2.10, unless otherwise indicated in 33.2.3.4.3.5 and 33.2.3.4.3.6.

33.2.3.4.3.2 Smoke alarms shall be powered from the building electrical system and, when activated, shall initiate an alarm that is audible in all sleeping areas.

33.2.3.4.3.3 Smoke alarms shall be installed on all levels, including basements but excluding crawl spaces and unfinished attics.

33.2.3.4.3.4 Additional smoke alarms shall be installed for living rooms, dens, day rooms, and similar spaces.

33.2.3.4.3.5 Smoke alarms in accordance with 33.2.3.4.3.1 shall not be required where buildings are protected throughout by an approved automatic sprinkler system, in accordance with 33.2.3.5, that uses quick-response or residential sprinklers, and are protected with approved smoke alarms installed in each sleeping room, in accordance with 9.6.2.10, that are powered by the building electrical system.

33.2.3.4.3.6 Smoke alarms in accordance with 33.2.3.4.3.1 shall not be required where buildings are protected throughout by an approved automatic sprinkler system, in accordance with 33.2.3.5, that uses quick-response or residential sprinklers, with existing battery-powered smoke alarms in each sleeping room, and where, in the opinion of the authority having jurisdiction, the facility has demonstrated that testing, maintenance, and a battery replacement program ensure the reliability of power to the smoke alarms.

33.2.3.5 Automatic Extinguishing Systems.

33.2.3.5.1 Reserved.

33.2.3.5.2 Where an automatic sprinkler system is installed, for either total or partial building coverage, the following requirements shall be met:

- (1) The system shall be in accordance with Section 9.7 and shall activate the fire alarm system in accordance with 33.2.3.4.1, modified by 33.2.3.5.2.1 through 33.2.3.5.2.6.
- (2) The adequacy of the water supply shall be documented to the authority having jurisdiction.

33.2.3.5.2.1* In prompt evacuation capability facilities, the following requirements shall be met:

- (1) An automatic sprinkler system in accordance with NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, shall be permitted.
- (2) Automatic sprinklers shall not be required in closets not exceeding 2.2 m² (24 ft²) and in bathrooms not exceeding 5.1 m² (55 ft²), provided that such spaces are finished with lath and plaster or materials providing a 15-minute thermal barrier.

33.2.3.5.2.2 In slow and impractical evacuation capability facilities, the following requirements shall be met:

- (1) An automatic sprinkler system in accordance with NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, with a 30-minute water supply, shall be permitted.
- (2) All habitable areas and closets shall be sprinklered.
- (3) Automatic sprinklers shall not be required in bathrooms not exceeding 5.1 m² (55 ft²), provided that such spaces are finished with lath and plaster or materials providing a 15-minute thermal barrier.

33.2.3.5.2.3 In prompt and slow evacuation facilities, where an automatic sprinkler system is in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*, sprinklers shall not be required in closets not exceeding 2.2 m² (24 ft²) and in bathrooms not exceeding 5.1 m² (55 ft²), provided that such spaces are finished with lath and plaster or materials providing a 15-minute thermal barrier.

33.2.3.5.2.4 In prompt and slow evacuation capability facilities up to and including four stories in height, systems installed in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be permitted.

33.2.3.5.2.5 In impractical evacuation capability facilities up to and including four stories in height, the following requirements shall be met:

- (1) Systems installed in accordance with NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, shall be permitted.
- (2) All habitable areas and closets shall be sprinklered.
- (3) Automatic sprinklers shall not be required in bathrooms not exceeding 5.1 m² (55 ft²), provided that such spaces are finished with lath and plaster or materials providing a 15-minute thermal barrier.

33.2.3.5.2.6 Initiation of the fire alarm system shall not be required for existing installations in accordance with 33.2.3.5.6.

33.2.3.5.3 Impractical Evacuation Capability. All impractical evacuation capability facilities shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 33.2.3.5.2.

33.2.3.5.4 Reserved.

33.2.3.5.5 Reserved.

33.2.3.5.6 Sprinkler piping serving not more than six sprinklers for any isolated hazardous area shall be permitted to be installed in accordance with 9.7.1.2 and shall meet the following requirements:

- (1) In new installations, where more than two sprinklers are installed in a single area, waterflow detection shall be pro-

vided to initiate the fire alarm system required by 33.2.3.4.1.

- (2) Duration of water supplies shall be as required for the sprinkler systems addressed in 33.2.3.5.2.

33.2.3.6 Construction of Corridor Walls.

33.2.3.6.1 Unless otherwise indicated in 33.2.3.6.1.1 through 33.2.3.6.1.4, corridor walls shall meet the following requirements:

- (1) The separation walls of sleeping rooms shall be capable of resisting fire for not less than ½ hour, which shall be considered to be achieved if the partitioning is finished on both sides with lath and plaster or materials providing a 15-minute thermal barrier.
- (2) Sleeping room doors shall be substantial doors, such as those of 440 mm (1¾-in.) thick, solid-bonded wood core construction or other construction of equal or greater stability and fire integrity.
- (3) Any vision panels shall be fixed fire window assemblies in accordance with 8.3.4 or shall be wired glass not exceeding 0.84 m² (1296 in.²) each in area and installed in approved frames.

33.2.3.6.1.1 In prompt evacuation capability facilities, all sleeping rooms shall be separated from the escape route by smoke partitions in accordance with Section 8.4, and door closing shall be regulated by 33.2.3.6.4.

33.2.3.6.1.2 The requirement of 33.2.3.6.1 shall not apply to corridor walls that are smoke partitions in accordance with Section 8.4 and that are protected by automatic sprinklers in accordance with 33.2.3.5 on both sides of the wall and door, and the following shall also apply:

- (1) In such instances, there shall be no limitation on the type or size of glass panels.
- (2) Door closing shall be regulated by 33.2.3.6.4.

33.2.3.6.1.3 Sleeping arrangements that are not located in sleeping rooms shall be permitted for nonresident staff members, provided that the audibility of the alarm in the sleeping area is sufficient to awaken staff who might be sleeping.

33.2.3.6.1.4 In previously approved facilities, where the facility has demonstrated to the authority having jurisdiction that the group is capable of evacuating the building in 8 minutes or less, or where the group achieves an E-score of three or less using the board and care occupancies evacuation capability determination methodology of NFPA 101A, *Guide on Alternative Approaches to Life Safety*, sleeping rooms shall be separated from escape routes by walls and doors that are smoke resistant.

33.2.3.6.2 Reserved.

33.2.3.6.3 No louvers or operable transoms or other air passages shall penetrate the wall, except properly installed heating and utility installations other than transfer grilles, which shall be prohibited.

33.2.3.6.4 Doors shall meet the following requirements:

- (1) Doors shall be provided with latches or other mechanisms suitable for keeping the doors closed.
- (2) No doors shall be arranged to prevent the occupant from closing the door.
- (3) Doors shall be self-closing or automatic-closing in accordance with 7.2.1.8 in buildings other than those protected throughout by an approved automatic sprinkler system in accordance with 33.2.3.5.2.

33.2.4 Reserved.**33.2.5 Building Services.****33.2.5.1 Utilities.** Utilities shall comply with Section 9.1.**33.2.5.2 Heating, Ventilating, and Air Conditioning.**

33.2.5.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of 9.2.1 and 9.2.2, except as otherwise required in this chapter.

33.2.5.2.2 No stove or combustion heater shall be located to block escape in case of fire caused by the malfunction of the stove or heater.

33.2.5.2.3 Unvented fuel-fired heaters shall not be used in any residential board and care facility.

33.3 Large Facilities.**33.3.1 General.****33.3.1.1 Scope.**

33.3.1.1.1 Section 33.3 shall apply to residential board and care occupancies providing sleeping accommodations for more than 16 residents.

33.3.1.1.2 Facilities having sleeping accommodations for not more than 16 residents shall be evaluated in accordance with Section 33.2.

33.3.1.1.3 Facilities meeting the requirements of Section 33.3 shall be considered to have met the requirements of Section 33.2 for prompt evacuation capability or slow evacuation capability.

33.3.1.2 Requirements Based on Evacuation Capability.

33.3.1.2.1 Prompt and Slow. Large facilities classified as prompt or slow evacuation capability, other than those meeting 33.3.1.2.1.1 or 33.3.1.2.1.2, shall comply with the requirements of Section 33.3 as indicated for the appropriate evacuation capability.

33.3.1.2.1.1* Facilities where the authority having jurisdiction has determined equivalent safety is provided in accordance with Section 1.4 shall not be required to comply with the requirements of Section 33.3, as indicated for the appropriate evacuation capability.

33.3.1.2.1.2 Facilities that were previously approved as complying with 33.3.1.2.2 shall not be required to comply with the requirements of Section 33.3, as indicated for the appropriate evacuation capability.

33.3.1.2.2* Impractical. Large facilities classified as impractical evacuation capability shall meet the requirements for limited care facilities in Chapter 19, unless the authority having jurisdiction has determined equivalent safety is provided in accordance with Section 1.4.

33.3.1.2.3 Evacuation Capability Determination.

33.3.1.2.3.1 Facility management shall furnish to the authority having jurisdiction, upon request, an evacuation capability determination using a procedure acceptable to the authority having jurisdiction.

33.3.1.2.3.2 Where the documentation required by 33.3.1.2.3.1 is not furnished, the evacuation capability shall be classified as impractical.

33.3.1.3 Minimum Construction Requirements.

33.3.1.3.1 Construction requirements for large facilities shall be as required by 33.3.1.3.

33.3.1.3.2 Where noted as "fully sheathed," the interior shall be covered with lath and plaster or materials providing a 15-minute thermal barrier.

33.3.1.3.3 For the purpose of construction requirements, stories shall be counted as follows:

- (1) Stories shall be counted starting with the primary level of exit discharge and ending with the highest occupied level.
- (2) Where the primary level of exit discharge is not readily apparent, the primary level of exit discharge of a building shall be that story that is level with or above finished grade of the exterior wall line for 50 percent or more of its perimeter.
- (3) Building levels below the primary level shall not be counted as a story in determining the height of the building.

33.3.1.3.4 The minimum construction requirements (*see 8.2.1*), based on the highest story normally used by board and care residents, shall be as follows:

- (1) Unless meeting the requirement of (2), one- or two-story facilities shall be any construction type that meets the requirements for 1-hour or greater fire resistance rating, that is Type IV(2HH), that is fully sheathed, or that is protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5.
- (2) One-story prompt evacuation capability facilities having 30 or fewer residents shall be permitted to be of any type construction.
- (3) Unless meeting the requirements of (4), three- to six-story facilities shall be Type I, Type II, or Type III construction that meets the requirements for 1-hour or greater fire resistance rating; Type IV construction that is protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5; or any other type of construction that is both sheathed and protected throughout by an approved automatic sprinkler system installed in accordance with 33.3.3.5, other than Type V(000).
- (4) Three- to four-story facilities of Type V(000) construction that are both fully sheathed and protected throughout by an approved, supervised automatic sprinkler system in accordance with 33.3.3.5 shall be considered to have met the requirements of 33.3.1.3.4(3).
- (5) Unless meeting the requirements of (6), facilities more than six stories high shall be any Type I or Type II(222) construction, and any Type II(111), Type III(211), or Type IV(2HH) construction that is protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5.
- (6) Any building of Type I, Type II(222), or Type II(111) construction shall be permitted to include roofing systems involving combustible supports, decking, or roofing, provided that the following criteria are met:
 - (a) The roof covering meets Class A requirements in accordance with NFPA 256, *Standard Methods of Fire Tests of Roof Coverings*.
 - (b) The roof is separated from all occupied portions of the building by a noncombustible floor assembly having not less than a 2-hour fire resistance rating that includes not less than 64 mm (2½ in.) of concrete or gypsum fill, and the attic or other space so developed shall be either unused or protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5.1.

33.3.1.4 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

33.3.2 Means of Egress.

33.3.2.1 General. Means of egress shall be in accordance with Chapter 7.

33.3.2.2 Means of Egress Components.

33.3.2.2.1 General. Components of means of egress shall be limited to the types described in 33.3.2.2.2 through 33.3.2.2.10.

33.3.2.2.2 Doors. Doors in means of egress shall be as follows:

- (1) Doors complying with 7.2.1 shall be permitted.
- (2) Doors within individual rooms and suites of rooms shall be permitted to be swinging or sliding.
- (3) No door in any means of egress, other than those meeting (4) or (5), shall be locked against egress when the building is occupied.
- (4) Delayed-egress locks in accordance with 7.2.1.6.1 shall be permitted, provided that not more than one device exists in a means of egress.
- (5) Access-controlled egress doors in accordance with 7.2.1.6.2 shall be permitted.
- (6) Revolving doors complying with 7.2.1.10 shall be permitted.

33.3.2.2.3 Stairs. Stairs complying with 7.2.2 shall be permitted.

33.3.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

33.3.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

33.3.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

33.3.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

33.3.2.2.8 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

33.3.2.2.9 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

33.3.2.2.10 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

33.3.2.3 Capacity of Means of Egress.

33.3.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

33.3.2.3.2 Street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs and ramps discharging onto the street floor.

33.3.2.3.3 The width of corridors serving an occupant load of 50 or more shall be sufficient for the occupant load served but shall be not less than 1120 mm (44 in.).

33.3.2.3.4 Corridors serving an occupant load fewer than 50 shall be not less than 915 mm (36 in.) wide.

33.3.2.4 Number of Exits. The minimum number of exits as required by Section 7.4 shall be provided on every story.

33.3.2.5 Arrangement of Means of Egress.

33.3.2.5.1 Access to all required exits shall be in accordance with Section 7.5.

33.3.2.5.2 Common paths of travel shall not exceed 33.5 m (110 ft) in buildings not protected throughout by an automatic sprinkler system in accordance with 33.3.3.5.

33.3.2.5.3 In buildings protected throughout by automatic sprinkler systems in accordance with 33.3.3.5, common paths of travel shall not exceed 48.8 m (160 ft).

33.3.2.5.4 Dead-end corridors shall not exceed 15 m (50 ft).

33.3.2.6 Travel Distance to Exits.

33.3.2.6.1 Travel distance from the door within a room, suite, or living unit to a corridor door shall not exceed 23 m (75 ft) in buildings not protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5.

33.3.2.6.2 Travel distance from the door within a room, suite, or living unit to a corridor door shall not exceed 38 m (125 ft) in buildings protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5.

33.3.2.6.3 Travel distance from the corridor door of any room to the nearest exit shall be in accordance with 33.3.2.6.3.1, 33.3.2.6.3.2, or 33.3.2.6.3.3.

33.3.2.6.3.1 Travel distance from the corridor door of any room to the nearest exit, measured in accordance with Section 7.6, shall not exceed 30 m (100 ft).

33.3.2.6.3.2 Travel distance to exits shall not exceed 61 m (200 ft) for exterior ways of exit access arranged in accordance with 7.5.3.

33.3.2.6.3.3 Travel distance to exits shall not exceed 61 m (200 ft) if the exit access and any portion of the building that is tributary to the exit access are protected throughout by approved automatic sprinkler systems in accordance with 33.3.3.5. In addition, the portion of the building in which 61-m (200-ft) travel distance is permitted shall be separated from the remainder of the building by construction having a fire resistance rating of not less than 1 hour for buildings not more than three stories in height and not less than 2 hours for buildings more than three stories in height.

33.3.2.7 Discharge from Exits. Exit discharge shall comply with Section 7.7.

33.3.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

33.3.2.9 Emergency Lighting. Emergency lighting in accordance with Section 7.9 shall be provided in all buildings with more than 25 rooms, unless each sleeping room has a direct exit to the outside of the building at ground level.

33.3.2.10 Marking of Means of Egress. Means of egress shall be marked in accordance with Section 7.10.

33.3.2.11 Special Means of Egress Features. (Reserved)

33.3.3 Protection.

33.3.3.1 Protection of Vertical Openings.

33.3.3.1.1 Vertical openings shall comply with 33.3.3.1.1.1, 33.3.3.1.1.2, or 33.3.3.1.1.3.

33.3.3.1.1.1 Vertical openings shall be enclosed or protected in accordance with Section 8.6.

33.3.3.1.1.2 Unprotected vertical openings not part of required egress shall be permitted to be waived by the authority having jurisdiction where such openings do not endanger required means of egress, provided that the building is protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5 and the exits and required ways of travel thereto are adequately safeguarded against fire and smoke within the building, or in which every individual room has direct access to an exterior exit without passing through a public corridor.

33.3.3.1.1.3 In buildings not more than two stories in height, unprotected vertical openings shall be permitted by the authority having jurisdiction, provided the building is protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5.

33.3.3.1.2 No floor below the level of exit discharge and used only for storage, heating equipment, or purposes other than residential occupancy shall have unprotected openings to floors used for residential occupancy.

33.3.3.2 Protection from Hazards.

33.3.3.2.1 Rooms containing high-pressure boilers, refrigerating machinery, transformers, or other service equipment subject to possible explosion shall not be located directly under or adjacent to exits, and such rooms shall be effectively separated from other parts of the building as specified in Section 8.7.

33.3.3.2.2 Hazardous areas, which shall include, but shall not be limited to, the following, shall be separated from other parts of the building by construction having a fire resistance rating of not less than 1 hour, with communicating openings protected by approved self-closing fire doors, or such area shall be equipped with automatic fire extinguishing systems:

- (1) Boiler and heater rooms
- (2) Laundries
- (3) Repair shops
- (4) Rooms or spaces used for storage of combustible supplies and equipment in quantities deemed hazardous by the authority having jurisdiction

33.3.3.3 Interior Finish.

33.3.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

33.3.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B.

33.3.3.3.3 Interior Floor Finish. Interior floor finish, other than approved, existing floor coverings, shall be Class I or Class II in corridors or exits.

33.3.3.4 Detection, Alarm, and Communications Systems.

33.3.3.4.1 General. A fire alarm system in accordance with Section 9.6 shall be provided, unless each sleeping room has exterior exit access in accordance with 7.5.3 and the building is not more than three stories in height.

33.3.3.4.2 Initiation. The required fire alarm system shall be initiated by all of the following means:

- (1) Manual means in accordance with 9.6.2, unless there are other effective means (such as a complete automatic sprinkler or automatic detection system) for notification of fire as required
- (2) A manual fire alarm box located at a convenient central control point under continuous supervision of responsible employees
- (3) Any automatic sprinkler system, other than those that are not required by another section of this *Code*
- (4) Any required detection system, other than sleeping room smoke alarms

33.3.3.4.3 Reserved.

33.3.3.4.4 Occupant Notification. Occupant notification shall be provided automatically, without delay, by internal audible alarm in accordance with 9.6.3.

33.3.3.4.5 Reserved.

33.3.3.4.6* Fire Department Notification. In case of a fire, provisions shall be made for the immediate notification of the public fire department, by either telephone or other means, or, where there is no public fire department, this notification shall be made to the private fire brigade.

33.3.3.4.7 Smoke Alarms. Smoke alarms shall be provided in accordance with 33.3.3.4.7.1, 33.3.3.4.7.2, or 33.3.3.4.7.3.

33.3.3.4.7.1 Each sleeping room shall be provided with an approved smoke alarm in accordance with 9.6.2.10 that is powered from the building electrical system.

33.3.3.4.7.2 Existing battery-powered smoke alarms, rather than building electrical service-powered smoke alarms, shall be accepted where, in the opinion of the authority having jurisdiction, the facility has demonstrated that testing, maintenance, and battery replacement programs ensure the reliability of power to the smoke alarms.

33.3.3.4.7.3 Sleeping room smoke alarms shall not be required in facilities having an existing corridor smoke detection system that comply with Section 9.6 and are connected to the building fire alarm system.

33.3.3.4.8 Smoke Detection Systems. All living areas as defined in 3.3.16.5 and all corridors shall be provided with smoke detectors that comply with *NFPA 72*[®], *National Fire Alarm Code*[®], and are arranged to initiate an alarm that is audible in all sleeping areas, as modified by 33.3.3.4.8.1 and 33.3.3.4.8.2.

33.3.3.4.8.1 Detectors shall not be required in living areas in facilities protected throughout by an approved automatic sprinkler system installed in accordance with 33.3.3.5.

33.3.3.4.8.2 Detectors shall not be required in unenclosed corridors, passageways, balconies, colonnades, or other arrangements with one or more sides along the long dimension fully or extensively open to the exterior at all times.

33.3.3.5 Extinguishment Requirements.

33.3.3.5.1* Automatic Extinguishment Systems. Where an automatic sprinkler system is installed for either total or partial building coverage, the system shall be installed in accordance with Section 9.7, as modified by 33.3.3.5.1.1, 33.3.3.5.1.2, and 33.3.3.5.1.3.

33.3.3.5.1.1 In buildings not more than four stories in height, a sprinkler system complying with NFPA 13R, *Standard*

for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height, shall be permitted.

33.3.3.5.1.2 Automatic sprinklers shall not be required in closets not exceeding 2.2 m^2 (24 ft^2) and in bathrooms not exceeding 5.1 m^2 (55 ft^2), provided that such spaces are finished with lath and plaster or materials with a 15-minute thermal barrier.

33.3.3.5.1.3 Initiation of the fire alarm system shall not be required for existing installations in accordance with 33.3.3.5.5.

33.3.3.5.2 All high-rise buildings shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 33.3.3.5, as modified by 33.3.3.5.3. Such systems shall initiate the fire alarm system in accordance with Section 9.6.

33.3.3.5.3 Automatic sprinklers shall not be required in small clothes closets where the smallest dimension does not exceed 915 mm (36 in.), the area does not exceed 2.2 m^2 (24 ft^2), and the walls and ceiling are finished with noncombustible or limited-combustible materials.

33.3.3.5.4 Automatic sprinkler systems shall be supervised in accordance with Section 9.7; waterflow alarms shall not be required to be transmitted off-site.

33.3.3.5.5 Sprinkler piping serving not more than six sprinklers for any isolated hazardous area in accordance with 9.7.1.2 shall be permitted; in new installations where more than two sprinklers are installed in a single area, waterflow detection shall be provided to initiate the fire alarm system required by 33.3.3.4.1.

33.3.3.5.6 Portable Fire Extinguishers. Portable fire extinguishers in accordance with 9.7.4.1 shall be provided near hazardous areas.

33.3.3.6 Corridors and Separation of Sleeping Rooms.

33.3.3.6.1 Access shall be provided from every resident use area to not less than one means of egress that is separated from all other rooms or spaces by walls complying with 33.3.3.6.3 through 33.3.3.6.6.3, unless otherwise indicated in 33.3.3.6.1.1 through 33.3.3.6.1.3.

33.3.3.6.1.1 Rooms or spaces, other than sleeping rooms, protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5 shall not be required to comply with 33.3.3.6.1.

33.3.3.6.1.2 Prompt evacuation capability facilities in buildings not over two stories in height where not less than one required means of egress from each sleeping room provides a path of travel to the outside without traversing any corridor or other spaces exposed to unprotected vertical openings, living areas, and kitchens shall not be required to comply with 33.3.3.6.1.

33.3.3.6.1.3 Rooms or spaces, other than sleeping rooms, provided with a smoke detection and alarm system connected to activate the building evacuation alarm, shall not be required to comply with 33.3.3.6.1. Furnishings, finishes, and furniture, in combination with all other combustibles within the spaces, shall be of minimum quantity and arranged so that a fully developed fire is unlikely to occur.

33.3.3.6.2 Sleeping rooms shall be separated from corridors, living areas, and kitchens by walls complying with 33.3.3.6.3 through 33.3.3.6.6.3.

33.3.3.6.3 Walls required by 33.3.3.6.1 or 33.3.3.6.2 shall comply with 33.3.3.6.3.1, 33.3.3.6.3.2, or 33.3.3.6.3.3.

33.3.3.6.3.1 Walls shall have a fire resistance rating of not less than $\frac{1}{2}$ hour.

33.3.3.6.3.2 In buildings protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5, walls shall be smoke partitions in accordance with Section 8.4, and the provisions of 8.4.3.5 shall not apply.

33.3.3.6.3.3 In buildings not more than two stories in height that are classified as prompt evacuation capability and that house not more than 30 residents, walls shall be smoke partitions in accordance with Section 8.4, and the provisions of 8.4.3.5 shall not apply.

33.3.3.6.4 Doors in walls required by 33.3.3.6.1 or 33.3.3.6.2 shall comply with 33.3.3.6.4.1, 33.3.3.6.4.2, 33.3.3.6.4.3, or 33.3.3.6.4.4.

33.3.3.6.4.1 Doors shall have a fire protection rating of not less than 20 minutes.

33.3.3.6.4.2 Solid-bonded wood core doors of not less than 440 mm ($1\frac{3}{4}$ in.) thickness shall be permitted to continue in use.

33.3.3.6.4.3 In buildings protected throughout by an approved automatic sprinkler system in accordance with 33.3.3.5, doors that are nonrated shall be permitted to continue in use.

33.3.3.6.4.4 Where automatic sprinkler protection is provided in the corridor in accordance with 31.3.5.6 through 31.3.5.8, the following requirements shall be met:

- (1) Doors shall not be required to have a fire protection rating but shall be in accordance with 8.4.3.
- (2) The provisions of 8.4.3.5 shall not apply.
- (3) Doors shall be equipped with latches for keeping the doors tightly closed.

33.3.3.6.5 Where walls and doors are required by 33.3.3.6.1 and 33.3.3.6.2, the following requirements shall be met:

- (1) Such walls and doors shall be constructed as smoke partitions in accordance with Section 8.4.
- (2) The provisions of 8.4.3.5 shall not apply.
- (3) No louvers, transfer grilles, operable transoms, or other air passages shall penetrate such walls or doors, except properly installed heating and utility installations.

33.3.3.6.6 Doors in walls required by 33.3.3.6.1 and 33.3.3.6.2 shall comply with 33.3.3.6.6.1, 33.3.3.6.6.2, or 33.3.3.6.6.3.

33.3.3.6.6.1 Doors shall be self-closing or automatic-closing in accordance with 7.2.1.8, and doors in walls separating sleeping rooms from corridors shall be automatic-closing in accordance with 7.2.1.8.2.

33.3.3.6.6.2 Doors to sleeping rooms that have occupant-control locks such that access is normally restricted to the occupants or staff personnel shall be permitted to be self-closing.

33.3.3.6.6.3 In buildings protected throughout by an approved automatic sprinkler system installed in accordance with 33.3.3.5, doors, other than doors to hazardous areas, vertical openings, and exit enclosures, shall not be required to be self-closing or automatic-closing.

33.3.3.7 Subdivision of Building Spaces. The following requirements shall be met for all sleeping floors.

33.3.3.7.1 Every sleeping room floor shall be divided into not less than two smoke compartments of approximately the same size, with smoke barriers in accordance with Section 8.5, unless otherwise indicated in 33.3.3.7.4, 33.3.3.7.5, and 33.3.3.7.6.

33.3.3.7.2 Smoke dampers shall not be required.

33.3.3.7.3 Additional smoke barriers shall be provided such that the travel distance from a sleeping room corridor door to a smoke barrier shall not exceed 46 m (150 ft).

33.3.3.7.4 Smoke barriers shall not be required in buildings protected throughout by an approved automatic sprinkler system installed in accordance with 33.3.3.5.

33.3.3.7.5 Smoke barriers shall not be required where each sleeping room is provided with exterior ways of exit access arranged in accordance with 7.5.3.

33.3.3.7.6 Smoke barriers shall not be required where the aggregate corridor length on each floor is not more than 46 m (150 ft).

33.3.4 Special Provisions. (Reserved)

33.3.5 Reserved.

33.3.6 Building Services.

33.3.6.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

33.3.6.2 Heating, Ventilating, and Air Conditioning.

33.3.6.2.1 Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

33.3.6.2.2 No stove or combustion heater shall be located such that it blocks escape in case of fire caused by the malfunction of the stove or heater.

33.3.6.2.3 Unvented fuel-fired heaters shall not be used in any board and care occupancy.

33.3.6.3 Elevators, Dumbwaiters, and Vertical Conveyors. Elevators, dumbwaiters, and vertical conveyors shall comply with the provisions of Section 9.4.

33.3.6.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

33.4* Suitability of an Apartment Building to House a Board and Care Occupancy.

33.4.1 General.

33.4.1.1 Scope.

33.4.1.1.1 Section 33.4 shall apply to apartment buildings that have one or more individual apartments used as a board and care occupancy.

33.4.1.1.2 Section 33.4 determines the suitability of such buildings to house a residential board and care facility.

33.4.1.1.3 The suitability of such buildings for apartments not used for board and care occupancies is covered in Chapter 31.

33.4.1.2 Requirements for individual apartments used as residential board and care occupancies shall be as specified in

Section 33.2. Egress from the apartment into the common building corridor shall be considered acceptable egress from the board and care facility.

33.4.1.3 Requirements Based on Evacuation Capability.

33.4.1.3.1* Apartment buildings housing board and care facilities shall comply with the requirements of Section 33.4, unless the authority having jurisdiction has determined that equivalent safety for housing a residential board and care facility is provided in accordance with Section 1.4.

33.4.1.3.2 All facilities shall meet the requirements of Chapter 31 and the additional requirements of Section 33.4.

33.4.1.4 Minimum Construction Requirements.

33.4.1.4.1 In addition to the requirements of Chapter 31, apartment buildings housing residential board and care facilities for groups classified as prompt or slow evacuation capability shall meet the construction requirements of 33.3.1.3, and those for groups classified as impractical evacuation capability shall meet the construction requirements of 19.1.6.

33.4.1.4.2 In applying the construction requirements of 33.4.1.4.1, the height shall be determined by the height of the residential board and care facility measured above the primary level of exit discharge.

33.4.2 Means of Egress. The requirements of Section 31.2 shall apply only to the parts of means of egress serving the apartment(s) used as a residential board and care occupancy.

33.4.3 Protection.

33.4.3.1 Interior Finish. The requirements of 31.3.3 shall apply only to the parts of means of egress serving the apartment(s) used as a residential board and care occupancy.

33.4.3.2 Construction of Corridor Walls. The requirements of 31.3.6 shall apply only to corridors serving the residential board and care facility, including that portion of the corridor wall separating the residential board and care facility from the common corridor.

33.4.3.3 Subdivision of Building Spaces. The requirements of 31.3.7 shall apply to those stories with an apartment(s) used as a residential board and care occupancy.

33.5 Reserved.

33.6 Reserved.

33.7 Operating Features.

33.7.1 Emergency Plan.

33.7.1.1 The administration of every residential board and care facility shall have, in effect and available to all supervisory personnel, written copies of a plan for protecting all persons in the event of fire, for keeping persons in place, for evacuating persons to areas of refuge, and for evacuating persons from the building when necessary.

33.7.1.2 The emergency plan shall include special staff response, including the fire protection procedures needed to ensure the safety of any resident, and shall be amended or revised whenever any resident with unusual needs is admitted to the home.

33.7.1.3 All employees shall be periodically instructed and kept informed with respect to their duties and responsibilities under the plan, and such instruction shall be reviewed by the staff not less than every 2 months.

33.7.1.4 A copy of the plan shall be readily available at all times within the facility.

33.7.2 Resident Training.

33.7.2.1 All residents participating in the emergency plan shall be trained in the proper actions to be taken in the event of fire.

33.7.2.2 The training required by 32.7.2.1 shall include actions to be taken if the primary escape route is blocked.

33.7.2.3 If the resident is given rehabilitation or habilitation training, training in fire prevention and the actions to be taken in the event of a fire shall be a part of the training program.

33.7.2.4 Residents shall be trained to assist each other in case of fire to the extent that their physical and mental abilities permit them to do so without additional personal risk.

33.7.3 Emergency Egress and Relocation Drills. Emergency egress and relocation drills shall be conducted in accordance with 33.7.3.1 through 33.7.3.6.

33.7.3.1 Emergency egress and relocation drills shall be conducted not less than six times per year on a bimonthly basis, with not less than two drills conducted during the night when residents are sleeping, as modified by 33.7.3.5 and 33.7.3.6.

33.7.3.2 The emergency drills shall be permitted to be announced in advance to the residents.

33.7.3.3 The drills shall involve the actual evacuation of all residents to an assembly point as specified in the emergency plan and shall provide residents with experience in egressing through all exits and means of escape required by this *Code*.

33.7.3.4 Exits and means of escape not used in any drill shall not be credited in meeting the requirements of this *Code* for board and care facilities.

33.7.3.5 Actual exiting from windows shall not be required to comply with 33.7.3; opening the window and signaling for help shall be an acceptable alternative.

33.7.3.6 If the board and care facility has an evacuation capability classification of impractical, those residents who cannot meaningfully assist in their own evacuation or who have special health problems shall not be required to actively participate in the drill. Section 19.7 shall apply in such instances.

33.7.4 Smoking.

33.7.4.1* Smoking regulations shall be adopted by the administration of board and care occupancies.

33.7.4.2 Where smoking is permitted, noncombustible safety-type ashtrays or receptacles shall be provided in convenient locations.

33.7.5* Furnishings, Bedding, and Decorations.

33.7.5.1 New draperies, curtains, and other similar loosely hanging furnishings and decorations in board and care facilities shall be in accordance with the provisions of 10.3.1.

33.7.5.2* New upholstered furniture within board and care facilities shall comply with 33.7.5.2.1 or 33.7.5.2.2.

33.7.5.2.1 New upholstered furniture shall be tested in accordance with the provisions of 10.3.2(1) and 10.3.3.

33.7.5.2.2 Upholstered furniture belonging to the residents in sleeping rooms shall not be required to be tested, provided

that a smoke alarm is installed in such rooms; battery-powered single-station smoke alarms shall be permitted in such rooms.

33.7.5.3* New mattresses within board and care facilities shall comply with 33.7.5.3.1 or 33.7.5.3.2.

33.7.5.3.1 New mattresses shall be tested in accordance with the provisions of 10.3.2(3) and 10.3.4.

33.7.5.3.2 Mattresses belonging to the residents in sleeping rooms shall not be required to be tested, provided that a smoke alarm is installed in such rooms; battery-powered single-station smoke alarms shall be permitted in such rooms.

33.7.6 Staff. Staff shall be on duty and in the facility at all times when residents requiring evacuation assistance are present.

Chapter 34 Reserved

Chapter 35 Reserved

Chapter 36 New Mercantile Occupancies

36.1 General Requirements

36.1.1 Application.

36.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as mercantile occupancies (*see 1.3.1*)
- (2) Additions made to, or used as, a mercantile occupancy (*see 4.6.7 and 36.1.1.3*)
- (3) Alterations, modernizations, or renovations of existing mercantile occupancies (*see 4.6.8*)
- (4) Existing buildings or portions thereof upon change of occupancy to a mercantile occupancy (*see 4.6.12*)

36.1.1.2 This chapter establishes life safety requirements for all new mercantile buildings. Specific requirements for suboccupancy groups such as Class A, Class B, and Class C mercantile occupancies; covered malls; and bulk merchandising retail buildings are contained in paragraphs pertaining thereto.

36.1.1.3 Additions to existing buildings shall comply with 36.1.1.3.1, 36.1.1.3.2, and 36.1.1.3.3.

36.1.1.3.1 Additions to existing buildings shall conform to the requirements for new construction.

36.1.1.3.2 Existing portions of the structure are not required to be modified, provided that the new construction has not diminished the fire safety features of the facility.

36.1.1.3.3 Existing portions shall be upgraded if the addition results in a change of mercantile subclassification. (*See 36.1.4.2.*)

36.1.1.4 When a mercantile occupancy changes from Class C to Class A or Class B, or from Class B to Class A, the provisions of this chapter shall apply.

36.1.2 Multiple Occupancies.

36.1.2.1 General.

36.1.2.1.1 All multiple occupancies shall be in accordance with 6.1.14 and 36.1.2.

36.1.2.1.2 Where there are differences in the specific requirements in this chapter and provisions for mixed occupancies or separated occupancies as specified in 6.1.14.3 and 6.1.14.4, the requirements of this chapter shall apply.

36.1.2.2 Combined Mercantile Occupancies and Parking Structures.

36.1.2.2.1 The fire barrier separating parking structures from a building classified as a mercantile occupancy shall be a fire barrier having a fire resistance rating of not less than 2 hours.

36.1.2.2.2 Openings in the fire barrier required by 36.1.2.2.1 shall not be required to be protected with fire protection-rated opening protectives in enclosed parking structures that are protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), or in open parking structures, provided all of the following conditions are met:

- (1) The openings do not exceed 25 percent of the area of the fire barrier in which they are located.
- (2) The openings are used as a public entrance and for associated sidelight functions.
- (3) The building containing the mercantile occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).
- (4) *Means are provided to prevent spilled fuel from accumulating adjacent to the openings and entering the building.
- (5) Physical means are provided to prevent vehicles from being parked or driven within 3050 mm (120 in.) of the openings.
- (6) The openings are protected as a smoke partition in accordance with Section 8.4 with no minimum fire protection rating required.

36.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Anchor Building.** See 3.3.27.2.
- (2) **Bulk Merchandising Retail Building.** See 3.3.27.4.
- (3) **Gross Leasable Area.** See 3.3.16.3.
- (4) **Open-Air Mercantile Operation.** See 3.3.156.

36.1.4 Classification of Occupancy.

36.1.4.1 General. Mercantile occupancies shall include all buildings and structures or parts thereof with occupancy as defined in 6.1.10.

36.1.4.2 Subclassification of Occupancy.

36.1.4.2.1 Mercantile occupancies shall be subclassified as follows:

- (1) **Class A** — All mercantile occupancies having an aggregate gross area of more than 2800 m² (30,000 ft²) or occupying more than three stories for sales purposes
- (2) **Class B** — All mercantile occupancies of more than 280 m² (3000 ft²), but not more than 2800 m² (30,000 ft²), aggregate gross area and occupying not more than three stories for sales purposes
- (3) **Class C** — All mercantile occupancies of not more than 280 m² (3000 ft²) gross area and used for sales purposes occupying one story only

36.1.4.2.2 For the purpose of the classification required in 36.1.4.2.1, the requirements of 36.1.4.2.2(A), 36.1.4.2.2(B), and 36.1.4.2.2(C) shall be met.

(A) The aggregate gross area shall be the total gross area of all floors used for mercantile purposes.

(B) Where a mercantile occupancy is divided into sections, regardless of fire separation, the aggregate gross area shall include the area of all sections used for sales purposes.

(C) Areas of floors not used for sales purposes, such as an area used only for storage and not open to the public, shall not be counted for the purposes of the classifications in 36.1.4.2.1(1), 36.1.4.2.1(2), and 36.1.4.2.1(3), but means of egress shall be provided for such nonsales areas in accordance with their occupancy as specified by other chapters of this *Code*.

36.1.4.2.3 Mezzanines shall comply with 8.6.9.

36.1.4.2.4 Where a number of tenant spaces under different management are located in the same building, the aggregate gross area for subclassification shall be one of the following:

- (1) Where tenant spaces are not separated, the aggregate gross floor area of all such tenant spaces shall be used in determining classification per 36.1.4.2.1.
- (2) Where individual tenant spaces are separated by fire barriers with a 2-hour fire resistance rating, each tenant space shall be individually classified.
- (3) Where tenant spaces are separated by fire barriers with a 1-hour fire resistance rating and the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), each tenant space shall be individually classified.
- (4) The tenant spaces in a mall building in accordance with 36.4.4 shall be classified individually.

36.1.5 Classification of Hazard of Contents.

36.1.5.1 The contents of mercantile occupancies shall be classified in accordance with Section 6.2.

36.1.5.2 Mercantile occupancies classified as high hazard in accordance with Section 6.2 shall meet the following additional requirements:

- (1) Exits shall be located so that not more than 23 m (75 ft) of travel from any point is needed to reach the nearest exit.
- (2) From every point, there shall be not less than two exits accessible by travel in different directions (no common path of travel).
- (3) All vertical openings shall be enclosed.

36.1.6 Minimum Construction Requirements. (No special requirements.)

36.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

36.2 Means of Egress Requirements.

36.2.1 General.

36.2.1.1 All means of egress shall be in accordance with Chapter 7 and this chapter.

36.2.1.2 No inside open stairway or inside open ramp shall be permitted to serve as a component of the required means of egress system for more than one floor.

36.2.1.3 Where there are two or more floors below the street floor, the same stairway or other exit shall be permitted to serve all floors, but all required exits from such areas shall be independent of any open stairways between the street floor and the floor below it.

36.2.1.4 Where a level, outside exit from upper floors is possible owing to hills, either 36.2.1.4.1 or 36.2.1.4.2 shall apply:

36.2.1.4.1 Such outside exits, if not also serving as an entrance from a principal street, shall be permitted to serve instead of horizontal exits.

36.2.1.4.2 Where such outside exits from the upper floor also serve as an entrance from a principal street, the upper floor shall be classified as a street floor in accordance with the definition of *street floor* in 3.3.216 and shall be subject to the requirements of this chapter for street floors.

36.2.1.5 For special considerations for high hazard contents, see 36.1.5.2.

36.2.2 Means of Egress Components.

36.2.2.1 General. Components of means of egress shall be limited to the types described in 36.2.2.2 through 36.2.2.12.

36.2.2.2 Doors.

36.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

36.2.2.2.2* Locks complying with 7.2.1.5.4 shall be permitted only on principal entrance/exit doors.

36.2.2.2.3 Reserved.

36.2.2.2.4 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted.

36.2.2.2.5 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted in buildings protected throughout by an approved, supervised fire detection system in accordance with Section 9.6 or an approved automatic sprinkler system in accordance with 9.7.1.1(1).

36.2.2.2.6 Where horizontal or vertical security grilles or doors are used as a part of the required means of egress from a tenant space, such grilles or doors shall comply with 7.2.1.4.1.4.

36.2.2.2.7 All doors at the foot of stairs from upper floors or at the head of stairs leading to floors below the street floor shall swing in the direction of egress travel.

36.2.2.2.8 Revolving doors complying with 7.2.1.10 shall be permitted.

36.2.2.3 Stairs.

36.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

36.2.2.3.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted.

36.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

36.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

36.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

36.2.2.7 Exit Passageways.

36.2.2.7.1 Exit passageways complying with 7.2.6 shall be permitted.

36.2.2.7.2* Exit passageways in a mall building shall be permitted to accommodate the following independently:

- (1) The portion of the occupant load assigned to the exit passageway from only the mall/pedestrian way
- (2) The largest occupant load assigned to the exit passageway from a single tenant space

36.2.2.8 Reserved.

36.2.2.9 Reserved.

36.2.2.10 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

36.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

36.2.2.12 Areas of Refuge.

36.2.2.12.1 Areas of refuge complying with 7.2.12 shall be permitted.

36.2.2.12.2 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), two rooms or spaces separated from each other by smoke-resistant partitions in accordance with the definition of *area of refuge* in 3.3.17 shall not be required.

36.2.3 Capacity of Means of Egress.

36.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

36.2.3.2 In Class A and Class B mercantile occupancies, street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs and ramps discharging through the street floor.

36.2.4 Number of Exits.

36.2.4.1 Exits shall comply with the following except as otherwise permitted by 36.2.4.2 through 36.2.4.5:

- (1) The number of means of egress shall be in accordance with Section 7.4.
- (2) Not less than two separate exits shall be provided on every story.
- (3) Not less than two separate exits shall be accessible from every part of every story.

36.2.4.2 Exit access as required by 36.2.4.1(3) shall be permitted to include a single exit access path for the distances permitted as common paths of travel by 36.2.5.3.

36.2.4.3 A single means of egress shall be permitted in a Class C mercantile occupancy, provided that the travel distance to the exit or to a mall does not exceed 23 m (75 ft).

36.2.4.4 A single means of egress shall be permitted in a Class C mercantile occupancy, provided that the travel distance to the exit or to a mall does not exceed 30 m (100 ft), and the story on which the occupancy is located and all communicating levels that are traversed to reach the exit or mall are protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).

36.2.4.5 A single means of egress to an exit or to a mall shall be permitted from a mezzanine within any Class A, Class B, or Class C mercantile occupancy, provided that the common path of travel does not exceed 23 m (75 ft), or does not exceed 30 m (100 ft) if protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).

36.2.5 Arrangement of Means of Egress.

36.2.5.1 Means of egress shall be arranged in accordance with Section 7.5.

36.2.5.2 Dead-end corridors shall comply with 36.2.5.2.1 or 36.2.5.2.2.

36.2.5.2.1 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), dead-end corridors shall not exceed 15 m (50 ft).

36.2.5.2.2 In all buildings not complying with 36.2.5.2.1, dead-end corridors shall not exceed 6100 mm (240 in.).

36.2.5.3 Common paths of travel shall be limited as follows:

- (1) Common paths of travel shall not exceed 23 m (75 ft) in mercantile occupancies classified as low or ordinary hazard.
- (2) Common paths of travel shall not exceed 30 m (100 ft) in mercantile occupancies classified as low or ordinary hazard where the building is protected throughout by an approved supervised automatic sprinkler system in accordance with 9.7.1.1(1).
- (3) Common paths of travel shall not be permitted in mercantile occupancies classified as high hazard.

36.2.5.4 Aisles leading to each exit shall be required, and the aggregate width of such aisles shall be not less than the required width of the exit.

36.2.5.5 Required aisles shall be not less than 915 mm (36 in.) in clear width.

36.2.5.6 In Class A mercantile occupancies, not less than one aisle of a 1525 mm (60 in.) minimum width shall lead directly to an exit.

36.2.5.7 In other than bulk merchandising retail buildings, if the only means of customer entrance is through one exterior wall of the building, two-thirds of the required egress width shall be located in such wall.

36.2.5.8 Not less than one-half of the required exits shall be located so as to be reached without passing through checkout stands.

36.2.5.9 Checkout stands or associated railings or barriers shall not obstruct exits, required aisles, or approaches thereto.

36.2.5.10* Where wheeled carts or buggies are used by customers, adequate provision shall be made for the transit and parking of such carts to minimize the possibility that they might obstruct means of egress.

36.2.5.11 Exit access in Class A and Class B mercantile occupancies that are protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), and exit access in all Class C mercantile occupancies, shall be permitted to pass through storerooms, provided that the following conditions are met:

- (1) Not more than 50 percent of exit access shall be provided through the storeroom.
- (2) The storeroom shall not be subject to locking.
- (3) The main aisle through the storeroom shall be not less than 1120 mm (44 in.) wide.
- (4) The path of travel through the storeroom, defined with fixed barriers, shall be direct and continuously maintained in an unobstructed condition.

36.2.6 Travel Distance to Exits. Travel distance shall be as specified in 36.2.6.1, 36.2.6.2, and 36.2.6.3 and shall be measured in accordance with Section 7.6.

36.2.6.1 In mercantile occupancies classified as ordinary hazard, travel distance shall not exceed 46 m (150 ft).

36.2.6.2 In mercantile occupancies classified as ordinary hazard in buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), travel distance shall not exceed 76 m (250 ft).

36.2.6.3 In mercantile occupancies classified as high hazard, travel distance shall not exceed 23 m (75 ft).

36.2.7 Discharge from Exits.

36.2.7.1 Exit discharge shall comply with Section 7.7 and 36.2.7.2.

36.2.7.2* Fifty percent of the exits shall be permitted to discharge through the level of exit discharge in accordance with 7.7.2 only where the building is protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), and the distance of travel from the termination of the exit enclosure to an outside street door shall not exceed 15 m (50 ft).

36.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

36.2.9 Emergency Lighting. Class A and Class B mercantile occupancies and mall buildings shall have emergency lighting facilities in accordance with Section 7.9.

36.2.10 Marking of Means of Egress. Where an exit is not immediately apparent from all portions of the sales area, means of egress shall have signs in accordance with Section 7.10.

36.2.11 Special Means of Egress Features. (Reserved)

36.3 Protection.

36.3.1 Protection of Vertical Openings. Any vertical opening shall be protected in accordance with Section 8.6, except under the following conditions:

- (1) In Class A or Class B mercantile occupancies protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), unprotected vertical openings shall be permitted at one of the following locations:
 - (a) Between any two floors
 - (b) Among the street floor, the first adjacent floor below, and adjacent floor (or mezzanine) above
- (2) In Class C mercantile occupancies, unprotected openings shall be permitted between the street floor and the mezzanine.
- (3) The draft stop and closely spaced sprinkler requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall not be required for unenclosed vertical openings permitted in 36.3.1(1) and 36.3.1(2).

36.3.2 Protection from Hazards.

36.3.2.1* Hazardous areas shall be protected in accordance with 36.3.2.1.1 or 36.3.2.1.2

36.3.2.1.1* Hazardous areas shall be protected in accordance with Section 8.7.

36.3.2.1.2 In general storage and stock areas protected by an automatic extinguishing system in accordance with 9.7.1.1(1) or 9.7.1.2, an enclosure shall be exempt from the provisions of 8.7.1.2.

36.3.2.2* High hazard contents areas, as classified in Section 6.2, shall meet the following criteria:

- (1) The area shall be separated from other parts of the building by fire barriers having a fire resistance rating of not less than 1 hour, with all openings therein protected by ¾-hour fire protection-rated self-closing fire door assemblies.
- (2) The area shall be protected by an automatic extinguishing system in accordance with 9.7.1.1(1) or 9.7.1.2.
- (3) In high hazard areas, all vertical openings shall be enclosed.

36.3.3 Interior Finish.

36.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

36.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B.

36.3.3.3 Interior Floor Finish.

36.3.3.3.1 Interior floor finish shall comply with Section 10.2.

36.3.3.3.2 Interior finish in exit enclosures shall be Class I or Class II.

36.3.4 Detection, Alarm, and Communications Systems.

36.3.4.1 General. Class A mercantile occupancies shall be provided with a fire alarm system in accordance with Section 9.6.

36.3.4.2 Initiation. Initiation of the required fire alarm system shall be by any one of the following:

- (1) Manual means in accordance with 9.6.2.1(1)
- (2) An approved automatic fire detection system that complies with 9.6.2.1(2) and provides protection throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5
- (3) An approved automatic sprinkler system that complies with 9.6.2.1(3) and provides protection throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5

36.3.4.3 Notification.

36.3.4.3.1 Occupant Notification. During all times that the mercantile occupancy is occupied, the required fire alarm system, once initiated, shall perform one of the following functions:

- (1) It shall activate an alarm in accordance with 9.6.3 throughout the mercantile occupancy. Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.
- (2) It shall activate an alarm signal in a continuously attended location for the purpose of initiating emergency action, by personnel trained to respond to emergencies, as follows:
 - (a) Emergency action shall be initiated by means of live voice public address system announcements originating from the attended location where the alarm signal is received.
 - (b) The live voice public address system shall be permitted to be used for other announcements, provided that the emergency action use takes precedence over any other use.

36.3.4.3.2 Emergency Forces Notification. Emergency forces notification shall be provided and shall include notifying the following:

- (1) The fire department in accordance with 9.6.4
- (2) The local emergency organization, if provided

36.3.5 Extinguishment Requirements.

36.3.5.1 Mercantile occupancies shall be protected by an approved automatic sprinkler system in accordance with 9.7.1.1(1) as follows:

- (1) Throughout all mercantile occupancies three or more stories in height
- (2) Throughout all mercantile occupancies exceeding 1115 m² (12,000 ft²) in gross area
- (3) Throughout stories below the level of exit discharge where such stories have an area exceeding 232 m² (2500 ft²) and used for the sale, storage, or handling of combustible goods and merchandise
- (4) Throughout multiple occupancies protected as mixed occupancies in accordance with 6.1.14 where the conditions of 36.3.5.1(1), 36.3.5.1(2), or 36.3.5.1(3) apply to the mercantile occupancy

36.3.5.2 Automatic sprinkler systems in Class A mercantile occupancies shall be supervised in accordance with 9.7.2.

36.3.5.3 Portable fire extinguishers shall be provided in all mercantile occupancies in accordance with 9.7.4.1.

36.3.6 Corridors.

36.3.6.1* Where access to exits is provided by corridors, such corridors shall be separated from use areas by walls having a fire resistance rating of not less than 1 hour in accordance with Section 8.3, except under any of the following conditions:

- (1) Where exits are available from an open floor area
- (2) Within a space occupied by a single tenant
- (3) Within buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)

36.3.6.2 Openings in corridor walls required by 36.3.6.1 to have a fire resistance rating shall be protected in accordance with Section 8.3.

36.3.7 Subdivision of Building Spaces. (No special requirements.)

36.4 Special Provisions.

36.4.1 Limited Access or Underground Buildings. See Section 11.7.

36.4.2 High-Rise Buildings. High-rise buildings shall comply with the automatic sprinkler requirements of 11.8.2.1.

36.4.3 Open-Air Mercantile Operations.

36.4.3.1 Open-air mercantile operations, such as open-air markets, gasoline filling stations, roadside stands for the sale of farm produce, and other outdoor mercantile operations shall be arranged and conducted to maintain free and unobstructed ways of travel at all times.

36.4.3.2 Ways of travel shall allow prompt escape from any point of danger in case of fire or other emergency, with no dead ends in which persons might be trapped due to display stands, adjoining buildings, fences, vehicles, or other obstructions.

36.4.3.3 Mercantile operations that are conducted in roofed-over areas shall be treated as mercantile buildings, provided that canopies over individual small stands to protect merchandise from the weather are not construed as constituting buildings for the purpose of this Code.

36.4.4 Mall Buildings. The purpose of 36.4.4 shall be to establish minimum standards of life safety for mall buildings having not more than three levels. (See 3.3.27.9.)

36.4.4.1 General. The mall building shall be treated as a single building for the purpose of calculation of means of egress and shall be subject to the requirements for appropriate occupancies,

except as modified by the provisions of 36.4.4; and the mall shall be of a clear width not less than that needed to accommodate egress requirements as set forth in other sections of this *Code*.

36.4.4.2 Pedestrian Way. The mall shall be permitted to be considered a pedestrian way, provided the criteria of 36.4.4.2.1 through 36.4.4.2.2 are met.

36.4.4.2.1 The travel distance within a tenant space to an exit or to the mall shall not exceed 61 m (200 ft) or the maximum travel distance permitted by the occupancy chapter.

36.4.4.2.2 An additional 61 m (200 ft) shall be permitted for travel through the mall space if all the following requirements are met:

- (1) The mall shall be of a clear width not less than that needed to accommodate egress requirements as set forth in other sections of this chapter but shall be not less than 6100 mm (240 in.) wide in its narrowest dimension.
- (2) On each side of the mall floor area, the mall shall be provided with an unobstructed exit access of not less than 3050 mm (120 in.) in clear width parallel to and adjacent to the mall tenant front.
- (3)*Such exit access shall lead to an exit having a width of not less than 1675 mm (66 in.).
- (4) The mall and all buildings connected thereto shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1). The system shall be installed in such a manner that any portion of the system serving tenant spaces can be taken out of service without affecting the operation of the portion of the system serving the mall.
- (5) Walls dividing tenant spaces from each other shall extend from the floor to the underside of the roof deck, floor deck above, or ceiling where the ceiling is constructed to limit the transfer of smoke. Where the tenant areas are provided with an engineered smoke control system, walls shall not be required to divide tenant spaces from each other. No separation shall be required between a tenant space and the mall.
- (6)*The mall shall be provided with a smoke control system.

36.4.4.3 Means of Egress Details.

36.4.4.3.1 Dead ends not exceeding a length equal to twice the width of the mall measured at the narrowest location within the dead-end portion of the mall shall be permitted.

36.4.4.3.2 Every story of a mall building shall be provided with the number of means of egress specified by Section 7.4 and as modified by 36.4.4.3.2.1 or 36.4.4.3.2.2.

36.4.4.3.2.1 Exit access travel shall be permitted to be common for the distances permitted as common paths of travel by 36.2.5.3.

36.4.4.3.2.2 A single means of egress shall be permitted in a Class C mercantile occupancy or a business occupancy, provided the travel distance to the exit or to a mall does not exceed 30 m (100 ft).

36.4.4.3.3 Every floor of a mall shall be provided with the number of means of egress specified by Section 7.4, with not less than two means of egress remotely located from each other.

36.4.4.3.4 Class A and Class B mercantile occupancies connected to a mall shall be provided with the number of means of egress required by Section 7.4, with not less than two means of egress remotely located from one another.

36.4.4.3.5* Each individual anchor building shall have means of egress independent of the mall.

36.4.4.3.6 Every mall shall be provided with unobstructed exit access parallel to and adjacent to the mall tenant fronts and extending to each mall exit.

36.4.4.3.7* Rooms housing building service equipment, janitor closets, and service elevators shall be permitted to open directly onto exit passageways, provided that the following criteria are met:

- (1) The required fire resistance rating between such rooms or areas and the exit passageway shall be maintained in accordance with 7.1.3.2.
- (2) Such rooms or areas shall be protected by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1); however, the exceptions in NFPA 13, *Standard for the Installation of Sprinkler Systems*, that permit the omission of sprinklers from such rooms shall not be permitted.
- (3) Service elevators opening into the exit passageway shall not open into areas other than exit passageways.
- (4) Where exit stair enclosures discharge into the exit passageway, the provisions of 7.2.1.5.7 shall apply regardless of the number of stories served.

36.4.4.3.8 Emergency Lighting. See 36.2.9.

36.4.4.4 Detection, Alarm, and Communications Systems.

36.4.4.4.1 General. Malls shall be provided with a fire alarm system in accordance with Section 9.6.

36.4.4.4.2 Initiation. Initiation of the required fire alarm system shall be by means of the required automatic sprinkler system in accordance with 9.6.2.1(3).

36.4.4.4.3 Notification.

36.4.4.4.3.1 Occupant Notification. During all times that the mall is occupied, the required fire alarm system, once initiated, shall perform one of the following functions.

- (1) It shall activate a general alarm in accordance with 9.6.3 throughout the mall.
- (2) Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.
- (3) It shall activate an alarm signal in a continuously attended location for the purpose of initiating emergency action by personnel trained to respond to emergencies. Emergency action shall be initiated by means of live voice public address system announcements originating from the attended location where the alarm signal is received. The live voice public address system shall be permitted to be used for other announcements, provided that the emergency action use takes precedence over any other use.

36.4.4.4.3.2 Emergency Forces Notification. Emergency forces notification shall be provided and shall include notifying the following:

- (1) The fire department in accordance with 9.6.4
- (2) The local emergency organization, if provided

36.4.4.4.4 Emergency Control. The fire alarm system shall be arranged to automatically actuate smoke management or smoke control systems in accordance with 9.6.5.2(3).

36.4.4.5 Tenant Spaces. Each individual tenant space shall have means of egress to the outside or to the mall, based on occupant load calculated by using Table 7.3.1.2.

36.4.4.6 Exit Passageways. Exit passageways in a mall building shall be permitted to accommodate the following independently:

- (1) The portion of the occupant load assigned to the exit passageway from only the mall
- (2) The largest occupant load assigned to the exit passageway from a single tenant space

36.4.4.7 Plastic Signs. Within every store or level and from side wall to side wall of each tenant space facing the mall, plastic signs shall be limited as follows:

- (1) Plastic signs shall not exceed 20 percent of the wall area facing the mall.
- (2) Plastic signs shall not exceed a height of 915 mm (36 in.) except if the sign is vertical, in which case the height shall not exceed 2440 mm (96 in.) and the width shall not exceed 915 mm (36 in.)
- (3) Plastic signs shall be located a minimum distance of 455 mm (18 in.) from adjacent tenants.
- (4) Plastics, other than foam plastics, shall meet one of the following criteria:
 - (a) They shall be light-transmitting plastics.
 - (b) They shall have a self-ignition temperature of 343°C (650°F) or greater when tested in accordance with ASTM D 1929, *Standard Test Method for Ignition Determining Temperatures of Plastic*, and a flame spread index not greater than 75 and a smoke developed index not greater than 450 when tested in the manner intended for use in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*.
- (5) Edges and backs of plastic signs in the mall shall be fully encased in metal.
- (6) Foam plastics shall have a maximum heat-release rate of 150 kW when tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*, and shall have physical characteristics in accordance with the following:
 - (a) The minimum density of foam plastic signs shall not be less than 320 kg/m³ (20 lb/ft³).
 - (b) The thickness of foam plastic signs shall not be greater than 13 mm (½ in.).

36.4.4.8 Kiosks. Kiosks and similar structures (temporary or permanent) shall not be considered as tenant spaces and shall meet the following requirements:

- (1) Combustible kiosks and similar structures shall be constructed of any of the following materials:
 - (a) Fire retardant-treated wood complying with the requirements for fire retardant-impregnated wood in NFPA 703, *Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*
 - (b) Light-transmitting plastics complying with Chapter 47 of the NFPA 5000TM, *Building Construction and Safety Code*TM
 - (c) Foam plastics having a maximum heat release rate not greater than 100 kW when tested in accordance with UL 1975
 - (d) Aluminum composite material (ACM) having a Class A rating as specified in Chapter 10 when tested as an assembly in the maximum thickness intended for use
 - (e) Textiles and films determined to be flame resistant in accordance with NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*

- (2) Kiosks or similar structures located within the mall shall be protected with approved fire suppression and detection devices.
- (3) The minimum horizontal separation between kiosks or groups of kiosks and other structures within the mall shall be 6100 mm (240 in.).
- (4) Each kiosk or group of kiosks or similar structure shall have a maximum area of 27.8 m² (300 ft²).

36.4.5 Bulk Merchandising Retail Buildings. New bulk merchandising retail buildings exceeding 1115 m² (12,000 ft²) in area shall comply with the requirements of this chapter as modified by 36.4.5.1 through 36.4.5.6.2.

36.4.5.1 Minimum Construction Requirements. Bulk merchandising retail buildings shall have a distance of not less than 4875 mm (192 in.) from the floor to the ceiling, from the floor to the floor above, or from the floor to the roof of any story.

36.4.5.2 Means of Egress Requirements.

36.4.5.2.1 All means of egress shall be in accordance with Chapter 7 and this chapter.

36.4.5.2.2 Not less than 50 percent of the required egress capacity shall be located independent of the main entrance/exit doors.

36.4.5.3 Storage, Arrangement, Protection, and Quantities of Hazardous Commodities.

36.4.5.3.1 The storage, arrangement, protection, and quantities of hazardous commodities shall be in accordance with the applicable portions of the following:

- (1) NFPA 13, *Standard for the Installation of Sprinkler Systems*
- (2) NFPA 30, *Flammable and Combustible Liquids Code*
- (3) NFPA 30B, *Code for the Manufacture and Storage of Aerosol Products*
- (4) NFPA 230, *Standard for the Fire Protection of Storage*
- (5) NFPA 430, *Code for the Storage of Liquid and Solid Oxidizers*
- (6) NFPA 432, *Code for the Storage of Organic Peroxide Formulations*
- (7) NFPA 434, *Code for the Storage of Pesticides*
- (8) NFPA 1124, *Code for the Manufacture, Transportation, Storage, and Retail Sales of Fireworks and Pyrotechnic Articles*

36.4.5.4 Detection, Alarm, and Communications Systems.

36.4.5.4.1 General. Bulk merchandising retail buildings shall be provided with a fire alarm system in accordance with Section 9.6.

36.4.5.4.2 Initiation. Initiation of the required fire alarm system shall be by means of the required approved automatic sprinkler system (see 36.4.5.5) in accordance with 9.6.2.1(3).

36.4.5.4.3 Occupant Notification. During all times that the mercantile occupancy is occupied, the required fire alarm system, once initiated, shall perform one of the following functions:

- (1) It shall activate an alarm in accordance with 9.6.3 throughout the mercantile occupancy. Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.
- (2) It shall activate an alarm signal in a continuously attended location for the purpose of initiating emergency action by personnel trained to respond to emergencies. Emergency action shall be initiated by means of live voice public address system announcements originating from the attended location where the alarm signal is received. The live voice public address system shall be permitted to be used for other announcements, provided that the emergency action use takes precedence over any other use.

36.4.5.4.4 Emergency Forces Notification. Emergency forces notification shall be provided and shall include notifying the following:

- (1) The fire department in accordance with 9.6.4
- (2) The local emergency organization, if provided

36.4.5.5 Extinguishing Requirements. Bulk merchandising retail buildings shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1) and the applicable provisions of the following:

- (1) NFPA 13, *Standard for the Installation of Sprinkler Systems*
- (2) NFPA 30, *Flammable and Combustible Liquids Code*
- (3) NFPA 30B, *Code for the Manufacture and Storage of Aerosol Products*
- (4) NFPA 230, *Standard for the Fire Protection of Storage*

36.4.5.6 Emergency Plan and Employee Training.

36.4.5.6.1 There shall be in effect an approved written plan for the emergency egress and relocation of occupants.

36.4.5.6.2 All employees shall be instructed and periodically drilled with respect to their duties under the plan.

36.5 Building Services.

36.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

36.5.2 Heating, Ventilating, and Air Conditioning. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

36.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

36.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

36.6 Reserved.

36.7 Operating Features.

36.7.1 Drills. In every Class A or Class B mercantile occupancy, employees shall be periodically trained in accordance with Section 4.7.

36.7.2 Extinguisher Training. Employees of mercantile occupancies shall be periodically instructed in the use of portable fire extinguishers.

36.7.3 Food service operations shall comply with 12.7.1.

Chapter 37 Existing Mercantile Occupancies

37.1 General Requirements.

37.1.1 Application.

37.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as mercantile occupancies. (See also 36.1.1.1.)

37.1.1.2 This chapter establishes life safety requirements for all existing mercantile buildings. Specific requirements for suboccupancy groups such as Class A, Class B, and Class C mercantile occupancies; covered malls; and bulk merchandising retail buildings are contained in paragraphs pertaining thereto.

37.1.1.3 Additions to existing buildings shall comply with 37.1.1.3.1, 37.1.1.3.2, and 37.1.1.3.3.

37.1.1.3.1 Additions to existing buildings shall conform to the requirements for new construction.

37.1.1.3.2 Existing portions of the structure are not required to be modified, provided that the new construction has not diminished the fire safety features of the facility.

37.1.1.3.3 Existing portions shall be upgraded if the addition results in a change of mercantile subclassification. (See 37.1.4.2.)

37.1.1.4 When a change in mercantile occupancy subclassification occurs, the following requirements shall be met:

- (1) When a mercantile occupancy changes from Class A to Class B or Class C, or from Class B to Class C, the provisions of this chapter shall apply.
- (2) When a mercantile occupancy changes from Class C to Class A or Class B, or from Class B to Class A, the provisions of Chapter 36 shall apply.

37.1.2 Multiple Occupancies.

37.1.2.1 General.

37.1.2.1.1 All multiple occupancies shall be in accordance with 6.1.14 and 37.1.2.

37.1.2.1.2 Where there are differences in the specific requirements in this chapter and provisions for mixed occupancies or separated occupancies as specified in 6.1.14.3 and 6.1.14.4, the requirements of this chapter shall apply.

37.1.2.2 Combined Mercantile Occupancies and Parking Structures.

37.1.2.2.1 The fire barrier separating parking structures from a building classified as a mercantile occupancy shall be a fire barrier having a fire resistance rating of not less than 2 hours.

37.1.2.2.2 Openings in the fire barrier required by 37.1.2.2.1 shall not be required to be protected with fire protection-rated opening protectives in enclosed parking structures that are protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), or in open parking structures, provided all of the following conditions are met:

- (1) The openings do not exceed 25 percent of the area of the fire barrier in which they are located.
- (2) The openings are used as a public entrance and for associated sidelight functions.
- (3) The building containing the mercantile occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).
- (4)*Means provided to prevent spilled fuel from accumulating adjacent to the openings and entering the building.
- (5) Physical means are provided to prevent vehicles from being parked or driven within 3050 mm (120 in.) of the openings.
- (6) The openings are protected as a smoke partition in accordance with Section 8.4 and with no minimum fire protection rating required.

37.1.3 Definitions. A list of terms used in this chapter follows:

- (1) **Anchor Building.** See 3.3.27.2.
- (2) **Bulk Merchandising Retail Building.** See 3.3.27.4.
- (3) **Gross Leasable Area.** See 3.3.16.3.
- (4) **Open-Air Mercantile Operation.** See 3.3.156.

37.1.4 Classification of Occupancy.

37.1.4.1 General. Mercantile occupancies shall include all buildings and structures or parts thereof with occupancy as defined in 6.1.10.

37.1.4.2 Subclassification of Occupancy.

37.1.4.2.1 Mercantile occupancies shall be subclassified as follows:

- (1) *Class A* — All mercantile occupancies having an aggregate gross area of more than 2800 m² (30,000 ft²) or occupying more than three stories for sales purposes
- (2) *Class B* — All mercantile occupancies of more than 280 m² (3000 ft²) but not more than 2800 m² (30,000 ft²) aggregate gross area and occupying not more than three stories for sales purposes
- (3) *Class C* — All mercantile occupancies of not more than 280 m² (3000 ft²) gross area used for sales purposes and occupying one story only, excluding mezzanines

37.1.4.2.2 For the purpose of the classification required in 37.1.4.2.1, the requirements of 37.1.4.2.2(A), 37.1.4.2.2(B), and 37.1.4.2.2(C) shall be met.

(A) The aggregate gross area shall be the total gross area of all floors used for mercantile purposes.

(B) Where a mercantile occupancy is divided into sections, regardless of fire separation, the aggregate gross area shall include the area of all sections used for sales purposes.

(C) Areas of floors not used for sales purposes, such as an area used only for storage and not open to the public, shall not be counted for the purposes of the classifications in 37.1.4.2.1(1), 37.1.4.2.1(2), and 37.1.4.2.1(3), but means of egress shall be provided for such nonsales areas in accordance with their occupancy as specified by other chapters of this *Code*.

37.1.4.2.3 The floor area of a mezzanine, or the aggregate floor area of multiple mezzanines, shall not exceed one-half of the floor area of the room or story in which the mezzanines are located; otherwise such mezzanine or aggregated mezzanines shall be treated as floors.

37.1.4.2.4 Where a number of tenant spaces under different management are located in the same building, the aggregate gross area for subclassification shall be one of the following:

- (1) Where tenant spaces are not separated, the aggregate gross floor area of all such tenant spaces shall be used in determining classification per 37.1.4.2.1.
- (2) Where individual tenant spaces are separated by fire barriers with a 1-hour fire resistance rating, each tenant space shall be individually classified.
- (3) The tenant spaces in a mall building in accordance with 37.4.4 shall be classified individually.

37.1.5 Classification of Hazard of Contents.

37.1.5.1 The contents of mercantile occupancies shall be classified in accordance with Section 6.2.

37.1.5.2 Mercantile occupancies classified as high hazard in accordance with Section 6.2 shall meet the following additional requirements:

- (1) Exits shall be located so that not more than 23 m (75 ft) of travel from any point is needed to reach the nearest exit.

- (2) From every point, there shall be not less than two exits accessible by travel in different directions (no common path of travel).

- (3) All vertical openings shall be enclosed.

37.1.6 Minimum Construction Requirements. (No special requirements)

37.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

37.2 Means of Egress Requirements.**37.2.1 General.**

37.2.1.1 All means of egress shall be in accordance with Chapter 7 and this chapter.

37.2.1.2 No inside open stairway, inside open escalator, or inside open ramp shall be permitted to serve as a component of the required means of egress system for more than one floor.

37.2.1.3 Where there are two or more floors below the street floor, the same stairway or other exit shall be permitted to serve all floors, but all required exits from such areas shall be independent of any open stairways between the street floor and the floor below it.

37.2.1.4 Where a level, outside exit from upper floors is possible owing to hills, either 37.2.1.4.1 or 37.2.1.4.2 shall apply.

37.2.1.4.1 Such outside exits, if not also serving as an entrance from a principal street, shall be permitted to serve instead of horizontal exits.

37.2.1.4.2 Where such outside exits from the upper floor also serve as an entrance from a principal street, the upper floor shall be classified as a street floor in accordance with the definition of *street floor* in 3.3.216 and shall be subject to the requirements of this chapter for street floors.

37.2.1.5 For special considerations for high hazard contents, see 37.1.5.2.

37.2.2 Means of Egress Components.

37.2.2.1 General. Components of means of egress shall be limited to the types described in 37.2.2.2 through 37.2.2.12.

37.2.2.2 Doors.

37.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

37.2.2.2.2* Locks complying with 7.2.1.5.4 shall be permitted only on principal entrance/exit doors.

37.2.2.2.3 The re-entry provisions of 7.2.1.5.7 shall not apply. (See 7.2.1.5.7.2(1).)

37.2.2.2.4 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted.

37.2.2.2.5 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted in buildings protected throughout by an approved, supervised fire detection system in accordance with Section 9.6 or an approved automatic sprinkler system in accordance with 9.7.1.1(1).

37.2.2.2.6 Where horizontal or vertical security grilles or doors are used as a part of the required means of egress from a tenant space, such grilles or doors shall comply with 7.2.1.4.1.4.

37.2.2.2.7 All doors at the foot of stairs from upper floors or at the head of stairs leading to floors below the street floor shall swing in the direction of egress travel.

37.2.2.2.8 Revolving doors complying with 7.2.1.10 shall be permitted.

37.2.2.2.9 In Class C mercantile occupancies, doors shall be permitted to swing inward against the direction of egress travel where such doors serve only the street floor area.

37.2.2.3 Stairs.

37.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

37.2.2.3.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted.

37.2.2.3.3 Winders complying with 7.2.2.2.4 shall be permitted.

37.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

37.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

37.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

37.2.2.7 Exit Passageways.

37.2.2.7.1 Exit passageways complying with 7.2.6 shall be permitted.

37.2.2.7.2* Exit passageways in a mall building shall be permitted to accommodate the following independently:

- (1) The portion of the occupant load assigned to the exit passageway from only the mall/pedestrian way
- (2) The largest occupant load assigned to the exit passageway from a single tenant space

37.2.2.8 Escalators and Moving Walks. Escalators and moving walks complying with 7.2.7 shall be permitted.

37.2.2.9 Fire Escape Stairs. Fire escape stairs complying with 7.2.8 shall be permitted.

37.2.2.10 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

37.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

37.2.2.12 Areas of Refuge.

37.2.2.12.1 Areas of refuge complying with 7.2.12 shall be permitted.

37.2.2.12.2 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), two rooms or spaces separated from each other by smoke-resistant partitions in accordance with the definition of area of refuge in 3.3.17 shall not be required.

37.2.3 Capacity of Means of Egress.

37.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

37.2.3.2 In Class A and Class B mercantile occupancies, street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs, ramps, escalators, and moving walks discharging through the street floor.

37.2.4 Number of Exits.

37.2.4.1 Exits shall comply with the following except as otherwise permitted by 37.2.4.2 through 37.2.4.5:

- (1) The number of means of egress shall be in accordance with Section 7.4.
- (2) Not less than two separate exits shall be provided on every story.
- (3) Not less than two separate exits shall be accessible from every part of every story.

37.2.4.2 Exit access as required by 37.2.4.1(3) shall be permitted to include a single exit access path for the distances permitted as common paths of travel by 37.2.5.3.

37.2.4.3 A single means of egress shall be permitted in a Class C mercantile occupancy, provided that the travel distance to the exit or to a mall does not exceed 23 m (75 ft).

37.2.4.4 A single means of egress shall be permitted in a Class C mercantile occupancy, provided that the travel distance to the exit or to a mall does not exceed 30 m (100 ft), and the story on which the occupancy is located and all communicating levels that are traversed to reach the exit or mall are protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).

37.2.4.5 A single means of egress to an exit or to a mall shall be permitted from a mezzanine within any Class A, Class B, or Class C mercantile occupancy, provided that the common path of travel does not exceed 23 m (75 ft), or does not exceed 30 m (100 ft) if protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).

37.2.5 Arrangement of Means of Egress.

37.2.5.1 Means of egress shall be arranged in accordance with Section 7.5.

37.2.5.2* Dead-end corridors shall not exceed 15 m (50 ft).

37.2.5.3* Common paths of travel shall be limited in accordance with 37.2.5.3.1 or 37.2.5.3.2.

37.2.5.3.1 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), a common path of travel shall be permitted for the first 30 m (100 ft).

37.2.5.3.2 In buildings not complying with 37.2.5.3.1, common paths of travel shall not exceed 23 m (75 ft).

37.2.5.4 Aisles leading to each exit shall be required, and the aggregate width of such aisles shall be not less than the required width of the exit.

37.2.5.5 Required aisles shall be not less than 710 mm (28 in.) in clear width.

37.2.5.6 In Class A mercantile occupancies, not less than one aisle of a 1525-mm (60-in.) minimum width shall lead directly to an exit.

37.2.5.7 In other than bulk merchandising retail buildings, if the only means of customer entrance is through one exterior wall of the building, two-thirds of the required egress width shall be located in such wall.

37.2.5.8 Not less than one-half of the required exits shall be located so as to be reached without passing through checkout stands.

37.2.5.9 Checkout stands or associated railings or barriers shall not obstruct exits, required aisles, or approaches thereto.

37.2.5.10* Where wheeled carts or buggies are used by customers, adequate provision shall be made for the transit and parking of such carts to minimize the possibility that they might obstruct means of egress.

37.2.5.11 Exit access in Class A mercantile occupancies that are protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1) and exit access in all Class B and Class C mercantile occupancies shall be permitted to pass through storerooms, provided that the following conditions are met:

- (1) Not more than 50 percent of exit access shall be provided through the storeroom.
- (2) The storeroom shall not be subject to locking.
- (3) The main aisle through the storeroom shall be not less than 1120 mm (44 in.) wide.
- (4) The path of travel through the storeroom, defined with fixed barriers, shall be direct and continuously maintained in an unobstructed condition.

37.2.6 Travel Distance to Exits. Travel distance shall be as specified in 37.2.6.1 and 37.2.6.2 and shall be measured in accordance with Section 7.6.

37.2.6.1 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), travel distance shall not exceed 76 m (250 ft).

37.2.6.2 In buildings not complying with 37.2.6.1, the travel distance shall not exceed 46 m (150 ft).

37.2.7 Discharge from Exits.

37.2.7.1 Exit discharge shall comply with Section 7.7 and 37.2.7.2.

37.2.7.2* Fifty percent of the exits shall be permitted to discharge through the level of exit discharge in accordance with 7.7.2 only where the building is protected throughout by an approved automatic sprinkler system in accordance with 9.7.1.1(1), and the distance of travel from the termination of the exit enclosure to an outside street door shall not exceed 15 m (50 ft).

37.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

37.2.9 Emergency Lighting. Class A and Class B mercantile occupancies and mall buildings shall have emergency lighting facilities in accordance with Section 7.9.

37.2.10 Marking of Means of Egress. Where an exit is not immediately apparent from all portions of the sales area, means of egress shall have signs in accordance with Section 7.10.

37.2.11 Special Means of Egress Features. (Reserved)

37.3 Protection.

37.3.1 Protection of Vertical Openings. Any vertical opening shall be protected in accordance with Section 8.6, except under the following conditions:

- (1) In Class A or Class B mercantile occupancies protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), unprotected vertical openings shall be permitted at one of the following locations:
 - (a) Between any two floors
 - (b) Among the street floor, the first adjacent floor below, and adjacent floor (or mezzanine) above
- (2) In Class C mercantile occupancies, unprotected openings shall be permitted between the street floor and the mezzanine.

- (3) The draft stop and closely spaced sprinkler requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall not be required for unenclosed vertical openings permitted in 37.3.1(1) and 37.3.1(2).

37.3.2 Protection from Hazards.

37.3.2.1* Hazardous areas shall be protected in accordance with 37.3.2.1.1 or 37.3.2.1.2.

37.3.2.1.1* Hazardous areas shall be protected in accordance with Section 8.7.

37.3.2.1.2 In general storage and stock areas protected by an automatic extinguishing system in accordance with 9.7.1.1(1) or 9.7.1.2, an enclosure shall be exempt from the provisions of 8.7.1.2.

37.3.2.2* High hazard contents areas, as classified in Section 6.2, shall meet the following criteria:

- (1) The area shall be separated from other parts of the building by fire barriers having a fire resistance rating of not less than 1 hour, with all openings therein protected by ¾-hour fire protection-rated self-closing fire door assemblies.
- (2) The area shall be protected by an automatic extinguishing system in accordance with 9.7.1.1(1) or 9.7.1.2.

37.3.3 Interior Finish.

37.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

37.3.3.2 Interior Wall and Ceiling Finish.

37.3.3.2.1 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B.

37.3.3.2.2 Existing Class C interior wall and ceiling finish shall be permitted as follows:

- (1) On walls
- (2) Throughout Class C stores

37.3.3.3 Interior Floor Finish. (No requirements)

37.3.4 Detection, Alarm, and Communications Systems.

37.3.4.1 General. Class A mercantile occupancies shall be provided with a fire alarm system in accordance with Section 9.6.

37.3.4.2 Initiation. Initiation of the required fire alarm system shall be by one of the following:

- (1) Manual means per 9.6.2.1(1)
- (2) An approved automatic fire detection system that complies with 9.6.2.1(2) and provides protection throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5
- (3) An approved automatic sprinkler system that complies with 9.6.2.1(3) and provides protection throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5

37.3.4.3 Notification.

37.3.4.3.1 Occupant Notification. During all times that the mercantile occupancy is occupied, the required fire alarm system, once initiated, shall perform one of the following functions:

- (1) It shall activate an alarm in accordance with 9.6.3 throughout the mercantile occupancy. Positive alarm sequence in accordance with 9.6.3.4 or a presignal system in accordance with 9.6.3.3 shall be permitted.

- (2) It shall activate an alarm signal in a continuously attended location for the purpose of initiating emergency action by personnel trained to respond to emergencies, as follows:
 - (a) Emergency action shall be initiated by means of live voice public address system announcements originating from the attended location where the alarm signal is received.
 - (b) The live voice public address system shall be permitted to be used for other announcements, provided that the emergency action use takes precedence over any other use.

37.3.4.3.2 Emergency Forces Notification. Emergency forces notification shall be provided and shall include notifying the following:

- (1) The fire department in accordance with 9.6.4
- (2) The local emergency organization, if provided

37.3.5 Extinguishment Requirements.

37.3.5.1 Mercantile occupancies, other than single-story buildings that meet the requirements of a street floor as defined in 3.3.216, shall be protected by an approved automatic sprinkler system in accordance with 9.7.1.1(1) as follows:

- (1) Throughout all mercantile occupancies with a story over 1400 m² (15,000 ft²) in area
- (2) Throughout all mercantile occupancies exceeding 2800 m² (30,000 ft²) in gross area
- (3) Throughout stories below the level of exit discharge where such stories have an area exceeding 232 m² (2500 ft²) and used for the sale, storage, or handling of combustible goods and merchandise
- (4) Throughout multiple occupancies protected as mixed occupancies in accordance with 6.1.14 where the conditions of 37.3.5.1(1), 37.3.5.1(2), or 37.3.5.1(3) apply to the mercantile occupancy

37.3.5.2 Reserved.

37.3.5.3 Portable fire extinguishers shall be provided in all mercantile occupancies in accordance with 9.7.4.1.

37.3.6 Corridors. (No requirements)

37.3.7 Subdivision of Building Spaces. (No special requirements)

37.4 Special Provisions.

37.4.1 Limited Access or Underground Buildings. See Section 11.7.

37.4.2 High-Rise Buildings. (No additional requirements)

37.4.3 Open-Air Mercantile Operations.

37.4.3.1 Open-air mercantile operations, such as open-air markets, gasoline filling stations, roadside stands for the sale of farm produce, and other outdoor mercantile operations shall be arranged and conducted to maintain free and unobstructed ways of travel at all times.

37.4.3.2 Ways of travel shall allow prompt escape from any point of danger in case of fire or other emergency, with no dead ends in which persons might be trapped due to display stands, adjoining buildings, fences, vehicles, or other obstructions.

37.4.3.3 Mercantile operations that are conducted in roofed-over areas shall be treated as mercantile buildings, provided that canopies over individual small stands to protect merchandise

from the weather are not construed as constituting buildings for the purpose of this Code.

37.4.4 Mall Buildings. The purpose of 37.4.4 shall be to establish minimum standards of life safety for mall buildings. (See 3.3.27.9.)

37.4.4.1 General. The mall building shall be treated as a single building for the purpose of calculation of means of egress and shall be subject to the requirements for appropriate occupancies, except as modified by the provisions of 37.4.4; and the mall shall be of a clear width not less than that needed to accommodate egress requirements as set forth in other sections of this Code.

37.4.4.2 Pedestrian Way. The mall shall be permitted to be considered a pedestrian way, provided the criteria of 37.4.4.2.1 and 37.4.4.2.2 are met.

37.4.4.2.1 The travel distance within a tenant space to an exit or to the mall shall not exceed 61 m (200 ft) or the maximum travel distance permitted by the occupancy chapter.

37.4.4.2.2 An additional 61 m (200 ft) shall be permitted for travel through the mall space if all the following requirements are met:

- (1) The mall shall be of a clear width not less than that needed to accommodate egress requirements as set forth in other sections of this chapter but shall be not less than 6100 mm (240 in.) wide in its narrowest dimension.
- (2) On each side of the mall floor area, the mall shall be provided with an unobstructed exit access of not less than 3050 mm (120 in.) in clear width parallel to and adjacent to the mall tenant front.
- (3)*Such exit access shall lead to an exit having a width of not less than 1675 mm (66 in.).
- (4) The mall and all buildings connected thereto shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).
- (5) Walls dividing tenant spaces from each other shall extend from the floor to the underside of the roof deck, to the floor deck above, or to the ceiling where the ceiling is constructed to limit the transfer of smoke. Where the tenant areas are provided with an engineered smoke control system, walls shall not be required to divide tenant spaces from each other. No separation shall be required between a tenant space and the mall.
- (6)*The mall shall be provided with a smoke control system.

37.4.4.3 Means of Egress Details.

37.4.4.3.1 Dead ends not exceeding a length equal to twice the width of the mall measured at the narrowest location within the dead-end portion of the mall shall be permitted.

37.4.4.3.2 Every story of a covered mall building shall be provided with the number of means of egress specified by Section 7.4 and as modified by 37.4.4.3.2.1 or 37.4.4.3.2.2.

37.4.4.3.2.1 Exit access travel shall be permitted to be common for the distances permitted as common paths of travel by 37.2.5.3.

37.4.4.3.2.2 A single means of egress shall be permitted in a Class C mercantile occupancy or a business occupancy, provided the travel distance to the exit or to a mall does not exceed 30 m (100 ft).

37.4.4.3.3 Every floor of a mall shall be provided with the number of means of egress specified by Section 7.4, with not less than two means of egress remotely located from each other.

37.4.4.3.4 Class A and Class B mercantile occupancies connected to a mall shall be provided with the number of means of egress required by Section 7.4, with not less than two means of egress remotely located from one another.

37.4.4.3.5* Each individual anchor building shall have means of egress independent of the mall.

37.4.4.3.6 Every mall shall be provided with unobstructed exit access parallel to and adjacent to the mall tenant fronts and extending to each mall exit.

37.4.4.3.7* Rooms housing building service equipment, janitor closets, and service elevators shall be permitted to open directly onto exit passageways, provided that the following criteria are met:

- (1) The required fire resistance rating between such rooms or areas and the exit passageway shall be maintained in accordance with 7.1.3.2.
- (2) Such rooms or areas shall be protected by an approved automatic sprinkler system in accordance with 9.7.1.1(1); however, the exceptions in NFPA 13, *Standard for the Installation of Sprinkler Systems*, that permit the omission of sprinklers from such rooms shall not be permitted.
- (3) Service elevators opening into the exit passageway shall not open into areas other than exit passageways.
- (4) Where exit stair enclosures discharge into the exit passageway, the provisions of 7.2.1.5.7 shall apply regardless of the number of stories served.

37.4.4.3.8 Emergency Lighting. See 37.2.9.

37.4.4.4 Detection, Alarm, and Communications Systems.

37.4.4.4.1 General. Malls shall be provided with a fire alarm system in accordance with Section 9.6.

37.4.4.4.2 Initiation. Initiation of the required fire alarm system shall be by means of the required automatic sprinkler system in accordance with 9.6.2.1(3).

37.4.4.4.3 Notification.

37.4.4.4.3.1 Occupant Notification. During all times that the mall is occupied, the required fire alarm system, once initiated, shall perform one of the following functions:

- (1) It shall activate an alarm in accordance with 9.6.3 throughout the mall.
- (2) Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.
- (3) It shall activate an alarm signal in a continuously attended location for the purpose of initiating emergency action by personnel trained to respond to emergencies. Emergency action shall be initiated by means of live voice public address system announcements originating from the attended location where the alarm signal is received. The live voice public address system shall be permitted to be used for other announcements, provided that the emergency action use takes precedence over any other use.

37.4.4.4.3.2 Emergency Forces Notification. Emergency forces notification shall be provided and shall include notifying the following:

- (1) The fire department in accordance with 9.6.4
- (2) The local emergency organization, if provided

37.4.4.4.4 Emergency Control. The fire alarm system shall be arranged to automatically actuate smoke management or smoke control systems in accordance with 9.6.5.2(3).

37.4.4.5 Tenant Spaces. Each individual tenant space shall have means of egress to the outside or to the mall based on occupant load calculated by using Table 7.3.1.2.

37.4.4.6 Exit Passageways. Exit passageways in a mall building shall be permitted to accommodate the following independently:

- (1) The portion of the occupant load assigned to the exit passageway from only the mall
- (2) The largest occupant load assigned to the exit passageway from a single tenant space

37.4.4.7 Plastic Signs. Within every store or level and from side wall to side wall of each tenant space facing the mall, plastic signs shall be limited as follows:

- (1) Plastic signs shall not exceed 20 percent of the wall area facing the mall.
- (2) Plastic signs shall not exceed a height of 915 mm (36 in.) except if the sign is vertical, in which case the height shall not exceed 2440 mm (96 in.) and the width shall not exceed 915 mm (36 in.)
- (3) Plastic signs shall be located a minimum distance of 455 mm (18 in.) from adjacent tenants.
- (4) Plastics, other than foam plastics, shall meet one of the following criteria:
 - (a) They shall be light-transmitting plastics
 - (b) They shall have a self-ignition temperature of 343°C (650°F) or greater when tested in accordance with ASTM D 1929, *Standard Test Method for Ignition Determining Temperatures of Plastic*, and a flame spread index not greater than 75 and a smoke developed index not greater than 450 when tested in the manner intended for use in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*.
- (5) Edges and backs of plastic signs in the mall shall be fully encased in metal.
- (6) Foam plastics shall have a maximum heat-release rate of 150 kW when tested in accordance with UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*, and shall have physical characteristics in accordance with the following:
 - (a) The minimum density of foam plastic signs shall not be less than 320 kg/m³ (20 lb/ft³).
 - (b) The thickness of foam plastic signs shall not be greater than 13 mm (½ in.).

37.4.4.8 Kiosks. Kiosks and similar structures (temporary or permanent) shall not be considered as tenant spaces and shall meet the following requirements:

- (1) Combustible kiosks and similar structures shall be constructed of any of the following materials:
 - (a) Fire retardant-treated wood complying with the requirements for fire retardant-impregnated wood in NFPA 703, *Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*
 - (b) Light-transmitting plastics complying with Chapter 47 of the NFPA 5000™, *Building Construction and Safety Code*™
 - (c) Foam plastics having a maximum heat release rate not greater than 100 kW when tested in accordance with UL 1975
 - (d) Aluminum composite material (ACM) having a Class A rating as specified in Chapter 10 when tested as an assembly in the maximum thickness intended for use

- (e) Textiles and films determined to be flame resistant in accordance with NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*
- (2) Kiosks or similar structures located within the mall shall be protected with approved fire suppression and detection devices.
- (3) The minimum horizontal separation between kiosks or groups of kiosks and other structures within the mall shall be 6100 mm (240 in.).
- (4) Each kiosk or group of kiosks or similar structure shall have a maximum area of 27.8 m² (300 ft²).

37.4.5 Bulk Merchandising Retail Buildings. Existing bulk merchandising retail buildings exceeding 1400 m² (15,000 ft²) in area shall comply with the requirements of this chapter as modified by 37.4.5.1 through 37.4.5.6.2.

37.4.5.1 Minimum Construction Requirements. (No requirements)

37.4.5.2 Means of Egress Requirements.

37.4.5.2.1 All means of egress shall be in accordance with Chapter 7 and this chapter.

37.4.5.2.2 Not less than 50 percent of the required egress capacity shall be located independent of the main entrance/exit doors.

37.4.5.3 Storage, Arrangement, Protection, and Quantities of Hazardous Commodities.

37.4.5.3.1 The storage, arrangement, protection, and quantities of hazardous commodities shall be in accordance with the applicable portions of the following:

- (1) NFPA 13, *Standard for the Installation of Sprinkler Systems*
- (2) NFPA 30, *Flammable and Combustible Liquids Code*
- (3) NFPA 30B, *Code for the Manufacture and Storage of Aerosol Products*
- (4) NFPA 230, *Standard for the Fire Protection of Storage*
- (5) NFPA 430, *Code for the Storage of Liquid and Solid Oxidizers*
- (6) NFPA 432, *Code for the Storage of Organic Peroxide Formulations*
- (7) NFPA 434, *Code for the Storage of Pesticides*
- (8) NFPA 1124, *Code for the Manufacture, Transportation, Storage, and Retail Sales of Fireworks and Pyrotechnic Articles*

37.4.5.4 Detection, Alarm, and Communications Systems.

37.4.5.4.1 General. Bulk merchandising retail buildings shall be provided with a fire alarm system in accordance with Section 9.6.

37.4.5.4.2 Initiation. Initiation of the required fire alarm system shall be by means of the required approved automatic sprinkler system (*see* 37.4.5.5) in accordance with 9.6.2.1(3).

37.4.5.4.3 Occupant Notification. During all times that the mercantile occupancy is occupied, the required fire alarm system, once initiated, shall perform one of the following functions:

- (1) It shall activate an alarm in accordance with 9.6.3 throughout the mercantile occupancy. Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.
- (2) It shall activate an alarm signal in a continuously attended location for the purpose of initiating emergency action by personnel trained to respond to emergencies. Emergency action shall be initiated by means of live voice public address system announcements originating from the attended location where the alarm signal is received. The live voice public address system shall be permitted to be used for other announcements, provided that the emergency action use takes precedence over any other use.

37.4.5.4.4 Emergency Forces Notification. Emergency forces notification shall be provided and shall include notifying the following:

- (1) The fire department in accordance with 9.6.4
- (2) The local emergency organization, if provided

37.4.5.5 Extinguishing Requirements. Bulk merchandising retail buildings shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1) and the applicable provisions of the following:

- (1) NFPA 13, *Standard for the Installation of Sprinkler Systems*
- (2) NFPA 30, *Flammable and Combustible Liquids Code*
- (3) NFPA 30B, *Code for the Manufacture and Storage of Aerosol Products*
- (4) NFPA 230, *Standard for the Fire Protection of Storage*

37.4.5.6 Emergency Plan and Employee Training.

37.4.5.6.1 There shall be in effect an approved written plan for the emergency egress and relocation of occupants.

37.4.5.6.2 All employees shall be instructed and periodically drilled with respect to their duties under the plan.

37.5 Building Services.

37.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

37.5.2 Heating, Ventilating, and Air Conditioning. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

37.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

37.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

37.6 Reserved.

37.7 Operating Features.

37.7.1 Drills. In every Class A or Class B mercantile occupancy, employees shall be periodically trained in accordance with Section 4.7.

37.7.2 Extinguisher Training. Employees of mercantile occupancies shall be periodically instructed in the use of portable fire extinguishers.

37.7.3 Food service operations shall comply with 13.7.1.

Chapter 38 New Business Occupancies

38.1 General Requirements.

38.1.1 Application.

38.1.1.1 The requirements of this chapter shall apply to the following:

- (1) New buildings or portions thereof used as business occupancies (*see* 1.3.1)
- (2) Additions made to, or used as, a business occupancy (*see* 4.6.7 and 38.1.1.3)
- (3) Alterations, modernizations, or renovations of existing business occupancies (*see* 4.6.8)

- (4) Existing buildings or portions thereof upon change of occupancy to a business occupancy (*see 4.6.12*)

38.1.1.2 This chapter establishes life safety requirements for all new business buildings.

38.1.1.3 Additions to existing buildings shall conform to the requirements for new construction. Existing portions of the structure shall not be required to be modified, provided that the new construction has not diminished the fire safety features of the facility.

38.1.2 Multiple Occupancies.

38.1.2.1 General.

38.1.2.1.1 All multiple occupancies shall be in accordance with 6.1.14 and 38.1.2.

38.1.2.1.2 Where there are differences in the specific requirements in this chapter and provisions for mixed occupancies or separated occupancies as specified in 6.1.14.3 and 6.1.14.4, the requirements of this chapter shall apply.

38.1.2.2 Combined Business Occupancies and Parking Structures.

38.1.2.2.1 The fire barrier separating parking structures from a building classified as a business occupancy shall be a fire barrier having a fire resistance rating of not less than 2 hours.

38.1.2.2.2 Openings in the fire barrier required by 38.1.2.2.1 shall not be required to be protected with fire protection-rated opening protectives in enclosed parking structures that are protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), or in open parking structures, provided all of the following conditions are met:

- (1) The openings do not exceed 25 percent of the area of the fire barrier in which they are located.
- (2) The openings are used as a public entrance and for associated sidelight functions.
- (3) The building containing the business occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).
- (4) *Means are provided to prevent spilled fuel from accumulating adjacent to the openings and entering the building.
- (5) Physical means are provided to prevent vehicles from being parked or driven within 3050 mm (120 in.) of the openings.
- (6) The openings are protected as a smoke partition in accordance with Section 8.4, with no minimum fire protection rating required.

38.1.3 Definitions. See Chapter 3.

38.1.4 Classification of Occupancy. Business occupancies shall include all buildings and structures or parts thereof with occupancy as defined in 6.1.11.

38.1.5 Classification of Hazard of Contents.

38.1.5.1 The contents of business occupancies shall be classified as ordinary hazard in accordance with Section 6.2.

38.1.5.2 For purposes of automatic sprinkler system design, a business occupancy shall be classified as a light hazard occupancy in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

38.1.6 Minimum Construction Requirements. (No requirements)

38.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

38.2 Means of Egress Requirements.

38.2.1 General.

38.2.1.1 All means of egress shall be in accordance with Chapter 7 and this chapter.

38.2.1.2 If, owing to differences in grade, any street floor exits are at points above or below the street or ground level, such exits shall comply with the provisions for exits from upper floors or floors below the street floor.

38.2.1.3 Stairs and ramps serving two or more floors below a street floor occupied for business use shall be permitted in accordance with 38.2.1.3.1 and 38.2.1.3.2.

38.2.1.3.1 Where two or more floors below the street floor are occupied for business use, the same stairs or ramps shall be permitted to serve each.

38.2.1.3.2 An inside open stairway or inside open ramp shall be permitted to serve as a required egress facility from not more than one floor level below the street floor.

38.2.1.4 Floor levels that are below the street floor; are used only for storage, heating, and other service equipment; and are not subject to business occupancy shall have means of egress in accordance with Chapter 42.

38.2.2 Means of Egress Components.

38.2.2.1 General. Means of egress components shall be limited to the types described in 38.2.2.2 through 38.2.2.12.

38.2.2.2 Doors.

38.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

38.2.2.2.2* Locks complying with 7.2.1.5.4 shall be permitted only on principal entrance/exit doors.

38.2.2.2.3 Reserved.

38.2.2.2.4 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted.

38.2.2.2.5 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

38.2.2.2.6 Where horizontal or vertical security grilles or doors are used as part of the required means of egress from a tenant space, such grilles or doors shall comply with 7.2.1.4.1.4.

38.2.2.2.7 Reserved.

38.2.2.2.8 Revolving doors complying with 7.2.1.10 shall be permitted.

38.2.2.3 Stairs.

38.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

38.2.2.3.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted.

38.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

38.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

38.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

38.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

38.2.2.8 Reserved.

38.2.2.9 Reserved.

38.2.2.10 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

38.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

38.2.2.12 Areas of Refuge.

38.2.2.12.1 Areas of refuge complying with 7.2.12 shall be permitted.

38.2.2.12.2 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), two rooms or spaces separated from each other by smoke-resistant partitions in accordance with the definition of area of refuge in 3.3.17 shall not be required.

38.2.3 Capacity of Means of Egress.

38.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

38.2.3.2* The clear width of any corridor or passageway serving an occupant load of 50 or more shall be not less than 1120 mm (44 in.).

38.2.3.3 Street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs and ramps discharging through the street floor.

38.2.4 Number of Exits.

38.2.4.1 Exits shall comply with the following except as otherwise permitted by 38.2.4.2 through 38.2.4.6:

- (1) The number of means of egress shall be in accordance with Section 7.4.
- (2) Not less than two separate exits shall be provided on every story.
- (3) Not less than two separate exits shall be accessible from every part of every story.

38.2.4.2 Exit access as required by 38.2.4.1(3) shall be permitted to include a single exit access path for the distances permitted as common paths of travel by 38.2.5.3.

38.2.4.3 A single exit shall be permitted for a room or area with a total occupant load of fewer than 100 persons, provided that the following criteria are met:

- (1) The exit shall discharge directly to the outside at the level of exit discharge for the building.
- (2) The total distance of travel from any point, including travel within the exit, shall not exceed 30 m (100 ft).
- (3) Such travel shall be on the same floor level or, if traversing of stairs is necessary, such stairs shall not exceed 4570 mm (180 in.) in height, and the stairs shall be provided with complete enclosures to separate them from any other part of the building, with no door openings therein.
- (4) A single outside stair in accordance with 7.2.2 shall be permitted to serve all floors permitted within the 4570-mm (180-in.) vertical travel limitation.

38.2.4.4 Any business occupancy not exceeding three stories, and not exceeding an occupant load of 30 people per floor, shall be permitted a single separate exit to each floor, provided the following criteria are met:

- (1) This arrangement shall be permitted only where the total travel distance to the outside of the building does not exceed 30 m (100 ft) and where the exit is enclosed in accordance with 7.1.3.2, serves no other levels, and discharges directly to the outside.
- (2) A single outside stair in accordance with 7.2.2 shall be permitted to serve all floors.

38.2.4.5 A single means of egress shall be permitted from a mezzanine within a business occupancy, provided that the common path of travel does not exceed 23 m (75 ft), or 30 m (100 ft) if protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).

38.2.4.6 A single exit shall be permitted for a maximum two-story, single-tenant space/building that is protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1) and where the total travel to the outside does not exceed 30 m (100 ft).

38.2.5 Arrangement of Means of Egress.

38.2.5.1 Means of egress shall be arranged in accordance with Section 7.5.

38.2.5.2 Dead-end corridors shall be permitted in accordance with 38.2.5.2.1 or 38.2.5.2.2.

38.2.5.2.1 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), dead-end corridors shall not exceed 15 m (50 ft).

38.2.5.2.2 In buildings other than those complying with 38.2.5.2.1, dead-end corridors shall not exceed 6100 mm (240 in.).

38.2.5.3 Limitations on common path of travel shall be in accordance with 38.2.5.3.1, 38.2.5.3.2, and 38.2.5.3.3.

38.2.5.3.1 Common path of travel shall not exceed first 30 m (100 ft) in a building protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).

38.2.5.3.2 Common path of travel shall not exceed first 30 m (100 ft) within a single tenant space having an occupant load not exceeding 30 persons.

38.2.5.3.3 In buildings other than those complying with 38.2.5.3.1 or 38.2.5.3.2, common path of travel shall not exceed 23 m (75 ft).

38.2.6 Travel Distance to Exits.

38.2.6.1 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), the travel distance shall not exceed 91 m (300 ft).

38.2.6.2 In buildings other than those complying with 38.2.6.1, the travel distance, measured in accordance with Section 7.6, shall not exceed 61 m (200 ft).

38.2.7 Discharge from Exits. Exit discharge shall comply with Section 7.7.

38.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

38.2.9 Emergency Lighting.

38.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9 in any building where any one of the following conditions exists:

- (1) The building is two or more stories in height above the level of exit discharge.
- (2) The occupancy is subject to 50 or more occupants above or below the level of exit discharge.
- (3) The occupancy is subject to 300 or more total occupants.

38.2.9.2 Emergency lighting in accordance with Section 7.9 shall be provided for all underground and limited access structures as defined in 3.3.217.11 and 3.3.217.3.

38.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

38.2.11 Special Means of Egress Features. (Reserved)

38.3 Protection.

38.3.1 Protection of Vertical Openings.

38.3.1.1 Vertical openings shall be enclosed or protected in accordance with Section 8.6, unless otherwise permitted by the following:

- (1) Unenclosed vertical openings in accordance with 8.6.8.2 shall be permitted.
- (2) Exit access stairs shall be permitted to be unenclosed in two-story, single-tenant spaces that are provided with a single exit in accordance with 38.2.4.2(5).

38.3.1.2 Floors that are below the street floor and are used for storage or other than a business occupancy shall have no unprotected openings to business occupancy floors.

38.3.2 Protection from Hazards.

38.3.2.1* Hazardous areas including, but not limited to, areas used for general storage, boiler or furnace rooms, and maintenance shops that include woodworking and painting areas shall be protected in accordance with Section 8.7.

38.3.2.2* High hazard contents areas, as classified in Section 6.2, shall meet the following criteria:

- (1) The area shall be separated from other parts of the building by fire barriers having a fire resistance rating of not less than 1 hour, with all openings therein protected by ¾-hour fire protection-rated self-closing fire doors assemblies.
- (2) The area shall be protected by an automatic extinguishing system in accordance with 9.7.1.1(1) or 9.7.1.2.

38.3.3 Interior Finish.

38.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

38.3.3.2 Interior Wall and Ceiling Finish.

38.3.3.2.1 Interior wall and ceiling finish material complying with Section 10.2 shall be Class A or Class B in exits and in exit access corridors.

38.3.3.2.2 Interior wall and ceiling finishes shall be Class A, Class B, or class C in all other areas.

38.3.3.3 Interior Floor Finish.

38.3.3.3.1 Interior floor finish shall comply with Section 10.2.

38.3.3.3.2 Interior finish in exit enclosures shall be Class I or Class II.

38.3.4 Detection, Alarm, and Communications Systems.

38.3.4.1 General. A fire alarm system in accordance with Section 9.6 shall be provided in all business occupancies where any one of the following conditions exists:

- (1) The building is two or more stories in height above the level of exit discharge.
- (2) The occupancy is subject to 50 or more occupants above or below the level of exit discharge.
- (3) The occupancy is subject to 300 or more total occupants.

38.3.4.2 Initiation. Initiation of the required fire alarm system shall be by one of the following:

- (1) By manual means in accordance with 9.6.2.1(1)
- (2) By means of an approved automatic fire detection system that complies with 9.6.2.1(2) and provides protection throughout the building
- (3) By means of an approved automatic sprinkler system that complies with 9.6.2.1(3) and provides protection throughout the building

38.3.4.3 Occupant Notification. During all times that the building is occupied, the required fire alarm system, once initiated, shall perform one of the following functions:

- (1) It shall activate a general alarm in accordance with 9.6.3 throughout the building; positive alarm sequence in accordance with 9.6.3.4 shall be permitted.
- (2) It shall activate an alarm signal in a continuously attended location for the purpose of initiating emergency action by personnel trained to respond to emergencies. Emergency action shall be initiated by means of live voice public address system announcements originating from the attended location where the alarm signal is received. The live voice public address system shall be permitted to be used for other announcements, provided that the emergency action use takes precedence over any other use.

38.3.5 Extinguishment Requirements. Portable fire extinguishers shall be provided in every business occupancy in accordance with 9.7.4.1.

38.3.6 Corridors.

38.3.6.1* Where access to exits is provided by corridors, such corridors shall be separated from use areas by walls having a fire resistance rating of not less than 1 hour in accordance with Section 8.3, unless one of the following conditions exists:

- (1)*Where exits are available from an open floor area
- (2)*Within a space occupied by a single tenant
- (3) Within buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)

38.3.6.2 Unenclosed exits available from an open floor area, or unenclosed exits that serve a space occupied by a single tenant, shall not be required to be protected in accordance with 38.3.6.1.

38.3.6.3 Openings in corridor walls required by 38.3.6.1 to have a fire resistance rating shall be protected in accordance with Section 8.3.

38.3.7 Subdivision of Building Spaces. (No special requirements)

38.4 Special Provisions.

38.4.1 Limited Access or Underground Buildings. See Section 11.7.

38.4.2* High-Rise Buildings. High-rise buildings shall comply with Section 11.8.

38.5 Building Services.

38.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

38.5.2 Heating, Ventilating, and Air Conditioning. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

38.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

38.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

38.6 Reserved.

38.7 Operating Features.

38.7.1 Drills. In all business occupancy buildings occupied by more than 500 persons, or by more than 100 persons above or below the street level, employees and supervisory personnel shall be periodically instructed in accordance with Section 4.7 and shall hold drills periodically where practicable.

38.7.2 Extinguisher Training. Designated employees of business occupancies shall be periodically instructed in the use of portable fire extinguishers.

38.7.3 Food service operations shall comply with 12.7.1.

Chapter 39 Existing Business Occupancies

39.1 General Requirements.

39.1.1 Application.

39.1.1.1 The requirements of this chapter shall apply to existing buildings or portions thereof currently occupied as business occupancies. (*See also 38.1.1.1.*)

39.1.1.2 This chapter establishes life safety requirements for existing business buildings. Specific requirements for high-rise buildings (*see definition in 3.3.27.7*) are contained in paragraphs pertaining thereto.

39.1.2 Multiple Occupancies.

39.1.2.1 General.

39.1.2.1.1 All multiple occupancies shall be in accordance with 6.1.14 and 39.1.2.

39.1.2.1.2 Where there are differences in the specific requirements in this chapter and provisions for mixed occupancies or separated occupancies as specified in 6.1.14.3 and 6.1.14.4, the requirements of this chapter shall apply.

39.1.2.2 Combined Business Occupancies and Parking Structures.

39.1.2.2.1 The fire barrier separating parking structures from a building classified as a business occupancy shall be a fire barrier having a fire resistance rating of not less than 2 hours.

39.1.2.2.2 Openings in the fire barrier required by 39.1.2.2.1 shall not be required to be protected with fire protection-rated opening protectives in enclosed parking structures that

are protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), or in open parking structures, provided all of the following conditions are met:

- (1) The openings do not exceed 25 percent of the area of the fire barrier in which they are located.
- (2) The openings are used as a public entrance and for associated sidelight functions.
- (3) The building containing the business occupancy is protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).
- (4)*Means are provided to prevent spilled fuel from accumulating adjacent to the openings and entering the building.
- (5) Physical means are provided to prevent vehicles from being parked or driven within 3050 mm (120 in.) of the openings.
- (6) The openings are protected as a smoke partition in accordance with Section 8.4, with no minimum fire protection rating required.

39.1.3 Definitions.

See Chapter 3.

39.1.4 Classification of Occupancy. Business occupancies shall include all buildings and structures or parts thereof with occupancy as defined in 6.1.11.

39.1.5 Classification of Hazard of Contents.

39.1.5.1 The contents of business occupancies shall be classified as ordinary hazard in accordance with Section 6.2.

39.1.5.2 For purposes of automatic sprinkler system design, a business occupancy shall be classified as a light hazard occupancy in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

39.1.6 Minimum Construction Requirements. (No requirements)

39.1.7 Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

39.2 Means of Egress Requirements.

39.2.1 General.

39.2.1.1 All means of egress shall be in accordance with Chapter 7 and this chapter.

39.2.1.2 If, owing to differences in grade, any street floor exits are at points above or below the street or ground level, such exits shall comply with the provisions for exits from upper floors or floors below the street floor.

39.2.1.3 Stairs and ramps serving two or more floors below a street floor occupied for business use shall be permitted in accordance with 39.2.1.3.1 and 39.2.1.3.2.

39.2.1.3.1 Where two or more floors below the street floor are occupied for business use, the same stairs, escalators, or ramps shall be permitted to serve each.

39.2.1.3.2 An inside open stairway, inside open escalator, or inside open ramp shall be permitted to serve as a required egress facility from not more than one floor level below the street floor.

39.2.1.4 Floor levels that are below the street floor; are used only for storage, heating, and other service equipment; and are not subject to business occupancy shall have means of egress in accordance with Chapter 42.

39.2.2 Means of Egress Components.

39.2.2.1 General. Means of egress components shall be limited to the types described in 39.2.2.2 through 39.2.2.12.

39.2.2.2 Doors.

39.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

39.2.2.2.2* Locks complying with 7.2.1.5.4 shall be permitted only on principal entrance/exit doors.

39.2.2.2.3 The re-entry provisions of 7.2.1.5.7 shall not apply. [See 7.2.1.5.7.2(1).]

39.2.2.2.4 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted.

39.2.2.2.5 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

39.2.2.2.6 Where horizontal or vertical security grilles or doors are used as part of the required means of egress from a tenant space, such grilles or doors shall comply with 7.2.1.4.1.4.

39.2.2.2.7 Approved existing horizontal-sliding or vertical-rolling fire doors shall be permitted in means of egress under the following conditions:

- (1) They are held open by fusible links.
- (2) The fusible links are rated at not less than 74°C (165°F).
- (3) The fusible links are located not more than 3050 mm (120 in.) above the floor.
- (4) The fusible links are in immediate proximity to the door opening.
- (5) The fusible links are not located above a ceiling.
- (6) The door is not credited with providing any protection under this *Code*.

39.2.2.2.8 Revolving doors complying with 7.2.1.10 shall be permitted.

39.2.2.3 Stairs.

39.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

39.2.2.3.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted.

39.2.2.3.3 Winders complying with 7.2.2.2.4 shall be permitted.

39.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

39.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

39.2.2.6 Ramps. Ramps complying with 7.2.5 shall be permitted.

39.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

39.2.2.8 Escalators and Moving Walks. Escalators and moving walks complying with 7.2.7 shall be permitted.

39.2.2.9 Fire Escape Stairs. Fire escape stairs complying with 7.2.8 shall be permitted.

39.2.2.10 Fire Escape Ladders. Fire escape ladders complying with 7.2.9 shall be permitted.

39.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

39.2.2.12 Areas of Refuge.

39.2.2.12.1 Areas of refuge complying with 7.2.12 shall be permitted.

39.2.2.12.2 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), two rooms or spaces separated from each other by smoke-resistant partitions in accordance with the definition of area of refuge in 3.3.17 shall not be required.

39.2.3 Capacity of Means of Egress.

39.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

39.2.3.2 The clear width of any corridor or passageway serving an occupant load of 50 or more shall be not less than 1120 mm (44 in.).

39.2.3.3 Street floor exits shall be sufficient for the occupant load of the street floor plus the required capacity of stairs, ramps, escalators, and moving walks discharging through the street floor.

39.2.4 Number of Exits.

39.2.4.1 Exits shall comply with the following except as otherwise permitted by 39.2.4.2 through 39.2.4.6:

- (1) The number of means of egress shall be in accordance with 7.4.1.1 and 7.4.1.3 through 7.4.1.6.
- (2) Not less than two separate exits shall be provided on every story.
- (3) Not less than two separate exits shall be accessible from every part of every story.

39.2.4.2 Exit access as required by 39.2.4.1(3) shall be permitted to include a single exit access path for the distances permitted as common paths of travel by 39.2.5.3.

39.2.4.3 A single exit shall be permitted for a room or area with a total occupant load of fewer than 100 persons, provided that the following criteria are met:

- (1) The exit shall discharge directly to the outside at the level of exit discharge for the building.
- (2) The total distance of travel from any point, including travel within the exit, shall not exceed 30 m (100 ft).
- (3) Such travel shall be on the same floor level or, if traversing of stairs is necessary, such stairs shall not exceed 4570 mm (180 in.) in height, and the stairs shall be provided with complete enclosures to separate them from any other part of the building, with no door openings therein.
- (4) A single outside stair in accordance with 7.2.2 shall be permitted to serve all floors permitted within the 4570-mm (180-in.) vertical travel limitation.

39.2.4.4 Any business occupancy not exceeding three stories, and not exceeding an occupant load of 30 people per floor, shall be permitted a single separate exit to each floor, provided the following criteria are met:

- (1) This arrangement shall be permitted only where the total travel distance to the outside of the building does not exceed 30 m (100 ft) and where the exit is enclosed in accordance with 7.1.3.2, serves no other levels, and discharges directly to the outside.

- (2) A single outside stair in accordance with 7.2.2 shall be permitted to serve all floors.

39.2.4.5 A single means of egress shall be permitted from a mezzanine within a business occupancy, provided that the common path of travel does not exceed 23 m (75 ft), or 30 m (100 ft) if protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).

39.2.4.6 A single exit shall be permitted for a maximum two-story, single-tenant space/building that is protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1) and where the total travel to the outside does not exceed 30 m (100 ft).

39.2.5 Arrangement of Means of Egress.

39.2.5.1 Means of egress shall be arranged in accordance with Section 7.5.

39.2.5.2* Dead-end corridors shall not exceed 15 m (50 ft).

39.2.5.3* Limitation on common path of travel shall be in accordance with 39.2.5.3.1, 39.2.5.3.2, and 39.2.5.3.3.

39.2.5.3.1 Common path of travel shall not exceed 30 m (100 ft) on a story protected throughout by an approved automatic sprinkler system in accordance with 9.7.1.1(1).

39.2.5.3.2 Common path of travel shall not be limited in a single-tenant space with an occupant load not exceeding 30 people.

39.2.5.3.3 In buildings other than those complying with 39.2.5.3.1 or 39.2.5.3.2, common path of travel shall not exceed 23 m (75 ft).

39.2.6 Travel Distance to Exits.

39.2.6.1 In buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1), the travel distance shall not exceed 91 m (300 ft).

39.2.6.2 In all buildings other than those complying with 39.2.6.1, the travel distance, measured in accordance with Section 7.6, shall not exceed 61 m (200 ft).

39.2.7 Discharge from Exits. Exit discharge shall comply with Section 7.7.

39.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8.

39.2.9 Emergency Lighting.

39.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9 in any building where any one of the following conditions exists:

- (1) The building is two or more stories in height above the level of exit discharge.
- (2) The occupancy is subject to 100 or more occupants above or below the level of exit discharge.
- (3) The occupancy is subject to 1000 or more total occupants.

39.2.9.2 Emergency lighting in accordance with Section 7.9 shall be provided for all underground and limited access structures as defined in 3.3.217.11 and 3.3.217.3.

39.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

39.2.11 Special Means of Egress Features. (Reserved)

39.3 Protection.

39.3.1 Protection of Vertical Openings.

39.3.1.1 Vertical openings, shall be enclosed or protected in accordance with Section 8.6 unless otherwise permitted by the following:

- (1) Unenclosed vertical openings in accordance with 8.6.8.2 shall be permitted.
- (2) Exit access stairs shall be permitted to be unenclosed in two-story, single-tenant spaces that are provided with a single exit in accordance with 39.2.4.2(5).
- (3) Unprotected vertical openings shall be permitted in buildings complying with all of the following:
 - (a) Where protected throughout by an approved automatic sprinkler system in accordance with 9.7.1.1(1)
 - (b) Where no unprotected vertical opening serves as any part of any required means of egress
 - (c) Where required exits consist of exit doors that discharge directly to grade in accordance with 7.2.1, outside stairs in accordance with 7.2.2, smokeproof enclosures in accordance with 7.2.3, or horizontal exits in accordance with 7.2.4

39.3.1.2 Floors that are below the street floor and are used for storage or other than a business occupancy shall have no unprotected openings to business occupancy floors.

39.3.2 Protection from Hazards.

39.3.2.1* Hazardous areas including, but not limited to, areas used for general storage, boiler or furnace rooms, and maintenance shops that include woodworking and painting areas shall be protected in accordance with Section 8.7.

39.3.2.2* High hazard contents areas, as classified in Section 6.2, shall meet the following criteria:

- (1) The area shall be separated from other parts of the building by fire barriers having a fire resistance rating of not less than 1 hour, with all openings therein protected by ¾-hour fire protection-rated self-closing fire door assemblies.
- (2) The area shall be protected by an automatic extinguishing system in accordance with 9.7.1.1(1) or 9.7.1.2.

39.3.3 Interior Finish.

39.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

39.3.3.2 Interior Wall and Ceiling Finish.

39.3.3.2.1 Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A or Class B in exits and in exit access corridors.

39.3.3.2.2 Interior wall and ceiling finishes shall be Class A, Class B, or Class C in all other areas.

39.3.3.3 Interior Floor Finish. (No requirements)

39.3.4 Detection, Alarm, and Communications Systems.

39.3.4.1 General. A fire alarm system in accordance with Section 9.6 shall be provided in all business occupancies where any one of the following conditions exists:

- (1) The building is two or more stories in height above the level of exit discharge.
- (2) The occupancy is subject to 100 or more occupants above or below the level of exit discharge.
- (3) The occupancy is subject to 1000 or more total occupants.

39.3.4.2 Initiation. Initiation of the required fire alarm system shall be by one of the following:

- (1) By manual means in accordance with 9.6.2.1(1)
- (2) By means of an approved automatic fire detection system that complies with 9.6.2.1(2) and provides protection throughout the building
- (3) By means of an approved automatic sprinkler system that complies with 9.6.2.1(3) and provides protection throughout the building

39.3.4.3 Occupant Notification. During all times that the building is occupied (*see* 7.2.1.1.3), the required fire alarm system, once initiated, shall perform one of the following functions:

- (1) It shall activate a general alarm in accordance with 9.6.3 throughout the building.
 - (a) Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.
 - (b) A presignal system in accordance with 9.6.3.3 shall be permitted.
- (2) It shall activate an alarm signal in a continuously attended location for the purpose of initiating emergency action by personnel trained to respond to emergencies. Emergency action shall be initiated by means of live voice public address system announcements originating from the attended location where the alarm signal is received. The live voice public address system shall be permitted to be used for other announcements, provided that the emergency action use takes precedence over any other use.

39.3.5 Extinguishment Requirements. Portable fire extinguishers shall be provided in every business occupancy in accordance with 9.7.4.1.

39.3.6 Corridors. (No requirements)

39.3.7 Subdivision of Building Spaces. (No special requirements)

39.4 Special Provisions.

39.4.1 Limited Access or Underground Buildings. See Section 11.7.

39.4.2 High-Rise Buildings.

39.4.2.1 All high-rise business occupancy buildings shall be provided with a reasonable degree of safety from fire, and such degree of safety shall be accomplished by one of the following:

- (1) The installation of a complete, approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)
- (2) The installation of an engineered life safety system which shall comply with the following:
 - (a) The engineered life safety system shall be developed by a registered professional engineer experienced in fire and life safety systems design
 - (b) The life safety system shall be approved by the authority having jurisdiction and might include any or all of the following systems:
 - i. Partial automatic sprinkler protection
 - ii. Smoke detection alarms
 - iii. Smoke control
 - iv. Compartmentation
 - v. Other approved systems

39.4.2.2* A limited but reasonable time shall be permitted for compliance with any part of 39.4.2.1, commensurate with the magnitude of expenditure and the disruption of services.

39.4.2.3 In addition to the requirements of 39.4.2.1 and 39.4.2.2, all buildings, regardless of height, shall comply with all other applicable provisions of this chapter.

39.5 Building Services.

39.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

39.5.2 Heating, Ventilating, and Air Conditioning. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

39.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

39.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

39.6 Reserved.

39.7 Operating Features.

39.7.1 Drills. In all business occupancy buildings occupied by more than 500 persons, or by more than 100 persons above or below the street level, employees and supervisory personnel shall be periodically instructed in accordance with Section 4.7 and shall hold drills periodically where practicable.

39.7.2 Extinguisher Training. Designated employees of business occupancies shall be periodically instructed in the use of portable fire extinguishers.

39.7.3 Food service operations shall comply with 13.7.1.

Chapter 40 Industrial Occupancies

40.1 General Requirements.

40.1.1 Application.

40.1.1.1 The requirements of this chapter shall apply to both new and existing industrial occupancies.

40.1.1.2 Industrial occupancies shall include factories making products of all kinds and properties used for operations such as processing, assembling, mixing, packaging, finishing or decorating, repairing, and similar operations.

40.1.1.3 Incidental high hazard operations protected in accordance with Section 8.7 and 40.3.2 in occupancies containing low or ordinary hazard contents shall not be the basis for high hazard industrial occupancy classification.

40.1.2 Multiple Occupancies. All multiple occupancies shall be in accordance with 6.1.14.

40.1.3 Definitions. See Chapter 3.

40.1.4 Classification of Occupancy. See 6.1.12.

40.1.4.1 Subclassification of Industrial Occupancies. Each industrial occupancy shall be subclassified according to its use as follows:

- (1) *General Industrial Occupancy.* A general industrial occupancy conducts ordinary and low hazard industrial operations in buildings of conventional design suitable for various types of industrial processes. Also included are multistory buildings where floors are occupied by different tenants or buildings suitable for such occupancy and, therefore, subject to possible use for types of industrial processes with a high density of employee population.

- (2) *Special Purpose Industrial Occupancy.* A special purpose industrial occupancy conducts ordinary and low hazard industrial operations in buildings designed for, and suitable only for, particular types of operations. Such occupancy is characterized by a relatively low density of employee population, with much of the area occupied by machinery or equipment.
- (3)* *High Hazard Industrial Occupancy.* A high hazard industrial occupancy conducts industrial operations that use high hazard materials or processes or houses high hazard contents. Incidental high hazard operations in low or ordinary occupancies that are protected in accordance with Section 8.4 and 40.3.2 shall not be the basis for overall occupancy classification.

40.1.4.2 Change of Industrial Occupancy Subclassification. Changing from one subclassification of industrial occupancy to another shall be permitted only if the structure, building, or portion thereof conforms to the requirements of this chapter that apply to new construction for the new use.

40.1.5 Classification of Hazard of Contents. Classification of hazard of contents shall be in accordance with Section 6.2.

40.1.6 Minimum Construction Requirements. (No requirements)

40.1.7* Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the occupant load factors of Table 7.3.1.2 that are characteristic of the use of the space or shall be determined as the maximum probable population of the space under consideration, whichever is greater.

40.2 Means of Egress Requirements.

40.2.1 General. Each required means of egress shall be in accordance with the applicable portions of Chapter 7.

40.2.2 Means of Egress Components.

40.2.2.1 General. Components of means of egress shall be limited to the types described in 40.2.2.2 through 40.2.2.13.

40.2.2.2 Doors.

40.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

40.2.2.2.2 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted.

40.2.2.2.3 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

40.2.2.2.4 Approved existing horizontal-sliding fire doors shall be permitted in the means of egress under the following conditions:

- (1) They are held open by fusible links.
- (2) The fusible links are rated at not less than 74°C (165°F).
- (3) The fusible links are located not more than 3050 mm (120 in.) above the floor.
- (4) The fusible links are in immediate proximity to the door opening.
- (5) The fusible links are not located above a ceiling.
- (6) The door is not credited with providing any protection under this Code.

40.2.2.3 Stairs.

40.2.2.3.1 Stairs shall comply with 7.2.2 and be permitted to be modified by 40.2.2.3.1(1) and 40.2.2.3.1(2).

- (1) Noncombustible, grated stair treads and noncombustible, grated landing floors shall be permitted.
- (2) Industrial equipment access stairs in accordance with 40.2.5.2 shall be permitted.

40.2.2.3.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted.

40.2.2.3.3 Existing winders complying with 7.2.2.2.4 shall be permitted.

40.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

40.2.2.5 Horizontal Exits.

40.2.2.5.1 Horizontal exits complying with 7.2.4 shall be permitted.

40.2.2.5.2* In horizontal exits where the opening is protected by a fire door assembly on each side of the wall in which it is located, one fire door shall be of the swinging type as provided in 7.2.4.3.6, and the other shall be permitted to be an automatic-sliding fire door that shall be kept open whenever the building is occupied.

40.2.2.6 Ramps. Ramps shall comply with 7.2.5, except that industrial equipment access ramps shall be permitted to be in accordance with 40.2.5.2.

40.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

40.2.2.8 Escalators and Moving Walks. Existing, previously approved escalators and moving walks complying with 7.2.7 and located within the required means of egress shall be permitted.

40.2.2.9 Fire Escape Stairs. Existing fire escape stairs complying with 7.2.8 shall be permitted.

40.2.2.10 Fire Escape Ladders.

40.2.2.10.1 Fire escape ladders complying with 7.2.9 shall be permitted.

40.2.2.10.2 Fixed industrial stairs in accordance with the minimum requirements for fixed stairs in ANSI A1264.1, *Safety Requirements for Workplace Floor and Wall Openings, Stairs and Railings Systems*, shall be permitted where fire escape ladders are permitted in accordance with 7.2.9.1.

40.2.2.11 Slide Escapes.

40.2.2.11.1 Approved slide escapes complying with 7.2.10 shall be permitted as components in 100 percent of the required means of egress for both new and existing high hazard industrial occupancies.

40.2.2.11.2 Slide escapes permitted by 40.2.2.11.1 shall be counted as means of egress only where regularly used in emergency egress drills, to ensure that occupants are familiar with their use through practice.

40.2.2.12 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

40.2.2.13 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

40.2.3 Capacity of Means of Egress. Capacity of means of egress shall comply with either of 40.2.3.1 or 40.2.3.2.

40.2.3.1 The capacity of means of egress shall be in accordance with Section 7.3.

40.2.3.2 In only special purpose industrial occupancies, means of egress shall be sized to accommodate the occupant load as determined in accordance with Table 7.3.1.2; spaces not subject to human occupancy because of the presence of machinery or equipment shall not be included in the computation.

40.2.4 Number of Means of Egress. See also Section 7.4.

40.2.4.1 The number of means of egress shall comply with either 40.2.4.1.1 or 40.2.4.1.2.

40.2.4.1.1 Not less than two means of egress shall be provided from every story or section, and not less than one exit shall be reached without traversing another story.

40.2.4.1.2 A single means of egress shall be permitted from any story or section in low and ordinary hazard industrial occupancies, provided that the exit can be reached within the distance permitted as a common path of travel.

40.2.4.2 In new buildings, floors or portions thereof with an occupant load of more than 500 shall have the minimum number of separate and remote means of egress specified by 7.4.1.2.

40.2.4.3 Areas with high hazard contents shall comply with Section 7.11.

40.2.5 Arrangement of Means of Egress. Means of egress, arranged in accordance with Section 7.5, shall not exceed that provided by Table 40.2.5.

40.2.5.1 Ancillary Facilities.

40.2.5.1.1* New ancillary facilities shall be arranged to allow travel in independent directions after leaving the ancillary facility so that both means of egress paths do not become compromised by the same fire or similar emergency.

40.2.5.1.2* New ancillary facilities in special purpose industrial occupancies where delayed evacuation is anticipated shall have not less than a 2-hour fire resistance-rated separation from the predominant industrial occupancy and shall have one means of egress that is separated from the predominant industrial occupancy by 2-hour fire resistance-rated construction.

40.2.5.2 Industrial Equipment Access.

40.2.5.2.1 Industrial equipment access walkways, platforms, ramps, and stairs that serve as a component of the means of egress from the involved equipment shall be permitted in accordance with the applicable provisions of Chapter 7 as modified by Table 40.2.5.2.1.

40.2.5.2.2 Any means of egress component permitted by 40.2.5.2.1 shall serve not more than 20 people.

40.2.6 Travel Distance to Exits. Travel distance, measured in accordance with Section 7.6, shall not exceed that provided by Table 40.2.6.

40.2.7 Discharge from Exits. Discharge from exits shall be in accordance with Section 7.7.

40.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8 or with natural lighting that provides the required level of illumination in structures occupied only during daylight hours.

40.2.9* Emergency Lighting.

40.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9, except as otherwise exempted by 40.2.9.2.

Table 40.2.5 Arrangements of Means of Egress

Level of Protection	General Industrial Occupancy	Special Purpose Industrial Occupancy	High Hazard Industrial Occupancy
Dead-End Corridor			
Protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	15 m (50 ft)	15 m (50 ft)	Prohibited except as permitted by 7.11.4.
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	15 m (50 ft)	15 m (50 ft)	Prohibited except as permitted by 7.11.4.
Common Path of Travel			
Protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	30 m (100 ft)	30 m (100 ft)	Prohibited except as permitted by 7.11.4.
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	15 m (50 ft)	15 m (50 ft)	Prohibited except as permitted by 7.11.4.

Table 40.2.5.2.1 Industrial Equipment Access Dimensional Criteria

Minimum horizontal dimension of any walkway, landing, or platform	560 mm (22 in.) clear
Minimum stair or ramp width	560 mm (22 in.) clear between rails
Minimum tread width	560 mm (22 in.) clear
Minimum tread depth	255 mm (10 in.)
Maximum riser height	230 mm (9 in.)
Handrails shall be permitted to terminate, at the required height, at a point directly above the top and bottom risers.	
Maximum height between landings	3660 mm (144 in.)
Minimum headroom	2030 mm (80 in.)

Table 40.2.6 Maximum Travel Distance to Exits

Level of Protection	General Industrial Occupancy	Special Purpose Industrial Occupancy	High Hazard Industrial Occupancy
Protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	76 m (250 ft) [†]	122 m (400 ft)	23 m (75 ft)
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	61 m (200 ft)	91 m (300 ft)	Not permitted

[†]In single-story buildings, a travel distance of 122 m (400 ft) shall be permitted, provided that a performance based analysis demonstrates that safe egress can be accomplished.

40.2.9.2 Emergency lighting shall not be required for the following:

- (1) Special purpose industrial occupancies without routine human habitation
- (2) Structures occupied only during daylight hours, with skylights or windows arranged to provide the required level of illumination on all portions of the means of egress during such hours

40.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

40.2.11 Special Means of Egress Features. (Reserved)

40.3 Protection.

40.3.1 Protection of Vertical Openings. Any vertical opening shall be protected in accordance with Section 8.6 unless otherwise permitted by one of the following:

- (1) In special purpose industrial and high hazard industrial occupancies where unprotected vertical openings exist and are necessary to manufacturing operations, such openings shall be permitted beyond the specified limits, provided that every floor level has direct access to one or more enclosed stairs or other exits protected against obstruction by any fire or smoke in the open areas connected by the unprotected vertical openings.
- (2) Approved, existing open stairs, existing open ramps, and existing escalators shall be permitted where connecting only two floor levels.
- (3) Approved existing unprotected vertical openings in buildings with low or ordinary hazard contents that are protected throughout by an approved automatic sprinkler system in accordance with 9.7.1.1(1) shall be permitted, provided that the following conditions exist:

- (a) The vertical opening does not serve as a required exit.
- (b) All required exits consist of outside stairs in accordance with 7.2.2, smokeproof enclosures in accordance with 7.2.3, or horizontal exits in accordance with 7.2.4.
- (4) Vertical openings in accordance with 8.6.8.2 shall be permitted.

40.3.2* Protection from Hazards.

40.3.2.1 All high hazard industrial occupancies, operations, or processes shall have approved, supervised automatic extinguishing systems in accordance with Section 9.7 or other protection appropriate to the particular hazard, such as explosion venting or suppression.

40.3.2.2 Protection in accordance with 40.3.2.1 shall be provided for any area subject to an explosion hazard in order to minimize danger to occupants in case of fire or other emergency before they have time to use exits to escape.

40.3.2.3 Activation of the fire extinguishing or suppression system required by 40.3.2.1 shall initiate the required building fire alarm system in accordance with 40.3.4.3.4.

40.3.2.4 Hazardous areas in industrial occupancies protected by approved automatic extinguishing systems in accordance with Section 9.7 shall be exempt from the smoke-resisting enclosure requirement of 8.7.1.2.

40.3.3 Interior Finish.

40.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

40.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A, Class B, or Class C in operating areas and shall be as required by 7.1.4 in exit enclosures.

40.3.3.3 Interior Floor Finish. (No requirements.)

40.3.4 Detection, Alarm, and Communications Systems.

40.3.4.1 General. A fire alarm system shall be required in accordance with Section 9.6 for industrial occupancies, unless the total capacity of the building is under 100 persons and of these fewer than 25 persons are above or below the level of exit discharge.

40.3.4.2 Initiation. Initiation of the required fire alarm system shall be by any of the following means:

- (1) Manual means in accordance with 9.6.2.1(1)
- (2) An approved automatic fire detection system in accordance with 9.6.2.1(2) throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5
- (3) An approved, supervised automatic sprinkler system in accordance with 9.6.2.1(3) throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5

40.3.4.3 Notification.

40.3.4.3.1 The required fire alarm system shall meet one of the following criteria:

- (1) It shall provide occupant notification in accordance with 9.6.3.
- (2) It shall sound an audible and visible signal in a constantly attended location for the purposes of initiating emergency action.

40.3.4.3.2 Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.

40.3.4.3.3 Existing presignal systems in accordance with 9.6.3.3 shall be permitted.

40.3.4.3.4 In high hazard industrial occupancies as described in 40.1.4.1(3), the required fire alarm system shall automatically initiate an occupant evacuation alarm signal in accordance with 9.6.3.

40.3.5 Extinguishment Requirements. (None)

40.3.6 Corridors. The provisions of 7.1.3.1 shall not apply.

40.4 Special Provisions: High-Rise Buildings. Automatic sprinkler requirements of 11.8.2.1 shall be required for new high-rise industrial occupancies, except for general low hazard or special purpose industrial occupancies.

40.5 Building Services.

40.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

40.5.2 Heating, Ventilating, and Air Conditioning. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

40.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

40.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

40.6* Special Provisions for Aircraft Servicing Hangars.

40.6.1 The requirements of Section 40.1 through Section 40.5 shall be met, except as modified by 40.6.1.1 through 40.6.1.4.

40.6.1.1 There shall be not less than two means of egress from each aircraft servicing area.

40.6.1.2 Exits from aircraft servicing areas shall be provided at intervals not exceeding 46 m (150 ft) on all exterior walls.

40.6.1.3 Where horizontal exits are provided, doors shall be provided in the horizontal exit fire barrier at intervals not exceeding 30 m (100 ft).

40.6.1.4 Where dwarf, or "smash," doors are provided in doors that accommodate aircraft, such doors shall be permitted for compliance with 40.6.1.1 through 40.6.1.3.

40.6.2 Means of egress from mezzanine floors in aircraft servicing areas shall be arranged so that the travel distance to the nearest exit from any point on the mezzanine does not exceed 23 m (75 ft), and such means of egress shall lead directly to a properly enclosed stair discharging directly to the exterior, to a suitable cutoff area, or to outside stairs.

40.6.3 Dead ends shall not exceed 15 m (50 ft) for other than high hazard contents areas and shall not be permitted for high hazard contents areas.

Chapter 41 Reserved

Chapter 42 Storage Occupancies

42.1 General Requirements.

42.1.1 Application.

42.1.1.1 The requirements of this chapter shall apply to both new and existing storage occupancies.

42.1.1.2 Storage occupancies shall include all buildings or structures used primarily for the storage or sheltering of goods, merchandise, products, vehicles, or animals.

42.1.2 Multiple Occupancies. All multiple occupancies shall be in accordance with 6.1.14.

42.1.3 Definitions. See Chapter 3.

42.1.4 Classification of Occupancy.

42.1.4.1 Storage occupancies shall include all buildings and structures or parts thereof with occupancy as defined in 6.1.13.

42.1.4.2 Incidental storage in another occupancy shall not be the basis for overall occupancy classification.

42.1.4.3 Storage occupancies or areas of storage occupancies that are used for the purpose of packaging, labeling, sorting, special handling, or other operations requiring an occupant load greater than that normally contemplated for storage shall be classified as industrial occupancies. (See Chapter 40.)

42.1.5 Classification of Hazard of Contents. Contents of storage occupancies shall be classified as low hazard, ordinary hazard, or high hazard, in accordance with Section 6.2, depending on the character of the materials stored, their packaging, and other factors.

42.1.6 Minimum Construction Requirements. (No requirements)

42.1.7* Occupant Load. The occupant load, in number of persons for whom means of egress and other provisions are required, shall be determined on the basis of the maximum probable population of the space under consideration.

42.2 Means of Egress Requirements.

42.2.1 General. Each required means of egress shall be in accordance with the applicable portions of Chapter 7.

42.2.2 Means of Egress Components.

42.2.2.1 General. Components of means of egress shall be limited to the types described in 42.2.2.2 through 42.2.2.12.

42.2.2.2 Doors.

42.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

42.2.2.2.2 Delayed-egress locks complying with 7.2.1.6.1 shall be permitted.

42.2.2.2.3 Access-controlled egress doors complying with 7.2.1.6.2 shall be permitted.

42.2.2.2.4 Approved existing horizontal-sliding fire doors shall be permitted in the means of egress under the following conditions:

- (1) They are held open by fusible links.
- (2) The fusible links are rated at not less than 74°C (165°F).
- (3) The fusible links are located not more than 3050 mm (120 in.) above the floor.
- (4) The fusible links are in immediate proximity to the door opening.
- (5) The fusible links are not located above a ceiling.
- (6) The door is not credited with providing any protection under this Code.

42.2.2.3 Stairs.

42.2.2.3.1 Stairs shall comply with 7.2.2 and shall be permitted to be modified by as follows:

- (1) Noncombustible, grated stair treads and noncombustible, grated landing floors shall be permitted.
- (2) Industrial equipment access stairs in accordance with 40.2.5.2 shall be permitted.

42.2.2.3.2 Spiral stairs complying with 7.2.2.2.3 shall be permitted.

42.2.2.3.3 Existing winders complying with 7.2.2.2.4 shall be permitted.

42.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

42.2.2.5 Horizontal Exits.

42.2.2.5.1 Horizontal exits complying with 7.2.4 shall be permitted.

42.2.2.5.2* In horizontal exits where the opening is protected by a fire door assembly on each side of the wall in which it is located, one fire door shall be of the swinging type as provided in 7.2.4.3.6, and the other shall be permitted to be an automatic-sliding fire door that shall be kept open whenever the building is occupied.

42.2.2.6 Ramps.

42.2.2.6.1 Ramps complying with 7.2.5 shall be permitted.

42.2.2.6.2 Industrial equipment access ramps in accordance with 40.2.5.2 shall be permitted.

42.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

42.2.2.8 Fire Escape Stairs. Existing fire escape stairs complying with 7.2.8 shall be permitted.

42.2.2.9 Fire Escape Ladders.

42.2.2.9.1 Fire escape ladders complying with 7.2.9 shall be permitted.

42.2.2.9.2 Fixed industrial stairs in accordance with the minimum requirements for fixed stairs in ANSI A1264.1, *Safety Requirements for Workplace Floor and Wall Openings, Stairs, and Railing Systems*, shall be permitted where fire escape ladders are permitted in accordance with 7.2.9.1

42.2.2.10 Slide Escapes. Existing slide escapes complying with 7.2.10 shall be permitted.

42.2.2.11 Alternating Tread Devices. Alternating tread devices complying with 7.2.11 shall be permitted.

42.2.2.12 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

42.2.3 Capacity of Means of Egress. The capacity of means of egress shall be in accordance with Section 7.3.

42.2.4 Number of Means of Egress. See also Section 7.4.

42.2.4.1 The number of means of egress shall comply with 42.2.4.1(1), 42.2.4.1(2), or 42.2.4.1(3).

- (1) In low hazard storage occupancies, a single means of egress shall be permitted from any story or section.

- (2) In ordinary hazard storage occupancies, a single means of egress shall be permitted from any story or section, provided that the exit can be reached within the distance permitted as a common path of travel.

- (3) All buildings or structures not complying with 42.2.4.1(1) or 42.2.4.1(2) and used for storage, and every section thereof considered separately, shall have not less than two separate means of egress as remotely located from each other as practicable.

42.2.4.2 In new buildings, floors or portions thereof with an occupant load of more than 500 persons shall have the minimum number of separate and remote means of egress specified by 7.4.1.2.

42.2.4.3 Areas with high hazard contents shall comply with Section 7.11.

42.2.5 Arrangement of Means of Egress.

42.2.5.1 Means of egress, arranged in accordance with Section 7.5, shall not exceed that provided by Table 42.2.5.1.

Table 42.2.5.1 Arrangements of Means of Egress

Level of Protection	Low Hazard Storage Occupancy	Ordinary Hazard Storage Occupancy	High Hazard Storage Occupancy
Dead-End Corridor			
Protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	No limits	30 m (100 ft)	Prohibited except as permitted by 7.11.4.
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	No limits	15 m (50 ft)	Prohibited except as permitted by 7.11.4.
Common Path of Travel			
Protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	No limits	30 m (100 ft)	Prohibited except as permitted by 7.11.4.
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	No limits	15 m (50 ft)	Prohibited except as permitted by 7.11.4.

42.2.6* Travel Distance to Exits. Travel distance, measured in accordance with Section 7.6, shall not exceed that provided by Table 42.2.6.

Table 42.2.6 Maximum Travel Distance to Exits

Level of Protection	Low Hazard Storage Occupancy	Ordinary Hazard Storage Occupancy	High Hazard Storage Occupancy
Protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	No limits	122 m (400 ft)	30 m (100 ft)
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	No limits	61 m (200 ft)	23 m (75 ft)
Flammable and combustible liquid products stored and protected in accordance with NFPA 30, <i>Flammable and Combustible Liquids Code</i>	Not applicable	Not applicable	46 m (150 ft)

42.2.7 Discharge from Exits. Discharge from exits shall be in accordance with Section 7.7.

42.2.8 Illumination of Means of Egress.

42.2.8.1 Means of egress shall be illuminated in accordance with Section 7.8.

42.2.8.2 In structures occupied only during daylight hours, means of egress shall be permitted to be illuminated with windows arranged to provide the required level of illumination on all portions of the means of egress during such hours when approved by the authority having jurisdiction.

42.2.9 Emergency Lighting. Emergency lighting shall be provided in normally occupied storage occupancies in accordance with Section 7.9, except for spaces occupied only during daylight hours with natural illumination in accordance with 42.2.8.2.

42.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

42.2.11 Special Means of Egress Features. (Reserved)

42.3 Protection.

42.3.1 Protection of Vertical Openings. Any vertical opening shall be protected in accordance with Section 8.6 unless otherwise permitted by one of the following:

- (1) Existing open stairs, existing open ramps, and existing open escalators shall be permitted when connecting only two floor levels.
- (2) Existing, unprotected vertical openings in buildings with low or ordinary hazard contents and protected throughout by an approved automatic sprinkler system in accordance with 9.7.1.1(1) shall be permitted where they do not serve as required exits. All required exits shall consist of outside stairs in accordance with 7.2.2, smokeproof enclosures in accordance with 7.2.3, or horizontal exits in accordance with 7.2.4.

42.3.2 Protection from Hazards. (No requirements.) (*See also Section 8.7.*)

42.3.3 Interior Finish.

42.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

42.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A, Class B, or Class C in storage areas and shall be as required by 7.1.4 in exit enclosures.

42.3.3.3 Interior Floor Finish. (No requirements.)

42.3.4 Detection, Alarm, and Communications Systems.

42.3.4.1 General. A fire alarm system shall be required in accordance with Section 9.6 for storage occupancies except as modified by 42.3.4.1.1, 42.3.4.1.2, and 42.3.4.1.3.

42.3.4.1.1 Storage occupancies limited to low hazard contents shall not be required to have a fire alarm system.

42.3.4.1.2 Storage occupancies with ordinary or high hazard contents not exceeding an aggregate floor area of 9300 m² (100,000 ft²) shall not be required to have a fire alarm system.

42.3.4.1.3 Storage occupancies protected throughout by approved automatic sprinkler system in accordance with Section 9.7 shall not be required to have a fire alarm system.

42.3.4.2 Initiation. Initiation of the required fire alarm system shall be by any of the following means:

- (1) Manual means in accordance with 9.6.2.1(1).
- (2) An approved automatic fire detection system in accordance with 9.6.2.1(2) throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5.
- (3) An approved, supervised automatic sprinkler system in accordance with 9.6.2.1(3) throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5.

42.3.4.3 Notification.

42.3.4.3.1 The required fire alarm system shall meet one of the following criteria:

- (1) It shall provide occupant notification in accordance with 9.6.3.
- (2) It shall sound an audible and visible signal in a constantly attended location for the purposes of initiating emergency action.

42.3.4.3.2 Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.

42.3.4.3.3 Existing presignal systems in accordance with 9.6.3.3 shall be permitted.

42.3.4.3.4 In high hazard storage occupancies, the required fire alarm system shall automatically initiate an occupant evacuation alarm signal in accordance with 9.6.3.

42.3.5 Extinguishment Requirements. (None)

42.3.6 Corridors. The provisions of 7.1.3.1 shall not apply.

42.4 Special Provisions. In all new high-rise buildings, all storage occupancies except for low hazard occupancies shall meet the automatic sprinkler requirements of 11.8.2.1.

42.4.1 High-Rise Buildings. Automatic sprinkler requirements of 11.8.2.1 shall be required for new high-rise storage occupancies, except for low hazard storage occupancies.

42.5 Building Services.

42.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

42.5.2 Heating, Ventilating, and Air Conditioning. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

42.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

42.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

42.6* Special Provisions for Aircraft Storage Hangars.

42.6.1 The requirements of Section 42.1 through Section 42.5 shall be met, except as modified by 42.6.1.1 through 42.6.1.4.

42.6.1.1 There shall be not less than two means of egress from each aircraft servicing area.

42.6.1.2 Exits from aircraft servicing areas shall be provided at intervals not exceeding 46 m (150 ft) on all exterior walls.

42.6.1.3 Where horizontal exits are provided, doors shall be provided in the horizontal exit fire barrier at intervals not exceeding 30 m (100 ft).

42.6.1.4 Where dwarf, or "smash," doors are provided in doors that accommodate aircraft, such doors shall be permitted for compliance with 42.6.1.1, 42.6.1.2, and 42.6.1.3.

42.6.2 Means of egress from mezzanine floors in aircraft storage areas shall be arranged so that the travel distance to the nearest exit from any point on the mezzanine does not exceed 23 m (75 ft), and such means of egress shall lead directly to a properly enclosed stair discharging directly to the exterior, to a suitable cutoff area, or to outside stairs.

42.6.3 Dead ends shall not exceed 15 m (50 ft) for other than high hazard contents areas and shall not be permitted for high hazard contents areas.

42.7* Special Provisions for Grain or Other Bulk Storage Elevators.

42.7.1 General. The requirements of Section 42.1 through Section 42.5 shall be met, except as modified by 42.7.2 through 42.7.4.2.

42.7.2 Number of Means of Egress. There shall be not less than two means of egress from all working levels of the head house as modified by 42.7.2.1, 42.7.2.2, and 42.7.2.3.

42.7.2.1 One of the two means of egress shall be a stair to the level of exit discharge that is enclosed by a dust-resistant 1-hour fire resistance-rated enclosure in accordance with 7.1.3.2.

42.7.2.2 The second means of egress shall be one of the following:

- (1) An exterior stair or basket ladder-type fire escape that is accessible from all working levels of the head house and provides a passage to ground level
- (2) An exterior stair or basket ladder-type fire escape that is accessible from all working levels of the head house, provides access to the top of adjoining structures, and provides a continuous path to the means of egress described in 42.7.3.

42.7.2.3 Existing Stair Enclosures. Stair enclosures in existing structures shall be permitted to have non-fire-rated dust resistant enclosures.

42.7.3 Fire Escapes. An exterior stair or basket ladder-type fire escape shall provide passage to ground level from the top of the end of an adjoining structure, such as a silo, conveyor, gallery, or gantry.

42.7.4 Underground Spaces.

42.7.4.1 Number of Means of Egress. Underground spaces shall have not less than two means of egress, one of which shall be permitted to be a means of escape that shall be arranged to eliminate dead ends.

42.7.4.2 Travel Distance to Exits. Travel distance, measured in accordance with Section 7.6, shall not exceed that provided by Table 42.7.4.2.

Table 42.7.4.2 Maximum Travel Distance to Means of Escape or Exits

Level of Protection	Travel Distance
Protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	122 m (400 ft)
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	61 m (200 ft)
Existing structures	Unlimited

42.8 Special Provisions for Parking Structures.

42.8.1 General Requirements.

42.8.1.1 Application. The provisions of 42.8.1 through 42.8.5.4 shall apply to parking structures of the closed or open type, above or below ground, but shall not apply to mechanical or exclusively attendant-type parking facilities that are not occupied by customers. The requirements of Section 42.1 through Section 42.7 shall not apply.

42.8.1.2 Multiple Occupancies.

42.8.1.2.1 Where both parking and repair operations are conducted in the same building, the entire building shall comply with Chapter 40 except as modified by 42.8.1.2.2.

42.8.1.2.2 Where the parking and repair sections are separated by not less than 1-hour fire-rated construction, the parking and repair sections shall be permitted to be treated separately.

42.8.1.2.3 In areas where repair operations are conducted, the means of egress shall comply with Chapter 40.

42.8.1.3 Definition: Open Parking Structure. See 3.3.217.7.

42.8.1.4 Classification of Occupancy. Incidental vehicle parking in another occupancy shall not be the basis for overall occupancy classification.

42.8.1.5 Classification of Hazard of Contents. Parking structures used only for the storage of vehicles shall be classified as ordinary hazard in accordance with Section 6.2.

42.8.1.6 Minimum Construction Requirements. (No requirements)

42.8.1.7 Occupant Load. (No requirements)

42.8.2 Means of Egress Requirements.

42.8.2.1 General. Means of egress shall be in accordance with Chapter 7 and this section.

42.8.2.2 Means of Egress Components.

42.8.2.2.1 General. Components of means of egress shall be limited to the types described in 42.8.2.2.2 through 42.8.2.2.9.

42.8.2.2.2 Doors.

42.8.2.2.2.1 Doors complying with 7.2.1 shall be permitted.

42.8.2.2.2.2 Special locking arrangements complying with 7.2.1.6 shall be permitted.

42.8.2.2.2.3 An opening for the passage of automobiles shall be permitted to serve as an exit from a street floor, provided that no door or shutter is installed therein.

42.8.2.2.3 Stairs.

42.8.2.2.3.1 Stairs complying with 7.2.2 shall be permitted.

42.8.2.2.3.2 Existing winders complying with 7.2.2.2.4 shall be permitted.

42.8.2.2.3.3 Paragraph 7.2.2.4.5.3(2) shall not apply to guards for parking garages that are accessible to the general public.

42.8.2.2.4 Smokeproof Enclosures. Smokeproof enclosures complying with 7.2.3 shall be permitted.

42.8.2.2.5 Horizontal Exits. Horizontal exits complying with 7.2.4 shall be permitted.

42.8.2.2.6 Ramps.

42.8.2.2.6.1 Ramps shall be permitted in accordance with any of the following conditions:

- (1) Ramps complying with 7.2.5 shall be permitted and shall not be subject to normal vehicular traffic where used as an exit.
- (2) In a ramp-type open parking structure with open vehicle ramps not subject to closure, the ramp shall be permitted to serve in lieu of the second means of egress from floors above the level of exit discharge, provided that the ramp discharges directly outside at the street level.
- (3) For parking structures extending only one floor level below the level of exit discharge, a vehicle ramp leading directly to the outside shall be permitted to serve in lieu of the second means of egress, provided that not door or shutter is installed therein.

42.8.2.2.6.2 Paragraph 7.2.2.4.5.3(2) shall not apply to guards for parking garages that are accessible to the general public.

42.8.2.2.7 Exit Passageways. Exit passageways complying with 7.2.6 shall be permitted.

42.8.2.2.8 Fire Escape Stairs. Fire escape stairs complying with 7.2.8 shall be permitted for existing parking structures only.

42.8.2.2.9 Areas of Refuge. Areas of refuge complying with 7.2.12 shall be permitted.

42.8.2.3 Capacity of Means of Egress. See also 42.8.2.4 and 42.8.2.5.

42.8.2.4 Number of Means of Egress. See also Section 7.4.

42.8.2.4.1 Not less than two means of egress shall be provided from every floor or section of every parking structure.

42.8.2.4.2 In new buildings, floors or portions thereof with an occupant load of more than 500 persons shall have the minimum number of separate and remote means of egress specified by 7.4.1.2.

42.8.2.5 Arrangement of Means of Egress. See also Section 7.5.

42.8.2.5.1 A common path of travel shall be permitted for the first 15 m (50 ft) from any point in the parking structure.

42.8.2.5.2 Dead ends shall not exceed 15 m (50 ft).

42.8.2.5.3 Where fuel-dispensing devices are located within a parking structure, 42.8.2.5.3.1 and 42.8.2.5.3.2 shall apply.

42.8.2.5.3.1 Travel away from the fuel-dispensing device in any direction shall lead to an exit with no dead end in which occupants might be trapped by fire.

42.8.2.5.3.2 Within closed parking structures containing fuel-dispensing devices, exits shall be arranged and located to meet the following additional requirements:

- (1) Exits shall lead to the outside of the building on the same level or to stairs; no upward travel shall be permitted unless direct outside exits are available from that floor.
- (2) Any story below that story at which fuel is being dispensed shall have exits leading directly to the outside via outside stairs or doors at ground level.

42.8.2.6 Travel Distance to Exits. Travel distance, measured in accordance with Section 7.6, shall not exceed that provided by Table 42.8.2.6.

42.8.2.7 Discharge from Exits. Exit discharge shall comply with Section 7.7.

42.8.2.8 Illumination of Means of Egress. Means of egress shall be illuminated in accordance with Section 7.8 or with natural lighting that provides the required level of illumination in structures occupied only during daylight hours.

42.8.2.9 Emergency Lighting. Parking structures shall be provided with emergency lighting in accordance with Section 7.9, except for structures occupied only during daylight hours and arranged to provide the required level of illumination of all portions of the means of egress by natural means.

42.8.2.10 Marking of Means of Egress. Means of egress shall have signs in accordance with Section 7.10.

42.8.2.11 Special Means of Egress Features. (Reserved)

42.8.3 Protection.

42.8.3.1 Protection of Vertical Openings.

42.8.3.1.1 Vertical Openings in Enclosed Parking Structures.

42.8.3.1.1.1 Vertical openings through floors in buildings four stories or more in height shall be enclosed with walls or partitions having a fire resistance rating of not less than 2 hours.

Table 42.8.2.6 Maximum Travel Distance to Exits

Level of Protection	Enclosed Parking Structure	Open Parking Structure	Parking Structure Open Not Less Than 50% On All Sides
Protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	61 m (200 ft)	122 m (400 ft)	122 m (400 ft)
Not protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1)	46 m (150 ft)	91 m (300 ft)	122 m (400 ft)

42.8.3.1.1.2 For buildings less than four stories, the walls or partitions required by 42.8.3.1.1.1 shall have a fire resistance rating of not less than 1 hour.

42.8.3.1.1.3 Ramps in enclosed parking structures shall not be required to be enclosed when either of the following safeguards is provided:

- (1) An approved, automatic sprinkler system fully protecting the parking structure
- (2) An approved, automatic, supervised fire detection system installed throughout the parking structure using detectors sensing products of combustion other than heat and mechanical ventilation system

42.8.3.2 Protection from Hazards. (No requirements)

42.8.3.3 Interior Finish.

42.8.3.3.1 General. Interior finish shall be in accordance with Section 10.2.

42.8.3.3.2 Interior Wall and Ceiling Finish. Interior wall and ceiling finish materials complying with Section 10.2 shall be Class A, Class B, or Class C in parking structures and shall be as required by 7.1.4 in exit enclosures.

42.8.3.3.3 Interior Floor Finish. (No requirements)

42.8.3.4 Detection, Alarm, and Communications Systems.

42.8.3.4.1 General. A fire alarm system shall be required in accordance with Section 9.6 for parking structures except as modified by 42.3.4.1.1, 42.3.4.1.2, and 42.3.4.1.3.

42.8.3.4.1.1 Parking structures not exceeding an aggregate floor area of 9300 m² (100,000 ft²) shall not be required to have a fire alarm system.

42.8.3.4.1.2 Open parking structures shall not be required to have a fire alarm system.

42.8.3.4.1.3 Parking structures protected throughout by an approved automatic sprinkler system in accordance with Section 9.7 shall not be required to have a fire alarm system.

42.8.3.4.2 Initiation. Initiation of the required fire alarm system shall be by one of the following:

- (1) Manual means in accordance with 9.6.2.1(1).
- (2) An approved automatic fire detection system in accordance with 9.6.2.1(2) throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5.
- (3) An approved supervised automatic sprinkler system in accordance with 9.6.2.1(3) throughout the building; plus a minimum of one manual fire alarm box in accordance with 9.6.2.5.

42.8.3.4.3 Notification.

42.8.3.4.3.1 The required fire alarm system shall sound an audible alarm in a continuously attended location for purposes of initiating emergency action.

42.8.3.4.3.2 Positive alarm sequence in accordance with 9.6.3.4 shall be permitted.

42.8.3.4.3.3 Existing presignal systems in accordance with 9.6.3.3 shall be permitted.

42.8.3.5 Extinguishing Requirements. (None)

42.8.3.6 Corridors. The provisions of 7.1.3.1 shall not apply.

42.8.4 Special Provisions: High-Rise Buildings. (No requirements)

42.8.5 Building Services.

42.8.5.1 Utilities. Utilities shall comply with the provisions of Section 9.1.

42.8.5.2 Heating, Ventilating, and Air Conditioning. Heating, ventilating, and air conditioning equipment shall comply with the provisions of Section 9.2.

42.8.5.3 Elevators, Escalators, and Conveyors. Elevators, escalators, and conveyors shall comply with the provisions of Section 9.4.

42.8.5.4 Rubbish Chutes, Incinerators, and Laundry Chutes. Rubbish chutes, incinerators, and laundry chutes shall comply with the provisions of Section 9.5.

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.1 The following is a suggested procedure for determining the Code requirements for a building or structure:

- (1) Determine the occupancy classification by referring to the occupancy definitions in Chapter 6 and the occupancy Chapter 12 through Chapter 42 (*see 6.1.14 for buildings with more than one use*).
- (2) Determine if the building or structure is new or existing (*see the definitions in Chapter 3*).
- (3) Determine the occupant load (*see 7.3.1*).
- (4) Determine the hazard of contents (*see Section 6.2*).

- (5) Refer to the applicable occupancy chapter of the *Code* (Chapter 12 through Chapter 42) [see Chapter 1 through Chapter 4 and Chapter 6 through Chapter 11, as needed, for general information (such as definitions) or as directed by the occupancy chapter].
- (6) Determine the occupancy subclassification or special use condition, if any, by referring to Chapter 18 and Chapter 19, health care occupancies; Chapter 22 and Chapter 23, detention and correctional occupancies; Chapter 28 and Chapter 29, hotels and dormitories; Chapter 32 and Chapter 33, residential board and care occupancies; and Chapter 36 and Chapter 37, mercantile occupancies, which contain subclassifications or special use definitions.
- (7) Proceed through the applicable occupancy chapter to verify compliance with each referenced section, subsection, paragraph, subparagraph, and referenced codes, standards, and other documents.
- (8) Where two or more requirements apply, the occupancy chapter generally takes precedence over the base Chapter 1 through Chapter 4 and Chapter 6 through Chapter 11.
- (9) Where two or more occupancy chapters apply, such as in a mixed occupancy (see 6.1.14), the most restrictive requirements apply.

A.1.1.2 The *Code* recognizes that panic in a burning building might be uncontrollable but deals with the potential panic hazard through measures designed to prevent the development of panic. Experience indicates that panic seldom develops, even in the presence of potential danger, as long as occupants of buildings are moving toward exits that they can see within a reasonable distance without obstructions or undue congestion in the path of travel. However, any uncertainty as to the location or adequacy of means of egress, the presence of smoke, or the stoppage of egress travel, such as might occur when one person stumbles and falls on the stairs, is potentially conducive to panic. The danger of panic is greatest when there are large numbers of people in a confined area.

A.1.1.5 Life safety in buildings includes more than safety from fire. Although fire safety has been the long-standing focus of NFPA 101, its widely known title, *Life Safety Code*, and its technical requirements respond to a wider range of concerns, including, for example, crowd safety.

A.1.1.6(1) This *Code* is intended to be adopted and used as part of a comprehensive program of building regulations that include building, mechanical, plumbing, electrical, fuel gas, fire prevention, and land use regulations.

A.1.2 The *Code* endeavors to avoid requirements that might involve unreasonable hardships or unnecessary inconvenience or interference with the normal use and occupancy of a building but provides for fire safety consistent with the public interest.

Protection of occupants is achieved by the combination of prevention, protection, egress, and other features with due regard to the capabilities and reliability of the features involved. The level of life safety from fire is defined through requirements directed at the following:

- (1) Prevention of ignition
- (2) Detection of fire
- (3) Control of fire development
- (4) Confinement of the effects of fire
- (5) Extinguishment of fire
- (6) Provision of refuge and/or evacuation facilities
- (7) Staff reaction
- (8) Provision of fire safety information to occupants

A.1.3 It is the intent of Section 1.3 that a building, addition, or alteration designed to meet the requirements of a prior edition of the *Code* be required to meet those requirements for the life of the building. It is intended that the initial assessment of the building, when new, should be based on new occupancy requirements for the edition of the *Code* in effect on the date of plan approval. Subsequent assessments of the building should be based on new occupancy requirements of that same edition of the *Code* for the life of the building. Requirements for existing buildings in this edition of the *Code* apply if those requirements are more restrictive.

In some cases, the requirements for new construction are less restrictive, and it might be justified to permit an existing building to use the less restrictive requirements. However, extreme care needs to be exercised when granting such permission, because the less restrictive provision might be the result of a new requirement elsewhere in the *Code*. For example, in editions of the *Code* prior to 1991, corridors in new health care occupancies were required to have a 1-hour fire resistance rating. Since 1991, these corridors have been required only to resist the passage of smoke. However, this provision is based on the new requirement that all new health care facilities be protected throughout by automatic sprinklers.

A.1.3.1 Various chapters contain specific provisions for existing buildings and structures that might differ from those for new construction.

A.1.4 Before a particular mathematical fire model or evaluation system is used, its purpose and limitations need to be known. The technical documentation should clearly identify any assumptions included in the evaluation. Also, it is the intent of the Committee on Safety to Life to recognize that future editions of this *Code* are a further refinement of this edition and earlier editions. The changes in future editions will reflect the continuing input of the fire protection/life safety community in its attempt to meet the purpose stated in this *Code*.

A.1.4.3 An equivalent method of protection provides an equal or greater level of safety. It is not a waiver or deletion of a *Code* requirement.

The prescriptive provisions of this *Code* provide specific requirements for broad classifications of buildings and structures. These requirements are stated in terms of fixed values, such as maximum travel distance, minimum fire resistance ratings, and minimum features of required systems, such as detection, alarm, suppression, and ventilation, and not in terms of overall building or system performance.

However, the equivalency clause in 1.4.3 permits the use of alternative systems, methods, or devices to meet the intent of the prescribed code provisions where approved as being equivalent. Equivalency provides an opportunity for a performance-based design approach. Through the rigor of a performance-based design, it can be demonstrated whether or not a building design is satisfactory and complies with the implicit or explicit intent of the applicable code requirement.

When employing the equivalency clause, it is important to clearly identify the prescriptive-based code provision being addressed (scope), to provide an interpretation of the intent of the provision (goals and objectives), to provide an alternative approach (proposed design), and to provide appropriate support for the suggested alternative (evaluation of proposed designs).

Performance resulting from proposed designs can be compared to the performance of the design features required by this *Code*. Using prescribed features as a baseline for comparison, it can then be demonstrated in the evaluation whether a

proposed design offers the intended level of performance. A comparison of safety provided can be used as the basis for establishing equivalency.

A.3.2.1 Approved. The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

A.3.2.2 Authority Having Jurisdiction (AHJ). The phrase "authority having jurisdiction," or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.3.2.3 Code. The decision to designate a standard as a "code" is based on such factors as the size and scope of the document, its intended use and form of adoption, and whether it contains substantial enforcement and administrative provisions.

A.3.2.5 Listed. The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

A.3.3.7 Air-Supported Structure. A cable-restrained air-supported structure is one in which the uplift is resisted by cables or webbing that is anchored by various methods to the membrane or that might be an integral part of the membrane. It is not a tensioned-membrane structure.

A.3.3.8 Aisle Accessway. *Aisle accessway* is the term used for the previously unnamed means of egress component leading to an aisle or other means of egress. For example, circulation space between parallel rows of seats having a width of 305 mm to 610 mm (12 in. to 24 in.) and a length not exceeding 30 m (100 ft) is an aisle accessway. Some of the circulation space between tables or seats in restaurants might be considered aisle accessway.

Depending on the width of aisle accessway, which is influenced by its length and expected utilization, the movement of a person through the aisle accessway might require others to change their individual speed of movement, alter their postures, move their chairs out of the way, or proceed ahead of the person.

A.3.3.16.2.1 Gross Floor Area. Where the term *floor area* is used, it should be understood to be gross floor area unless otherwise specified.

A.3.3.16.4 Hazardous Area. Hazardous areas include those areas used for the storage or use of combustibles or flammables; toxic, noxious, or corrosive materials; or heat-producing appliances.

A.3.3.17 Area of Refuge. An area of refuge has a temporary use during egress. It generally serves as a staging area that provides relative safety to its occupants while potential emergencies are assessed, decisions are made, and mitigating activities are begun. Taking refuge within such an area is, thus, a stage of the total egress process; a stage between egress from the immediately threatened area and egress to a public way.

An area of refuge might be another building connected by a bridge or balcony, a compartment of a subdivided story, an elevator lobby, or an enlarged story-level exit stair landing. An area of refuge is accessible by means of horizontal travel or, as a minimum, via an accessible route meeting the requirements of ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*.

This *Code* recognizes any floor in a building protected throughout by an approved, supervised automatic sprinkler system as an area of refuge. This recognition acknowledges the ability of a properly designed and functioning automatic sprinkler system to control a fire at its point of origin and to limit the production of toxic products to a level that is not life threatening.

The requirement for separated rooms or spaces can be met on an otherwise undivided floor by enclosing the elevator lobby with ordinary glass or other simple enclosing partitions that are smoke resisting.

For some occupancies, one accessible room or space is permitted.

A.3.3.21 Atrium. As defined in NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*, a large-volume space is an uncompartmented space, generally two or more stories in height, within which smoke from a fire either in the space or in a communicating space can move and accumulate without restriction. Atria and covered malls are examples of large-volume spaces.

A.3.3.23.1 Fire Barrier. A fire barrier might be vertically or horizontally aligned, such as a wall or floor assembly.

A.3.3.23.2 Smoke Barrier. A smoke barrier might be vertically or horizontally aligned, such as a wall, floor, or ceiling assembly. A smoke barrier might or might not have a fire resistance rating. Application of smoke barrier criteria where required elsewhere in the *Code* should be in accordance with Section 8.3.

A.3.3.23.3 Thermal Barrier. Finish ratings, as published in the *UL Fire Resistance Directory*, are one way of determining thermal barrier.

A.3.3.24 Birth Center. A birth center is a low-volume service for healthy, childbearing women, and their families, who are capable of ambulation in the event of fire or fire-threatening events. Birth center mothers and babies have minimal analgesia, receive no general or regional anesthesia, and are capable of ambulation, even in second-stage labor.

A.3.3.27 Building. The term *building* is to be understood as if followed by the words *or portions thereof*. (See also *Structure*, A.3.3.217.)

A.3.3.27.3 Apartment Building. The *Code* specifies that, wherever there are three or more living units in a building, the building is considered an apartment building and is required to comply with either Chapter 30 or Chapter 31, as appropriate. Townhouse units are considered to be apartment buildings if there are three or more units in the building. The type of wall required between units in order to consider them to be separate buildings is normally established by the authority having jurisdiction. If the units are separated by a wall of sufficient fire resistance and structural integrity to be considered as separate buildings, then the provisions of Chapter 24 apply to each townhouse. Condominium status is a form of ownership, not occupancy; for example, there are condominium warehouses, condominium apartments, and condominium offices.

A.3.3.27.5 Existing Building. With respect to judging whether a building should be considered existing, the deciding factor is not when the building was designed or when construction started but, rather, the date plans were approved for construction by the appropriate authority having jurisdiction.

A.3.3.27.6 Flexible Plan and Open Plan Educational or Day-Care Building. Flexible plan buildings have movable corridor walls and movable partitions of full-height construction with doors leading from rooms to corridors. Open plan buildings have rooms and corridors delineated by tables, chairs, desks, bookcases, counters, low-height partitions, or similar furnishings. It is the intent that low-height partitions not exceed 1525 mm (60 in.).

A.3.3.27.7 High-Rise Building. It is the intent of this definition that, in determining the level from which the highest occupiable floor is to be measured, the enforcing agency should exercise reasonable judgment, including consideration of overall accessibility to the building by fire department personnel and vehicular equipment. Where a building is situated on a sloping terrain and there is building access on more than one level, the enforcing agency might select the level that provides the most logical and adequate fire department access.

A.3.3.27.8 Historic Building. Designation for a historic building might be in an official national, regional, or local historic register, listing, or inventory.

A.3.3.27.9 Mall Building. A mall building may enclose one or more uses, such as retail stores, drinking establishments, entertainment and amusement facilities, offices, and other similar uses.

A.3.3.27.10 Special Amusement Building. Such structures include amusements such as a haunted house, a roller coaster-type ride within a building, a multilevel play structure within a building, a submarine ride, and similar amusements where the occupants are not in the open air.

A.3.3.30 Cellular or Foamed Plastic. Cellular or foamed plastic might contain foamed and unfoamed polymeric or monomeric precursors (prepolymer, if used), plasticizers, fillers, extenders, catalysts, blowing agents, colorants, stabilizers, lubricants, surfactants, pigments, reaction control agents, processing aids, and flame retardants.

A.3.3.34 Common Path of Travel. Common path of travel is measured in the same manner as travel distance but terminates at that point where two separate and distinct routes become available. Paths that merge are common paths of travel.

A.3.3.35.1 Fire Compartment. Additional fire compartment information is contained in 8.2.2.

In the provisions for fire compartments utilizing the outside walls of a building, it is not intended that the outside wall be specifically fire resistance-rated unless required by other standards. Likewise, it is not intended that outside windows or doors be protected, unless specifically required for exposure protection by another section of this *Code* or by other standards.

A.3.3.35.2 Smoke Compartment. In the provision of smoke compartments using the outside walls or the roof of a building, it is not intended that outside walls or roofs or any openings therein be capable of resisting the passage of smoke. Application of smoke compartment criteria where required elsewhere in the *Code* should be in accordance with Section 8.5.

A.3.3.38 Critical Radiant Flux. Critical radiant flux is the property determined by the test procedure of NFPA 253, *Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source*. The unit of measurement of critical radiant flux is watts per square centimeter (W/cm^2).

A.3.3.48 Dormitory. Rooms within dormitories intended for the use of individuals for combined living and sleeping purposes are guest rooms or guest suites. Examples of dormitories are college dormitories, fraternity and sorority houses, and military barracks.

A.3.3.52 Electroluminescent. This light source is typically contained inside the device.

A.3.3.57 Evacuation Capability. The evacuation capability of the residents and staff is a function of both the ability of the residents to evacuate and the assistance provided by the staff. It is intended that the evacuation capability be determined by the procedure acceptable to the authority having jurisdiction. It is also intended that the timing of drills, the rating of residents, and similar actions related to determining the evacuation capability be performed by persons approved by or acceptable to the authority having jurisdiction. The evacuation capability can be determined by the use of the definitions in 3.3.57, the application of NFPA 101A, *Guide on Alternative Approaches to Life Safety*, Chapter 5, or a program of drills (timed).

Where drills are used in determining evacuation capability, it is suggested that the facility conduct and record fire drills six times per year on a bimonthly basis, with a minimum of two drills conducted during the night when residents are sleeping, and that the facility conduct the drills in consultation with the authority having jurisdiction. Records should indicate the time taken to reach a point of safety, date and time of day, location of simulated fire origin, escape paths used, and comments relating to residents who resisted or failed to participate in the drills.

Translation of drill times to evacuation capability is determined as follows:

- (1) 3 minutes or less — prompt
- (2) Over 3 minutes, but not in excess of 13 minutes — slow
- (3) More than 13 minutes — impractical

Evacuation capability, in all cases, is based on the time of day or night when evacuation of the facility would be most difficult, such as when residents are sleeping or fewer staff are present.

Evacuation capability determination is considered slow if the following conditions are met:

- (1) All residents are able to travel to centralized dining facilities without continuous staff assistance.
- (2) There is continuous staffing whenever there are residents in the facility.

A.3.3.60 Existing. See *Existing Building*, A.3.3.27.5.

A.3.3.62 Exit. Exits include exterior exit doors, exit passageways, horizontal exits, exit stairs, and exit ramps. In the case of a stairway, the exit includes the stair enclosure, the door to the stair enclosure, stairs and landings inside the enclosure, the door from the stair enclosure to the outside or to the level of exit discharge, and any exit passageway and its associated doors if such are provided so as to discharge the stair directly to the outside. In the case of a door leading directly from the street floor to the street or open air, the exit comprises only the door.

Doors of small individual rooms, as in hotels, while constituting exit access from the room, are not referred to as exits except where they lead directly to the outside of the building from the street floor.

A.3.3.62.1 Horizontal Exit. Horizontal exits should not be confused with egress through doors in smoke barriers. Doors in smoke barriers are designed only for temporary protection against smoke, whereas horizontal exits provide protection against serious fire for a relatively long period of time in addition to providing immediate protection from smoke. (See 7.2.4.)

A.3.3.67 Exposure Fire. An exposure fire usually refers to a fire that starts outside a building, such as a wildlands fire or vehicle fire, and that consequently exposes the building to a fire.

A.3.3.69.2 Limited Care Facility. Limited care facilities and residential board and care occupancies both provide care to people with physical and mental limitations. However, the goals and programs of the two types of occupancies differ greatly. The requirements in this *Code* for limited care facilities are based on the assumption that these are medical facilities, that they provide medical care and treatment, and that the patients are not trained to respond to the fire alarm; that is, the patients do not participate in fire drills but, rather, await rescue. (See Section 18.7.)

The requirements for residential board and care occupancies are based on the assumption that the residents are provided with personal care and activities that foster continued independence, that the residents are encouraged and taught to overcome their limitations, and that most residents, including all residents in prompt and slow homes, are trained to respond to fire drills, to the extent they are able. Residents are required to participate in fire drills. (See Section 32.7.)

A.3.3.77 Fire Model. Due to the complex nature of the principles involved, models are often packaged as computer software. Any relevant input data, assumptions, and limitations needed to properly implement the model will be attached to the fire models.

A.3.3.80 Fire Scenario. A fire scenario defines the conditions under which a proposed design is expected to meet the fire safety goals. Factors typically include fuel characteristics, ignition sources, ventilation, building characteristics, and occupant locations and characteristics. The term *fire scenario* includes more than the characteristics of the fire itself but excludes design specifications and excludes any characteristics that do not vary from one fire to another; the latter are called assumptions. The term *fire scenario* is used here to mean only those specifications required to calculate the fire's development and effects but, in other contexts, the term might be used to mean both the initial specifications and the subse-

quent development and effects (that is, a complete description of fire from conditions prior to ignition to conditions following extinguishment).

A.3.3.81 Fire Watch. Duties of the fire watch might include notifying the fire department and building occupants of an emergency, preventing a fire from occurring, or extinguishing small fires.

A.3.3.84 Flame Spread. See Section 10.2.

A.3.3.85 Flashover. Flashover occurs when the surface temperatures of combustible contents rise, producing pyrolysis gases, and the room heat flux becomes sufficient to heat all such gases to their ignition temperatures.

A.3.3.95 Grandstand. Where the term *grandstand* is preceded by an adjective denoting a material, it means a grandstand the essential members of which, exclusive of seating, are of the material designated.

A.3.3.106 Heat Release Rate (HRR). The heat release rate of a fuel is related to its chemistry, physical form, and availability of oxidant and is ordinarily expressed as British thermal units per second (Btu/s) or kilowatts (kW).

Chapter 40 and Chapter 42 include detailed provisions on high hazard industrial and storage occupancies.

A.3.3.110.1 Day-Care Home. A day-care home is generally located within a dwelling unit.

A.3.3.113 Hotel. So-called apartment hotels should be classified as hotels because they are potentially subject to the same transient occupancy as hotels. Transients are those who occupy accommodations for less than 30 days.

A.3.3.114.1 Externally Illuminated. The light source is typically a dedicated incandescent or fluorescent source.

A.3.3.114.2 Internally Illuminated. The light source is typically incandescent, fluorescent, electroluminescent, photoluminescent, light-emitting diodes, or self-luminous.

A.3.3.120 Interior Finish. Interior finish is not intended to apply to surfaces within spaces such as those that are concealed or inaccessible. Furnishings that, in some cases, might be secured in place for functional reasons should not be considered as interior finish.

A.3.3.120.2 Interior Floor Finish. Interior floor finish includes coverings applied over a normal finished floor or stair treads and risers.

A.3.3.131.1 Fuel Load. Fuel load includes interior finish and trim.

A.3.3.135.2 Limited-Combustible (Material). Materials subject to increase in combustibility or flame spread index beyond the limits herein established through the effects of age, moisture, or other atmospheric condition are considered combustible. See NFPA 259, *Standard Test Method for Potential Heat of Building Materials* and NFPA 220, *Standard on Types of Building Construction*.

A.3.3.136 Means of Egress. A means of egress comprises the vertical and horizontal travel and includes intervening room spaces, doorways, hallways, corridors, passageways, balconies, ramps, stairs, elevators, enclosures, lobbies, escalators, horizontal exits, courts, and yards.

A.3.3.143 Modification. Modification does not include repair or replacement of interior finishes.

A.3.3.151 Objective. Objectives define a series of actions necessary to make the achievement of a goal more likely. Objectives are stated in more specific terms than goals and are measured on a more quantitative, rather than qualitative, basis.

A.3.3.152.1 Ambulatory Health Care Occupancy. It is not the intent that occupants be considered to be incapable of self-preservation just because they are in a wheelchair or use assistive walking devices such as a cane, a walker, or crutches. Rather it is the intent to address emergency care centers that receive patients who have been rendered incapable of self-preservation due to the emergency, such as being rendered unconscious as a result of an accident or being unable to move oneself due to sudden illness.

A.3.3.152.2 Assembly Occupancy. Assembly occupancies might include the following:

- (1) Armories
- (2) Assembly halls
- (3) Auditoriums
- (4) Bowling lanes
- (5) Club rooms
- (6) College and university classrooms, 50 persons and over
- (7) Conference rooms
- (8) Courtrooms
- (9) Dance halls
- (10) Drinking establishments
- (11) Exhibition halls
- (12) Gymnasiums
- (13) Libraries
- (14) Mortuary chapels
- (15) Motion picture theaters
- (16) Museums
- (17) Passenger stations and terminals of air, surface, underground, and marine public transportation facilities
- (18) Places of religious worship
- (19) Pool rooms
- (20) Recreation piers
- (21) Restaurants
- (22) Skating rinks
- (23) Special amusement buildings regardless of occupant load
- (24) Theaters

Assembly occupancies are characterized by the presence or potential presence of crowds with attendant panic hazard in case of fire or other emergency. They are generally open or occasionally open to the public, and the occupants, who are present voluntarily, are not ordinarily subject to discipline or control. Such buildings are ordinarily occupied by able-bodied persons and are not used for sleeping purposes. Special conference rooms, snack areas, and other areas incidental to, and under the control of, the management of other occupancies, such as offices, fall under the 50-person limitation.

Restaurants and drinking establishments with an occupant load of fewer than 50 persons should be classified as mercantile occupancies.

For special amusement buildings, see 12.4.7 and 13.4.7.

A.3.3.152.3 Business Occupancy. Business occupancies include the following:

- (1) Air traffic control towers (ATCTs)
- (2) City halls
- (3) College and university instructional buildings, classrooms under 50 persons, and instructional laboratories

- (4) Courthouses
- (5) Dentists' offices
- (6) Doctors' offices
- (7) General offices
- (8) Outpatient clinics, ambulatory
- (9) Town halls

Doctors' and dentists' offices are included, unless of such character as to be classified as ambulatory health care occupancies. (See 3.3.152.1.)

Birth centers should be classified as business occupancies if they are occupied by fewer than four patients, not including infants, at any one time; do not provide sleeping facilities for four or more occupants; and do not provide treatment procedures that render four or more patients, not including infants, incapable of self-preservation at any one time. For birth centers occupied by patients not meeting these parameters, see Chapter 18 or Chapter 19, as appropriate.

Service facilities common to city office buildings such as newsstands, lunch counters serving fewer than 50 persons, barber shops, and beauty parlors are included in the business occupancy group.

City halls, town halls, and courthouses are included in this occupancy group insofar as their principal function is the transaction of public business and the keeping of books and records. Insofar as they are used for assembly purposes, they are classified as assembly occupancies.

A.3.3.152.4 Day-Care Occupancy. Day-care occupancies include the following:

- (1) Adult day-care occupancies, except where part of a health care occupancy
- (2) Child day-care occupancies
- (3) Day-care homes
- (4) Kindergarten classes that are incidental to a child day-care occupancy
- (5) Nursery schools

In areas where public schools offer only half-day kindergarten programs, many child day-care occupancies offer state-approved kindergarten classes for children who need full-day care. Because these classes are normally incidental to the day-care occupancy, the requirements of the day-care occupancy should be followed.

A.3.3.152.5 Detention and Correctional Occupancy. Detention and correctional occupancies include the following:

- (1) Adult and juvenile substance abuse centers
- (2) Adult and juvenile work camps
- (3) Adult community residential centers
- (4) Adult correctional institutions
- (5) Adult local detention facilities
- (6) Juvenile community residential centers
- (7) Juvenile detention facilities
- (8) Juvenile training schools

A.3.3.152.6 Educational Occupancy. Educational occupancies include the following:

- (1) Academies
- (2) Kindergartens
- (3) Schools

An educational occupancy is distinguished from an assembly occupancy in that the same occupants are regularly present.

A.3.3.152.7 Health Care Occupancy. Health care occupancies include the following:

- (1) Ambulatory health care facilities
- (2) Hospitals
- (3) Limited care facilities
- (4) Nursing homes

Occupants of health care occupancies typically have physical or mental illness, disease, or infirmity. They also include infants, convalescents, or infirm aged persons.

A.3.3.152.8 Industrial Occupancy. Industrial occupancies include the following:

- (1) Dry cleaning plants
- (2) Factories of all kinds
- (3) Food processing plants
- (4) Gas plants
- (5) Hangars (for servicing/maintenance)
- (6) Laundries
- (7) Power plants
- (8) Pumping stations
- (9) Refineries
- (10) Sawmills
- (11) Telephone exchanges

In evaluating the appropriate classification of laboratories, the authority having jurisdiction should treat each case individually based on the extent and nature of the associated hazards. Some laboratories are classified as occupancies other than industrial, for example, a physical therapy laboratory or a computer laboratory.

A.3.3.152.8.1 General Industrial Occupancy. General industrial occupancies include multistory buildings where floors are occupied by different tenants or buildings suitable for such occupancy and, therefore, are subject to possible use for types of industrial processes with a high density of employee population.

A.3.3.152.8.2 High Hazard Industrial Occupancy. A high hazard occupancy includes occupancies where gasoline and other flammable liquids are handled, used, or stored under such conditions that involve possible release of flammable vapors; where grain dust, wood flour or plastic dusts, aluminum or magnesium dust, or other explosive dusts are produced; where hazardous chemicals or explosives are manufactured, stored, or handled; where cotton or other combustible fibers are processed or handled under conditions that might produce flammable flyings; and where other situations of similar hazard exist. Chapter 40 and Chapter 42 include detailed provisions on high hazard industrial and storage occupancies.

A.3.3.152.9 Mercantile Occupancy. Mercantile occupancies include the following:

- (1) Auction rooms
- (2) Department stores
- (3) Drugstores
- (4) Restaurants with fewer than 50 persons
- (5) Shopping centers
- (6) Supermarkets

Office, storage, and service facilities incidental to the sale of merchandise and located in the same building should be considered part of the mercantile occupancy classification.

A.3.3.152.12 Residential Occupancy. Residential occupancies are treated as separate occupancies in this *Code* as follows:

- (1) One- and two-family dwellings (Chapter 24)

- (2) Lodging or rooming houses (Chapter 26)
- (3) Hotels, motels, and dormitories (Chapter 28 and Chapter 29)
- (4) Apartment buildings (Chapter 30 and Chapter 31)

A.3.3.152.13 Residential Board and Care Occupancy. The following are examples of facilities that are classified as residential board and care occupancies:

- (1) A group housing arrangement for physically or mentally handicapped persons who normally attend school in the community, attend worship in the community, or otherwise use community facilities
- (2) A group housing arrangement for physically or mentally handicapped persons who are undergoing training in preparation for independent living, for paid employment, or for other normal community activities
- (3) A group housing arrangement for the elderly that provides personal care services but that does not provide nursing care
- (4) Facilities for social rehabilitation, alcoholism, drug abuse, or mental health problems that contain a group housing arrangement and that provide personal care services but do not provide acute care
- (5) Assisted living facilities
- (6) Other group housing arrangements that provide personal care services but not nursing care

A.3.3.152.15 Storage Occupancy. Storage occupancies include the following:

- (1) Barns
- (2) Bulk oil storage
- (3) Cold storage
- (4) Freight terminals
- (5) Grain elevators
- (6) Hangars (for storage only)
- (7) Parking structures
- (8) Stables
- (9) Truck and marine terminals
- (10) Warehouses

Storage occupancies are characterized by the presence of relatively small numbers of persons in proportion to the area.

A.3.3.159 Outside Stair. See 7.2.2.

A.3.3.161 Performance Criteria. Performance criteria are stated in engineering terms. Engineering terms include temperatures, radiant heat flux, and levels of exposure to fire products. Performance criteria provide threshold values used to evaluate a proposed design.

A.3.3.163 Personal Care. Personal care involves responsibility for the safety of the resident while inside the building. Personal care might include daily awareness by management of the resident's functioning and whereabouts, making and reminding a resident of appointments, the ability and readiness for intervention in the event of a resident experiencing a crisis, supervision in the areas of nutrition and medication, and actual provision of transient medical care.

A.3.3.164 Photoluminescent. The light source is considered internally illuminated.

A.3.3.166 Platform. Platforms also include the head tables for special guests; the raised area for lecturers and speakers; boxing and wrestling rings; theater-in-the-round; and for similar purposes wherein there are no overhead drops, pieces of scenery, or stage effects other than lighting and a screening val-

ance. A platform is not intended to be prohibited from using a curtain as a valance to screen or hide the electric conduit, lighting track, or similar fixtures, nor is a platform prohibited from using curtains that are used to obscure the back wall of the stage; a curtain between the auditorium and the stage (grand or house curtain), a maximum of four leg drops; or a valance to screen light panels, plumbing, and similar equipment from view.

A.3.3.173 Proposed Design. The design team might develop a number of trial designs that will be evaluated to determine whether they meet the performance criteria. One of the trial designs will be selected from those that meet the performance criteria for submission to the authority having jurisdiction as the proposed design.

The proposed design is not necessarily limited to fire protection systems and building features. It also includes any component of the proposed design that is installed, established, or maintained for the purpose of life safety, without which the proposed design could fail to achieve specified performance criteria. Therefore, the proposed design often includes emergency procedures and organizational structures that are needed to meet the performance criteria specified for the proposed design.

A.3.3.176 Ramp. See 7.2.5.

A.3.3.188.1 Festival Seating. Festival seating describes situations in assembly occupancies where live entertainment events are held that are expected to result in overcrowding and high audience density that can compromise public safety. It is not the intent to apply the term *festival seating* to exhibitions; sports events; dances; conventions; and bona fide political, religious, and educational events. Assembly occupancies with 1.4 m² (15 ft²) or more per person should not be considered festival seating.

A.3.3.190 Self-Luminous. An example of a self-contained power source is tritium gas. Batteries do not qualify as a self-contained power source. The light source is typically contained inside the device.

A.3.3.191 Self-Preservation (Day-Care Occupancy). Examples of clients who are incapable of self-preservation include infants, clients who are unable to use stairs because of confinement to a wheelchair or other physical disability, and clients who cannot follow directions or a group to the outside of a facility due to mental or behavioral disorders. It is the intent of this *Code* to classify children under the age of 24 months as incapable of self-preservation. Examples of direct intervention by staff members include carrying a client, pushing a client outside in a wheelchair, and guiding a client by direct hand-holding or continued bodily contact. If clients cannot exit the building by themselves with minimal intervention from staff members, such as verbal orders, classification as incapable of self-preservation should be considered.

A.3.3.202 Smoke Partition. A smoke partition is not required to have a fire resistance rating.

A.3.3.203 Smokeproof Enclosure. For further guidance, see the following publications:

- (1) ASHRAE *Handbook and Product Directory — Fundamentals*
- (2) *Design of Smoke Management Systems*, by Klote and Milke
- (3) NFPA 105, *Standard for the Installation of Smoke Door Assemblies*

A.3.3.208.1 Design Specification. Design specifications include both hardware and human factors, such as the condi-

tions produced by maintenance and training. For purposes of performance-based design, the design specifications of interest are those that affect the ability of the building to meet the stated goals and objectives.

A.3.3.214.1 Occupiable Story. Stories used exclusively for mechanical equipment rooms, elevator penthouses, and similar spaces are not occupiable stories.

A.3.3.216 Street Floor. Where, due to differences in street levels, two or more stories are accessible from the street, each is a street floor. Where there is no floor level within the specified limits for a street floor above or below ground level, the building has no street floor.

A.3.3.217 Structure. The term *structure* is to be understood as if followed by the words *or portion thereof*. (See also *Building*, A.3.3.27.)

A.3.3.217.2 Air-Supported Structure. A cable-restrained air-supported structure is one in which the uplift is resisted by cables or webbing that is anchored by various methods to the membrane or that might be an integral part of the membrane. It is not a tensioned-membrane structure.

A.3.3.217.6 Open Structure. Open structures are often found in oil refining, chemical processing, or power plants. Roofs or canopies without enclosing walls are not considered an enclosure.

A.3.3.217.11 Underground Structure. In determining openings in exterior walls, doors or access panels are permitted to be included. Windows are also permitted to be included if they are openable or provide a breakable glazed area.

A.3.3.222 Tent. A tent might also include a temporary tensioned-membrane structure.

A.4.1 The goals in Section 4.1 reflect the scope of this *Code* (see Section 1.1). Other fire safety goals that are outside the scope of this *Code* might also need to be considered, such as property protection and continuity of operations. Compliance with this *Code* can assist in meeting goals outside of the *Code*'s scope.

A.4.1.1 Reasonable safety risk is further defined by subsequent language in this *Code*.

A.4.1.1(1) The phrase "intimate with the initial fire development" refers to the person(s) at the ignition source or first materials burning, not to all persons within the same room or area.

A.4.1.2 An assembly occupancy is an example of an occupancy where the goal of providing for reasonably safe emergency and nonemergency crowd movement has applicability. A detention or correctional occupancy is an example of an occupancy where emergency and nonemergency crowd movement is better addressed by detention and correctional facilities specialists than by this *Code*.

A.4.3 Additional assumptions that need to be identified for a performance-based design are addressed in Chapter 5.

A.4.5.4 Fire alarms alert occupants to initiate emergency procedures, facilitate orderly conduct of fire drills, and initiate response by emergency services.

A.4.6.3 See A.4.6.4.

A.4.6.4 In existing buildings, it is not always practical to strictly apply the provisions of this *Code*. Physical limitations can cause the need for disproportionate effort or expense with little increase in life safety. In such cases, the authority having jurisdiction should be satisfied that reasonable life safety is ensured.

In existing buildings, it is intended that any condition that represents a serious threat to life be mitigated by the application of appropriate safeguards. It is not intended to require modifications for conditions that do not represent a significant threat to life, even though such conditions are not literally in compliance with the *Code*.

An example of what is intended by 4.6.4 would be an historic ornamental guardrail baluster with spacing that does not comply with the 100-mm (4-in.) requirement. Because reducing the spacing would have minimal impact on life safety but could damage the historic character of the guardrail, the existing spacing might be approved by the authority having jurisdiction.

A.4.6.8 The following is an example of what is intended by 4.6.8. In a hospital that has 1830-mm (72-in.) wide corridors, such corridors cannot be reduced in width, even though the provisions for existing hospitals do not require 1830-mm (72-in.) wide corridors. However, if a hospital has 3050-mm (120-in.) wide corridors, they are permitted to be reduced to 2440 mm (96 in.) in width, which is the requirement for new construction. If the hospital corridor is 915 mm (36 in.) wide, it would have to be increased to 1220 mm (48 in.). If alterations require replacement of a portion of a hospital corridor wall, such portion of the corridor would not be required to be increased to 2440 mm (96 in.) in width, unless it was practical to do so.

A.4.6.11.1 Fatal fires have occurred when, for example, a required stair has been closed for repairs or removed for rebuilding, or when a required automatic sprinkler system has been shut off to change piping.

A.4.6.11.2 See also NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*.

A.4.6.12 Examples of changes from one occupancy subclassification to another subclassification of the same occupancy could include a change from a Class B to a Class A mercantile occupancy. Hospitals and nursing homes are both health care occupancies and are defined separately, but they are not established as separate suboccupancies; thus, a change from one to the other does not constitute a change of occupancy subclassification.

For example, a building was used as a hospital but has been closed for four years. It is again to be used as a hospital. As long as the building was not used as another occupancy during the time it was closed, it would be considered an existing hospital.

Hotels and apartments, although both residential occupancies, are treated separately, and a change from one to the other constitutes a change of occupancy.

A.4.6.13.2 Examples of such features include automatic sprinklers, fire alarm systems, standpipes, and portable fire extinguishers. The presence of a life safety feature, such as sprinklers or fire alarm devices, creates a reasonable expectation by the public that these safety features are functional. When systems are inoperable or taken out of service but the devices remain, they present a false sense of safety. Also, before taking any life safety features out of service, extreme care needs to be exercised to ensure that the feature is not required, was not originally provided as an alternative or equivalent, or is no longer required due to other new requirements in the current *Code*. It is not intended that the entire system or protection feature be removed. Instead, components such as sprinklers, initiating devices, notification appliances, stand-

pipe hose, and exit systems should be removed to reduce the likelihood of relying on inoperable systems or features.

A.4.7 The purpose of emergency egress and relocation drills is to educate the participants in the fire safety features of the building, the egress facilities available, and the procedures to be followed. Speed in emptying buildings or relocating occupants, while desirable, is not the only objective. Prior to an evaluation of the performance of an emergency egress and relocation drill, an opportunity for instruction and practice should be provided. This educational opportunity should be presented in a nonthreatening manner, with consideration to the prior knowledge, age, and ability of audience.

The usefulness of an emergency egress and relocation drill and the extent to which it can be performed depends on the character of the occupancy.

In buildings where the occupant load is of a changing character, such as hotels or department stores, no regularly organized emergency egress and relocation drill is possible. In such cases, the emergency egress and relocation drills are to be limited to the regular employees, who can, however, be thoroughly schooled in the proper procedure and can be trained to properly direct other occupants of the building in case of emergency evacuation or relocation. In occupancies such as hospitals, regular employees can be rehearsed in the proper procedure in case of fire; such training always is advisable in all occupancies whether or not regular emergency egress and relocation drills can be held.

A.4.7.2 If an emergency egress and relocation drill is considered merely as a routine exercise from which some persons are allowed to be excused, there is a grave danger that, in an actual emergency, the evacuation and relocation will not be successful. However, there might be circumstances under which all occupants do not participate in an emergency egress and relocation drill, for example, infirm or bedridden patients in a health care occupancy.

A.4.7.4 Fire is always unexpected. If the drill is always held in the same way at the same time, it loses much of its value. When, for some reason during an actual fire, it is not possible to follow the usual routine of the emergency egress and relocation drill to which occupants have become accustomed, confusion and panic might ensue. Drills should be carefully planned to simulate actual fire conditions. Not only should drills be held at varying times, but different means of exit or relocation areas should be used, based on an assumption that fire or smoke might prevent the use of normal egress and relocation avenues.

A.4.7.6 The written record required by this paragraph should include such details as the date, time, participants, location, and results of that drill.

A.5.1.1 Chapter 5 of this *Code* provides requirements for the evaluation of a performance-based life safety design. The evaluation process is summarized in Figure A.5.1.1.

Code Criteria. On the left side of Figure A.5.1.1 is input from the *Code*. The life safety goals have been stated in Section 4.1. The objectives necessary to achieve these goals are stated in Section 4.2. Section 5.2 specifies the measures that are to be used to determine whether the objectives have been met.

Input. At the top of Figure A.5.1.1 is the input necessary to evaluate a life safety design.

The design specifications are to include certain retained prescriptive requirements as specified in Section 5.3. All assumptions about the life safety design and the response of the

building and its occupants to a fire are to be clearly stated as indicated in Section 5.4. Scenarios are used to assess the adequacy of the design. Eight sets of initiating events are specified for which the ensuing outcomes are to be satisfactory.

Performance Assessment. Appropriate methods for assessing performance are to be used per Section 5.6. Safety factors are to be applied to account for uncertainties in the assessment as stated in Section 5.7. If the resulting predicted outcome of the scenarios is bounded by the performance criteria, the objectives have been met and the life safety design is considered to be in compliance with this *Code*. Although not part of this *Code*, a design that fails to comply can be changed and reassessed as indicated on the right side of Figure A.5.1.1.

Documentation. The approval and acceptance of a life safety design are dependent on the quality of the documentation of the process. Section 5.8 specifies a minimum set of documentation that is to accompany a submission.

The performance option of this *Code* establishes acceptable levels of risk to occupants of buildings and structures as addressed in Section 1.1. While the performance option of this *Code* does contain goals, objectives and performance criteria necessary to provide an acceptable level of risk to occupants, it does not describe how to meet the goals, objectives, and performance criteria. Design and engineering are needed to develop solutions that meet the provisions of Chapter 5. The *SFPE Engineering Guide to Performance-Based Fire Protection Analysis and Design of Buildings* provides a framework for these assessments. Other useful references include the *Australian Fire Engineering Guidelines* and the *British Standard Firesafety Engineering in Buildings*.




FIGURE A.5.1.1 Performance-Based Life Safety Code Compliance Process.

A.5.1.4 A third-party reviewer is a person or group of persons chosen by the authority having jurisdiction to review proposed performance-based designs.

A.5.1.7 Continued compliance with the goals and objectives of the *Code* involves many factors. The building construction — including openings, interior finish, and fire- and smoke-resistive construction — and the building and fire protection systems need to retain at least the same level of performance as is provided for the original design parameters. The use and occupancy should not change to the degree that assumptions made about the occupant characteristics, combustibility of furnishings, and existence of trained personnel are no longer valid. In addition, actions provided by other personnel, such as emergency responders, should not be diminished below the documented assumed levels. Also, actions needed to maintain reliability of systems at the anticipated level need to meet the initial design criteria.

A.5.2.2 One of the following methods can be used to avoid exposing occupants to untenable conditions.

Method 1. The design team can set detailed performance criteria that ensure that occupants are not incapacitated by fire effects. The *SFPE Engineering Guide to Performance-Based Fire Protection Analysis and Design of Buildings* describes a process of establishing tenability limits.

The guide references D. A. Purser, “Toxicity Assessment of Combustion Products,” Chapters 2–8, *SFPE Handbook of Fire Protection Engineering*, National Fire Protection Association, Quincy, MA, 1995, which describes a fractional effective dose (FED) calculation approach also contained in the 1996 edition of NFPA 269, *Standard Test Method for Developing Toxic Potency Data for Use in Fire Hazard Modeling*. FED addresses carbon monoxide, hydrogen cyanide, carbon dioxide, hydrogen chloride, hydrogen bromide, and anoxia effects. It is possible to use the test data, combined with laboratory experience, to estimate the FED value that leads to the survival of virtually all people. This value is about 0.8.

There is a relationship between exposures leading to death and those leading to incapacitation. Kaplan (Kaplan et al., *Journal of Fire Science*, 2:286–305 (1984)) found that rodent susceptibility is similar to that of humans and that for the narcotic gases, CO and HCN, incapacitation occurs at one-third to one-half of the lethal exposure. Gann (Gann et al., *Fire and Materials* 18:193 (1994)) found that carbon monoxide dominates the lethality of fire smoke, since most fire deaths occur remote from the fire room, in fires that have proceeded past flashover. Thus, if an FED value of 0.8 were used for a nonlethal exposure, an FED of 0.3 would be reasonable for a nonincapacitating exposure.

If the authority having jurisdiction or the design professional is concerned with potential toxic fire effects other than those addressed by the FED procedure as documented, the calculation procedure can be expanded by adding additional terms to the FED equation, with each term expressed as a ratio. The numerator of the ratio is the cumulative exposure to that fire effect, measured as an integral of the product of instantaneous exposure (concentration for toxic products) and time. The denominator of the ratio is the quantity of cumulative exposure for which FED equals the chosen threshold value (that is, 0.8 or 0.3) based on that fire effect alone.

ASTM is actively considering standards that would extend the list of toxic fire effects with standard values.

If the authority having jurisdiction or the design professional is concerned with potential fire effects other than toxicity, the calculation procedure can be modified to include other fire effects, such as thermal effects.

For buildings where an unusually large fraction of the occupants are especially vulnerable, the calculation procedure should be modified to use FED values lower than 0.8 or 0.3.

Method 2. For each design fire scenario and the design specifications, conditions, and assumptions, the design team can demonstrate that each room or area will be fully evacuated before the smoke and toxic gas layer in that room descends to a level lower than 1830 mm (72 in.) above the floor. The timing of such an evacuation means that no occupant is exposed to fire effects. Such an evacuation requires calculation of the locations, movement, and behavior of occupants, because fire effects and occupants are kept separate by moving the occupants. A level of 1525 mm (60 in.) is often used in calculations, but at that level, a large fraction of the population would not be able to stand, walk, or run normally and still avoid inhalation of toxic gases. They would have to bend over or otherwise move their heads closer to the floor level.

Method 3. For each design fire scenario and the design specifications and assumptions, the design team can demonstrate that the smoke and toxic gas layer will not descend to a level lower than 1830 mm (72 in.) above the floor in any occupied room. The advantage of this procedure is that it conservatively requires that no occupant need be exposed to fire effects, regardless of where occupants are or where they move. This removes the need to make any calculations regarding occupants, including their behavior, movement locations, pre-fire characteristics, and reactions to fire effects. This procedure is even more conservative and simpler than the procedure in Method 2, because it does not allow fire effects in occupied rooms to develop to a point where people could be affected at any time during the fire.

Method 4. For each design fire scenario and the design specifications and assumptions, the design team can demonstrate that no fire effects will reach any occupied room. The advantage of this procedure is that it removes the need to make any calculations regarding occupants, including their behavior, movement, locations, pre-fire characteristics, and reactions to fire effects. A further advantage is that it also removes the need for some of the modeling of fire effects, because it is not necessary to model the filling of rooms, only the spread of fire effects to those rooms. This procedure is even more conservative and simpler than the procedures in Methods 2 and 3, because it does not allow any fire effects in occupied rooms.

A.5.3.1 This requirement applies both to systems and features required by the *Code* that reference applicable standards and to any additional systems or features included in the design at the discretion of the design team. The referenced standards are hereby expected to state maintenance, testing, and other requirements needed to provide positive assurance of an acceptable level of reliability. The referenced standards themselves might be prescriptive- or performance-based.

A.5.4.1 The design specifications and other conditions form the input to evaluation of proposed designs (*see Section 5.6*). Where a specification or condition is not known, a reasonable estimation is permitted. However, the design team must take steps to ensure that the estimation is valid during the life of the building. Any estimations need to be documented. (*See Section 5.8.*)

A.5.4.4 Systems addressed by this requirement include automatic fire suppression systems and fire alarm systems. Performance issues that need to be documented might include response time indexes, discharge densities, and distribution patterns. Calculations should not include an unlimited supply of extinguishing agent if only a limited supply will be provided in the actual structure or building.

A.5.4.5.1 Examples of design features that might be incorporated to modify expected occupant characteristics include training, use of staff to assist with notification and movement, or type of notification appliance used.

A.5.4.5.2 The four basic characteristics — sensibility, reactivity, mobility, and susceptibility — comprise a minimum, exhaustive set of mutually exclusive performance characteristics of people in buildings that can affect a fire safety system's ability to meet life safety objectives. The characteristics are briefly described as follows.

- (1) *Sensibility – to physical cues.* Ability to sense the sounding of an alarm; can also include discernment and discrimination of visual and olfactory cues in addition to auditory emanations from the fire itself.
- (2) *Reactivity – ability to interpret correctly cues and take appropriate action.* Can be function of cognitive capacity, speed of instinctive reaction, or group dynamics; might need to consider reliability or likelihood of a wrong decision, as in situations where familiarity with the premises influences wayfinding.
- (3) *Mobility – speed of movement.* Determined by individual capabilities as well as crowding phenomena such as arching at doorways.
- (4) *Susceptibility – to products of combustion.* Metabolism, lung capacity, pulmonary disease, allergies, or other physical limitations that affect survivability in a fire environment.

In application, as with the use of computer evacuation models, assumptions can address a larger number of factors that are components of these basic performance characteristics. Examples follow:

- (1) *Alertness:* Awake/asleep, can depend on time of day
- (2) *Responsiveness:* Ability to sense cues and react
- (3) *Commitment:* Degree to which occupant is committed to an activity underway before the alarm
- (4) *Focal point:* Point at which an occupant's attention is focused, for example, to front of classroom, stage, or server in business environment
- (5) *Physical and mental capabilities:* Can affect ability to sense, respond, and react to cues; might be related to age or disability
- (6) *Role:* Can determine whether occupant will lead or follow others
- (7) *Familiarity:* Can depend on time spent in building or participation in emergency training
- (8) *Social affiliation:* Extent to which an occupant will act/react as an individual or as a member of a group
- (9) *Condition:* Over the course of the fire, the effects — both physiological and psychological — of the fire and its combustion products on each occupant

A.5.4.5.4 The number of people expected to be contained in a room or area should be based on the occupant load factor specified in Table 7.3.1.2 or other approved sources.

A.5.4.5.5 For example, in hospitals, staff characteristics such as number, location, quality, and frequency of training should be considered.

A.5.4.7 Design proposals need to state explicitly any design specifications or estimations regarding building fire safety plans, inspection programs, or other ongoing programs whose performance is necessary for the building, when occupied and operational, to meet the stated goals and objectives. Programs of interest include any maintenance, training, labeling, or certification programs required to ensure operational status or reliability in building systems or features.

A.5.4.9 The design elements required to be excluded by 5.4.9 include those about the interrelations between the performance of building elements and systems, occupant behavior, or emergency response actions that conflict with each other. For each fire scenario, care needs to be taken to ensure that conflicts in actions do not occur. Typical conflicts could include (1) assuming a fire door will remain closed during the fire to contain smoke while this same door is used by occupants during egress from the area, and (2) assuming fire apparatus will arrive immediately from a distant location to provide water to fire department connections and similar situations.

For example, an assumption that compartmentation blocking the passage of fire and smoke will be maintained at the door to a stairwell cannot be paired with an assumption that evacuation through that door will extend over many minutes.

A.5.4.10 The provisions required by 5.4.10 to be documented include those that are in excess of basic requirements covered by referenced codes and standards, typical design requirements, and operating procedures. It includes provisions such as more frequent periodic testing and maintenance to increase the reliability of fire protection systems, redundant systems to increase reliability, on-site guard service to enhance detection of fires and aid in fire response procedures, staff training, availability and performance of emergency response personnel, and other factors.

A.5.5 Design fire scenarios define the challenge a building is expected to withstand. Design fire scenarios capture and limit value judgments on the type and severity of the fire challenge to which a proposed fire safety system needs to respond. The system includes any and all aspects of the proposed design that are intended to mitigate the effects of a fire, such as egress system, automatic detection and suppression, barriers, staff training, and placement of manual extinguishers.

Design fire scenarios come from two sources: those that are specified in paragraphs 5.5.3.1 through 5.5.3.8 and those that are developed by the design team based on the unique characteristics of the building as required by 5.5.2. In most, if not all, cases, more than one design fire scenario will be developed to meet the requirements of 5.5.2.

Once the set of design fire scenarios is established, both those specified by 5.5.3.1 through 5.5.3.8 and those that are developed as required by 5.5.2, they need to be quantified into a format that can be used for the evaluation of proposed designs. The *SFPE Engineering Guide to Performance-Based Fire Protection Analysis and Design of Buildings* outlines a process and identifies tools and references that can be used at each step of this process.

A.5.5.2 The protection systems and features used to meet the challenge of the design fire scenario should be typical of, and consistent with, those used for other similar areas of the building. They should not be designed to be more effective in the building area addressed than in similar areas not included and that are, therefore, not explicitly evaluated.

A.5.5.3 It is desirable to consider a wide variety of different fire scenarios to evaluate the complete life safety capabilities

of the building or structure. Fire scenarios should not be limited to a single or a couple of worst-case fire scenarios.

The descriptive terms used to indicate the rate of fire growth for the scenarios are intended to be generic. Use of *t*-squared fires is not required for any scenario.

A.5.5.3.1 Scenario 1. An example of such a scenario for a health care occupancy would involve a patient room with two occupied beds with a fire initially involving one bed and the room door open. This is a cursory example in that much of the explicitly required information indicated in 5.5.3.1 can be determined from the information provided in the example. Note that it is usually necessary to consider more than one scenario to capture the features and conditions typical of an occupancy.

A.5.5.3.2 Scenario 2. Examples of such scenarios are a fire involving ignition of gasoline as an accelerant in a means of egress, clothing racks in corridors, renovation materials, or other fuel configurations that can cause an ultrafast fire. The means of egress chosen is the doorway with the largest egress capacity among doorways normally used in the ordinary operation of the building. The baseline occupant characteristics for the property are assumed. At ignition, doors are assumed to be open throughout the building.

A.5.5.3.3 Scenario 3. An example of such a scenario is a fire in a storage room adjacent to the largest occupiable room in the building. The contents of the room of fire origin are specified to provide the largest fuel load and the most rapid growth in fire severity consistent with the normal use of the room. The adjacent occupiable room is assumed to be filled to capacity with occupants. Occupants are assumed to be somewhat impaired in whatever form is most consistent with the intended use of the building. At ignition, doors from both rooms are assumed to be open. Depending on the design, doorways connect the two rooms or they connect via a common hallway or corridor.

For purposes of this scenario, an occupiable room is a room that might contain people, that is, a location within a building where people are typically found.

A.5.5.3.4 Scenario 4. An example of such a scenario is a fire originating in a concealed wall- or ceiling-space adjacent to a large, occupied function room. Ignition involves concealed combustibles, including wire or cable insulation and thermal or acoustical insulation. The adjacent function room is assumed to be occupied to capacity. The baseline occupant characteristics for the property are assumed. At ignition, doors are assumed to be open throughout the building.

A.5.5.3.5 Scenario 5. An example of such a scenario is a cigarette fire in a trash can. The trash can is close enough to room contents to ignite more substantial fuel sources but is not close enough to any occupant to create an intimate-with-ignition situation. If the intended use of the property involves the potential for some occupants to be incapable of movement at any time, the room of origin is chosen as the type of room likely to have such occupants, filled to capacity with occupants in that condition. If the intended use of the property does not involve the potential for some occupants to be incapable of movement, the room of origin is chosen to be an assembly or function area characteristic of the use of the property, and the trash can is placed so that it is shielded by furniture from suppression systems. At ignition, doors are assumed to be open throughout the building.

A.5.5.3.6 Scenario 6. An example of such a scenario is a fire originating in the largest fuel load of combustibles possible in normal operation in a function or assembly room, or in a process/manufacturing area, characteristic of the normal operation of the property. The configuration, type, and geometry of the combustibles are chosen so as to produce the most rapid and severe fire growth or smoke generation consistent with the normal operation of the property. The baseline occupant characteristics for the property are assumed. At ignition, doors are assumed to be closed throughout the building.

This scenario includes everything from a big couch fire in a small dwelling to a rack fire in combustible liquids stock in a big box retail store.

A.5.5.3.7 Scenario 7. An example of such a scenario is an exposure fire. The initiating fire is the closest and most severe fire possible consistent with the placement and type of adjacent properties and the placement of plants and combustible adornments on the property. The baseline occupant characteristics for the property are assumed.

This category includes wildlands/urban interface fires and exterior wood shingle problems, where applicable.

A.5.5.3.8 Scenario 8. This scenario addresses a set of conditions with a typical fire originating in the building with any one passive or active fire protection system or feature being ineffective. Examples include unprotected openings between floors or between fire walls or fire barrier walls, failure of rated fire doors to close automatically, shutoff of sprinkler system water supply, nonoperative fire alarm system, inoperable smoke management system, or automatic smoke dampers blocked open. This scenario should represent a reasonable challenge to the other building features provided by the design and presumed to be available.

The concept of a fire originating in ordinary combustibles is intentionally selected for this scenario. This fire, although presenting a realistic challenge to the building and the associated building systems, does not represent the worst-case scenario or the most challenging fire for the building. Examples include the following:

- (1) *A fire originating in ordinary combustibles in the corridor of a patient wing of a hospital.* Staff is assumed not to close any patient room doors upon detection of fire. The baseline occupant characteristics for the property are assumed, and the patient rooms off the corridor are assumed to be filled to capacity. At ignition, doors to patient rooms are not equipped with self-closing devices and are assumed to be open throughout the smoke compartment.
- (2) *A fire originating in ordinary combustibles in a large assembly room or area in the interior of the building.* The automatic suppression systems are assumed to be out of operation. The baseline occupant characteristics for the property are assumed, and the room of origin is assumed to be filled to capacity. At ignition, doors are assumed to be closed throughout the building.
- (3) *A fire originating in ordinary combustibles in an unoccupied small function room adjacent to a large assembly room or area in the interior of the building.* The automatic detection systems are assumed to be out of operation. The baseline occupant characteristics for the property are assumed, the room of origin is assumed to be unoccupied, and the assembly room is assumed to be filled to capacity. At ignition, doors are assumed to be closed throughout the building.

A.5.5.3.8(3) The exemption is applied to each active or passive fire protection system individually and requires two different types of information to be developed by analysis and approved by the authority having jurisdiction. System reliability is to be analyzed and accepted. Design performance in the absence of the system is also to be analyzed and accepted, but acceptable performance does not require fully meeting the stated goals and objectives. It might not be possible to meet fully the goals and objectives if a key system is unavailable, and yet no system is totally reliable. The authority having jurisdiction will determine which level of performance, possibly short of the stated goals and objectives, is acceptable, given the very low probability (that is, the system's unreliability probability) that the system will not be available.

A.5.6 The *SFPE Engineering Guide to Performance-Based Fire Protection Analysis and Design of Buildings* outlines a process for evaluating whether trial designs meet the performance criteria during the design fire scenarios.

The procedures described in Sections 5.2 and 5.4 identify required design fire scenarios among the design fire scenarios within which a proposed fire safety design is required to perform and the associated untenable conditions that are to be avoided in order to maintain life safety. Section 5.6 discusses methods that form the link from the scenarios and criteria to the goals and objectives.

Assessment methods are used to demonstrate that the proposed design will achieve the stated goals/objectives, by providing information indicating that the performance criteria of Section 5.2 can be adequately met. Assessment methods are permitted to be either tests or modeling.

Tests. Test results can be directly used to assess a fire safety design when they accurately represent the scenarios developed by using Section 5.4 and provide output data matching the performance criteria in Section 5.2. Because the performance criteria for this *Code* are stated in terms of human exposure to lethal fire effects, no test will suffice. However, tests will be needed to produce data for use in models and other calculation methods.

Standardized Tests. Standardized tests are conducted on various systems and components to determine whether they meet some predetermined, typically prescriptive criteria. Results are given on a pass/fail basis: The test specimen either does or does not meet the pre-established criteria. The actual performance of the test specimen is not usually recorded.

Scale. Tests can be either small, intermediate, or full scale. Small-scale tests are used to test activation of detection and suppression devices and the flammability and toxicity of materials. Usually, the item to be tested is placed within the testing device or apparatus. Intermediate-scale tests can be used to determine the adequacy of system components — for example, doors and windows — as opposed to entire systems. The difference between small- and intermediate-scale tests is usually one of definition provided by those conducting the test. Full-scale tests are typically used to test building and structural components or entire systems. The difference between intermediate- and large-scale tests is also subject to the definition of those performing the test. Full-scale tests are intended to most closely depict performance of the test subject as installed in the field, that is, most closely represent real world performance.

Full-scale building evacuations can provide information on how the evacuation of a structure is likely to occur for an existing building with a given population without subjecting occupants to the real physical or psychological effects of a fire.

Data Uses. The data obtained from standardized tests have three uses for verification purposes. First, the test results can be used instead of a model. This use is typically the role of full-scale test results. Second, the test results can be used as a basis for validating the model. The model predictions match well with the test results. Therefore, the model can be used in situations similar to the test scenario. Third, the test results can be used as input to models. This is typically the use of small-scale tests, specifically flammability tests.

Start-Up Test. Start-up test results can be used to demonstrate that the fire safety system performs as designed. The system design might be based on modeling. If the start-up test indicates a deficiency, the system needs to be adjusted and retested until it can be demonstrated that the design can meet the performance criteria. Typically, start-up tests apply only to the installation to which they are designed.

Experimental Data. Experimental data from nonstandardized tests can be used when the specified scenario and the experimental setup are similar. Typically, experimental data are applicable to a greater variety of scenarios than are standardized test results.

Human and Organizational Performance Tests. Certain tests determine whether inputs used to determine human performance criteria remain valid during the occupancy of a building. Tests of human and organizational performance might include any of the following:

- (1) Measuring evacuation times during fire drills
- (2) Querying emergency response team members to determine whether they know required procedures
- (3) Conducting field tests to ensure that emergency response team members can execute tasks within predetermined times and accuracy limits.

Design proposals should include descriptions of any tests needed to determine whether stated goals, objectives, and performance criteria are being met.

Modeling. Models can be used to predict the performance criteria for a given scenario. Because of the limitations on using only tests for this purpose, models are expected to be used in most, if not all, performance-based design assessments.

Fire models do not model fires: they model the effects of a (user) specified fire — that is, a heat release rate curve is input. For ease, the term *fire model* will be used instead of the more accurate *fire effects model*.

The effect of fire and its toxic products on the occupants can be modeled, as can the movement and behavior of occupants during the fire. The term *evacuation model* will be used to describe models that predict the location and movements of occupants, and the term *tenability model* will be used to describe models that predict the effects on occupants of specified levels of exposure to fire effects.

Types of Fire Models. Fire models are used to predict fire-related performance criteria. Fire models can be either probabilistic or deterministic. Several types of deterministic models are available: computational fluid dynamics (CFD or field) models, zone models, purpose-built models, and hand calculations. Probabilistic fire models are also available but are less likely to be used for this purpose.

Probabilistic fire models use the probabilities as well as the severity of various events as the basis of evaluation. Some probabilistic models incorporate deterministic models, but this is not a requirement. Probabilistic models attempt to predict the likelihood or probability that events or severity associated with an unwanted fire will occur or they predict the “ex-

pected” loss, which can be thought of as the probability-weighted average severity across all possible scenarios. Probabilistic models can be manifested as fault or event trees or other system models that use frequency or probability data as input. These models tend to be manifested as computer software, but this is not a requirement. Furthermore, the discussion that follows under “Sources of Models” can also be applied to probabilistic models, although it concentrates on deterministic models.

CFD models provide the most accurate predictions of all the deterministic models, because they divide a given space into thousands of smaller volumes. However, since they are still models, they are not absolute in their depiction of reality. In addition, they are much more expensive to use because they are computationally intensive. Because of their expense, complexity, and intensive computational needs, CFD models require much greater scrutiny than do zone models. It is much more difficult to provide multiple runs of CFD models to check sensitivity to a variety of factors such as design fire cell resolution and ventilation.

Zone models are more widely used than CFD models because they provide reasonably accurate predictions in much less time. It is much easier to assess the sensitivity of different parameters with zone models because they generally run much faster and the output is much easier to interpret. Prediction of fire growth and spread has a large number of variables associated with it. Consequently, the zone models, with their crudeness and speed, have advantages over the more complex CFD models.

Purpose-built models (also known as stand-alone models) are similar to zone models in their ease of use. However, purpose-built models do not provide a comprehensive model. Instead, they predict the value of one variable of interest. For example, such a model can predict the conditions of a ceiling jet at a specified location under a ceiling, but a zone model would “transport” those conditions throughout the enclosure.

Purpose-built models might or might not be manifested as computer software. Models that are not are referred to as hand calculations. These purpose-built models are, therefore, simple enough that the data management capabilities of a computer are not necessary. Many of these calculations are found in the *SFPE Handbook of Fire Protection Engineering*.

Types of Evacuation Models. Three categories of evacuation models can be considered: single-parameter estimation methods, movement models, and behavioral simulation models.

Single-parameter estimations are generally used for simple estimates of movement time. They are usually based on equations derived from observations of movement in nonemergency situations. They can be hand calculations or simple computer models. Examples include calculation methods for flow times based on widths of exit paths and travel times based on travel distances. Sources for these methods include the *SFPE Handbook of Fire Protection Engineering* and the *NFPA Fire Protection Handbook*.

Movement models generally handle large numbers of people in a network flow similar to water in pipes or ball bearings in chutes. They tend to optimize occupant behavior, resulting in predicted evacuation times that can be unrealistic and far from conservative. However, they can be useful in an overall assessment of a design, especially in early evaluation stages where an unacceptable result with this sort of model indicates that the design has failed to achieve the life safety objectives.

Behavioral simulation models take into consideration more of the variables related to occupant movement and behavior. Occupants are treated as individuals and can have characteristics

assigned to them uniquely, allowing a more realistic simulation of the design under consideration. However, given the limited availability of data for the development of these models, for their verification by their authors, or for input when using them, their predictive reliability is questionable.

Tenability Models. In general, tenability models will be needed only to automate calculations for the time-of-exposure effect equations referenced in A.5.2.2.

Other Models. Models can be used to describe combustion (as noted, most fire models only characterize fire effects), automatic system performance, and other elements of the calculation. There are few models in common use for these purposes, so they are not described further here.

Sources of Models. Compendia of computer fire models are found in Friedman's *Survey of Computer Models for Fire and Smoke* and the *SFPE Computer Software Directory*. Within these references are models that were developed by the Building Fire Research Laboratory of National Institute of Standards and Technology, which can be downloaded from the Internet at <http://www.bfrl.nist.gov/864/fmabs.html>. Evacuation models in all three categories are discussed in the *SFPE Handbook of Fire Protection Engineering* and the *NFPA Fire Protection Handbook*.

Validation. Models undergo limited validation. Most can be considered demonstrated only for the experimental results they were based on or the limited set of scenarios to which the model developers compared the model's output, or a combination of both.

The Society of Fire Protection Engineers has a task group that independently evaluates computer models. In January 1998, they finished their first evaluation and had chosen a second model for evaluation. Until more models can be independently evaluated, the model user has to rely on the available documentation and previous experience for guidance regarding the appropriate use of a given model.

The design professional should present the proposal, and the authority having jurisdiction, when deciding whether to approve a proposal, should consider the strength of the evidence presented for the validity, accuracy, relevance, and precision of the proposed methods. An element in establishing the strength of scientific evidence is the extent of external review and acceptance of the evidence by peers of the authors of that evidence.

Models have limitations. Most are not user-friendly. For that reason, experienced users are able to construct more reasonable models and better interpret output than are novices. For these reasons, the third-party review and equivalency sections are provided. This is not meant to discourage the use of models, only to indicate that they should be used with caution by those well-versed in their nuances.

Input Data. The first step in using a model is to develop the input data. The heat release rate curve specified by the user is the driving force of a fire effects model. If this curve is incorrectly defined, the subsequent results are not usable. In addition to the smoldering and growth phases that will be specified as part of the scenario definition, two additional phases are needed to complete the input heat release rate curve — steady burning and burnout.

Steady burning is characterized by its duration, which is a function of the total amount of fuel available to be burned. In determining the duration of this phase, the designer needs to consider how much fuel has been assumed to be consumed in the smoldering and growth phases and how much is assumed to be consumed in the burnout phase that follows. A common assumption is that the burnout phase is the mirror image of

the preceding phases, with a reversed heat release rate curve and the same amount of fuel consumed in the burnout phase as in the growth phase. Depending on the assumptions made regarding the amount of fuel consumed during burnout, the time at which this phase starts is likely to be easy to determine.

The preceding discussion assumes that the burning objects are solid (for example, tables and chairs). If liquid or gaseous fuels are involved, the shape of the curve will be different. For example, smoldering is not relevant for burning liquids or gases, and the growth period is very short, typically measured in seconds. Peak heat release rate can depend primarily on the rate of release, on the leak rate (gases and liquid sprays), or on the extent of spill (pooled liquids). The steady burning phase is once again dependent upon the amount of fuel available to burn. Like the growth phase, the burnout phase is typically short (for example, closing a valve), although it is conceivable that longer times might be appropriate, depending on the extinguishment scenario.

Material properties are usually needed for all fuel items, both initial and secondary, and the enclosure surfaces of involved rooms or spaces.

For all fires of consequence, it is reasonable to assume that the fire receives adequate ventilation. If there is insufficient oxygen, the fire will not be sustained. An overabundance of oxygen is only a concern in special cases (for example, hermetically sealed spaces) when a fire might not occur due to dilution of the fuel (that is, a flammable mixture is not produced). Therefore, given that the scenarios of interest will occur in nonhermetically sealed enclosures, it is reasonable to assume that adequate ventilation is available and that, if a fire starts, it will continue to burn until it either runs out of fuel or is extinguished by other means. The only variable that might need to be assumed is the total vent width.

Maximum fire extent is affected by two geometric aspects: burning object proximity to walls and overall enclosure dimensions.

Conservatively, when a fire is "against a wall" or "in a corner," the effective heat release of the fire can be doubled and quadrupled, respectively. For the burning object to be considered against the wall or in the corner, it needs to be either touching the enclosure surface or within 51 mm (2 in.) of the surface. The reasoning behind this convention is that a wall effectively cuts the fire plume in half, whereas a corner results in one quarter of the plume if the burning object is closer to the center of the room. Conceptually, the same amount of combustible vapors are produced, regardless of the burning object's position, but the presence of walls/corners results in a smaller volume in which to burn them. In other words, walls and corners effectively concentrate the flammable vapors resulting from pyrolysis of the fuel.

The room dimensions affect the time required for a room to flashover. For a given amount and type of fuel, under the same ventilation conditions, a small room will flashover before a large room. In a large room with a small amount of fuel, a fire will behave as if it is burning outside — that is, adequate oxygen for burning and no concentration of heat exist. If the fuel package is unchanged but the dimensions of the room are decreased, the room will begin to have an affect on the fire, assuming adequate ventilation. The presence of the relatively smaller enclosure results in the buildup of a hot layer of smoke and other products of combustion under the ceiling. This buildup, in turn, feeds more heat back to the seat of the fire, which results in an increase in the pyrolysis rate of the fuel and thus increases the amount of heat energy released by the

fire. The room enclosure surfaces themselves also contribute to this radiation feedback effect.

Probabilistic data are expressed as either a frequency (units of inverse time) or a probability (unitless, but applicable to a stated period of time). An example of the former is the expected number of failures per year and the range of the latter is between zero and one, inclusive. Probabilities can be either objective or subjective. Subjective probabilities express a degree of belief that an event will occur. Objective probabilities are based on historical data and can be expressed as a reliability of an item such as a component or a system.

A.5.6.3.3 Procedures used to develop required input data need to preserve the intended conservatism of all scenarios and assumptions. Conservatism is only one means to address the uncertainty inherent in calculations and does not remove the need to consider safety factors, sensitivity analysis, and other methods of dealing with uncertainty. The *SFPE Engineering Guide to Performance-Based Fire Protection Analysis and Design of Buildings* outlines a process for identifying and treating uncertainty.

A.5.6.4 An assessment method translates input data, which might include test specifications, parameters or variables for modeling, or other data, into output data, which are measured against the performance criteria. Computer fire models should be evaluated for their predictive capability in accordance with ASTM E 1355, *Standard Guide for Evaluating the Predictive Capability of Fire Models*.

A.5.7 The assessment of precision required in 5.8.2 will require a sensitivity and uncertainty analysis, which can be translated into safety factors.

Sensitivity Analysis. The first run a model user makes should be labeled as the base case, using the nominal values of the various input parameters. However, the model user should not rely on a single run as the basis for any performance-based fire safety system design. Ideally, each variable or parameter that the model user made to develop the nominal input data should have multiple runs associated with it, as should combinations of key variables and parameters. Thus, a sensitivity analysis should be conducted that provides the model user with data that indicate how the effects of a real fire might vary and how the response of the proposed fire safety design might also vary.

The interpretation of a model's predictions can be a difficult exercise if the model user does not have knowledge of fire dynamics or human behavior.

Reasonableness Check. The model user should first try to determine whether the predictions actually make sense, that is, whether they do not upset intuition or preconceived expectations. Most likely, if the results do not pass this test, an input error has been committed.

Sometimes the predictions appear to be reasonable but are, in fact, incorrect. For example, a model can predict higher temperatures farther from the fire than closer to it. The values themselves might be reasonable, for example, they are not hotter than the fire, but they do not "flow" down the energy as expected.

A margin of safety can be developed using the results of the sensitivity analysis in conjunction with the performance criteria to provide the possible range of time during which a condition is estimated to occur.

Safety factors and margin of safety are two concepts used to quantify the amount of uncertainty in engineering analyses.

Safety factors are used to provide a margin of safety and represent, or address, the gap in knowledge between the theoretically perfect model — reality — and the engineering models that can only partially represent reality.

Safety factors can be applied either to the predicted level of a physical condition or to the time at which the condition is predicted to occur. Thus, a physical or a temporal safety factor, or both, can be applied to any predicted condition. A predicted condition (that is, a parameter's value) and the time at which it occurs are best represented as distributions. Ideally, a computer fire model predicts the expected or nominal value of the distribution. Safety factors are intended to represent the spread of these distributions.

Given the uncertainty associated with data acquisition and reduction, and the limitations of computer modeling, any condition predicted by a computer model can be thought of as an expected or nominal value within a broader range. For example, an upper layer temperature of 600°C (1110°F) is predicted at a given time. If the modeled scenario is then tested (that is, full-scale experiment based on the computer model's input data), the actual temperature at that given time could be 640°C or 585°C (1185°F or 1085°F). Therefore, the temperature should be reported as 600°C + 40°C/–15°C (1110°F + 70°F/–25°F) or a range of 585°C to 640°C (1085°F to 1185°F).

Ideally, predictions are reported as a nominal value, a percentage, or an absolute value. As an example, an upper layer temperature prediction could be reported as "600°C (1110°F), 30°C (55°F)" or "600°C (1110°F), 5 percent." In this case, the physical safety factor is 0.05 (that is, the amount by which the nominal value should be degraded and enhanced). Given the state-of-the-art of computer fire modeling, this is a very low safety factor. Physical safety factors tend to be on the order of tens of percent. A safety factor of 50 percent is not unheard of.

Part of the problem in establishing safety factors is that it is difficult to state the percentage or range that is appropriate. These values can be obtained when the computer model predictions are compared to test data. However, using computer fire models in a design mode does not facilitate this comparison, because (1) the room being analyzed has not been built yet and (2) test scenarios do not necessarily depict the intended design.

A sensitivity analysis should be performed based on the assumptions that affect the condition of interest. A base case that uses all nominal values for input parameters should be developed. The input parameters should be varied over reasonable ranges and the variation in predicted output should be noted. This output variation can then become the basis for physical safety factors.

The temporal safety factor addresses the issue of when a condition is predicted and is a function of the rate at which processes are expected to occur. If a condition is predicted to occur 2 minutes after the start of the fire, this can be used as a nominal value. A process similar to that already described for physical safety factors can also be employed to develop temporal safety factors. In this case, however, the rates (for example, of heat release and toxic product generation) will be varied instead of absolute values (for example, material properties).

The margin of safety can be thought of as a reflection of societal values and can be imposed by the authority having jurisdiction for that purpose. Because the time for which a condition is predicted will most likely be the focus of the authority having jurisdiction (for example, the model predicts

that occupants will have 5 minutes to safely evacuate), the margin of safety will be characterized by temporal aspects and tacitly applied to the physical margin of safety.

Escaping the harmful effects of fire (or mitigating them) is, effectively, a race against time. When assessing fire safety system designs based on computer model predictions, the choice of an acceptable time is important. When an authority having jurisdiction is faced with the predicted time of untenability, a decision needs to be made regarding whether sufficient time is available to ensure the safety of building occupants. The authority having jurisdiction is assessing the margin of safety. Is there sufficient time to get everyone out safely? If the authority having jurisdiction feels that the predicted egress time is too close to the time of untenability, the authority having jurisdiction can impose an additional period of time that the designer will have to incorporate into the system design. In other words, the authority having jurisdiction can impose a greater margin of safety than that originally proposed by the designer.

A.5.8.1 The *SFPE Engineering Guide to Performance-Based Fire Protection Analysis and Design of Buildings* describes the documentation that should be provided for a performance-based design.

Proper documentation of a performance design is critical to the design acceptance and construction. Proper documentation will also ensure that all parties involved understand what is necessary for the design implementation, maintenance, and continuity of the fire protection design. If attention to details is maintained in the documentation, there should be little dispute during approval, construction, start-up, and use.

Poor documentation could result in rejection of an otherwise good design, poor implementation of the design, inadequate system maintenance and reliability, and an incomplete record for future changes or for testing the design forensically.

A.5.8.2 The sources, methodologies, and data used in performance-based designs should be based on technical references that are widely accepted and used by the appropriate professions and professional groups. This acceptance is often based on documents that are developed, reviewed, and validated under one of the following processes:

- (1) Standards developed under an open consensus process conducted by recognized professional societies, codes or standards organizations, or governmental bodies
- (2) Technical references that are subject to a peer review process and published in widely recognized peer-reviewed journals, conference reports, or other publications
- (3) Resource publications such as the *SFPE Handbook of Fire Protection Engineering*, which are widely recognized technical sources of information

The following factors are helpful in determining the acceptability of the individual method or source:

- (1) Extent of general acceptance in the relevant professional community. Indications of this acceptance include peer-reviewed publication, widespread citation in the technical literature, and adoption by or within a consensus document.
- (2) Extent of documentation of the method, including the analytical method itself, assumptions, scope, limitations, data sources, and data reduction methods.

- (3) Extent of validation and analysis of uncertainties. This includes comparison of the overall method with experimental data to estimate error rates as well as analysis of the uncertainties of input data, uncertainties and limitations in the analytical method, and uncertainties in the associated performance criteria.
- (4) Extent to which the method is based on sound scientific principles.
- (5) Extent to which the proposed application is within the stated scope and limitations of the supporting information, including the range of applicability for which there is documented validation. Factors such as spatial dimensions, occupant characteristics, and ambient conditions, can limit valid applications.

In many cases, a method will be built from, and will include, numerous component analyses. These component analyses should be evaluated using the same factors that are applied to the overall method as outlined in items (1) through (5).

A method to address a specific fire safety issue, within documented limitations or validation regimes, might not exist. In such a case, sources and calculation methods can be used outside of their limitations, provided that the design team recognizes the limitations and addresses the resulting implications.

The technical references and methodologies to be used in a performance-based design should be closely evaluated by the design team and the authority having jurisdiction, and possibly by a third-party reviewer. The strength of the technical justification should be judged using criteria in items (1) through (5). This justification can be strengthened by the presence of data obtained from fire testing.

A.5.8.11 Documentation for modeling should conform to ASTM 1472, *Standard Guide for Documenting Computer Software*, although most, if not all, models were originally developed before this standard was promulgated.

A.6.1.2.1 Assembly Occupancy. Assembly occupancies might include the following:

- (1) Armories
- (2) Assembly halls
- (3) Auditoriums
- (4) Bowling lanes
- (5) Club rooms
- (6) College and university classrooms, 50 persons and over
- (7) Conference rooms
- (8) Courtrooms
- (9) Dance halls
- (10) Drinking establishments
- (11) Exhibition halls
- (12) Gymnasiums
- (13) Libraries
- (14) Mortuary chapels
- (15) Motion picture theaters
- (16) Museums
- (17) Passenger stations and terminals of air, surface, underground, and marine public transportation facilities
- (18) Places of religious worship
- (19) Pool rooms
- (20) Recreation piers
- (21) Restaurants
- (22) Skating rinks
- (23) Special amusement buildings regardless of occupant load
- (24) Theaters

Assembly occupancies are characterized by the presence or potential presence of crowds with attendant panic hazard in case of fire or other emergency. They are generally or occasionally open to the public, and the occupants, who are present voluntarily, are not ordinarily subject to discipline or control. Such buildings are ordinarily occupied by able-bodied persons and are not used for sleeping purposes. Special conference rooms, snack areas, and other areas incidental to, and under the control of, the management of other occupancies, such as offices, fall under the 50-person limitation.

Restaurants and drinking establishments with an occupant load of fewer than 50 persons should be classified as mercantile occupancies.

For special amusement buildings, see 12.4.7 and 13.4.7.

A.6.1.3.1 Educational Occupancy. Educational occupancies include the following:

- (1) Academies
- (2) Kindergartens
- (3) Schools

An educational occupancy is distinguished from an assembly occupancy in that the same occupants are regularly present.

A.6.1.4.1 Day-Care Occupancy. Day-care occupancies include the following:

- (1) Adult day-care occupancies, except where part of a health care occupancy
- (2) Child day-care occupancies
- (3) Day-care homes
- (4) Kindergarten classes that are incidental to a child day-care occupancy
- (5) Nursery schools

In areas where public schools offer only half-day kindergarten programs, many child day-care occupancies offer state-approved kindergarten classes for children who need full-day care. Because these classes are normally incidental to the day-care occupancy, the requirements of the day-care occupancy should be followed.

A.6.1.5.1 Health Care Occupancy. Health care occupancies include the following:

- (1) Hospitals
- (2) Limited care facilities
- (3) Nursing homes

Occupants of health care occupancies typically have physical or mental illness, disease, or infirmity. They also include infants, convalescents, or infirm aged persons.

A.6.1.6.1 Ambulatory Health Care Occupancy. The intent of 6.1.6.1 is not that occupants be considered to be incapable of self-preservation just because they are in a wheelchair or use assistive walking devices such as a cane, a walker, or crutches. It is the intent to address emergency care centers that receive patients who have been rendered incapable of self-preservation due to the emergency, such as being rendered unconscious as a result of an accident or being unable to move oneself due to sudden illness.

A.6.1.7.1 Detention and Correctional Occupancy. Detention and correctional occupancies include the following:

- (1) Adult and juvenile substance abuse centers
- (2) Adult and juvenile work camps
- (3) Adult community residential centers

- (4) Adult correctional institutions
- (5) Adult local detention facilities
- (6) Juvenile community residential centers
- (7) Juvenile detention facilities
- (8) Juvenile training schools

A.6.1.7.2 Chapter 22 and Chapter 23 address the residential housing areas of the detention and correctional occupancy as defined in 3.3.152.5. Examples of uses other than residential housing include gymnasiums or industries.

A.6.1.8.1.1 One- and Two-Family Dwelling. The definition of *one- and two-family dwelling* states that each dwelling unit can be "occupied by members of a single family with not more than three outsiders." The *Code* does not define the term *family*. The definition of family is subject to federal, state, and local regulations and might not be restricted to a person or a couple (two people) and their children. The following examples aid in differentiating between a single-family dwelling and a lodging or rooming house:

- (1) An individual or a couple (two people) who rent a house from a landlord and then sublease space for up to three individuals should be considered a family renting to a maximum of three outsiders, and the house should be regulated as a single-family dwelling in accordance with Chapter 24.
- (2) A house rented from a landlord by an individual or a couple (two people) in which space is subleased to four or more individuals, but not more than 16, should be considered and regulated as a lodging or rooming house in accordance with Chapter 26.
- (3) A residential building that is occupied by four or more individuals, but not more than 16, each renting from a landlord, without separate cooking facilities, should be considered and regulated as a lodging or rooming house in accordance with Chapter 26.

A.6.1.8.1.3 Hotel. So-called apartment hotels should be classified as hotels because they are potentially subject to the same transient occupancy as hotels. Transients are those who occupy accommodations for less than 30 days.

A.6.1.8.1.4 Dormitory. Rooms within dormitories intended for the use of individuals for combined living and sleeping purposes are guest rooms or guest suites. Examples of dormitories include college dormitories, fraternity and sorority houses, and military barracks.

A.6.1.9.1 Residential Board and Care Occupancy. The following are examples of facilities classified as residential board and care occupancies:

- (1) A group housing arrangement for physically or mentally handicapped persons who normally attend school in the community, attend worship in the community, or otherwise use community facilities
- (2) A group housing arrangement for physically or mentally handicapped persons who are undergoing training in preparation for independent living, for paid employment, or for other normal community activities
- (3) A group housing arrangement for the elderly that provides personal care services but that does not provide nursing care
- (4) Facilities for social rehabilitation, alcoholism, drug abuse, or mental health problems that contain a group housing arrangement and that provide personal care services but do not provide acute care
- (5) Assisted living facilities
- (6) Other group housing arrangements that provide personal care services but not nursing care

A.6.1.10.1 Mercantile Occupancy. Mercantile occupancies include the following:

- (1) Auction rooms
- (2) Department stores
- (3) Drugstores
- (4) Restaurants with fewer than 50 persons
- (5) Shopping centers
- (6) Supermarkets

Office, storage, and service facilities incidental to the sale of merchandise and located in the same building should be considered part of the mercantile occupancy classification.

A.6.1.11.1 Business Occupancy. Business occupancies include the following:

- (1) Air traffic control towers (ATCTs)
- (2) City halls
- (3) College and university instructional buildings, classrooms under 50 persons, and instructional laboratories
- (4) Courthouses
- (5) Dentists' offices
- (6) Doctors' offices
- (7) General offices
- (8) Outpatient clinics, ambulatory
- (9) Town halls

Doctors' and dentists' offices are included, unless of such character as to be classified as ambulatory health care occupancies as defined in 3.3.152.1.

Birth centers occupied by fewer than four patients, not including infants, at any one time; not providing sleeping facilities for four or more occupants; and not providing treatment procedures that render four or more patients, not including infants, incapable of self-preservation at any one time should be classified as business occupancies. For birth centers occupied by patients not meeting these parameters, see Chapter 18 or Chapter 19, as appropriate.

Service facilities common to city office buildings such as newsstands, lunch counters serving fewer than 50 persons, barber shops, and beauty parlors are included in the business occupancy group.

City halls, town halls, and courthouses are included in this occupancy group insofar as their principal function is the transaction of public business and the keeping of books and records. Insofar as they are used for assembly purposes, they are classified as assembly occupancies.

A.6.1.12.1 Industrial Occupancy. Industrial occupancies include the following:

- (1) Dry cleaning plants
- (2) Factories of all kinds
- (3) Food processing plants
- (4) Gas plants
- (5) Hangars (for servicing/maintenance)
- (6) Laundries
- (7) Power plants
- (8) Pumping stations
- (9) Refineries
- (10) Sawmills
- (11) Telephone exchanges

In evaluating the appropriate classification of laboratories, the authority having jurisdiction should treat each case individually based on the extent and nature of the associated hazards. Some laboratories are classified as occupancies other

than industrial; for example, a physical therapy laboratory or a computer laboratory.

A.6.1.13.1 Storage Occupancy. Storage occupancies include the following:

- (1) Barns
- (2) Bulk oil storage
- (3) Cold storage
- (4) Freight terminals
- (5) Grain elevators
- (6) Hangars (for storage only)
- (7) Parking structures
- (8) Stables
- (9) Truck and marine terminals
- (10) Warehouses

Storage occupancies are characterized by the presence of relatively small numbers of persons in proportion to the area.

A.6.1.14.1.2 Examples of uses that might be incidental to another occupancy include the following:

- (1) A newsstand (mercantile) in an office building
- (2) A giftshop (mercantile) in a hotel
- (3) A small storage area (storage) in any occupancy
- (4) Minor office space (business) in any occupancy
- (5) A maintenance area (industrial) in any occupancy

A.6.1.14.1.2(2) Examples of uses that have occupant loads below the occupancy classification threshold levels include the following:

- (1) An assembly use with fewer than 50 persons within a business occupancy
- (2) An educational use with fewer than 6 persons within an apartment building.

A.6.2.1.3 Under the provision of 6.2.1.3, any violation of the requirements of Chapter 11 through Chapter 42 for separation or protection of hazardous operation or storage would inherently involve violation of the other sections of the *Code*, unless additional egress facilities appropriate to high hazard contents were provided.

A.6.2.2.1 These classifications do not apply to the application of sprinkler protection classifications. (*See NFPA 13, Standard for the Installation of Sprinkler Systems.*)

A.6.2.2.2 Chapter 42 recognizes storage of noncombustible materials as low hazard. In other occupancies it is assumed that, even where the actual contents hazard is normally low, there is sufficient likelihood that some combustible materials or hazardous operations will be introduced in connection with building repair or maintenance, or some psychological factor might create conditions conducive to panic, so that the egress facilities cannot safely be reduced below those specified for ordinary hazard contents.

A.6.2.2.3 Ordinary hazard classification represents the conditions found in most buildings and is the basis for the general requirements of this *Code*.

The fear of poisonous fumes or explosions is necessarily a relative matter to be determined on a judgment basis. All smoke contains some toxic fire gases but, under conditions of ordinary hazard, there should be no unduly dangerous exposure during the period necessary to escape from the fire area, assuming there are proper exits.

A.6.2.2.4 High hazard contents include occupancies where flammable liquids are handled or used or are stored under conditions involving possible release of flammable vapors; where grain dust, wood flour or plastic dust, aluminum or magnesium dust, or other explosive dusts are produced; where hazardous chemicals or explosives are manufactured, stored, or handled; where cotton or other combustible fibers are processed or handled under conditions producing flammable flyings; and other situations of similar hazard.

Chapter 40 and Chapter 42 include detailed provisions on high hazard contents.

A.7.1.1 Portable ladders, rope fire escapes, and similar emergency escape devices can have a useful function in facilitating escape from burning buildings lacking adequate exits of the stairway or other standard type, but they are not the equivalent of standard exits, and their use is not in any way recognized by this *Code* as satisfying the requirements for means of egress. Furthermore, many such devices are of types unsuitable for use by aged or infirm persons or by small children. Therefore, such devices can provide a false sense of security and should not be used as an excuse for not providing standard exit facilities.

A.7.1.3.2.1(1) In existing buildings, existing walls in good repair and consisting of lath and plaster, gypsum wallboard, or masonry units can usually provide satisfactory protection for the purposes of this requirement where a 1-hour fire resistance rating is required. Further evaluation might be needed where a 2-hour fire resistance rating is required. Additional guidelines can be found in Appendix D of NFPA 914, *Code for Fire Protection of Historic Structures*, and in the *SFPE Handbook of Fire Protection Engineering*.

A.7.1.3.2.1(2) In existing buildings, existing walls in good repair and consisting of lath and plaster, gypsum wallboard, or masonry units can usually provide satisfactory protection for the purposes of this requirement where a 1-hour fire resistance rating is required. Further evaluation might be needed where a 2-hour fire resistance rating is required. Additional guidelines can be found in Appendix D of NFPA 914, *Code for Fire Protection of Historic Structures*, and in the *SFPE Handbook of Fire Protection Engineering*.

A.7.1.3.2.1(5) Means of egress from the level of exit discharge is permitted to pass through an exit stair enclosure or exit passageway serving other floors. Doors for convenience purposes and unrelated to egress also are permitted to provide access to and from exit stair enclosures and exit passageways if such doors are from corridors or normally occupied spaces.

A.7.1.3.2.3 This provision prohibits the use of exit enclosures for storage or for installation of equipment not necessary for safety. Occupancy is prohibited other than for egress, refuge, and access. The intent is that the exit enclosure essentially be “sterile” with respect to fire safety hazards.

A.7.1.4.1 See Chapters 12 through 42 for further limitations on interior wall and ceiling finish.

A.7.1.4.2 See Chapters 12 through 42 for further limitations on interior floor finish.

A.7.1.5 For the purpose of this requirement, projections include devices such as lighting equipment, emergency signaling equipment, environmental controls and equipment, security devices, signs, and decorations that are typically limited in area.

A.7.1.6.4 The foreseeable slip conditions are those that are likely to be present at the location of the walking surface during the use of the building or area. A foreseeable condition of a swimming pool deck is that it is likely to be wet.

Regarding the slip resistance of treads, it should be recognized that, when walking up or down stairs, a person’s foot exerts a smaller horizontal force against treads than is exerted when walking on level floors. Therefore, materials used for floors that are acceptable as slip resistant (as described by ASTM F 1637, *Standard Practice for Safe Walking Surfaces*) provide adequate slip resistance where used for stair treads. Such slip resistance includes the important leading edges of treads, the part of the tread that the foot first contacts during descent, which is the most critical direction of travel. If stair treads are wet, there is an increased danger of slipping, just as there is an increased danger of slipping on wet floors of similar materials. A small wash or drainage slope on exterior stair treads is, therefore, recommended to shed water. (See *Templer, J. A., The Staircase: Studies of Hazards, Falls, and Safer Design*, Cambridge, MA: MIT Press, 1992.)

A.7.1.7.2 Aside from the problems created for persons who are mobility impaired, small changes of elevations in floors are best avoided because of the increased occurrence of missteps where the presence of single steps, a series of steps, or a ramp is not readily apparent. Although small changes of elevation pose significant fall risks in the case of individual movement, they are even more undesirable where crowds traverse the area.

A contrasting marking stripe on each stepping surface can be helpful at the nosing or leading edge so that the location of each step is readily apparent, especially when viewed in descent. Such stripes should be not less than 25 mm (1 in.) but should not exceed 51 mm (2 in.) in width. Other methods could include a relatively higher level of lighting, contrasting colors, contrasting textures, highly prominent handrails, warning signs, a combination thereof, or other similar means. The construction or application of marking stripes should be such that slip resistance is consistent over the walking surface and no tripping hazard is created (see also A.7.2.2.3.3.2). Depending on the distractions of the surroundings, the familiarity of users with a particular small change of level, and especially the number of people that might be in a group traversing the change of level (thereby reducing visibility of the level changes), a strong argument can be made for the elimination of steps and ramps that might pose a risk of missteps.

A.7.1.8 Means of egress components that might require protection with guards include stairs, landings, balconies, corridors, passageways, floor or roof openings, ramps, aisles, porches, and mezzanines.

A.7.1.10.1 A proper means of egress allows unobstructed travel at all times. Any type of barrier including, but not limited to, the accumulations of snow and ice in those climates subject to such accumulations is an impediment to free movement in the means of egress.

A.7.2.1.1.3 Although 7.2.1.1.3 and 7.2.1.5.1 permit locking of means of egress doors where a building is not considered occupied, the *Code* does not intend to permit occupants to be locked beyond their control in buildings or building spaces, except for detention and correctional occupancies and health care occupancies.

A.7.2.1.2.1 Figure A.7.2.1.2.1(a) and Figure A.7.2.1.2.1(b) illustrate the method of measuring door width for purposes of calculating egress capacity.




FIGURE A.7.2.1.2.1(a) Door Width — Egress Capacity.




FIGURE A.7.2.1.2.3(a) Minimum Clear Width.




FIGURE A.7.2.1.2.1(b) Door Width — Egress Capacity with Permitted Obstructions.




FIGURE A.7.2.1.2.3(b) Minimum Clear Width with Permitted Obstructions.

A.7.2.1.2.3 Figure A.7.2.1.2.3(a) and Figure A.7.2.1.2.3(b) illustrate the method of measuring clear width for doors.

In cases where a chapter requires a door width, for example, of not less than 915 mm (36 in.), this requirement can be met by a door leaf of the minimum specified width if the term *clear width* does not appear as part of the minimum width requirement. A pair of cross-corridor doors subject to such a requirement would be judged under the following criteria:

- (1) Each door leaf is required to be not less than 915 mm (36 in.) in width.
- (2) The pair of doors is required to provide sufficient, clear, unobstructed width (which will be less than the door leaf width measurement) to handle its assigned occupant load, based on a calculation using the appropriate egress capacity factor in Table 7.3.3.1.

Where swinging doors do not open at least 90 degrees, the clear width of the doorway should be measured between the face of the door and the stop.

It is not the intent to regulate projections above the 2030-mm (80-in.) height.

A.7.2.1.4.1 Where doors are subject to two-way traffic, or where their opening can interfere with pedestrian traffic, an appropriately located vision panel can reduce the chance of accidents.

Swinging doors in horizontal or vertical rolling partitions complying with the following should be permitted in a means of egress where the following criteria are met:

- (1) The door or doors comply with 7.2.1.4.
- (2) The partition in which the doors are mounted complies with the applicable fire protection rating and closes upon smoke detection or power failure at a speed not exceeding 230 mm/s (9 in./s) and not less than 150 mm/s (6 in./s).
- (3) The doors mounted in the partition are self-closing or automatic-closing in accordance with 7.2.1.8.

A.7.2.1.4.4 The requirement of 7.2.1.4.4 is not intended to apply to the swing of cross-corridor doors such as smoke barrier doors and horizontal exits.

A.7.2.1.5.7 It is intended that the re-entry provisions apply only to enclosed exit stairs, not to outside stairs. This arrangement makes it possible to leave the stairway at such floor if the fire renders the lower part of the stair unusable during egress or if the occupants seek refuge on another floor.

A.7.2.1.5.9 Examples of devices that might be arranged to release latches include knobs, levers, and panic bars. This requirement is permitted to be satisfied by the use of conventional types of hardware, whereby the door is released by turning a lever, knob, or handle or by pushing against a panic bar, but not by unfamiliar methods of operation such as a blow to break glass. The operating devices should be capable of being operated with one hand and should not require tight grasping, tight pinching, or twisting of the wrist to operate.

A.7.2.1.5.9.3 Examples of devices that, when used with a latch, can be arranged to require not more than one additional releasing operation include night latches, dead bolts, and security chains.

A.7.2.1.5.11 Examples of devices prohibited by this requirement include locks, padlocks, hasps, bars, chains, or combinations thereof.

A.7.2.1.6.1(3) It is not the intent to require a direct physical or electrical connection between the door release device and the lock. It is the intent to allow door movement initiated by operating the door release device required in 7.2.1.5.9 as one option to initiate the irreversible process.

Several factors need to be considered in approving an increase in delay time from 15 seconds to 30 seconds. Some of those factors include occupancy, occupant density, ceiling height, fire hazards present, fire protection features provided, and the location of the delayed egress locks. An example of a location where the increase on delay time might not be approved is at an exit stair discharge door.

A.7.2.1.6.1(4) In the event that the authority having jurisdiction has permitted increased operation time, the sign should reflect the appropriate time.

A.7.2.1.8.1 Examples of doors designed to normally be kept closed include those to a stair enclosure or horizontal exit.

A.7.2.1.9 Powered doors are divided into two categories — power assisted and power operated. Power-assisted doors that conform to ANSI/BHMA A156.19, *American National Standard for Power Assist & Low Energy Power Operated Doors*, use limited power to operate the door. They require fewer safeguards as compared to full power-operated doors. These door operators are for swinging doors only. Power-operated doors that conform to ANSI/BHMA A156.10, *American National Standard for Power Operated Pedestrian Doors*, require more power to operate the door and require additional safeguards to provide protection against personal injury. Power-operated doors can be swinging, sliding, or folding doors.

A.7.2.1.9.1 An example of the type of door addressed by 7.2.1.9.1 is one actuated by a motion-sensing device upon the approach of a person.

A.7.2.1.9.1.5 Although a single power-operated door leaf located within a two-leaf opening might alone not provide more than 760 mm (30 in.) of clear width in the emergency break-out mode, where both leaves are broken out to become side-hinged, the required egress width is permitted to be provided by the width of the entire opening.

A.7.2.2.2.1(2) It is the intent of 7.2.2.2.1(2) to permit the use of Table 7.2.2.2.1(b) in existing buildings, even where there is a change in occupancy per 4.6.12. Safety improvements should be made that are reasonable and feasible at minimal cost. Improvements include removal, repair, or replacement of step coverings as described in A.7.2.2.3.5, particularly Figure A.7.2.2.3.5(e), and addition of functional handrails and guardrails in place of or in conjunction with other rails as described in 7.2.2.4.

A.7.2.2.2.4 If properly designed and constructed, stairs with winders are not necessarily more dangerous than other stairs. Attention to the following factors helps to make winders generally more effective for egress and safety. Handrails should be continuous, without breaks at newel posts, from story to story. Handrails located at a greater than normal distance from the inner turn of winders can improve safety by constraining stair users to walk on the portion of the treads providing deeper treads, which should have not less than 280 mm (11 in.) of depth. Combinations of straight flights and winders are best arranged with winders located only below the straight flight. This arrangement is best because the winders provide larger tread dimensions over much of their width than do typical treads on straight flights. A descending person will, thus, be unlikely to experience a reduction of tread depth during descent, a condition of nonuniformity that is best avoided.

A.7.2.2.3.3.2 The tripping hazard referred to in 7.2.2.3.3.2 occurs especially during descent, where the tread walking surface has projections such as strips of high-friction materials or lips from metal pan stairs that are not completely filled with concrete or other material. Tread nosings that project over adjacent treads can also be a tripping hazard. ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*, illustrates projecting nosing configurations that minimize the hazard.

Where environmental conditions (such as illumination levels and directionality or a complex visual field that draws a person's attention away from stair treads) lead to a hazardous reduction in one's ability to perceive stair treads, they should be made of a material that allows ready discrimination of the number and position of treads. In all cases, the leading edges of all treads should be readily visible during both ascent and descent. A major factor in injury-producing stair accidents and in the ability to use stairs efficiently in conditions such as egress is the clarity of the stair treads as separate stepping surfaces.

A.7.2.2.3.4 A small drainage slope for stair treads subject to wetting can improve tread slip resistance (see also A.7.2.2.3.3.2). A consistent slope to a side of the stair, where drainage is possible, might be preferable to a front-to-back slope of the treads. Providing a pitch of 10 mm/m to 21 mm/m ($\frac{1}{8}$ in./ft to $\frac{1}{4}$ in./ft) aids the shedding of water from a nominally horizontal surface.

A.7.2.2.3.5 Figure A.7.2.2.3.5(a), Figure A.7.2.2.3.5(b), Figure A.7.2.2.3.5(c), and Figure A.7.2.2.3.5(d) illustrate the method for measuring riser height and tread depth. Stairs that are covered with resilient floor coverings might need additional tread depth beyond the minimum specified in the *Code*. Any horizontal projection of resilient covering materials beyond the tread nosing and riser, such as carpet and underlayment, can interfere with users' feet and thereby reduce usable tread depth. At the tread nosing, such resilient covering materials might not be capable of providing stable support for users' feet. Generally, effective tread depth is reduced by the uncompressed thickness of such resilient coverings and might be further reduced over time if coverings are not well secured and consequently move forward at the nosings. [See Figure A.7.2.2.3.5(e).]




FIGURE A.7.2.2.3.5(a) Riser Measurement with Tread Slope to Front.




FIGURE A.7.2.2.3.5(b) Riser Measurement with Tread Slope to Back.




FIGURE A.7.2.2.3.5(c) Tread Depth.




FIGURE A.7.2.2.3.5(d) Tread Measurement with Stable Support at Leading Edge.




FIGURE A.7.2.2.3.5(e) Tread Measurement with Unstable Stepping Surface at Leading Edge.

A.7.2.2.4.1.4 The intent of this provision is to place handrails for the required egress width only, regardless of the actual width. The required egress width is provided along the natural path of travel to and from the building. Examples of this requirement are shown in Figure A.7.2.2.4.1.4. The reduced intermediate handrail spacing of 1525 mm (60 in.) along with a handrail height within the permissible height limits allows users to reach and grasp one handrail. Except as noted in 7.2.2.4.2 and 7.2.2.4.4, handrails are not required on stair landings.

A.7.2.2.4.4 Figure A.7.2.2.4.4 illustrates some of the requirements of 7.2.2.4.4.

A.7.2.2.4.4.4 Additional handrails, beyond those required by the Code, are permitted at heights other than those stipulated. For example, where children under the age of 5 are major users of a facility, an additional handrail at a height in the range of 710 mm to 810 mm (28 in. to 32 in.) might be useful. Generally, children prefer to use, and can effectively use, handrails that are located at shoulder to head height due to their developmental characteristics and their less developed balance and walking abilities. At age 3, head height ranges from 890 mm to 1015 mm (35 in. to 40 in.); shoulder height averages 735 mm (29 in.). At age 5, head height ranges from 990 mm to 1170 mm (39 in. to 46 in.); shoulder height ranges from 785 mm to 940 mm (31 in. to 37 in.).

A.7.2.2.4.4.5 This 38-mm (1½-in.) clearance assumes that the wall and other surfaces adjacent to the handrail are smooth. Where rough surfaces are used, greater clearances are recommended. Ergonomic studies suggest that not less than 57 mm (2¼ in.) is a more appropriate clearance, even to smooth surfaces. It is important to note that the 90-mm (3½-in.) projection allowance of Table 7.2.2.2.1(a) and Table 7.2.2.2.1(b) and 7.3.2.2 does not prohibit such larger clearances; the 90 mm (3½ in.) refers to stair width required for egress capacity, for example, not the actual width.

A.7.2.2.4.4.6(2) Handrails should be designed so they can be grasped firmly with a comfortable grip and so the hand can be slid along the rail without encountering obstructions. The profile of the rail should comfortably match the hand grips. For example, a round profile such as is provided by the simplest round tubing or pipe having an outside diameter of 38 mm to 51 mm (1½ in. to 2 in.) provides good graspability








FIGURE A.7.2.2.4.1.4 Assumed Natural Paths of Travel on Monumental Stairs with Various Handrail Locations.



ELEVATION VIEW (straight stair)



PLAN VIEW (return stair)

FIGURE A.7.2.2.4.4 Handrail Details.

for adults. Factors such as the use of a handrail by small children and the wall-fixing details should be taken into account in assessing handrail graspability. The most functional as well as the most preferred handrail shape and size is circular with a 38-mm (1½-in.) outside diameter (according to research conducted using adults). Handrails used predominantly by children should be designed at the lower end of the permitted dimensional range.

Handrails are one of the most important components of a stair; therefore, design excesses such as oversized wood handrail sections should be avoided unless there is a readily perceived and easily grasped handhold provided. In handrail design, it is useful to remember at all times the effectiveness of a simple round profile that allows some locking action by fingers as they curl around the handrail.

Perimeter dimension, referred to in 7.2.2.4.4.6(2), is the length of the shortest loop that wraps completely around the railing.

A.7.2.2.4.5.2(3) This reduction in required height applies only to the stair, not to the landings.

A.7.2.2.4.5.3 Vertical intermediate rails are preferred to reduce climbability.

A.7.2.2.5.2 The purpose of this provision is to protect the exterior wall of a stairway from fires in other portions of the building. If the exterior wall of the stair is flush with the building exterior wall, the fire would need to travel around 180 degrees in order to impact the stair. This has not been a problem in existing buildings, so no protection is required. However, if the angle of exposure is less than 180 degrees, protection of either the stair wall or building wall is required.

Figure A.7.2.2.5.2(a), Figure A.7.2.2.5.2(b), and Figure A.7.2.2.5.2(c) illustrate the requirement, assuming nonrated glass on the exterior wall of the stair is used.




FIGURE A.7.2.2.5.2(a) Stairway with Nonrated Exterior Wall in Same Plane as Building Exterior Wall.




FIGURE A.7.2.2.5.2(b) Stairway with Unprotected Exterior Perimeter Protruding Past Building Exterior Wall.

A.7.2.2.5.3 An example of a use with the potential to interfere with egress is storage.

A.7.2.2.5.4 Figure A.7.2.2.5.4 shows an example of a stairway marking sign.

A.7.2.2.6.2 The guards that are required by 7.1.8 and detailed in 7.2.2.4.5 will usually meet this requirement where the stair is not more than three stories high. Special architectural treatment, including application of such devices as metal or masonry screens and grilles, will usually be necessary to com-




FIGURE A.7.2.2.5.2(c) Stairway with Nonrated Exterior Wall Exposed by Adjacent Exterior Wall of Building.

**NORTH STAIR
FLOOR**

5

**SUB-BASEMENT TO 24TH FLOOR
NO ROOF ACCESS
↓
DOWN TO FIRST FLOOR
FOR EXIT DISCHARGE**

FIGURE A.7.2.2.5.4 Example of a Stairway Marking Sign.

ply with the intent of this requirement for stairs over three stories in height.

A.7.2.2.6.5 See A.7.2.2.3.4.

A.7.2.3.9.1 The design pressure differences required by 7.2.3.9.1 are based on specific gas temperatures and ceiling heights. The system is required to be approved because anticipated conditions might be different from those on which the design pressure differences were calculated and, thus, different design pressure differences might be needed. For additional information on necessary minimum design pressure differences, including calculational techniques, or maximum pressure differences across doors to ensure reasonable operating forces, see NFPA 92A, *Recommended Practice for Smoke-Control Systems*.

A.7.2.4.1.2 Example. One way to provide the required egress capacity from the upper floor of a department store building 107 m × 61 m (350 ft × 200 ft), with an occupant load of 1166 per floor, would be to furnish eight 1120-mm (44-in.) stairs. [See Figure A.7.2.4.1.2(a).]

Assume that this building is divided into two sections by a fire barrier meeting the requirements for a horizontal exit,

one 40 m × 61 m (130 ft × 200 ft) and the other 67 m × 61 m (220 ft × 200 ft), with two pairs of 1170-mm (46-in.) double egress doors, with each door providing 1120 mm (44 in.) of clear egress width [see Figure A.7.2.4.1.2(b)]. The smaller section, considered separately, will require the equivalent of three 1120-mm (44-in.) exit stairs, and the larger section will require five such exits. The horizontal exits will serve as one of the three exits required for the smaller section and two of the five exits required for the larger section. Therefore, only two 1120-mm (44-in.) exit stairs from the smaller section and three 1120-mm (44-in.) exit stairs from the larger section will be required if the exits can be arranged to meet the requirements for the 46-m (150-ft) travel distance permitted from any point in a nonsprinklered building. Thus, the total number of exit stairs required for the building will be five, as compared to eight if no horizontal exit had been provided.

Another option would be the use of two 1420-mm (56-in.) exit stairs from the larger section, which would reduce the total number of stairways required from the floor to four [see Figure A.7.2.4.1.2(c)]. However, if the building were further subdivided by a second fire wall meeting the requirements for a horizontal exit, no further reduction in stairways would be permitted in order to comply with the requirement that horizontal exits provide a maximum of one-half of egress capacity.




FIGURE A.7.2.4.1.2(a) Eight Exits, None via Horizontal Exit, Required to Provide the Necessary Egress Capacity.

A.7.2.4.3.8 For further information, see NFPA 105, *Standard for the Installation of Smoke Door Assemblies*.

A.7.2.4.3.9 Fusible link-actuated automatic-closing doors do not qualify for use in horizontal exits under these provisions, because smoke might pass through the opening before there is sufficient heat to release the hold-open device. Such doors are also objectionable because, once closed, they are difficult to open and would inhibit orderly egress.

A.7.2.5.6.1 The guards required by 7.1.8 and detailed in 7.2.2.4.5 for the unenclosed sides of ramps will usually meet this requirement where the ramp is not more than three stories high. Special architectural treatment, including application of such devices as metal or masonry screens and grilles, will usually be necessary to comply with the intent of the requirements for ramps over three stories in height.

A.7.2.5.6.2 Providing a pitch of 10 mm/m to 21 mm/m ($\frac{1}{8}$ in./ft to $\frac{1}{4}$ in./ft) will aid the shedding of water from a nominally horizontal surface.




FIGURE A.7.2.4.1.2(b) Number of Stairs Reduced by Three Through Use of Two Horizontal Exits; Egress Capacity Not Reduced.




FIGURE A.7.2.4.1.2(c) Number of Stairs Further Reduced by Widening Stairs in Larger Compartment, But Not to Less Than One-Half the Required Number and Capacity of Exits from That Compartment.

A.7.2.6 An exit passageway serves as a horizontal means of exit travel that is protected from fire in a manner similar to an enclosed interior exit stair. Where it is desired to offset exit stairs in a multistory building, an exit passageway can be used to preserve the continuity of the protected exit by connecting the bottom of one stair to the top of the stair that continues to the street floor. Probably the most important use of an exit passageway is to satisfy the requirement that at least 50 percent of the exit stairs discharge directly outside from multistory buildings (see 7.7.2). Thus, if it is impractical to locate the stair on an exterior wall, an exit passageway can be connected to the bottom of the stair to convey the occupants safely to an outside exit door. In buildings of extremely large area, such as shopping malls and some factories, the exit passageway can be used to advantage where the travel distance to reach an exit would otherwise be excessive.

A.7.2.6.1 Examples of building elements that might be arranged as exit passageways include hallways, corridors, passages, tunnels, underfloor passageways, or overhead passageways.

A.7.2.6.4(1) Where an exit passageway serves occupants on the level of exit discharge as well as other floors, it should not be required that the occupant loads be added, thus increasing

the width of the exit passageway. The situation is the same as that in which occupants from the level of exit discharge join occupants from upper floors for a few feet of horizontal travel through a stair enclosure.

A.7.2.8.7 Swinging stairs, although superior to fire escape ladders, are generally unsatisfactory, even for emergency use. Although such stairs are permitted by this *Code*, they should not be used where it is reasonably possible to terminate the fire escape stair at the ground.

A.7.2.8.7.9 A latch is desirable for holding swinging stairs down after they have swung to the ground.

A.7.2.11 Special consideration should be given prior to the application of such devices where children, the elderly, or physically disabled persons use such devices. These devices present obstacles in ascent and descent that differ from those for stairs and ladders.

A.7.2.12.2.3 The clear width of not less than 1220 mm (48 in.) is needed for a three-person carry of an occupied wheelchair up or down a stair. This procedure, as well as the more difficult two-person wheelchair carry or roll, requires training and experience. Safer, alternative stair descent measures for transporting a person who normally requires a wheelchair include evacuation chairs and self-braking stair descent devices. In addition to having such devices available where needed, and having persons trained and experienced in their use, it is important to have people trained and experienced in wheelchair transfer techniques.

In view of the logistical difficulties as well as the dangers inherent in carrying occupied wheelchairs or otherwise transporting their occupants on stairs, the preferred means of egress from an area of refuge consists of facilities normally employed for ingress and egress by people using wheelchairs. Foremost among these options are elevators meeting the fire-fighter service requirements of ASME A17.1, *Safety Code for Elevators and Escalators*.

A.7.2.12.2.4 The use of elevators for egress, especially during an emergency such as a fire, is not an approach to be taken without considerable planning, ongoing effort, and a high degree of understanding by everyone involved with the evacuation of persons with mobility impairments. Due in part to the limited capacity of elevators, as well as to the conflicting demands for elevator use for fire-fighting activities, even elevators in accordance with 7.2.12.2.4 cannot be considered as satisfying any of the *Code's* requirements for egress capacity, number of means of egress, or travel distance to an exit.

A.7.2.12.2.6 The instructions should include the following:

- (1) Directions to find other means of egress
- (2) Advice that persons able to use exit stairs do so as soon as possible, unless they are assisting others
- (3) Information on planned availability of assistance in the use of stairs or supervised operation of elevators and how to summon such assistance
- (4) Directions for use of the emergency communication system

To facilitate an adequate degree of understanding of the use of areas of refuge and of the associated assisted egress procedures, information should be provided to those using the facilities. The exact content of the information, its organization (for example, as a set of instructions), and its format (for example, either posted instructions in the area of refuge or information otherwise transmitted to facility users) should

be determined on a case-by-case basis. The information should be tailored to the specific facility, its emergency plan, the intended audience, and the intended presentation format. The following provides suggested information content addressing two situations.

- (1) *Refuge with Elevator Use.* An area of refuge provided in the elevator lobby serves as a staging area for persons unable to use stairs and needing assistance for their evacuation during an emergency. The elevator(s) will be taken out of automatic service and operated by emergency service personnel. Persons unable to evacuate down the exit stairs without assistance and needing transportation by elevator should make certain the elevator lobby doors are closed while they wait in the elevator lobby for assistance. The two-way communication system should be used if there is a delay of more than several minutes in the arrival of an elevator that will provide transportation to the ground floor. Alternatively, another refuge area, and assistance with evacuation, is available in the designated exit stair.
- (2) *Refuge with Stair Use.* An area of refuge within the designated exit stair serves as a staging area for persons needing assistance for their evacuation during an emergency. Persons unable to use the stairs unassisted, or who wish to move down the stairs at a slower pace, should wait on the stair landing. The two-way communication system should be used if assistance is needed.

A.7.2.12.3.1 Figure A.7.2.12.3.1 illustrates the application of the minimum space requirement to an area of refuge located within an exit stair enclosure. Note that each of the two required spaces is sufficient to allow the parking of a standard wheelchair. Preferably, such spaces should be provided adjacent to each other in a location where the presence of people taking temporary shelter in an area of refuge will be immediately apparent to rescue personnel and other evacuees.




FIGURE A.7.2.12.3.1 Exit Stair Used as an Area of Refuge.

A.7.2.12.3.2 The method of meeting the tenability performance criteria required of an area of refuge of less than 93 m² (1000 ft²) can involve controlling the exposing fire (for example, via automatic sprinkler protection), installing smoke-resisting doors in the smoke-resisting barriers (see NFPA 105, *Standard for the Installation of Smoke Door Assemblies*), providing smoke control to prevent or limit smoke migration through cracks or other leakage paths (see NFPA 92A, *Recommended Practice for Smoke-Control Systems*), or providing other means or a combination of these means.

Calculations, if used, need to be based on established engineering relationships and equations. Such calculational procedures are described in NFPA 92A, *Recommended Practice for Smoke-Control Systems*, and the *SFPE Handbook of Fire Protection Engineering*. Tenable conditions are those that maintain the

temperature of any smoke in the area of refuge at less than 93°C (200°F) if the smoke is more than 1525 mm (60 in.) above the floor, and at less than 49°C (120°F) if the smoke descends below the 1525 mm (60 in.) level in the area of refuge. Also, if the smoke descends below the 1525 mm (60 in.) level, tenable conditions require not less than 16 percent oxygen and not more than 30,000 ppm/min exposure to carbon monoxide. The exposing conditions used in the calculations should be in accordance with the following:

- (1) The exposing space is sprinkler protected: the temperature of the exposing smoke is 93°C (200°F), the smoke layer extends to the floor, the oxygen content is 16 percent, and the carbon monoxide concentration is 2000 ppm (0.2 percent).
- (2) The exposing space is a nonsprinklered corridor finished with Class A interior wall and ceiling finish: the temperature of the exposing smoke is 316°C (600°F), the smoke layer extends to a level 610 mm (24 in.) above the floor, the oxygen content is 3 percent, and the carbon monoxide concentration is 50,000 ppm (5 percent).
- (3) The exposing space is either not a corridor or, if a corridor, the corridor is not finished with a Class A interior wall and ceiling finish: the temperature of the exposing smoke is 815°C (1500°F), the smoke layer extends to a level 610 mm (24 in.) above the floor, the oxygen content is 3 percent, and the carbon monoxide concentration is 50,000 ppm (5 percent).

A.7.2.12.3.4 Requirements for fire resistance ratings in excess of 1 hour, fire protection ratings in excess of 20 minutes, and prohibitions on duct penetrations appear in other *Code* sections. For example, if the barrier creating the area of refuge is also part of an exit stair enclosure that connects more than three stories or is a horizontal exit, a fire resistance rating of the barrier of not less than 2 hours and a fire protection rating for opening protectives such as doors of not less than 1½ hours would be required for most occupancies.

For further information on door openings in smoke-resisting barriers, see NFPA 105, *Standard for the Installation of Smoke Door Assemblies*.

Generally, by providing one barrier that subdivides a floor area, two areas of refuge can be created. This subdivision method and the possibility of creating areas of refuge within compartmented elevator lobbies or on enlarged stair landings of exit stair enclosures make less onerous any requirement for a story to have more than one accessible means of egress.

A.7.2.13.1 It is the intent of 7.2.13.1 that elevators serving as a means of egress serve only independent towers or the tower portion of any integral structure. For elevators that are used as a component in the means of egress, the elevator lobbies, elevator shaft, and machine room need to be protected from the effects of fire.

A.7.2.13.6 One or more of the following approaches can be used to restrict exposure of elevator equipment to water:

- (1) A combination of sealed elevator lobby doors, sloped floors, floor drains, and sealed elevator shaft walls is used.
- (2) The elevator is mounted on the building exterior that normally operates in the elements, and seals are used on the elevator lobby doors.
- (3) The elevator shaft is separated from the building at each floor by an exterior elevator lobby designed to prevent water entry into the elevator shaft.

Information gained from ongoing research concerning waterflow and elevators could lead to the development of water-resistant or water-protected elevator equipment specifically for fire applications. Such equipment should be used only with the building elements (for example, sealed elevator lobby doors, sloped floors, floor drains) for which it is developed. Further information is available from the NIST publication, *Feasibility of Fire Evacuation by Elevators at FAA Control Towers*.

A.7.2.13.7 Cooling equipment dedicated to the elevator machine room can be used to minimize requirements for standby power.

A.7.2.13.8 Communication between elevator lobbies and a central control point can be by telephone or intercom. Auditory alarms should be designed so that they do not interfere with people talking on communications systems.

A.7.2.13.9 Smoke detection in the elevator lobby will result in a Phase I recall of the elevators. The elevators will then be automatically taken out of normal service and will be available to be operated by emergency service personnel.

A.7.3.1.2 The normal occupant load is not necessarily a suitable criterion, because the greatest hazard can occur when an unusually large crowd is present, which is a condition often difficult for authorities having jurisdiction to control by regulatory measures. The principle of this *Code* is to provide means of egress for the maximum probable number of occupants rather than to attempt to limit occupants to a number commensurate with available means of egress. However, limits of occupancy are specified in certain special cases for other reasons.

Suggested occupant load factors for components of large airport terminal buildings are given in Table A.7.3.1.2. However, the authority having jurisdiction might elect to use different occupant load factors, provided that egress requirements are satisfied.

Table A.7.3.1.2 Airport Terminal Occupant Load Factors

Airport Terminal Area	m ² (gross)	ft ² (gross)
Concourse	9.3	100
Waiting areas	1.4	15
Baggage claim	1.9	20
Baggage handling	27.9	300

Mall Buildings. The figure used in determining the occupancy load for mall shopping centers of varying sizes was arrived at empirically by surveying over 270 mall shopping centers, by studying mercantile occupancy parking requirements, and by observing the number of occupants per vehicle during peak seasons.

These studies show that, with an increase in shopping center size, there is a decrease in the number of occupants per square foot of gross leasable area.

This phenomenon is explained when one considers that above a certain shopping center gross leasable area [approximately 56,000 m² (600,000 ft²)], there exists a multiplicity of the same types of stores. The purpose of duplicate types of stores is to increase the choices available to a customer for any given type of merchandise. Therefore, when shopping center size increases, the occupant load increases as well, but at a

declining rate. In using Table 7.3.1.2, the occupant load factor is applied only to the gross leasable area that uses the mall as a means of egress.

A.7.3.4.1.1 The criteria of 7.3.4.1.1 provide for minimum widths for small spaces such as individual offices. The intent is that these reductions in required width apply to spaces formed by furniture and movable walls so that accommodations can easily be made for mobility-impaired individuals. One side of a path could be a fixed wall, provided that the other side is movable. This does not exempt the door widths or widths of fixed-wall corridors, regardless of the number of people or length.

Figure A.7.3.4.1.1(a) and Figure A.7.3.4.1.1(b) present selected anthropometric data for adults. The male and female figures depicted in the figure are average, 50th percentile, in size. Some dimensions apply to very large, 97.5 percentile, adults (noted as 97.5 P).

A.7.5.1.1.1 See A.7.5.1.5.

A.7.5.1.3.2 Figure A.7.5.1.3.2(a) through Figure A.7.5.1.3.2(e) illustrate the method of measurement intended by 7.5.1.3.2.

A.7.5.1.4.2 It is difficult in actual practice to construct scissor stairs so that products of combustion that have entered one stairway do not penetrate into the other. Use as separate required exits is discouraged. The term *limited-combustible* is intentionally not included in 7.5.1.4.2. The user's attention is directed to the definitions of *limited-combustible* and *noncombustible* in 3.3.135.2 and 3.3.135.3, respectively.

A.7.5.1.5 The terms *dead end* and *common path of travel* are commonly used interchangeably. Although the concepts of each are similar in practice, they are two different concepts.

A common path of travel exists where a space is arranged so that occupants within that space are able to travel in only one direction to reach any of the exits or to reach the point at which the occupants have the choice of two paths of travel to remote exits. Part (a) of Figure A.7.5.1.5 is an example of a common path of travel.

While a dead end is similar to a common path of travel, a dead end can exist where there is no path of travel from an occupied space but can also exist where an occupant enters a corridor thinking there is an exit at the end and, finding none, is forced to retrace his or her path to reach a choice of exits. Part (b) of Figure A.7.5.1.5 is an example of such a dead-end arrangement.

Combining the two concepts, part (c) of Figure A.7.5.1.5 is an example of a combined dead-end/common path of travel problem.

Common paths of travel and dead-end travel are measured using the same principles used to measure travel distance as described in Section 7.6 of the *Code*. Starting in the room shown in part (d) of Figure A.7.5.1.5, measurement is made from the most remote point in the room, A, along the natural path of travel, and through the doorway along the centerline of the corridor to point C, located at the centerline of the corridor, which then provides the choice of two different paths to remote exits; this is common path of travel. The space between point B and point C is a dead end. (See 3.3.34 for the definition of *common path of travel*.)

A.7.5.2.2 Doors that lead through wall paneling and that harmonize in appearance with the rest of the wall to avoid detracting from some desired aesthetic or decorative effect are not acceptable, because casual occupants might not be aware of such means of egress even though it is visible.

A.7.5.4.1 An accessible means of egress should comply with the accessible route requirements of ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*.

A.7.6 Table A.7.6 is a compilation of the requirements of the individual occupancy chapters (Chapters 12 through 42) for permissible length of common path of travel, dead-end corridors, and travel distance to not less than one of the required exits.

A dead end exists where an occupant enters a corridor thinking there is an exit at the end and, finding none, is forced to retrace the path traveled to reach a choice of egress travel paths. Although relatively short dead ends are permitted by this *Code*, it is better practice to eliminate them wherever possible, as they increase the danger of persons being trapped in case of fire. Compliance with the dead-end limits does not necessarily mean that the requirements for remoteness of exits have been met. Such lack of compliance is particularly true in small buildings or buildings with short public hallways. Adequate remoteness can be obtained in such cases by further reducing the length of dead ends. (See also A.7.5.1.5.)

A.7.6.1 The natural exit access (path of travel) is influenced by the contents and occupancy of the building. Furniture, fixtures, machinery, or storage can serve to increase the length of travel. It is good practice in building design to recognize the influence of contents and occupancy by spacing exits for a completely open floor area at closer intervals than is required, thus reducing the hazard of excessive travel distances due to the introduction of furniture, fixtures, machinery, or storage and minimizing the possibility of violating the travel distance requirements of this *Code*.

A.7.6.2 Examples of locations where open stairways might exist include between mezzanines or balconies and the floor below.

A.7.7.1 An exit from the upper stories in which the direction of egress travel is generally downward should not be arranged so that it is necessary to change to travel in an upward direction at any point before discharging to the outside. A similar prohibition of reversal of the vertical component of travel should be applied to exits from stories below the floor of exit discharge. However, an exception is permitted in the case of stairs used in connection with overhead or underfloor exit passageways that serve the street floor only.

It is important that ample roadways be available from buildings in which there are large numbers of occupants so that exits will not be blocked by persons already outside. Two or more avenues of departure should be available for all but very small places. Location of a larger theater — for example, on a narrow dead-end street — might be prohibited by the authority having jurisdiction under this rule, unless some alternate way of travel to another street is available.

Exterior walking surfaces within the exit discharge are not required to be paved and often are provided by grass or similar surfaces. Where discharging exits into yards, across lawns, or onto similar surfaces, in addition to providing the required width to allow all occupants safe access to a public way, such access also is required to meet the following:

- (1) The provisions of 7.1.7 with respect to changes in elevation
- (2) The provisions of 7.2.2 for stairs, as applicable
- (3) The provisions of 7.2.5 for ramps, as applicable
- (4) The provisions of 7.1.10 with respect to maintaining the means of egress free of obstructions that would prevent its use, such as snow and the need for its removal in some climates




FIGURE A.7.3.4.1.1(a) Anthropometric Data (in mm) for Adults; Male and Female Figures of Average, 50th Percentile, Size, Some Dimensions Apply to Very Large, 97.5 Percentile (97.5 P), Adults.




FIGURE A.7.3.4.1.1(b) Anthropometric Data (in in.) for Adults; Male and Female Figures of Average, 50th Percentile, Size, Some Dimensions Apply to Very Large, 97.5 Percentile (97.5 P), Adults.




FIGURE A.7.5.1.3.2(a) Diagonal Rule for Exit Remoteness.




FIGURE A.7.5.1.3.2(b) Diagonal Rule for Exit and Exit Access Remoteness.




FIGURE A.7.5.1.3.2(c) Exit Separation and Diagonal Measurement of Area Served.




FIGURE A.7.5.1.3.2(d) Exit Separation Measured Along Corridor Path.




FIGURE A.7.5.1.3.2(e) Diagonal Measurement for Unusually Shaped Areas.




FIGURE A.7.5.1.5 Common Paths of Travel and Dead-End Corridors.

A.7.8.1.1 Illumination provided outside the building should be to either a public way or a distance away from the building that is considered safe, whichever is closest to the building being evacuated.

A.7.8.1.3 A desirable form of means of egress lighting is by lights recessed in walls about 305 mm (12 in.) above the floor. Such lights are not likely to be obscured by smoke.

A.7.8.1.3(4) Some processes, such as manufacturing or handling of photosensitive materials, cannot be performed in areas provided with the minimum specified lighting levels. The use of spaces with lighting levels below 10.8 lux (1 ft-candle) might necessitate additional safety measures, such as written emergency plans, training of new employees in emergency evacuation procedures, and periodic fire drills.

A.7.8.1.4 An example of the failure of any single lighting unit is the burning out of an electric bulb.

A.7.8.2.1 An example of a power source with reasonably ensured reliability is a public utility electric service.

Table A.7.6 Common Path, Dead-End, and Travel Distance Limits (by occupancy)

Type of Occupancy	Common Path Limit				Dead-End Limit				Travel Distance Limit			
	Unsprinklered		Sprinklered		Unsprinklered		Sprinklered		Unsprinklered		Sprinklered	
	m	(ft)	m	(ft)	m	(ft)	m	(ft)	m	(ft)	m	(ft)
Assembly												
New	6.1/23 ^a	(20/75)	6.1/23 ^a	(20/75)	6.1 ^b	(20)	6.1 ^b	(20)	45 ^c	(150)	76 ^c	(250)
Existing	6.1/23 ^a	(20/75)	6.1/23 ^a	(20/75)	6.1 ^b	(20)	6.1 ^b	(20)	45 ^c	(150)	76 ^c	(250)
Educational												
New	23	(75)	30	(100)	6.1	(20)	15	(50)	45	(150)	60	(200)
Existing	23	(75)	30	(100)	6.1	(20)	15	(50)	45	(150)	60	(200)
Day Care												
New	23	(75)	30	(100)	6.1	(20)	15	(50)	45 ^d	(150)	60 ^d	(200)
Existing	23	(75)	30	(100)	6.1	(20)	15	(50)	45 ^d	(150)	60 ^d	(200)
Health Care												
New	NR	NR	NR	NR	9.1	(30)	9.1	(30)	NA	NA	60 ^d	(200)
Existing	NR	NR	NR	NR	NR	NR	NR	NR	45 ^d	(150)	60 ^d	(200)
Ambulatory Health Care												
New	23 ^e	(75)	30 ^e	(100)	6.1	(20)	15	(50)	45 ^d	(150)	60 ^d	(200)
Existing	23 ^e	(75)	30 ^e	(100)	15	(50)	15	(50)	45 ^d	(150)	60 ^d	(200)
Detention and Correctional												
New — Use conditions II, III, IV	15	(50)	30	(100)	15	(50)	15	(50)	45 ^d	(150)	60 ^d	(200)
New — Use condition V	15	(50)	30	(100)	6.1	(20)	6.1	(20)	45 ^d	(150)	60 ^d	(200)
Existing — Use conditions II, III, IV, V	15 ^f	(50)	30 ^f	(100)	NR	NR	NR	NR	45 ^d	(150)	60 ^d	(200)
Residential												
One- and two-family dwellings	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
Lodging or rooming houses	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
Hotels and dormitories												
New	10.7 ^{g,i}	(35)	15 ^{g,i}	(50)	10.7	(35)	15	(50)	53 ^{d,h}	(175)	99 ^{d,h}	(325)
Existing	10.7 ^g	(35)	15 ^g	(50)	15	(50)	15	(50)	53 ^{d,h}	(175)	99 ^{d,h}	(325)
Apartments												
New	10.7 ^g	(35)	15 ^g	(50)	10.7	(35)	15	(50)	53 ^{d,h}	(175)	99 ^{d,h}	(325)
Existing	10.7 ^g	(35)	15 ^g	(50)	15	(50)	15	(50)	53 ^{d,h}	(175)	99 ^{d,h}	(325)
Board and care												
Small, new and existing	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
Large, new	NA	NA	38 ⁱ	(125)	NA	NA	15	(50)	NA	NA	99 ^{d,h}	(325)
Large, existing	33	(110)	49	(160)	15	(50)	15	(50)	53 ^{d,h}	(175)	99 ^{d,h}	(325)
Mercantile												
Class A, B, C												
New	23	(75)	30	(100)	6.1	(20)	15	(50)	46	(150)	76	(250)
Existing	23	(75)	30	(100)	15	(50)	15	(50)	46	(150)	76	(250)
Open air	NR	NR	NR	NR	0	(0)	0	(0)	NR	NR	NR	NR
Mall												
New	23	(75)	30	(100)	6.1	(20)	15	(50)	46	(150)	120 ^j	(400)
Existing	23	(75)	30	(100)	15	(50)	15	(50)	46	(150)	120 ^j	(400)
Business												
New	23 ^k	(75)	30 ^k	(100)	6.1	(20)	15	(50)	60	(200)	91	(300)
Existing	23 ^k	(75)	30 ^k	(100)	15	(50)	15	(50)	60	(200)	91	(300)

Table A.7.6 *Continued*

Type of Occupancy	Common Path Limit				Dead-End Limit				Travel Distance Limit			
	Unsprinklered		Sprinklered		Unsprinklered		Sprinklered		Unsprinklered		Sprinklered	
	m	(ft)	m	(ft)	m	(ft)	m	(ft)	m	(ft)	m	(ft)
Industrial												
General	15	(50)	30	(100)	15	(50)	15	(50)	60 ⁿ	(200)	75 ^l	(250)
Special purpose	15	(50)	30	(100)	15	(50)	15	(50)	91	(300)	122	(400)
High hazard	0	(0)	0	(0)	0	(0)	0	(0)	0	(0)	23	(75)
Aircraft servicing hangars, ground floor	15 ^m	(50)	30 ^m	(100)	15 ^m	(50)	15 ^m	(50)	note n	note n	note n	note n
Aircraft servicing hangars, mezzanine floor	15 ^m	(50)	23 ^m	(75)	15 ^m	(50)	15 ^m	(50)	23	(75)	23	(75)
Storage												
Low hazard	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR
Ordinary hazard	15	(50)	30	(100)	15	(50)	30	(100)	60	(200)	122	(400)
High hazard	0	(0)	0	(0)	0	(0)	0	(0)	23	(75)	30	(100)
Parking structures, open	15	(50)	15	(50)	15	(50)	15	(50)	91	(300)	122	(400)
Parking structures, enclosed	15	(50)	15	(50)	15	(50)	15	(50)	45	(150)	60	(200)
Aircraft storage hangars, ground floor	15 ^m	(50)	30 ^m	(100)	15 ^m	(50)	15 ^m	(50)	note n	note n	note n	note n
Aircraft servicing hangars, mezzanine floor	15 ^m	(50)	23 ^m	(75)	15 ^m	(50)	15 ^m	(50)	23	(75)	23	(75)
Underground spaces in grain elevators	15 ^m	(50)	30 ^m	(100)	15 ^m	(50)	30 ^m	(100)	60	(200)	122	(400)

NA: Not applicable.

NR: No requirement.

^a6.1 m (20 ft) for common path serving >50 persons; 23 m (75 ft) for common path serving ≤50 persons.

^b6.1-m (20-ft) Dead-end corridors permitted; 6.1-m (20-ft) dead-end aisles permitted.

^cSee Chapter 12 and Chapter 13 for special considerations for smoke-protected assembly seating in arenas and stadia.

^dThis dimension is for the total travel distance, assuming incremental portions have fully utilized their permitted maximums. For travel distance within the room, and from the room exit access door to the exit, see the appropriate occupancy chapter.

^eSee business occupancies, Chapter 38 and Chapter 39.

^fSee Chapter 23 for special considerations for existing common paths.

^gThis dimension is from the room/corridor or suite/corridor exit access door to the exit; thus, it applies to corridor common path.

^hSee appropriate occupancy chapter for special travel distance considerations for exterior ways of exit access.

ⁱSee appropriate occupancy chapter for requirement for second exit access based on room area.

^jSee 36.4.4 and 37.4.4 for special travel distance considerations in covered malls considered pedestrian ways.

^kSee Chapter 38 and Chapter 39 for special common path considerations for single tenant spaces.

^lSee Chapter 40 for industrial occupancy special travel distance considerations.

^mSee Chapter 40 and Chapter 42 for special requirements if high hazard.

ⁿSee Chapter 40 and Chapter 42 for special requirements on spacing of doors in aircraft hangars.

A.7.9.1.1 Emergency lighting provided outside the building should be to either a public way or a distance away from the building that is considered safe, whichever is closest to the building being evacuated.

A.7.9.2.1 The illumination uniformity ratio is determined by the following formula:

$$\frac{\text{Maximum illumination at any point}}{\text{Minimum illumination at any point}}$$

A.7.9.2.2 Where approved by the authority having jurisdiction, this requirement is permitted to be met by means such as the following.

- (1) Two separate electric lighting systems with independent wiring, each adequate alone to provide the specified lighting. One such system is permitted to be supplied from an outside source such as a public utility service and the other from an electric generator on the premises driven by an independent source of power. Both sources of illumination should be in regular simultaneous operation whenever the building is occupied during periods of darkness.

- (2) An electric circuit or circuits used only for means of egress illumination, with two independent electric sources arranged so that, on the failure of one, the other will automatically and immediately operate. One such source is permitted to be a connection from a public utility or similar outside power source and the other an approved storage battery with suitable provision to keep it automatically charged. Such a battery should be provided with automatic controls that, after operation of the battery due to failure of the primary power source or to turn-off the primary electric source for the lights, the battery will be shut off after its specified period of operation and will be automatically recharged and ready for further service when the primary current source is turned on again.
- (3) Electric battery-operated emergency lighting systems complying with the provisions of 7.9.2.2 and operating on a separate circuit and at a voltage different from that of the primary light can be used where permitted. (See NFPA 70, *National Electrical Code*®.)

These requirements are not intended to prohibit the connection of a feeder serving exit lighting and similar emergency functions ahead of the service disconnecting means, but such provision does not constitute an acceptable alternate source of power. Such a connection furnishes only supplementary protection for emergency electrical functions, particularly where intended to allow the fire department to open the main disconnect without hampering exit activities. Provision should be made to alert the fire department that certain power and lighting is fed by an emergency generator and will continue operation after the service disconnect is opened.

Where emergency lighting is provided by automatic transfer between normal power service and an emergency generator, it is the intent to prohibit the installation, for any reason, of a single switch that can interrupt both energy sources.

A.7.9.2.4 Automobile-type lead storage batteries are not suitable by reason of their relatively short life when not subject to frequent discharge and recharge as occurs in automobile operation.

For proper selection and maintenance of appropriate batteries, see NFPA 70, *National Electrical Code*®.

A.7.10.1.2 Where a main entrance serves also as an exit, it will usually be sufficiently obvious to occupants so that no exit sign is needed.

The character of the occupancy has a practical effect on the need for signs. In any assembly occupancy, hotel, department store, or other building subject to transient occupancy, the need for signs will be greater than in a building subject to permanent or semipermanent occupancy by the same people, such as an apartment house where the residents are presumed to be familiar with exit facilities by reason of regular use thereof. Even in a permanent residence-type building, however, there is need for signs to identify exit facilities such as outside stairs that are not subject to regular use during the normal occupancy of the building.

There are many types of situations where the actual need for signs is debatable. In cases of doubt, however, it is desirable to be on the safe side by providing signs, particularly because posting signs does not ordinarily involve any material expense or inconvenience.

The requirement for the locations of exit signs visible from any direction of exit access is illustrated in Figure A.7.10.1.2.

A.7.10.1.5.2 For externally illuminated signs in accordance with 7.10.6 and internally illuminated signs listed without a




FIGURE A.7.10.1.2 Location of Exit Signs.

viewing distance, the rated viewing distance should be considered to be 30 m (100 ft). However, placing signs to meet the 30 m (100 ft) viewing distance in other than exit access corridors might create operating difficulties or encourage placement of a sign above the line of sight. To resolve the viewing distance versus placement issue, consideration should be given to increasing the level of illumination and the size of the exit legend to the viewing distance proportionally if signs are placed at greater distances.

A.7.10.1.6 See A.7.10.3.

A.7.10.1.7 See 3.3.114.2 for definition of *internally illuminated*.

A.7.10.1.8 In stores, for example, an otherwise adequate exit sign could be rendered inconspicuous by a high-intensity illuminated advertising sign located in the immediate vicinity.

Red is the traditional color for exit signs and is required by law in many places. However, at an early stage in the development of the *Code*, a provision made green the color for exit signs, following the concept of traffic lights in which green indicates safety and red is the signal to stop. During the period when green signs were specified by the *Code*, many such signs were installed, but the traditional red signs also remained. In

1949, the Fire Marshals Association of North America voted to request that red be restored as the required exit sign color, because it was found that the provision for green involved difficulties in law enactment that were out of proportion to the importance of safety. Accordingly, the 10th edition of the *Code* specified red where not otherwise required by law. The present text avoids any specific requirement for color on the assumption that either red or green will be used in most cases and that there are some situations in which a color other than red or green could actually provide better visibility.

A.7.10.2 A sign complying with 7.10.2 and indicating the direction of the nearest approved exit should be placed at the point of entrance to any escalator or moving walk. (See A.7.10.3.)

A.7.10.3 Where graphics are used, the symbols provided in NFPA 170, *Standard for Fire Safety Symbols*, should be used. Such signs need to provide equal visibility and illumination and are to comply with the other requirements of Section 7.10.

A.7.10.3.2 Pictograms may be used in lieu of, or in addition to, signs with text.

A.7.10.4 It is not the intent of this paragraph to require emergency lighting but only to have the sign illuminated by emergency lighting if emergency lighting is required and provided.

It is not the intent to require that the entire stroke width and entire stroke height of all letters comprising the word EXIT be visible per the requirements of 7.10.6.3 under normal or emergency lighting operation, provided that the sign is visible and legible at a 30-m (100-ft) distance under all room illumination conditions.

A.7.10.5.1 See A.7.8.1.3(4).

A.7.10.5.2 It is the intent to prohibit a freely accessible light switch to control the illumination of either an internally or externally illuminated exit sign.

A.7.10.5.2.2 The flashing repetition rate should be approximately one cycle per second, and the duration of the off-time should not exceed ¼ second per cycle. During on-time, the illumination levels need to be provided in accordance with 7.10.6.3. Flashing signs, when activated with the fire alarm system, might be of assistance.

A.7.10.6.1 Experience has shown that the word EXIT or other appropriate wording is plainly legible at 30 m (100 ft) if the letters are as large as specified in 7.10.6.1.

A.7.10.6.2 Figure A.7.10.6.2 shows examples of acceptable locations of directional indicators with regard to left and right orientation. Directional indicators are permitted to be placed under the horizontal stroke of the letter T, provided that spacing of not less than 9.5 mm (¾ in.) is maintained from the horizontal and vertical strokes of the letter T.

EXIT>
<EXIT
<EXIT>

FIGURE A.7.10.6.2 Directional Indicators.

A.7.10.6.3 Colors providing a good contrast are red or green letters on matte white background. Glossy background and glossy letter colors should be avoided.

The average luminance of the letters and background is measured in footlamberts or candela per square meter. The contrast ratio is computed from these measurements by the following formula:

$$\text{Contrast} = \frac{L_g - L_e}{L_g}$$

Where L_g is the greater luminance and L_e is the lesser luminance, either the variable L_g or L_e is permitted to represent the letters, and the remaining variable will represent the background. The average luminance of the letters and background can be computed by measuring the luminance at the positions indicated in Figure A.7.10.6.3 by numbered spots.




FIGURE A.7.10.6.3 Measurement of Exit Sign Luminance.

A.7.10.7.2 Photoluminescent signs need a specific minimum level of light on the face of the sign to ensure that the sign is charged for emergency operation and legibility in both the normal and emergency modes. Additionally, the type of light source (for example, incandescent, fluorescent, halogen, metal halide) is important. Each light source produces different types of visible and invisible light (for example, UV) that might affect the ability of some photoluminescent signs to charge and might also affect the amount of light output available during emergency mode. This type of sign would not be suitable where the illumination levels are permitted to decline. The charging light source should not be connected to automatic timers, because the continuous illumination of the sign is needed; otherwise, the sign illumination would not be available because it would be discharged.

A.7.10.8.3 The likelihood of occupants mistaking passageways or stairways that lead to dead-end spaces for exit doors and becoming trapped governs the need for exit signs. Thus, such areas should be marked with a sign that reads as follows:

NO EXIT

Supplementary identification indicating the character of the area, such as TO BASEMENT, STOREROOM, LINEN CLOSET, or the like, is permitted to be provided.

A.7.10.8.4(1) These signs are to be used in place of signs that indicate that elevators are not to be used during fires. Examples of these signs include the following:

In The Event of Fire, This Elevator Will Be Used by the Fire Department for Evacuation of People.

PROTECTED ELEVATOR —
USABLE IN EMERGENCIES

A.7.10.8.4(2) The wording of these signs should reflect human behavior in fires and the control specifics of the elevator system. Subparagraph 7.10.8.4 addresses signs, but provisions for notification of the vision impaired need to be considered. For information about human behavior with respect to elevator evacuation see Groner and Levin, "Human Factors Considerations in the Potential for Using Elevators in Building Emergency Evacuation Plans"; Levin and Groner, "Human Behavior Aspects of Staging Areas for Fire Safety in GSA Buildings"; and Levin and Groner, "Human Factors Considerations for the Potential Use of Elevators for Fire Evacuation of FAA Air Traffic Control Towers." Some examples of messages on signs that could be displayed are shown in Table A.7.10.8.4(2).

Table A.7.10.8.4(2) Elevator Status Messages

Elevator Status	Message
Normal use	Elevator in Service
Elevators recalled and waiting for fire service	Please Wait for Fire Department or Use Stairs
Elevator out of service	Elevator Out of Service

A.7.11.1 Twenty-three meters (75 ft) can be traversed in approximately 10 seconds to 15 seconds, even when allowing for a momentary delay to decide which way to go, during which it can be assumed that the average individual can hold his or her breath.

A.8.2.1.2 Table A.8.2.1.2 is Table 3.1 from NFPA 220, *Standard on Types of Building Construction*, and is reproduced in this annex for the convenience of users of this *Code*.

A.8.2.2.3 To ensure that a fire barrier is continuous, it is necessary to seal completely all openings where the fire barrier abuts other fire barriers, the exterior walls, the floor below, and the floor or ceiling above. In 8.2.2.3(2), the fire resistance rating of the bottom of the interstitial space is provided by that membrane alone. Ceilings of rated floor/ceiling and roof/ceiling assemblies do not necessarily provide the required fire resistance.

A.8.2.3.1 NFPA 251, ANSI/UL 263, and ASTM E119 are considered nationally recognized methods of determining fire resistance and have been found to yield equivalent test methods.

A.8.2.4.2 The intent of this provision is to allow the provisions of either ASCE/SFPE 29 or ACI 216.1/TMS0216.1 for the calculation for fire resistance of concrete or masonry elements or assemblies.

A.8.3.1(3) Walls in good condition with lath and plaster, or gypsum board of not less than 13 mm (½ in.) on each side, can be considered as providing at least a ½-hour fire resistance rating. Additional information on archaic material assemblies can be found in Appendix D of NFPA 914, *Code for Fire Protection of Historic Structures*.

A.8.3.3.2 Some door assemblies have been tested to meet the conditions of acceptance of NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*. Where such assemblies are used, the provisions of 8.3.2 should be applied instead of those of 8.3.3.2.

A.8.3.3.6 Some window assemblies have been tested to meet the conditions of acceptance of NFPA 251, *Standard Methods of*

Tests of Fire Endurance of Building Construction and Materials. Where such assemblies are used, the provisions of 8.3.2 should be applied instead of those of 8.3.3.6.

A.8.3.4.2 Longer ratings might be required where opening protectives are provided for property protection as well as life safety. NFPA 80, *Standard for Fire Doors and Fire Windows*, should be consulted for standard practice in the selection and installation of fire door assemblies and fire window assemblies.

Table 8.3.4.2, Note 1. A vision panel in a fire door is not a fire window, and thus, it is not the intent of the "NP" notations in the "Fire Windows" column of Table 8.3.4.2 to prohibit vision panels in fire doors.

A.8.3.5.6.3(1)(c) Criteria associated with fireblocking can be found in 8.14.2 of NFPA 5000™, *Building Construction and Safety Code*™.

A.8.4.1 Although a smoke partition is intended to limit the free movement of smoke, it is not intended to provide an area that would be free of smoke.

A.8.4.2(2) An architectural, exposed, suspended-grid acoustical tile ceiling with penetrations for sprinklers, ducted HVAC supply and return air diffusers, speakers, and recessed light fixtures is capable of limiting the transfer of smoke.

A.8.4.3.4 Gasketing of doors should not be necessary, as the clearances in NFPA 80, *Standard for Fire Doors and Fire Windows*, effectively achieve resistance to the passage of smoke if the door is relatively tight-fitting.

A.8.4.6.2 An air transfer opening as defined in NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, is an opening designed to allow the movement of environmental air between two contiguous spaces.

A.8.5.1 Wherever smoke barriers and doors therein require a degree of fire resistance as specified by requirements in the various occupancy chapters (Chapter 12 through Chapter 42), the construction should be a fire barrier that has been specified to limit the spread of fire and restrict the movement of smoke.

Although a smoke barrier is intended to restrict the movement of smoke, it may not result in tenability throughout the adjacent smoke compartment. The adjacent smoke compartment should be safer than the area on the fire side, thus allowing building occupants to move to that area. Eventually, evacuation from the adjacent smoke compartment may be required.

A.8.5.2 To ensure that a smoke barrier is continuous, it is necessary to seal completely all openings where the smoke barrier abuts other smoke barriers, fire barriers, exterior walls, the floor below, and the floor or ceiling above. It is not the intent to prohibit a smoke barrier from stopping at a fire barrier if the fire barrier meets the requirements of a smoke barrier (that is, the fire barrier is a combination smoke barrier/fire barrier).

A.8.5.3.1 The clearance for proper operation of smoke doors is defined as 3 mm (⅛ in.). For additional information on the installation of smoke-control door assemblies, see NFPA 105, *Standard for the Installation of Smoke Door Assemblies*.

A.8.5.3.4 Where, because of operational necessity, it is desired to have smoke barrier doors that are usually open, such doors should be provided with hold-open devices that are activated to close the doors by means of the operation of smoke detectors and other alarm functions.

Table A.8.2.1.2 Fire Resistance Ratings (in hours) for Type I through Type V Construction

	Type I		Type II			Type III		Type IV	Type V	
	443	332	222	111	000	211	200	2HH	111	000
Exterior Bearing Walls										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0 ¹	2	2	2	1	0 ¹
Supporting one floor only	4	3	2	1	0 ¹	2	2	2	1	0 ¹
Supporting a roof only	4	3	1	1	0 ¹	2	2	2	1	0 ¹
Interior Bearing Walls										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	2	1	0
Supporting one floor only	3	2	2	1	0	1	0	1	1	0
Supporting roofs only	3	2	1	1	0	1	0	1	1	0
Columns										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	H ²	1	0
Supporting one floor only	3	2	2	1	0	1	0	H ²	1	0
Supporting roofs only	3	2	1	1	0	1	0	H ²	1	0
Beams, Girders, Trusses, and Arches										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	H ²	1	0
Supporting one floor only	3	2	2	1	0	1	0	H ²	1	0
Supporting roofs only	3	2	1	1	0	1	0	H ²	1	0
Floor Construction	3	2	2	1	0	1	0	H ²	1	0
Roof Construction	2	1½	1	1	0	1	0	H ²	1	0
Exterior Nonbearing Walls ³	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹	0 ¹

Those members that shall be permitted to be of approved combustible material.

¹See A.3.1 (table) [in NFPA 220].

²“H” indicates heavy timber members; see text for requirements.

³Exterior nonbearing walls meeting the conditions of acceptance of NFPA 285, *Standard Method of Test for the Evaluation of Flammability Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components Using the Intermediate-Scale, Multistory Test Apparatus*, shall be permitted to be used.

[220:Table 3.1]

A.8.6.2 Openings might include items such as stairways, hoistways for elevators, dumbwaiters, and inclined and vertical conveyors; shaftways used for light, ventilation, or building services; or expansion joints and seismic joints used to allow structural movements.

A.8.6.5 The application of the 2-hour rule in buildings not divided into stories is permitted to be based on the number of levels of platforms or walkways served by the stairs.

A.8.6.6(7) Given that a mezzanine meeting the maximum one-third area criterion of 8.6.9.2.1 is not considered a story, it is permitted, therefore, to have 100 percent of its exit access within the communicating area run back through the story below.

A.8.6.7 Where atriums are used, there is an added degree of safety to occupants because of the large volume of space into which smoke can be dissipated. However, there is a need to ensure that dangerous concentrations of smoke are promptly removed from the atrium, and the exhaust system needs careful design. For information about systems that can be used to provide smoke protection in these spaces, see the following:

- (1) NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*
- (2) *Design of Smoke Management Systems*

A.8.6.7(1)(c) The intent of the requirement for closely spaced sprinklers is to wet the atrium glass wall to ensure that the surface of the glass is wet upon operation of the sprinklers,

with a maximum spacing of sprinklers of 1830 mm (72 in.) on centers. Provided that it can be shown that the glass can be wet by the sprinklers using a given discharge rate and that the 1830-mm (72-in.) spacing is not exceeded, the intent of the requirement is met. It is important that the entire glass area surface is wet. Due consideration should be given to the height of the glass panels and any horizontal members that may interfere with sprinkler wetting action.

A.8.6.7(5) See NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*. The engineering analysis should include the following elements:

- (1) Fire dynamics, including fire size and location, materials likely to be burning, fire plume geometry, fire plume or smoke layer impact on means of egress, and tenability conditions during the period of occupant egress
- (2) Response and performance of building systems, including passive barriers, automatic detection and extinguishing, and smoke control
- (3) Response time required for building occupants to reach building exits, including any time required to exit through the atrium as permitted by 8.6.7(2)

A.8.6.7(6) Activation of the ventilation system by manual fire alarms, extinguishing systems, and detection systems can cause unwanted operation of the system, and it is suggested that consideration be given to zoning of the activation functions so the ventilation system operates only when actually needed.

A.8.6.8.2(4) This requirement prohibits means of egress down or up the convenience opening. It does not prohibit means of escape from running down or up the convenience opening within residential dwelling units.

A.8.6.8.6(2) The intent is to place a limitation on the size of the opening to which the protection applies. The total floor opening should not exceed twice the projected area of the escalator or moving walk at the floor. Also, the arrangement of the opening is not intended to circumvent the requirements of 8.6.7.

As with any opening through a floor, the openings around the outer perimeter of the escalators should be considered as vertical openings. The sprinkler draftstop installation is intended to provide adequate protection for these openings, provided that the criteria of NFPA 13, *Standard for the Installation of Sprinkler Systems*, as well as the area criteria described in the preceding paragraph, are met.

A.8.7.1.1 Areas requiring special hazard protection include, but are not limited to, areas such as those used for storage of combustibles or flammables, areas housing heat-producing appliances, or areas used for maintenance purposes.

A.8.7.2 For details, see NFPA 68, *Guide for Venting of Deflagrations*.

A.8.7.3.2 NFPA 58, *Liquefied Petroleum Gas Code*, permits portable butane-fueled appliances in restaurants and in attended commercial food catering operations where fueled by not in excess of two 0.28-kg (10-oz) LP-Gas capacity, nonrefillable butane containers having a water capacity not in excess of 0.4 kg (1.08 lb) per container. Containers are required to be directly connected to the appliance, and manifolding of containers is not permitted. Storage of cylinders is also limited to 24 containers, with an additional 24 permitted where protected by a 2-hour fire resistance-rated barrier.

A.8.7.5 While the scope of NFPA 99, *Standard for Health Care Facilities*, is limited to health care occupancies, it is the intent

that this requirement be applied to hyperbaric facilities used in all occupancies.

A.9.3.1 For guidance on designing, installing, acceptance testing, periodic testing, and maintaining engineered smoke-control systems, see the following (*see A.23.3.1.3 for existing detention and correctional occupancies*):

- (1) NFPA 92A, *Recommended Practice for Smoke-Control Systems*
- (2) NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*
- (3) NFPA SPP-53, *Smoke Control in Fire Safety Design*
- (4) *Design of Smoke Management Systems*
- (5) ASHRAE *Guideline 5: Guideline for Commissioning Smoke Management Systems*

A.9.4.1 Under certain conditions, elevators are recognized as means of egress.

The use of elevators for emergency evacuation purposes where operated by trained emergency service personnel (for example, building personnel, fire personnel) should be utilized in the building evacuation program. Elevators are normally capable of manual, in-car fire fighter operation (Phase II) after elevator recall (Phase I). In addition, there usually are two or more shafts wherever there are more than three elevators, which further enhances the possibilities for elevator use during a fire emergency where operated by trained personnel.

In high-rise buildings, in towers, or in deep underground spaces where travel over considerable vertical distance on stairs can cause persons incapable of such physical effort to collapse before they reach the street exit, stairways are permitted to be used for initial escape from the immediate area of danger, and elevators are permitted to be used to complete the travel to the street.

It can be reasonably assumed that in all buildings of sufficient height to indicate the need for elevators, elevators will be provided for normal use; for this reason, no requirements for mandatory installation of elevators are included in the *Code*.

For additional information on elevators, see ASME A17.1, *Safety Code for Elevators and Escalators*, and ASME A17.3, *Safety Code for Existing Elevators and Escalators*.

A.9.4.5 Continued operation of solid-state elevator equipment is contingent on maintaining the ambient temperature in the range specified by the elevator manufacturer. If the machine room ventilation/air conditioning is connected to the general building system, and that system is shut down during a fire, the fire department might lose the use of elevators due to excessive heat in the elevator machine room.

A.9.6.1 The provisions of Section 9.6 cover the basic functions of a complete fire alarm system, including fire detection, alarm, and communications. These systems are primarily intended to provide the indication and warning of abnormal conditions, the summoning of appropriate aid, and the control of occupancy facilities to enhance protection of life.

Some of the provisions of Section 9.6 originated with NFPA 72®, *National Fire Alarm Code*®. For purposes of this *Code*, some provisions of Section 9.6 are more stringent than those of NFPA 72®, *National Fire Alarm Code*®, which should be consulted for additional details.

A.9.6.1.6 Records of conducted maintenance and testing and a copy of the certificate of compliance should be maintained.

A.9.6.1.7 A fire watch should at least involve some special action beyond normal staffing, such as assigning an additional security guard(s) to walk the areas affected. These individuals should be specially trained in fire prevention and in occupant and fire department notification techniques, and they should understand the particular fire safety situation for public education purposes. (Also see NFPA 601, *Standard for Security Services in Fire Loss Prevention*.)

A.9.6.2.4 It is not the intent of 9.6.2.4 to require manual fire alarm boxes to be attached to movable partitions or to equipment, nor is it the intent to require the installation of permanent structures for mounting purposes only.

A.9.6.2.6 Manual fire alarm boxes can include those with key-operated locks for detention areas or psychiatric hospitals, manual fire alarm boxes in areas where explosive vapors or dusts might be a hazard, or manual fire alarm boxes in areas with corrosive atmospheres. The appearance of manual fire alarm boxes for special uses often differs from those used in areas of normal occupancy. Manual fire alarm boxes, such as those with locks, that are located in areas where the general public has limited access might need to have signage advising persons to seek assistance from staff in the event a fire is noted.

A.9.6.2.10.3 A dwelling unit is that structure, area, room, or combination of rooms, including hotel rooms/suites, in which a family or individual lives. A dwelling unit includes living areas only and not common usage areas in multifamily buildings such as corridors, lobbies, and basements.

A.9.6.3.2.1 Elevator lobbies have been considered areas subject to unwanted alarms due to factors such as low ceilings and smoking. In the past several years, new features have become available to reduce this problem. These features are, however, not necessarily included in any specific installation.

A.9.6.3.2.2 The concept addressed is that detectors used for releasing service, such as door or damper closing and fan shut-down, are not required to sound the building alarm.

A.9.6.3.2.3 The concept addressed is that detectors used for releasing service, such as door or damper closing and fan shut-down, are not required to sound the building alarm.

A.9.6.3.6.2 To approve an evacuation plan to selectively notify building occupants, the authority having jurisdiction should consider several building parameters, including building compartmentation, detection and suppression system zones, occupant loads, and the number and arrangement of the means of egress.

In high-rise buildings, it is typical to evacuate the fire floor, the floor(s) above, and the floor immediately below. Other areas are then evacuated as the fire develops.

A.9.6.5.4 Control devices (fire alarm relays) can be located at a motor control center that is located floors away from the device to be activated, such as air-handling units and exhaust fans located on the roof. The requirement for monitoring for integrity only applies to the installation wiring between the fire alarm control unit and the auxiliary fire alarm relay. It does not apply to the wiring between the auxiliary fire alarm relay and the emergency control device (for example, motor stop/start control relay) or between the emergency control device and the equipment to be controlled (for example, air-handling units and exhaust fans). For example, although the auxiliary fire alarm relay is required be located within 915 mm (36 in.) of the emergency control device, there is no limit

specified for the distance between the emergency control device and the equipment to be controlled.

A.9.7.1.1 For a discussion of the effectiveness of automatic sprinklers as well as a general discussion on automatic sprinklers, see the NFPA *Fire Protection Handbook*. Where partial sprinkler protection is permitted by another section of this Code, the limited area systems provisions of NFPA 13, *Standard for the Installation of Sprinkler Systems*, should apply.

A.9.7.1.3 Properly designed automatic sprinkler systems provide the dual function of both automatic alarms and automatic extinguishment. Dual function is not provided in those cases where early detection of incipient fire and early notification of occupants are needed to initiate actions in behalf of life safety earlier than can be expected from heat-sensitive fire detectors.

A.9.7.2.1 NFPA 72®, *National Fire Alarm Code*®, provides details of standard practice in sprinkler supervision. Subject to the approval of the authority having jurisdiction, sprinkler supervision is also permitted to be provided by direct connection to municipal fire departments or, in the case of very large establishments, to a private headquarters providing similar functions. NFPA 72®, *National Fire Alarm Code*®, covers such matters.

Where municipal fire alarm systems are involved, reference should also be made to NFPA 1221, *Standard for the Installation, Maintenance, and Use of Emergency Services Communications Systems*.

A.9.7.4.1 For a description of standard types of extinguishers and their installation, maintenance, and use, see NFPA 10, *Standard for Portable Fire Extinguishers*. The labels of recognized testing laboratories on extinguishers provide evidence of tests indicating the reliability and suitability of the extinguisher for its intended use. Many unlabeled extinguishers are offered for sale that are substandard by reason of insufficient extinguishing capacity, questionable reliability, or ineffective extinguishing agents for fires in ordinary combustible materials or because they pose a personal hazard to the user.

A.9.7.6 A fire watch should at least involve some special action beyond normal staffing, such as assigning an additional security guard(s) to walk the areas affected. These individuals should be specially trained in fire prevention and in the use of fire extinguishers and occupant hose lines, in notifying the fire department, in sounding the building fire alarm, and in understanding the particular fire safety situation for public education purposes. Some authorities having jurisdiction require fire fighters to be assigned to the area, with direct radio communication to the local fire department. (Also see NFPA 601, *Standard for Security Services in Fire Loss Prevention*.)

A.10.2 The requirements pertaining to interior finish are intended to restrict the spread of fire over the continuous surface forming the interior portions of a building.

A.10.2.2 Table A.10.2.2 provides a compilation of the interior finish requirements of the occupancy chapters (Chapter 12 through Chapter 42) of this Code.

A.10.2.2.2 This paragraph recognizes that traditional finish floors and floor coverings such as wood flooring and resilient floor coverings have not proved to present an unusual hazard.

A.10.2.2.2(2) Compliance with Title 16 CFR 1630, *Standard for the Surface Flammability of Carpets and Rugs* (FFI-70), is considered equivalent to compliance with ASTM D 2859.

Table A.10.2.2 Interior Finish Classification Limitations

Occupancy	Exits	Exit Access Corridors	Other Spaces
Assembly — New			
>300 occupant load	A	A or B	A or B
≤300 occupant load	I or II	I or II	
Assembly — Existing			
>300 occupant load	A	A or B	A or B
≤300 occupant load	A	A or B	A, B, or C
Educational — New	I or II	I or II	A or B;
Educational — Existing	A	A or B	C on low partitions [†]
Day-Care Centers — New	A	A	A, B, or C
Day-Care Centers — Existing	I or II	I or II	A or B
Day-Care Homes — New	A or B	A or B	A or B
Day-Care Homes — Existing	A or B	A or B	A, B, or C
Health Care — New	A	A	A
Health Care — Existing	A or B	B on lower portion of corridor wall [†]	B in small individual rooms [†]
Detention and Correctional — New (sprinklers mandatory)	A or B	A or B	A or B
Detention and Correctional — Existing	I or II	A or B	A, B, or C
1- and 2-Family Dwellings, Lodging or Rooming Houses	A or B	I or II	A, B, or C
Hotels and Dormitories — New	A, B, or C	A, B, or C	A, B, or C
Hotels and Dormitories — Existing	A	A or B	A, B, or C
Apartment Buildings — New	I or II	I or II	A, B, or C
Apartment Buildings — Existing	A or B	I or II [†]	A, B, or C
Residential, Board and Care — (See Chapter 32 and Chapter 33)	I or II [†]	A or B	A, B, or C
Mercantile — New	A	A or B	A or B
Mercantile — Existing Class A or Class B Stores	I or II	A or B	A or B
Mercantile — Existing Class C Stores	A or B	A or B	Ceilings — A or B; walls — A, B, or C
Business and Ambulatory Health Care — New	A, B, or C	A, B, or C	A, B, or C
Business and Ambulatory Health Care — Existing	A or B	A or B	A, B, or C
Industrial	I or II	A or B	A, B, or C
Storage	A or B	A, B, or C	A, B, or C
	I or II	I or II	

Notes:

1. Class A interior wall and ceiling finish — flame spread 0–25, (new) smoke developed 0–450.
2. Class B interior wall and ceiling finish — flame spread 26–75, (new) smoke developed 0–450.
3. Class C interior wall and ceiling finish — flame spread 76–200, (new) smoke developed 0–450.
4. Class I interior floor finish — critical radiant flux, not less than 0.45 W/cm².
5. Class II interior floor finish — critical radiant flux, not less than 0.22 W/cm² but less than 0.45 W/cm².
6. Automatic sprinklers — where a complete standard system of automatic sprinklers is installed, interior wall and ceiling finish with flame spread rating not exceeding Class C is permitted to be used in any location where Class B is required and with rating of Class B in any location where Class A is required; similarly, Class II interior floor finish is permitted to be used in any location where Class I is required, and no critical radiant flux rating is required where Class II is required. These provisions do not apply to new detention and correctional occupancies.
7. Exposed portions of structural members complying with the requirements for heavy timber construction are permitted.

[†]See corresponding chapters for details.

A.10.2.3 See A.10.2.4.1.

A.10.2.3.4 It has been shown that the method of mounting interior finish materials may affect actual performance. Where materials are tested in intimate contact with a substrate to determine a classification, such materials should be installed in intimate contact with a similar substrate. Such details are especially important for “thermally thin” materials. For further information, see NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*.

Some interior wall and ceiling finish materials, such as fabrics not applied to a solid backing, do not lend themselves to a test made in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*. In these cases, the large-scale test outlined in NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*, is permitted to be used.

Prior to 1978, the test report described by NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, included an evaluation of the fuel contribution as well as the flame spread rating and the smoke development value. However, it is now recognized that the measurement on which the fuel contribution is based does not provide a valid measure. Therefore, although the data are recorded during the test, the information is no longer normally reported. Classification of interior wall and ceiling finish thus relies only on flame spread index and smoke development value.

The 450 smoke development value limit is based solely on obscuration. (See A.10.2.4.1.)

A.10.2.3.7 The methodology specified in NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*, includes provisions for measuring smoke obscuration. Such measurement is considered desirable, but the basis for specific recommended values is not currently available. (See A.10.2.4.1.)

A.10.2.3.7.1 See A.10.2.3.7 and A.10.2.4.1.

A.10.2.4 Surface nonmetallic raceway products, as permitted by NFPA 70, *National Electrical Code*®, are not interior finishes.

A.10.2.4.1 Previous editions of the *Code* have regulated textile materials on walls and ceilings using NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*. Full-scale room/corner fire test research has shown that flame spread indices produced by NFPA 255 might not reliably predict all aspects of the fire behavior of textile wall and ceiling coverings.

NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*, and NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, both known as room-corner tests, were developed for assessing the fire and smoke obscuration performance of textile wall coverings and interior wall and ceiling finish materials, respectively. As long as an interior wall or ceiling finish material is tested by NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*, or by NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, as appropriate, using a mounting system, substrate, and adhesive (if appropriate) that are representative of actual use, the room-corner test provides an adequate evaluation of a product's flammability and smoke obscuration behavior. Manufacturers, installers, and specifiers should be encouraged to use NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*, or NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, as appropriate — but not

both — because each of these standard fire tests has the ability to characterize actual product behavior, as opposed to data generated by tests using NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, which only allows comparisons of one product's performance with another. If a manufacturer or installer chooses to test a wall finish in accordance with NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, additional testing in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, is not necessary.

The test results from NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, are suitable for classification purposes but should not be used as input into fire models, because they are not generated in units suitable for engineering calculations. Actual test results, for heat, smoke, and combustion product release from NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*, and from NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, are suitable for use as input into fire models for performance-based design.

A.10.2.4.2 Expanded vinyl wall covering consists of a woven textile backing, an expanded vinyl base coat layer, and a non-expanded vinyl skin coat. The expanded base coat layer is a homogeneous vinyl layer that contains a blowing agent. During processing, the blowing agent decomposes, which causes this layer to expand by forming closed cells. The total thickness of the wall covering is approximately 1.4 mm to 1.8 mm (0.055 in. to 0.070 in.).

A.10.2.4.4 Light-transmitting plastics are used for a variety of purposes, including light diffusers, exterior wall panels, skylights, canopies, glazing, and the like. Previous editions of the *Code* have not addressed the use of light-transmitting plastics. Light-transmitting plastics will not normally be used in applications representative of interior finishes. Accordingly, NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, can produce test results that might or might not apply.

Light-transmitting plastics are regulated by the United States model building codes; see, for example, the *Uniform Building Code*, the *Standard Building Code*, and the *National Building Code*. Model building codes provide adequate regulation for most applications of light-transmitting plastics. Where an authority having jurisdiction determines that a use is contemplated that differs from uses regulated by model building codes, light-transmitting plastics in such applications can be substantiated by fire tests that demonstrate the combustibility characteristics of the light-transmitting plastics for the use intended under actual fire conditions.

A.10.2.6 Fire-retardant coatings need to be applied to surfaces properly prepared for the material, and application needs to be consistent with the product listing. Deterioration of coatings applied to interior finishes can occur due to repeated cleaning of the surface or painting over applied coatings.

A.10.2.6.1 It is the intent of the *Code* to mandate interior wall and ceiling finish materials that obtain their fire performance and smoke developed characteristics in their original form. However, in renovations, particularly those involving historic buildings, and in changes of occupancy, the required fire performance or smoke developed characteristics of existing surfaces of walls, partitions, columns, and ceilings might have to be secured by applying approved fire-retardant coatings to surfaces having higher flame spread ratings than permitted. Such treatments should comply with the requirements of NFPA 703, *Standard for Fire Retardant Impregnated Wood and Fire Retardant*

Coatings for Building Materials. When fire-retardant coatings are used, they need to be applied to surfaces properly prepared for the material, and application needs to be consistent with the product listing. Deterioration of coatings applied to interior finishes can occur due to repeated cleaning of the surface or painting over applied coatings, but permanency must be assured in some appropriate fashion. Fire-retardant coatings must possess the desired degree of permanency and be maintained so as to retain the effectiveness of the treatment under the service conditions encountered in actual use.

A.10.2.7.2 The fire performance of some floor finishes has been tested, and traditional finish floors and floor coverings such as wood flooring and resilient floor coverings have not proved to present an unusual hazard.

A.10.2.7.3 The flooring radiant panel provides a measure of a floor covering's tendency to spread flames where located in a corridor and exposed to the flame and hot gases from a room fire. The flooring radiant panel test method is to be used as a basis for estimating the fire performance of a floor covering installed in the building corridor. Floor coverings in open building spaces and in rooms within buildings merit no further regulation, provided that it can be shown that the floor covering is at least as resistant to spread of flame as a material that meets the U.S. federal flammability standard 16 CFR 1630, *Standard for the Surface Flammability of Carpets and Rugs* (FF 1-70). All carpeting sold in the U.S. since 1971 is required to meet this standard and, therefore, is not likely to become involved in a fire until a room reaches or approaches flashover. Therefore, no further regulations are necessary for carpet other than carpet in exitways and corridors.

It has not been found necessary or practical to regulate interior floor finishes on the basis of smoke development.

Full scale fire tests and fire experience have shown floor coverings in open building spaces merit no regulation beyond the United States federally mandated DOC FF 1-70 "pill test." This is because floor coverings meeting the FF 1-70 will not spread flame significantly until a room fire approaches flashover. At flashover the spread of flame across a floor covering will have minimal impact on the already existing hazard. The minimum critical radiant flux of a floor covering that will pass the FF 1-70 has been determined to be approximately 0.04 watts/cm² (Tu, King-Mon and Davis, Sanford, Flame Spread of Carpet Systems Involved in Room Fires, NFSIR 76-1013, Center for Fire Research, National Bureau of Standards, June 1976). The flooring radiant panel is only able to determine critical radiant flux values to 0.1 watts/cm². This provision will prevent use of a noncomplying material, which may create a problem, especially when the *Code* is used outside the U.S. where U.S. Federal regulation FF-1 (16 CFR 1630) is not mandated.

A.10.3.1 Testing per NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*, applies to textiles and films used in a hanging configuration. If the textiles and films are to be applied to surfaces of buildings or backing materials as interior finishes for use in buildings, they should be treated as interior wall and ceiling finishes in accordance with Section 10.2 of this *Code*, and they should then be tested for flame spread rating and smoke development values in accordance with NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, or for flame spread and flashover in accordance with NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*.

The test results from NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*, are suitable for classification purposes but should not be used as input into fire

models, because they are not generated in units suitable for engineering calculations.

A.10.3.2 The Class I requirement associated with testing per NFPA 260, *Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture*, the char length of not more than 38 mm (1.5 in.) required with testing per NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*; and the char length of not more than 51 mm (2 in.) required in FF4-72, *Standard for the Flammability of Mattresses*, are indicators that the furniture item or mattress is resistant to a cigarette ignition. Although rooms or spaces protected by an approved automatic sprinkler system are exempt from cigarette ignition resistance testing, a fire that smolders for an excessive period of time without flaming can reduce the tenability within the room or area of fire origin without developing the temperatures necessary to operate automatic sprinklers.

The test results from NFPA 260, *Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture*, and NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*, are suitable for classification purposes but should not be used as input into fire models, because they are not generated in units suitable for engineering calculations.

A.10.3.2(3) Regardless of sprinkler protection provided, U.S. federal regulations require mattresses in the United States to comply with 16 CFR 1632.

A.10.3.3 The intent of the provisions of 10.3.3 is as follows.

- (1) The peak heat release rate of not more than 250 kW by a single upholstered furniture item was chosen based on maintaining a tenable environment within the room of fire origin. The sprinkler exception was developed because the sprinkler system helps to maintain tenable conditions even if the single upholstered furniture item were to have a peak rate of heat release in excess of 250 kW.
- (2) The total energy release of not more than 40 MJ by the single upholstered furniture item during the first 5 minutes of the test was established as an additional safeguard to protect against the adverse conditions that would be created by an upholstered furniture item that released its heat in other than the usual measured scenario. During the test for measurement of rate of heat release, the instantaneous heat release value usually peaks quickly and then quickly falls off so as to create a triangle-shaped curve. In the atypical case, if the heat release were to peak and remain steady at that elevated level, as opposed to quickly falling off, the 250-kW limit would not ensure safety. Again, only a sprinkler exception is permitted in lieu of the test because of the ability of the sprinkler system to control the fire.

Actual test results for heat, smoke, and combustion product release from ASTM E 1537, *Standard Method of Fire Testing of Real Scale Upholstered Furniture Items*, might be suitable for use as input into fire models for performance-based design.

A.10.3.4 The intent of the provisions of 10.3.4 is as follows.

- (1) The peak heat release rate of not more than 250 kW by a single mattress was chosen based on maintaining a tenable environment within the room of fire origin. The sprinkler exception was developed because the sprinkler system helps to maintain tenable conditions even if the single mattress were to have a peak rate of heat release in excess of 250 kW.
- (2) The total energy release of not more than 40 MJ by the single mattress during the first 5 minutes of the test was

established as an additional safeguard to protect against the adverse conditions that would be created by a mattress that released its heat in other than the usual measured scenario. During the test for measurement of rate of heat release, the instantaneous heat release value usually peaks quickly and then quickly falls off so as to create a triangle-shaped curve. In the atypical case, if the heat release were to peak and remain steady at that elevated level, as opposed to quickly falling off, the 250-kW limit would not ensure safety. Again, only a sprinkler exception is permitted in lieu of the test because of the ability of the sprinkler system to control the fire.

Actual test results for heat, smoke, and combustion product release from NFPA 267, *Standard Method of Test for Fire Characteristics of Mattresses and Bedding Assemblies Exposed to Flaming Ignition Source*, and ASTM E 1590, *Standard Method for Fire Testing of Real Scale Mattresses*, might be suitable for use as input into fire models for performance-based design.

A.10.3.5 Christmas trees not effectively flame-retardant treated, ordinary crepe paper decorations, and pyroxylin plastic decorations might be classified as highly flammable.

A.10.3.7 UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*, is not intended for evaluating interior wall and ceiling finish materials.

Actual test results for heat, smoke, and combustion product release from UL 1975 might be suitable for use as input into fire models intended for performance-based design.

A.11.2.2 Escape chutes, controlled descent devices, and elevators are permitted to provide escape routes in special structures; however, they should not be substituted for the provisions of this *Code*.

A.11.3.1.3.1(2) The incidental accessory uses are intended to apply to small office spaces or lounge areas and similar uses that are used by tower employees.

A.11.3.2.4 The Washington Monument in Washington, DC, is an example of a tower where it would be impracticable to provide a second stairway.

A.11.5 For further information on pier fire protection, see NFPA 307, *Standard for the Construction and Fire Protection of Marine Terminals, Piers, and Wharves*.

A.11.6 Fire safety information for manufactured home parks is found in NFPA 501A, *Standard for Fire Safety Criteria for Manufactured Home Installations, Sites, and Communities*.

A.11.7.2 It is not the intent that emergency access openings be readily openable from the exterior by the public but that they can easily be opened with normal fire department equipment.

A.11.8.2.1 Where an occupancy chapter (Chapter 12 through Chapter 42) permits the omission of sprinklers in specific spaces, such as small bathrooms and closets in residential occupancies, the building is still considered to be protected throughout for the purposes of 11.8.2.1.

A.11.8.3.1 The need for voice communication can be based on a decision regarding staged or partial evacuation versus total evacuation of all floors. The determination of need is a function of occupancy classification and building height.

A.11.8.4.2(A) The Class 1, Type 60, standby power required by 11.8.4.2(A) is established in accordance with the provisions of Table 2.2.2 and Table 2.2.3 of NFPA 110, *Standard for Emer-*

gency and Standby Power Systems. The last class identification in Table 2.2.3 is for those emergency power systems that might have a different minimum running time requirement than those shown in the table. Therefore, it is the intent that the standby power required by 11.8.4.2(A) have an operation of not less than 1 hour running time before refueling is required.

A.11.8.5 It is not the intent of the paragraph to require any of the equipment in the list, other than the telephone for fire department use, but only to provide the controls, panels, annunciators, and similar equipment at this location if the equipment is provided or required by another section of the *Code*.

A.11.9.3.3.1 The requirements of this paragraph can be considered as a Class 4, Type 60 system per NFPA 110, *Standard for Emergency and Standby Power Systems*.

A.12.1.2.2 Example. An assembly room for the residents of a detention occupancy will not normally be subject to simultaneous occupancy.

A.12.1.3 An understanding of the term *accessory room* might be useful to the enforcer of the *Code*, although the term is not used within the *Code*. An accessory room includes a dressing room, the property master's work and storage rooms, the carpenter's room, or similar rooms necessary for legitimate stage operations.

A.12.1.4 Assembly occupancy requirements should be determined on a room-by-room basis, a floor-by-floor basis, and a total building basis. The requirements for each room should be based on the occupant load of that room and the requirements for each floor should be based on the occupant load of that floor, but the requirements for the assembly building overall should be based on the total occupant load. Therefore, it is quite feasible to have several assembly occupancies with occupant loads of 300 or less grouped together in a single building. Such a building would be an assembly occupancy with an occupant load of over 1000.

A.12.1.7.1 The increase in occupant load above that calculated using occupant load factors from Table 7.3.1.2 is permitted if the provisions of 12.1.7.1 are followed. The owner or operator has the right to submit plans and to be permitted an increase in occupant load if the plans comply with the *Code*. The authority having jurisdiction is permitted to reject the plan for increase in occupant load if the plan is unrealistic, inaccurate, or otherwise does not properly reflect compliance with other *Code* requirements. It is not the intent of the provisions of 12.1.7.1 to prohibit an increase in occupant load solely on the basis of exceeding the limits calculated using occupant load factors from Table 7.3.1.2.

To assist in preventing serious overcrowding incidents in sports arenas, stadia, and similar occupancies, spectator standing room should not be permitted between the seating areas and the playing areas, except in horse race and dog track facilities.

Where a capacity or near-capacity audience is anticipated, all seating should be assigned with tickets showing the section, row, and seat number.

Where standing room is permitted, the capacity of the standing area should meet the following criteria:

- (1) It should be determined on the basis of 0.46 m² (5 ft²) per person.
- (2) It should have its capacity added to the seating capacity in determining egress requirements.

- (3) It should be located to the rear of the seating area.
- (4) It should be assigned standing-room-only tickets according to the area designated for the purpose.

The number of tickets sold or otherwise distributed should not exceed the aggregate number of seats plus the approved standing room numbers.

A.12.2.2.3.1(1) The seating plan and the means of egress should be reviewed each time the seating is substantially rearranged.

A.12.2.3.2 The provisions of 12.2.3.2 should be applied within the audience seating chamber and to the room doors. The capacity of means of egress components encountered after leaving the audience seating chamber, such as concourses, lobbies, exit stair enclosures, and the exit discharge, should be calculated in accordance with Section 7.3.

A.12.2.3.6.5 The original *Code* wording exempted sports arenas and railway stations. If an assembly occupancy was not similar to a sports arena or railway station, it was often judged ineligible to use the provision of 12.2.3.6.5. A list of exempted assembly venues also raises the question as to why other occupancies are not included and necessitates additions to the list. For example, an exhibit hall of very large size might have several main entrances/exits. A theater extending the width of a block cannot really have a main entrance/exit in one confined location. A restaurant might have a main entrance serving the parking lot and another main entrance for those entering from the street. The authority having jurisdiction needs to determine where such arrangements are acceptable.

A.12.2.4 It is not the intent to require four means of egress from each level of an assembly occupancy building having a total occupant load of more than 1000 where, individually, the floors have occupant loads of less than 1000.

A.12.2.5.4.2 This requirement and the associated requirement of 12.2.5.4.3 have the effect of prohibiting festival seating unless it truly is a form of seating, such as lawn seating, where generous spaces are commonly maintained between individuals and small groups so that people can circulate freely at any time. Such lawn seating will be characterized by densities of about one person per 1.4 m² (15 ft²). Both requirements prohibit uncontrolled crowd situations, such as in front of stages at rock music concerts where the number and density of people is uncontrolled by architectural or management features.

A.12.2.5.4.3 This requirement is intended to facilitate rapid emergency access to individuals who are experiencing a medical emergency, especially in the case of cardiopulmonary difficulties, where there is a need for rapid medical attention from trained personnel. The requirement also addresses the need for security and law enforcement personnel to reach individuals whose behavior is endangering themselves and others.

A.12.2.5.4.4 The catchment area served by an aisle accessway or aisle is the portion of the total space that is naturally served by the aisle accessway or aisle. Hence, the requirement for combining the required capacity where paths converge is, in effect, a restatement of the idea of a catchment area. The establishment of catchment areas should be based on a balanced use of all means of egress, with the number of persons in proportion to egress capacity.

A.12.2.5.5 For purposes of the means of egress requirements of this *Code*, tablet-arm chair seating is not considered seating at

tables. Dinner theater-style configurations are required to comply with the aisle accessway provisions applying to seating at tables and the aisle requirements of 12.2.5.6, if the aisles contain steps or are ramped. Generally, if aisles contain steps or are ramped, all of this *Code's* requirements for aisles, stairs, and ramps are required to be met. (Also see 7.1.7 and A.7.1.7.2.)

A.12.2.5.5.1 Seats having reclining backs are assumed to be in their most upright position when unoccupied.

A.12.2.5.5.4 The system known as *continental seating* has one pair of egress doors provided for every five rows that is located close to the ends of the rows. In previous editions of the *Code*, such egress doors were required to provide a clear width of not less than 1675 mm (66 in.) discharging into a foyer, into a lobby, or to the exterior of the building. This continental seating arrangement can result in egress flow times (that is, with nominal flow times of approximately 100 seconds, rather than 200 seconds) that are approximately one-half as long as those resulting where side aisles lead to more remote doors. Such superior egress flow time performance is desirable in some situations; however, special attention should be given either to a comparably good egress capacity for other parts of the egress system or to sufficient space to accommodate queuing outside the seating space.

A.12.2.5.6.3 It is the intent to permit handrails to project not more than 90 mm (3½ in.) into the clear width of aisles required by 12.2.5.6.3.

A.12.2.5.6.4 Technical information about the convenience and safety of ramps and stairs having gradients in the region of 1 in 8 clearly suggests that the goal should be slopes for ramps that are less steep and combinations of stair risers and treads that are, for example, superior to 100-mm (4-in.) risers and 865-mm (32-in.) treads. This goal should be kept in mind by designers in establishing the gradient of seating areas to be served by aisles.

A.12.2.5.6.5(2) Tread depth is more important to stair safety than is riser height. Therefore, in cases where the seating area gradient is less than 5 in 11, it is recommended that the tread dimension be increased beyond 280 mm (11 in.) rather than reducing the riser height. Where the seating area gradient exceeds 8 in 11, it is recommended that the riser height be increased while maintaining a tread depth of not less than 280 mm (11 in.).

A.12.2.5.6.7 Failure to provide a handrail within a 760-mm (30-in.) horizontal distance of all required portions of the aisle stair width means that the egress capacity calculation is required to be modified as specified by 12.2.3.3(3). This modification might lead to an increase in the aisle width. Although this increase will compensate for reduced egress efficiency, it does not help individuals walking on such portions of stairs to recover from missteps other than by possibly reducing marginally the crowding that might exacerbate the problem of falls. (See also 7.2.2.4.)

A.12.2.5.6.8 Certain tread cover materials such as plush carpets, which are often used in theaters, produce an inherently well-marked tread nosing under most lighting conditions. On the other hand, concrete treads have nosings with a sharp edge and, especially under outdoor lighting conditions, are difficult to discriminate. Therefore, concrete trends require an applied marking stripe. The slip resistance of such marking stripes should be similar to the rest of the treads, and no trip-

ping hazard should be created; luminescent, self-luminous, and electroluminescent tread markings have the advantage of being apparent in reduced light or in the absence of light.

A.12.2.5.7 For purposes of the means of egress requirements of this *Code*, seating at counters or at other furnishings is considered to be the same as seating at tables.

A.12.2.5.7.2 Effectively, where the aisle accessway is bounded by movable seating, the 305-mm (12-in.) minimum width might be increased by about 380 mm to 760 mm (15 in. to 30 in.) as seating is pushed in toward tables. Moreover, it is such movement of chairs during normal and emergency egress situations that makes the zero-clearance allowance workable. The allowance also applies to booth seating where people sitting closest to the aisle normally move out ahead of people farthest from the aisle.

A.12.2.5.7.3 See A.12.2.5.8.3.

A.12.2.5.7.4 The minimum width requirement as a function of accessway length is as follows:

- (1) 0 mm (0 in.) for the first 1830 mm (72 in.) of length toward the exit
- (2) 305 mm (12 in.) for the next 1830 mm (72 in.), that is, up to 3660 mm (144 in.) of length
- (3) 305 mm to 610 mm (12 in. to 24 in.) for lengths from 3660 mm to 10,900 mm (144 in. to 432 in.), the maximum length to the closest aisle or egress doorway permitted by 12.2.5.7.4

Any additional width needed for seating is to be added to these widths, as described in 12.2.5.8.3.

A.12.2.5.8.1 See 7.1.7 and A.7.1.7.2 for special circulation safety precautions applicable where small elevation differences occur.

A.12.2.5.8.2 It is important to make facilities accessible to people using wheelchairs. See ICC/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*, which provides guidance on appropriate aisle widths.

A.12.2.5.8.3 Figure A.12.2.5.8.3 shows typical measurements involving seating and tables abutting an aisle. For purposes of the means of egress requirements of this *Code*, seating at counters or other furnishings is considered to be the same as seating at tables.




FIGURE A.12.2.5.8.3 Seating at Tables Abutting an Aisle.

A.12.2.11.1.1 This requirement includes provisions of guards and rails at the front of boxes, galleries, and balconies, and at aisle accessways adjacent to vomitories and orchestra pits.

A.12.3.1(1) The allowance for unenclosed stairs or ramps presumes the balcony or mezzanine complies with the other provisions of the *Code*, such as travel distance to exits in accordance with 12.2.6 and numbers of exits in accordance with 12.2.4. For the purposes of this exception, a balcony with glazing that provides a visual awareness of the main assembly area is considered open.

A.12.3.4.2.3 The intent is to require detectors only in nonsprinklered hazardous areas that are unoccupied. When the building is occupied, the detectors in the unoccupied, unsprinklered hazardous areas will initiate occupant notification. If the building is unoccupied, the fire in the nonsprinklered hazardous area is not a life safety issue, and the detectors, upon activation, are not required to notify anyone. The signal from a detector is permitted to be sent to a control panel in an area that is occupied when the building is occupied, but that is unoccupied when the building is unoccupied, without the need for central station monitoring or the equivalent.

A.12.3.5.2(2) It is the intent to permit a single multipurpose room of less than 1115 m² (12,000 ft²) to have certain small rooms as part of the single room. These rooms could be a kitchen, office, equipment room, and the like. It is also the intent that an addition could be made to an existing building without requiring that the existing building be sprinklered, where both the new and existing buildings have independent means of egress and a fire-rated separation is provided to isolate one building from the other.

A school gymnasium with egress independent of, and separated from, the school would be included in this exception, as would a function hall attached to a church with a similar egress arrangement.

A.12.4.1.1 Life safety evaluations are examples of performance-based approaches to life safety. In this respect, significant guidance in the form and process of life safety evaluations is provided by Chapter 5, keeping in mind the firesafety emphasis in Chapter 5. The general approach to performance criteria, scenarios, evaluation, safety factors, documentation, maintenance, and periodic assessment (including a warrant of fitness) all apply to the broader considerations in a life safety evaluation. A life safety evaluation deals not only with fire but also with fire, storm, collapse, crowd behavior, and other related safety considerations for which a checklist is provided in A.12.4.1.3. Chapter 5 provides guidance, based on fire safety requirements, for establishing a documented case showing that products of combustion in all conceivable fire scenarios will not significantly endanger occupants using means of egress in the facility (for example, because of fire detection, automatic suppression, smoke control, large-volume space, or management procedures). Moreover, means of egress facilities plus facility management capabilities should be adequate to cope with scenarios where certain egress routes are blocked for some reason.

In addition to making realistic assumptions about the capabilities of persons in the facility (for example, an assembled crowd including many disabled persons or persons unfamiliar with the facility), the life safety evaluation should include a factor of safety of not less than 2.0 in all calculations relating to hazard development time and required egress time (the combination of flow time and other time needed to detect and

assess an emergency condition, initiate egress, and move along the egress routes). The factor of safety takes into account the possibility that half of the egress routes might not be used (or be usable) in certain situations.

Regarding crowd behavior, the potential hazards created by larger masses of people and greater crowd densities (which can be problematic during ingress, occupancy, and egress) demand that technology be used by designers, managers, and authorities responsible for buildings to compensate for the relaxed egress capacity provisions of Table 12.4.2.3. In very large buildings for assembly use, the hazard of crowd crushes can exceed that of fire or structural failure. Therefore, the building designers, managers, event planners, security personnel, police authorities, and fire authorities, as well as the building construction authorities, should understand the potential problems and solutions, including coordination of their activities. For crowd behavior, this understanding includes factors of space, energy, time, and information, as well as specific crowd management techniques such as metering. Published guidance on these factors and techniques is found in the *SFPE Handbook of Fire Protection Engineering*, Section 3, Chapter 13, pp. 3-263–3-285 (Pauls, J., “Movement of People”), and the publications referenced therein.

Table 12.2.3.2 and Table 12.4.2.3 are based on a linear relationship between number of seats and nominal flow time, with not less than 200 seconds (3.3 minutes) for 2000 seats plus 1 second for every additional 50 seats up to 25,000. Beyond 25,000 total seats, the nominal flow time is limited to 660 seconds (11 minutes). Nominal flow time refers to the flow time for the most able group of patrons; some groups less familiar with the premises or less able groups might take longer to pass a point in the egress system. Although three or more digits are noted in the tables, the resulting calculations should be assumed to provide only two significant figures of precision.

A.12.4.1.3 Factors to be considered in a Life Safety Evaluation include the following:

(1) Nature of the Events Being Accommodated

- (a) Ingress, intra-event movement, and egress patterns
- (b) Ticketing and seating policies/practices
- (c) Event purpose (e.g., sports contest, religious meeting)
- (d) Emotional qualities (e.g., competitiveness) of event
- (e) Time of day when event held
- (f) Time duration of single event
- (g) Time duration of attendees' occupancy of the building

(2) Occupant Characteristics and Behavior

- (a) Homogeneity
- (b) Cohesiveness
- (c) Familiarity with building
- (d) Familiarity with similar events
- (e) Capability (as influenced by factors such as age, physical abilities)
- (f) Socioeconomic factors
- (g) Small minority involved with recreational violence
- (h) Emotional involvement with the event and other occupants
- (i) Use of alcohol or drugs
- (j) Food consumption
- (k) Washroom utilization

(3) Management

- (a) Clear, contractual arrangements for facility operation/use as follows:
 - i. Between facility owner and operator
 - ii. Between facility operator and event promoter

- iii. Between event promoter and performer
- iv. Between event promoter and attendee
- v. With police forces
- vi. With private security services
- vii. With ushering services

- (b) Experience with the building
- (c) Experience with similar events and attendees
- (d) Thorough, up-to-date operations manual
- (e) Training of personnel
- (f) Supervision of personnel
- (g) Communications systems and utilization
- (h) Ratios of management and other personnel to attendees
 - (i) Location/distribution of personnel
 - (j) Central command location
 - (k) Rapport between personnel and attendees
 - (l) Personnel supportive of attendee goals
- (m) Attendees respect for personnel due to the following:
 - i. Dress (uniform) standards
 - ii. Age and perceived experience
 - iii. Personnel behavior, including interaction
 - iv. Distinction between crowd management and control
 - v. Management's concern for facility quality (e.g., cleanliness)
 - vi. Management's concern for entire event experience of attendees (i.e., not just during the occupancy of the building)

(4) Emergency Management Preparedness

- (a) Complete range of emergencies addressed in operations manual
- (b) Power loss
- (c) Fire
- (d) Severe weather
- (e) Earthquake
- (f) Crowd incident
- (g) Terrorism
- (h) Hazardous materials
 - (i) Transportation accident (e.g., road, rail, air)
 - (j) Communications systems available
- (k) Personnel and emergency forces ready to respond
- (l) Attendees clearly informed of situation and proper behavior

(5) Building Systems

- (a) Structural soundness
- (b) Normal static loads
- (c) Abnormal static loads (e.g., crowds, precipitation)
- (d) Dynamic loads (e.g., crowd sway, impact, explosion, wind, earthquake)
- (e) Stability of nonstructural components (e.g., lighting)
- (f) Stability of movable (e.g., telescoping) structures
- (g) Fire protection
- (h) Fire prevention (e.g., maintenance, contents, house-keeping)
 - (i) Compartmentation
 - (j) Automatic detection and suppression of fire
- (k) Smoke control
 - (l) Alarm and communications systems
- (m) Fire department access routes and response capability
- (n) Structural integrity
- (o) Weather protection
- (p) Wind

- (q) Precipitation (attendees rush for shelter or hold up egress of others)
- (r) Lightning
- (s) Circulation systems
- (t) Flowline or network analysis
- (u) Wayfinding and orientation
- (v) Merging of paths (e.g., precedence behavior)
- (w) Decision/branching points
- (x) Route redundancies
- (y) Counterflow, crossflow, and queuing situations
- (z) Control possibilities, including metering
- (aa) Flow capacity adequacy
- (bb) System balance
- (cc) Movement time performance
- (dd) Flow times
- (ee) Travel times
- (ff) Queuing times
- (gg) Route quality
- (hh) Walking surfaces (e.g., traction, discontinuities)
- (ii) Appropriate widths and boundary conditions
- (jj) Handrails, guardrails, and other rails
- (kk) Ramp slopes
- (ll) Step geometries
- (mm) Perceptual aspects (e.g., orientation, signage, marking, lighting, glare, distractions)
- (nn) Route choices, especially for vertical travel
- (oo) Resting/waiting areas
- (pp) Levels of service (overall crowd movement quality)
- (qq) Services
- (rr) Washroom provision and distribution
- (ss) Concessions
- (tt) First aid and EMS facilities
- (uu) General attendee services

A scenario-based approach to performance-based fire safety is addressed in Chapter 5. In addition to using such scenarios and, more generally, the attention to performance criteria, evaluation, safety factors, documentation, maintenance, and periodic assessment required when the Chapter 5 option is used, life safety evaluations should consider scenarios based on characteristics important in assembly occupancies. These characteristics include the following:

- (1) Whether there is a local or mass awareness of an incident, event, or condition that might provoke egress
- (2) Whether the incident, event, or condition stays localized or spreads
- (3) Whether or not egress is designed by facility occupants
- (4) Whether there is a localized start to any egress or mass start to egress
- (5) Whether exits are available or not available

Examples of scenarios and sets of characteristics that might occur in a facility include the following.

Scenario 1. Characteristics: Mass start, egress desired (by management and attendees), exits not available, local awareness.

Normal egress at the end of an event occurs just as a severe weather condition induces evacuees at the exterior doors to retard or stop their egress. The backup that occurs in the egress system is not known to most evacuees, who continue to press forward (potentially resulting in a crowd crush).

Scenario 2. Characteristics: Mass start, egress not desired (by management), exits possibly not available, mass awareness.

An earthquake occurs during an event. The attendees are relatively safe in the seating area. The means of egress outside the seating areas are relatively unsafe and vulnerable to after-shock damage. Facility management discourages mass egress until the means of egress can be checked and cleared for use.

Scenario 3. Characteristics: Local start, incident stays local, egress desired (by attendees and management), exits available, mass awareness.

A localized civil disturbance (for example, firearms violence) provokes localized egress, which is seen by attendees, generally, who then decide to leave also.

Scenario 4. Characteristics: Mass start, egress desired, incident spreads, exits not available, mass awareness.

In an open-air facility unprotected from wind, precipitation, and lightning, sudden severe weather prompts egress to shelter but not from the facility. The means of egress congest and block quickly as people in front stop once they are under shelter while people behind them continue to press forward (potentially resulting in a crowd crush).

These scenarios illustrate some of the broader factors to be taken into account when assessing the capability of both building systems and management features on which reliance is placed in a range of situations, not just fire emergencies. Some scenarios also illustrate the conflicting motivations of management and attendees based on differing perceptions of danger and differing knowledge of hazards, countermeasures, and capabilities. Mass egress might not be the most appropriate life safety strategy in some scenarios, such as Scenario 2.

Table A.12.4.1.3 summarizes the characteristics in the scenarios and provides a framework for developing other characteristics and scenarios that might be important for a particular facility, hazard, occupant type, event, or management.

A.12.4.2 Outdoor facilities are not accepted as inherently smoke-protected but must meet the requirements of smoke-protected assembly seating in order to utilize the special requirements for means of egress.

A.12.4.2.1(1)(b) The engineering analysis should be part of the life safety evaluation required by 12.4.1.

Table A.12.4.1.3 Life Safety Evaluation Scenario Characteristics Matrix

Scenario	Management						Occupants						Other
	Local Awareness	Mass Awareness	Incident Localized	Incident Spreads	Egress Desired	Egress Not Desired	Egress Desired	Egress Not Desired	Local Start	Mass Start	Exits Available	Exits Not Available	
1	X				X		X			X		X	
2		X				X				X		X	
3		X	X		X		X		X				
4		X		X			X			X		X	

A.12.4.5.7 Proscenium openings may be protected by one of three means:

- (1) A listed, minimum 20-minute opening protective assembly that might be a door or a curtain
- (2) A fire curtain in accordance with 12.4.5.7.2(A) through 12.4.5.7.2(G) with the fabric tested for 30 minutes
- (3) A water curtain in accordance with NFPA 13

A.12.4.5.12 Prior editions of the *Code* required stages to be protected by a Class III standpipe system in accordance with NFPA 14, *Standard for the Installation of Standpipe, Private Hydrant, and Hose Systems*. NFPA 14 requires that Class II and Class III standpipes be automatic — not manual — because they are intended to be used by building occupants. Automatic standpipe systems are required to provide not less than 1890 L/min (500 gpm) at 689 kN (100 psi). This requirement often can be met only if a fire pump is installed. Installation of a fire pump presents an unreasonable burden for the system supplying the two hose outlets at the side of the stage. The revised wording of 12.4.5.12 offers some relief by permitting the hose outlets to be in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

A.12.4.7 Where a special amusement building is installed inside another building, such as within an exhibit hall, the special amusement building requirements apply only to the special amusement building. For example, the smoke detectors required by 12.4.7.4 are not required to be connected to the building's system. Where installed in an exhibit hall, such smoke detectors are also required to comply with the provisions applicable to an exhibit.

A.12.4.7.1 The aggregate horizontal projections of a multi-level play structure are indicative of the number of children who might be within the structure and at risk from a fire or similar emergency. The word "aggregate" is used in recognition that the platforms and tubes that make up the multilevel play structure run above each other at various levels. In calculating the area of the projections, it is important to account for all areas that might be expected to be occupied within, on top, or beneath the components of the structure when the structure is used for its intended function.

A.12.4.7.2 See A.12.4.7.1.

A.12.4.7.7.3 Consideration should be given to the provision of directional exit marking on or adjacent to the floor.

A.12.4.10.2(2) Delayed egress locks doors from the airport loading walkway into the airport terminal building might compromise life safety due to the limited period of time the airport loading walkway will provide protection for emergency egress. The requirement of 12.4.10.2(2) would not limit the use of access-controlled or delayed-egress hardware from the airport terminal building into the airport loading walkway.

A.12.7.1.4(5) NFPA 58, *Liquefied Petroleum Gas Code*, permits portable butane-fueled appliances in restaurants and in attended commercial food catering operations where fueled by not more than two 0.3-L (10-oz) LP-Gas capacity, nonrefillable butane containers that have a water capacity not exceeding 0.5 kg (1.08 lb) per container. The containers are required to be directly connected to the appliance, and manifold of containers is not permitted. Storage of cylinders is also limited to 24 containers, with an additional 24 permitted where protected by a 2-hour fire resistance-rated barrier.

A.12.7.2(3)(a) Securely supported altar candles in churches that are well separated from any combustible material are per-

mitted. On the other hand, lighted candles carried by children wearing cotton robes present a hazard too great to be permitted. There are many other situations of intermediate hazard where the authority having jurisdiction will have to exercise judgment.

A.12.7.3.3 The term *unprotected materials containing foamed plastic* is meant to include foamed plastic items covered by "thermally thin" combustible fabrics or paint. (See A.10.2.3.4.)

A.12.7.4.3.4(3) The authority having jurisdiction might use the field flame test contained in NFPA 705, *Recommended Practice for a Field Flame Test for Textiles and Films*, as one method of determining flame retardancy.

A.12.7.4.3.7.1(3) See A.12.4.1.1.

A.12.7.5 The training program in crowd management should develop a clear appreciation of factors of space, energy, time, and information, as well as specific crowd management techniques such as metering. Published guidelines on these factors and techniques are found in the *SFPE Handbook of Fire Protection Engineering*, Section 3, Chapter 13.

A.12.7.6 It is important that an adequate number of competent attendants are on duty at all times when the assembly occupancy is occupied.

A.12.7.6.3 It is not the intent of this provision to require an announcement in bowling alleys, cocktail lounges, restaurants, or places of worship.

A.13.1.2.2 Example. An assembly room for the residents of a detention occupancy will not normally be subject to simultaneous occupancy.

A.13.1.3 An understanding of the term *accessory room* might be useful to the enforcer of the *Code*, although the term is not used within the *Code*. An accessory room includes a dressing room, the property master's work and storage rooms, the carpenter's room, or similar rooms necessary for legitimate stage operations.

A.13.1.4 Assembly occupancy requirements should be determined on a room-by-room basis, a floor-by-floor basis, and a total building basis. The requirements for each room should be based on the occupant load of that room and the requirements for each floor should be based on the occupant load of that floor, but the requirements for the assembly building overall should be based on the total occupant load. Therefore, it is quite feasible to have several assembly occupancies with occupant loads of 300 or less grouped together in a single building. Such a building would be an assembly occupancy with an occupant load of over 1000.

A.13.1.7.1 The increase in occupant load above that calculated using occupant load factors from Table 7.3.1.2 is permitted, if the provisions of 13.1.7.1 are followed. The owner or operator has the right to submit plans and to be permitted an increase in occupant load if the plans comply with the *Code*. The authority having jurisdiction is permitted to reject the plan for increase in occupant load if the plan is unrealistic, inaccurate, or otherwise does not properly reflect compliance with other *Code* requirements. It is not the intent of the provisions of 13.1.7.1 to prohibit an increase in occupant load solely on the basis of exceeding the limits calculated using occupant load factors from Table 7.3.1.2.

Existing auditorium and arena structures might not be designed for the added occupant load beyond the fixed seating. The authority having jurisdiction should consider exit access

and aisles before permitting additional occupant load in areas using seating such as festival seating or movable seating on the auditorium or arena floor area.

To assist in preventing serious overcrowding incidents in sports arenas, stadia, and similar occupancies, spectator standing room should not be permitted between the seating areas and the playing areas, except in horse race and dog track facilities.

Where a capacity or near-capacity audience is anticipated, all seating should be assigned with tickets showing the section, row, and seat number.

Where standing room is permitted, the capacity of the standing area should meet the following criteria:

- (1) It should be determined on the basis of 0.46 m^2 (5 ft^2) per person.
- (2) It should have its capacity added to the seating capacity in determining egress requirements.
- (3) It should be located to the rear of the seating area.
- (4) It should be assigned standing-room-only tickets according to the area designated for the purpose.

The number of tickets sold or otherwise distributed should not exceed the aggregate number of seats plus the approved standing room numbers.

A.13.2.2.3.1(1) The seating plan and the means of egress should be reviewed each time the seating is substantially rearranged.

A.13.2.2.3.2 The provisions of 13.2.3.2 should be applied within the audience seating chamber and to the room doors. The capacity of means of egress components encountered after leaving the audience seating chamber, such as concourses, lobbies, exit stair enclosures, and the exit discharge, should be calculated in accordance with Section 7.3.

A.13.2.3.6.5 The original *Code* wording exempted sports arenas and railway stations. If an assembly occupancy was not similar to a sports arena or railway station, it was often judged ineligible to use the provision of 13.2.3.6.5. A list of exempted assembly venues also raises the question as to why other occupancies are not included and necessitates additions to the list. For example, an exhibit hall of very large size might have several main entrances/exits. A theater extending the width of a block cannot really have a main entrance/exit in one confined location. A restaurant might have a main entrance serving the parking lot and another main entrance for those entering from the street. The authority having jurisdiction needs to determine where such arrangements are acceptable.

A.13.2.4 It is not the intent to require four means of egress from each level of an assembly occupancy building having a total occupant load of more than 1000 where, individually, the floors have occupant loads of less than 1000.

A.13.2.5.4.2 This requirement and the associated requirement of 13.2.5.4.3 have the effect of prohibiting festival seating unless it truly is a form of seating, such as lawn seating, where generous spaces are commonly maintained between individuals and small groups so that people can circulate freely at any time. Such lawn seating will be characterized by densities of about one person per 1.4 m^2 (15 ft^2). Both requirements prohibit uncontrolled crowd situations, such as in front of stages at rock music concerts where the number and density of people is uncontrolled by architectural or management features.

A.13.2.5.4.3 This requirement is intended to facilitate rapid emergency access to individuals who are experiencing a medical emergency, especially in the case of cardiopulmonary diffi-

culties, where there is a need for rapid medical attention from trained personnel. The requirement also addresses the need for security and law enforcement personnel to reach individuals whose behavior is endangering themselves and others.

A.13.2.5.4.4 The catchment area served by an aisle accessway or aisle is the portion of the total space that is naturally served by the aisle accessway or aisle. Hence, the requirement for combining the required capacity where paths converge is, in effect, a restatement of the idea of a catchment area. The establishment of catchment areas should be based on a balanced use of all means of egress, with the number of persons in proportion to egress capacity.

A.13.2.5.5 For purposes of the means of egress requirements of this *Code*, tablet-arm chair seating is not considered seating at tables. Dinner theater-style configurations are required to comply with the aisle accessway provisions applying to seating at tables and the aisle requirements of 13.2.5.6, if the aisles contain steps or are ramped. Generally, if aisles contain steps or are ramped, all of this *Code's* requirements for aisles, stairs, and ramps are required to be met. (*Also see 7.1.7 and A.7.1.7.2.*)

A.13.2.5.5.1 Seats having reclining backs are assumed to be in their most upright position when unoccupied.

A.13.2.5.5.4 The system known as *continental seating* has one pair of egress doors provided for every five rows that is located close to the ends of the rows. In previous editions of the *Code*, such egress doors were required to provide a clear width of not less than 1675 mm (66 in.) discharging into a foyer, into a lobby, or to the exterior of the building. This continental seating arrangement can result in egress flow times (that is, with nominal flow times of approximately 100 seconds rather than 200 seconds) that are approximately one-half as long as those resulting where side aisles lead to more remote doors. Such superior egress flow time performance is desirable in some situations; however, special attention should be given either to a comparably good egress capacity for other parts of the egress system or to sufficient space to accommodate queuing outside the seating space.

A.13.2.5.6.3 It is the intent to permit handrails to project not more than 90 mm ($3\frac{1}{2}$ in.) into the clear width of aisles required by 13.2.5.6.3.

A.13.2.5.6.4 Technical information about the convenience and safety of ramps and stairs having gradients in the region of 1 in 8 clearly suggests that the goal should be slopes for ramps that are less steep and combinations of stair risers and treads that are, for example, superior to 100-mm (4-in.) risers and 865-mm (32-in.) treads. This goal should be kept in mind by designers in establishing the gradient of seating areas to be served by aisles.

A.13.2.5.6.5(1)(a) Completely uniform tread dimensions are preferred over aisle stair designs where tread depths alternate between relatively small intermediate treads between seating platforms and relatively large treads at seating platforms. A larger tread that is level with the seating platform is not needed to facilitate easy access to and egress from a row of seating. If this arrangement is used, it is important to provide a tread depth that is better than minimum for the intermediate tread; hence, 330 mm (13 in.) is specified. Where nonuniformities exist due to construction tolerance, they should not exceed 4.8 mm ($\frac{3}{16}$ in.) between adjacent treads.

A.13.2.5.6.5(2) Tread depth is more important to stair safety than is riser height. Therefore, in cases where the seating area

gradient is less than 5 in 11, it is recommended that the tread dimension be increased beyond 280 mm (11 in.) rather than reducing the riser height. Where the seating area gradient exceeds 8 in 11, it is recommended that the riser height be increased while maintaining a tread depth of not less than 280 mm (11 in.).

A.13.2.5.6.7 Failure to provide a handrail within a 760-mm (30-in.) horizontal distance of all required portions of the aisle stair width means that the egress capacity calculation is required to be modified as specified by 13.2.3.3(3). This modification might lead to an increase in the aisle width. Although this increase will compensate for reduced egress efficiency, it does not help individuals walking on such portions of stairs to recover from missteps other than by possibly reducing marginally the crowding that might exacerbate the problem of falls. (See also 7.2.2.4.)

A.13.2.5.6.8 Certain tread cover materials such as plush carpets, which are often used in theaters, produce an inherently well-marked tread nosing under most lighting conditions. On the other hand, concrete treads have nosings with a sharp edge and, especially under outdoor lighting conditions, are difficult to discriminate. Therefore, concrete treads require an applied marking stripe. The slip resistance of such marking stripes should be similar to the rest of the treads, and no tripping hazard should be created; luminescent, self-luminous, and electroluminescent tread markings have the advantage of being apparent in reduced light or in the absence of light.

A.13.2.5.7 For purposes of the means of egress requirements of this *Code*, seating at counters or at other furnishings is considered to be the same as seating at tables.

A.13.2.5.7.2 Effectively, where the aisle accessway is bounded by movable seating, the 305-mm (12-in.) minimum width might be increased by about 380 mm to 760 mm (15 in. to 30 in.) as seating is pushed in toward tables. Moreover, it is such movement of chairs during normal and emergency egress situations that makes the zero-clearance exception workable. The exception also applies to booth seating where people sitting closest to the aisle normally move out ahead of people farthest from the aisle.

A.13.2.5.7.3 See A.13.2.5.8.3.

A.13.2.5.7.4 The minimum width requirement as a function of accessway length is as follows:

- (1) 0 mm (0 in.) for the first 1830 mm (72 in.) of length toward the exit
- (2) 305 mm (12 in.) for the next 1830 mm (72 in.), that is, up to 3660 mm (144 in.) of length
- (3) 305 mm to 610 mm (12 in. to 24 in.) for lengths from 3660 mm to 10,900 mm (144 in. to 432 in.), the maximum length to the closest aisle or egress doorway permitted by 13.2.5.7.4

Any additional width needed for seating is to be added to these widths, as described in 13.2.5.8.3.

A.13.2.5.8.1 See 7.1.7 and A.7.1.7.2 for special circulation safety precautions applicable where small elevation differences occur.

A.13.2.5.8.2 It is important to make facilities accessible to people using wheelchairs. See ICC/ANSI A117.1 *American National Standard for Accessible and Usable Buildings and Facilities*, which provides guidance on appropriate aisle widths.

A.13.2.5.8.3 Figure A.13.2.5.8.3 shows typical measurements involving seating and tables abutting an aisle. Note that, for purposes of the means of egress requirements of this *Code*, seating at counters or other furnishings is considered to be the same as seating at tables.




FIGURE A.13.2.5.8.3 Seating at Tables Abutting an Aisle.

A.13.3.1(1) The allowance for unenclosed stairs or ramps presumes the balcony or mezzanine complies with the other provisions of the *Code*, such as travel distance to exits in accordance with 13.2.6 and numbers of exits in accordance with 13.2.4. For the purposes of this exception, a balcony with glazing that provides a visual awareness of the main assembly area is considered open.

A.13.3.4.2.3 The intent is to require detectors only in nonsprinklered hazardous areas that are unoccupied. Where the building is occupied, the detectors in the unoccupied, unsprinklered hazardous areas will initiate occupant notification. If the building is unoccupied, the fire in the nonsprinklered hazardous area is not a life safety issue, and the detectors, upon activation, are not required to notify anyone. The signal from a detector is permitted to be sent to a control panel in an area that is occupied when the building is occupied, but that is unoccupied when the building is unoccupied, without the need for central station monitoring or the equivalent.

A.13.4.1.1 Life safety evaluations are examples of performance-based approaches to life safety. In this respect, significant guidance in the form and process of life safety evaluations is provided by Chapter 5, keeping in mind the firesafety emphasis in Chapter 5. The general approach to performance criteria, scenarios, evaluation, safety factors, documentation, maintenance, and periodic assessment (including a warrant of fitness) all apply to the broader considerations in a life safety evaluation. A life safety evaluation deals not only with fire but also with fire, storm, collapse, crowd behavior, and other related safety considerations for which a checklist is provided in A.13.4.1.3. Chapter 5 provides guidance, based on fire safety requirements, for establishing a documented case showing that products of combustion in all conceivable fire scenarios will not significantly endanger occupants using means of egress in the facility (for example, because of fire detection, automatic suppression, smoke control, large-volume space, or management procedures). Moreover, means of egress facilities plus facility management capabilities should

be adequate to cope with scenarios where certain egress routes are blocked for some reason.

In addition to making realistic assumptions about the capabilities of persons in the facility (for example, an assembled crowd including many disabled persons or persons unfamiliar with the facility), the life safety evaluation should include a factor of safety of not less than 2.0 in all calculations relating to hazard development time and required egress time (the combination of flow time and other time needed to detect and assess an emergency condition, initiate egress, and move along the egress routes). This factor of safety takes into account the possibility that half of the egress routes might not be used (or usable) in certain situations.

Regarding crowd behavior, the potential hazards created by larger masses of people and greater crowd densities (which can be problematic during ingress, occupancy, and egress) demand that technology be used by designers, managers, and authorities responsible for buildings to compensate for the relaxed egress capacity provisions of Table 13.4.2.3. In very large buildings for assembly use, the hazard of crowd crushes can exceed that of fire or structural failure. Therefore, the building designers, managers, event planners, security personnel, police authorities, and fire authorities, as well as the building construction authorities, should understand the potential problems and solutions, including coordination of their activities. For crowd behavior, this understanding includes factors of space, energy, time, and information, as well as specific crowd management techniques such as metering. Published guidance on these factors and techniques is found in the *SFPE Handbook of Fire Protection Engineering*, Section 3, Chapter 13, pp. 3-263-3-285 (Pauls, J., "Movement of People") and the publications referenced therein.

Table 13.2.3.2 and Table 13.4.2.3 are based on a linear relationship between number of seats and nominal flow time, with not less than 200 seconds (3.3 minutes) for 2000 seats plus 1 second for every additional 50 seats up to 25,000. Beyond 25,000 total seats, the nominal flow time is limited to 660 seconds (11 minutes). Nominal flow time refers to the flow time for the most able group of patrons; some groups less familiar with the premises or less able groups might take longer to pass a point in the egress system. Although three or more digits are noted in the tables, the resulting calculations should be assumed to provide only two significant figures of precision.

A.13.4.1.3 Factors to be considered in a life safety evaluation might include the following.

- (1) Nature of the Events Being Accommodated
 - (a) Ingress, intra-event movement, and egress patterns
 - (b) Ticketing and seating policies/practices
 - (c) Event purpose (e.g., sports contest, religious meeting)
 - (d) Emotional qualities (e.g., competitiveness) of event
 - (e) Time of day when event held
 - (f) Time duration of single event
 - (g) Time duration of attendees' occupancy of the building
- (2) Occupant Characteristics and Behavior
 - (a) Homogeneity
 - (b) Cohesiveness
 - (c) Familiarity with building
 - (d) Familiarity with similar events
 - (e) Capability (as influenced by factors such as age, physical abilities)
 - (f) Socioeconomic factors
 - (g) Small minority involved with recreational violence
- (h) Emotional involvement with the event and other occupants
- (i) Use of alcohol or drugs
- (j) Food consumption
- (k) Washroom utilization
- (3) Management
 - (a) Clear, contractual arrangements for facility operation/use as follows:
 - i. Between facility owner and operator
 - ii. Between facility operator and event promoter
 - iii. Between event promoter and performer
 - iv. Between event promoter and attendee
 - v. With police forces
 - vi. With private security services
 - vii. With ushering services
 - (b) Experience with the building
 - (c) Experience with similar events and attendees
 - (d) Thorough, up-to-date operations manual
 - (e) Training of personnel
 - (f) Supervision of personnel
 - (g) Communications systems and utilization
 - (h) Ratios of management and other personnel to attendees
 - (i) Location/distribution of personnel
 - (j) Central command location
 - (k) Rapport between personnel and attendees
 - (l) Personnel supportive of attendee goals
 - (m) Attendees respect for personnel due to the following:
 - i. Dress (uniform) standards
 - ii. Age and perceived experience
 - iii. Personnel behavior, including interaction
 - iv. Distinction between crowd management and control
 - v. Management's concern for facility quality (e.g., cleanliness)
 - vi. Management's concern for entire event experience of attendees (i.e., not just during the occupancy of the building)
- (4) Emergency Management Preparedness
 - (a) Complete range of emergencies addressed in operations manual
 - (b) Power loss
 - (c) Fire
 - (d) Severe weather
 - (e) Earthquake
 - (f) Crowd incident
 - (g) Terrorism
 - (h) Hazardous materials
 - (i) Transportation accident (e.g., road, rail, air)
 - (j) Communications systems available
 - (k) Personnel and emergency forces ready to respond
 - (l) Attendees clearly informed of situation and proper behavior
- (5) Building Systems
 - (a) Structural soundness
 - (b) Normal static loads
 - (c) Abnormal static loads (e.g., crowds, precipitation)
 - (d) Dynamic loads (e.g., crowd sway, impact, explosion, wind, earthquake)
 - (e) Stability of nonstructural components (e.g., lighting)
 - (f) Stability of movable (e.g., telescoping) structures
 - (g) Fire protection

- (h) Fire prevention (e.g., maintenance, contents, house-keeping)
- (i) Compartmentation
- (j) Automatic detection and suppression of fire
- (k) Smoke control
- (l) Alarm and communications systems
- (m) Fire department access routes and response capability
- (n) Structural integrity
- (o) Weather protection
- (p) Wind
- (q) Precipitation (attendees rush for shelter or hold up egress of others)
- (r) Lightning
- (s) Circulation systems
- (t) Flowline or network analysis
- (u) Waywinding and orientation
- (v) Merging of paths (e.g., precedence behavior)
- (w) Decision/branching points
- (x) Route redundancies
- (y) Counterflow, crossflow, and queuing situations
- (z) Control possibilities, including metering
- (aa) Flow capacity adequacy
- (bb) System balance
- (cc) Movement time performance
- (dd) Flow times
- (ee) Travel times
- (ff) Queuing times
- (gg) Route quality
- (hh) Walking surfaces (e.g., traction, discontinuities)
 - (ii) Appropriate widths and boundary conditions
 - (jj) Handrails, guardrails, and other rails
- (kk) Ramp slopes
- (ll) Step geometries
- (mm) Perceptual aspects (e.g., orientation, signage, marking, lighting, glare, distractions)
- (nn) Route choices, especially for vertical travel
- (oo) Resting/waiting areas
- (pp) Levels of service (overall crowd movement quality)
- (qq) Services
- (rr) Washroom provision and distribution
- (ss) Concessions
- (tt) First aid and EMS facilities
- (uu) General attendee services

A scenario-based approach to performance-based fire safety is addressed in Chapter 5. In addition to utilizing such scenarios and, more generally, the attention to performance criteria, evaluation, safety factors, documentation, maintenance, and periodic assessment required when the Chapter 5 option is used, life safety evaluations should consider scenarios based on characteristics important in assembly occupancies. These characteristics include the following:

- (1) Whether there is a local or mass awareness of an incident, event, or condition that might provoke egress
- (2) Whether the incident, event, or condition stays localized or spreads
- (3) Whether or not egress is designed by facility occupants
- (4) Whether there is a localized start to any egress or mass start to egress
- (5) Whether exits are available or not available

Examples of scenarios and sets of characteristics that might occur in a facility include the following.

Scenario 1. Characteristics: Mass start, egress desired (by management and attendees), exits not available, local awareness.

Normal egress at the end of an event occurs just as a severe weather condition induces evacuees at the exterior doors to retard or stop their egress. The backup that occurs in the egress system is not known to most evacuees, who continue to press forward potentially resulting in a crowd crush.

Scenario 2. Characteristics: Mass start, egress not desired (by management), exits possibly not available, mass awareness.

An earthquake occurs during an event. The attendees are relatively safe in the seating area. The means of egress outside the seating areas are relatively unsafe and vulnerable to after-shock damage. Facility management discourages mass egress until the means of egress can be checked and cleared for use.

Scenario 3. Characteristics: Local start, incident stays local, egress desired (by attendees and management), exits available, mass awareness.

A localized civil disturbance (for example, firearms violence) provokes localized egress, which is seen by attendees, generally, who then decide to leave also.

Scenario 4. Characteristics: Mass start, egress desired, incident spreads, exits not available, mass awareness.

In an open-air facility unprotected from wind, precipitation, and lightning, sudden severe weather prompts egress to shelter but not from the facility. The means of egress congest and block quickly as people in front stop once they are under shelter while people behind them continue to press forward, potentially resulting in a crowd crush.

These scenarios illustrate some of the broader factors to be taken into account when assessing the capability of both building systems and management features on which reliance is placed in a range of situations, not just fire emergencies. Some scenarios also illustrate the conflicting motivations of management and attendees based on differing perceptions of danger and differing knowledge of hazards, countermeasures, and capabilities. Mass egress might not be the most appropriate life safety strategy in some scenarios, such as Scenario 2.

Table A.13.4.1.3 summarizes the characteristics in the scenarios and provides a framework for developing other characteristics and scenarios that might be important for a particular facility, hazard, occupant type, event, or management.

A.13.4.2 Outdoor facilities are not accepted as inherently smoke-protected but must meet the requirements of smoke-protected assembly seating in order to use the special requirements for means of egress.

A.13.4.2.1(1)(b) The engineering analysis should be part of the life safety evaluation required by 13.4.1.

A.13.4.5.12 Prior editions of the *Code* required stages to be protected by a Class III standpipe system in accordance with NFPA 14, *Standard for the Installation of Standpipe, Private Hydrant, and Hose Systems*. NFPA 14 requires that Class II and Class III standpipes be automatic — not manual — because they are intended to be used by building occupants. Automatic standpipe systems are required to provide not less than 1890 L/min (500 gpm) at 689 kN/m² (100 psi). This requirement often can be met only if a fire pump is installed. Installation of a fire pump presents an unreasonable burden for the system supplying the two hose outlets at the side of the stage. The revised wording of 13.4.5.12 offers some relief by permitting the hose outlets to be in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

Table A.13.4.1.3 Life Safety Evaluation Scenario Characteristics Matrix

Scenario	Local Awareness	Mass Awareness	Incident Localized	Incident Spreads	Management		Occupants		Local Start	Mass Start	Exits Available	Exits Not Available	Other
					Egress Desired	Egress Not Desired	Egress Desired	Egress Not Desired					
1	X				X		X			X		X	
2		X				X		X		X		X	
3		X	X		X		X		X				
4		X		X			X			X		X	

A.13.4.7 Where a special amusement building is installed inside another building, such as within an exhibit hall, the special amusement building requirements apply only to the special amusement building. For example, the smoke detectors required by 13.4.7.4 are not required to be connected to the building's system. Where installed in an exhibit hall, such smoke detectors are also required to comply with the provisions applicable to an exhibit.

A.13.4.7.1 The aggregate horizontal projections of a multi-level play structure are indicative of the number of children who might be within the structure and at risk from a fire or similar emergency. The word "aggregate" is used in recognition that the platforms and tubes that make up the multilevel play structure run above each other at various levels. In calculating the area of the projections, it is important to account for all areas that might be expected to be occupied within, on top, or beneath the components of the structure when the structure is used for its intended function.

A.13.4.7.2 See A.13.4.7.1.

A.13.4.7.7.3 Consideration should be given to the provision of directional exit marking on or adjacent to the floor.

A.13.4.10.2(2) Delayed egress locks doors from the airport loading walkway into the airport terminal building might compromise life safety due to the limited period of time the airport loading walkway will provide protection for emergency egress. The requirement of 13.4.10.2(2) would not limit the use of access-controlled or delayed-egress hardware from the airport terminal building into the airport loading walkway.

A.13.7.1.4(5) NFPA 58, *Liquefied Petroleum Gas Code*, permits portable butane-fueled appliances in restaurants and in attended commercial food catering operations where fueled by not in excess of two 0.3-L (10-oz) LP-Gas capacity, nonrefillable butane containers that have a water capacity not exceeding 0.5 kg (1.08 lb) per container. The containers are required to be directly connected to the appliance, and manifolding of containers is not permitted. Storage of cylinders is also limited to 24 containers, with an additional 24 permitted where protected by a 2-hour fire resistance-rated barrier.

A.13.7.2(3)(a) Securely supported altar candles in churches that are well separated from any combustible material, are permitted. On the other hand, lighted candles carried by children wearing cotton robes present a hazard too great to be permitted. There are many other situations of intermediate hazard where the authority having jurisdiction will have to exercise judgment.

A.13.7.3.3 The term *unprotected materials containing foamed plastic* is meant to include foamed plastic items covered by "thermally-thin" combustible fabrics or paint. (See A.10.2.3.4.)

A.13.7.4.3.4(3) The authority having jurisdiction might use the field flame test contained in NFPA 705, *Recommended Practice for a Field Flame Test for Textiles and Films*, as one method of determining flame retardancy.

A.13.7.4.3.7.1(3) See A.13.4.1.1.

A.13.7.5 The training program in crowd management should develop a clear appreciation of factors of space, energy, time, and information, as well as specific crowd management techniques such as metering. Published guidelines on these factors and techniques are found in the *SFPE Handbook of Fire Protection Engineering*, Section 3, Chapter 13.

A.13.7.6 It is important that an adequate number of competent attendants are on duty at all times when the assembly occupancy is occupied.

A.13.7.6.3 It is not the intent of this provision to require an announcement in bowling alleys, cocktail lounges, restaurants, or places of worship.

A.14.2.2.3 See A.7.2.2.4.4.4 regarding additional handrails on stairs that are used extensively by children 5 years of age or less.

A.14.2.5.8 A corridor roofed over and enclosed on its long side and open to the atmosphere at the end is permitted to be considered an exterior corridor if either of the following criteria are met:

- (1) Clear story openings for the corridor are provided on both sides of the corridor and above adjacent roofs or buildings, and such clear openings are not less than one-half the height of the corridor walls.
- (2) The corridor roof has unobstructed openings to the sky not less than 50 percent of the area of the roof.

The openings detailed in A.14.2.5.8(1) and A.14.2.5.8(2) are to be equally distributed, and, if louvers are installed, they are to be fixed open with a clear area based on the actual openings between louver vanes.

A.14.2.11.1 It is highly desirable that all windows be of a type that can be readily opened from inside and to have them large enough and low enough for use by students, teachers, and fire fighters. Windows are permitted to serve as a supplementary means of emergency escape, particularly where ladders can be raised by fire fighters or others.

A.14.3.4.2.3.1 Occupied portions of the building should have access to a central point for manual activation of the evacuation signal.

A.14.3.4.2.3.2 Occupied portions of the building should have access to a central point for manual activation of the evacuation signal.

A.14.3.4.3.1.1 Use of the distinctive three-pulse temporal pattern fire alarm evacuation signal that is required by *NFPA 72®*, *National Fire Alarm Code®*, will help educate students to recognize the need to evacuate when they are in other occupancies.

A.14.7.2.1 The requirements are, of necessity, general in scope, as it is recognized that they apply to all types of educational occupancies as well as conditions of occupancies, such as truant schools; schools for the mentally handicapped, vision impaired, hearing impaired, and speech impaired; and public schools. It is fully recognized that no one code can meet all the conditions of the various buildings involved, and it will be necessary for site administrators to issue supplements to these requirements, but all supplements should be consistent with these requirements.

A.14.7.3.1 Particular attention should be given to keeping all doors unlocked; keeping doors that serve to protect the safety of paths of egress closed and under no conditions blocked open, such as doors on stairway enclosures; keeping outside stairs and fire escape stairs free from all obstructions and clear of snow and ice; and allowing no accumulation of snow or ice or materials of any kind outside exit doors that might prevent the opening of the door or interfere with rapid escape from the building.

Any condition likely to interfere with safe egress should be corrected immediately, if possible, or otherwise should be reported at once to the appropriate authorities.

A.15.2.2.3 See A.7.2.2.4.4.4 regarding additional handrails on stairs that are used extensively by children 5 years of age or less.

A.15.2.5.8 A corridor roofed over and enclosed on its long side and open to the atmosphere at the end is permitted to be considered an exterior corridor if either of the following criteria are met:

- (1) Clear story openings for the corridor are provided on both sides of the corridor and above adjacent roofs or buildings, and such clear openings are not less than one-half the height of the corridor walls.
- (2) The corridor roof has unobstructed openings to the sky not less than 50 percent of the area of the roof.

The openings detailed in A.15.2.5.8(1) and A.15.2.5.8(2) are to be equally distributed, and, if louvers are installed, they are to be fixed open with a clear area based on the actual openings between louver vanes.

A.15.2.11.1 It is highly desirable that all windows be of a type that can be readily opened from inside and to have them large enough and low enough for use by students, teachers, and fire fighters. Windows are permitted to serve as a supplementary means of emergency escape, particularly where ladders can be raised by fire fighters or others.

A.15.3.4.2.3.1 Occupied portions of the building should have access to a central point for manual activation of the evacuation signal.

A.15.3.4.2.3.2 Occupied portions of the building should have access to a central point for manual activation of the evacuation signal.

A.15.3.4.3.1.1 The audible occupant notification signal for evacuation of an educational occupancy building should be the distinctive three-pulse temporal pattern fire alarm evacuation signal that is required of new systems by *NFPA 72®*, *National Fire Alarm Code®*. The temporal pattern will help educate students to recognize the need to evacuate when they are in

other occupancies. Existing fire alarm systems should be modified, as feasible, to sound the three-pulse temporal pattern.

A.15.3.6(2) This provision permits valve supervision in accordance with Section 9.7 rather than requiring that the entire automatic sprinkler system be electrically supervised. It is intended that the valve supervision be performed electrically, not by chaining and locking the valves in the open position.

A.15.7.2.1 The requirements are, of necessity, general in scope, as it is recognized that they apply to all types of educational occupancies as well as conditions of occupancies, such as truant schools; schools for the mentally handicapped, vision impaired, hearing impaired, and speech impaired; and public schools. It is fully recognized that no one code can meet all the conditions of the various buildings involved, and it will be necessary for site administrators to issue supplements to these requirements, but all supplements should be consistent with these requirements.

A.15.7.3.1 Particular attention should be given to keeping all doors unlocked; keeping doors that serve to protect the safety of paths of egress closed and under no conditions blocked open, such as doors on stairway enclosures; keeping outside stairs and fire escape stairs free from all obstructions and clear of snow and ice; and allowing no accumulation of snow or ice or materials of any kind outside exit doors that might prevent the opening of the door or interfere with rapid escape from the building.

Any condition likely to interfere with safe egress should be corrected immediately, if possible, or otherwise should be reported at once to the appropriate authorities.

A.16.1.1 Day-care occupancies do not provide for the full-time maintenance of a client. Occupancies that provide a primary place of residence are addressed in other occupancy chapters. (See Chapter 24 through Chapter 33.)

The requirements of Chapter 16 are based on the need to adequately protect the occupants in case of fire. The requirements assume that adequate staffing will be available and are based on staffing similar to that outlined in Table A.16.1.1.

Table A.16.1.1 Staffing

Staff-to-Client Ratio	Age (months)
1:3	0–24
1:4	25–36
1:7	37–60
1:10	61–96
1:12	≥97
1:3	Clients incapable of self-preservation

If staff-to-client ratios fall below that suggested by Table A.16.1.1, it is the responsibility of the authority having jurisdiction to determine the additional safeguards beyond the requirements of Chapter 16 that are necessary. Typical additional provisions might include restricting the day-care occupancy to the level of exit discharge, requiring additional smoke detection, requiring automatic sprinkler protection, requiring better or additional means of egress, and similar types of items, depending on the situation.

A.16.1.4.3 A conversion from a day-care occupancy with more than 12 clients to a day-care home is not considered a change of occupancy. The resulting day-care home should be permitted to meet the requirements of Chapter 17 for existing day-care homes.

A.16.2.2.2.4 The purpose of this requirement is to prevent arrangements whereby a child can be trapped in a closet. It is intended that this provision be broadly interpreted by the authority having jurisdiction to include equipment such as refrigerators and freezers.

A.16.2.2.3 See A.7.2.2.4.4.4 regarding additional handrails on stairs that are used extensively by children 5 years of age or less.

A.16.3.2.1(2)(a) It is not the intent to classify a room with a domestic-type clothes washer and a domestic-type clothes dryer as a laundry.

A.16.6.1.4.2 A conversion from a day-care occupancy with more than 12 clients to a day-care home is not considered a change of occupancy. The resulting day-care home should be permitted to meet the requirements of Chapter 17 for existing day-care homes.

A.16.7.1 The requirements are, of necessity, general in scope, because it is recognized that they apply to all types of day-care occupancies as well as conditions of occupancies, such as truant day-care occupancies; occupancies for the mentally handicapped, vision impaired, hearing impaired, and speech impaired; adult day-care; care of infants; and day-care occupancies. It is fully recognized that no one code can meet all the conditions of the various buildings involved, and it will be necessary for site administrators, through the written fire emergency response plan, to issue supplements to these requirements; however, all supplements should be consistent with these requirements. Additionally, it is recommended that fire safety be a part of the educational programs of the occupancy for clients.

Fire emergency response plans need to be written and made available to all employees, including temporary or substitute staff, so that all employees know what is expected of them during a fire emergency. The elements needed in the written plan should be identified in coordination with the authority having jurisdiction.

The facility fire emergency response plan might be a module of a facility disaster plan that covers other emergencies.

The proper safeguarding of clients during a fire emergency requires prompt and effective response by the facility employees in accordance with the fire emergency response plan. Duties covered under the plan should be assigned by position rather than by employee name. Such assignment ensures that, in the absence of an employee, the duties of the position will be performed by a substitute or temporary employee assigned to the position. Temporary or substitute employees should be instructed in advance regarding their duties under the plan for the position to which they are assigned.

Written fire emergency response plans should include, but should not be limited to, information for employees regarding methods and devices available for alerting occupants of a fire emergency. Employees should know how the fire department is to be alerted. Even where automatic systems are expected to alert the fire department, the written plan should provide for backup alerting procedures by staff. Other responses of employees to a fire emergency should include the following:

- (1) Removal of clients in immediate danger to areas of safety, as set forth in the plan

- (2) Methods of using building features to confine the fire and its byproducts to the room or area of origin
- (3) The control of actions and behaviors of clients during removal or evacuation activities and at predetermined safe assembly areas

The written plan should state clearly the facility policy regarding the actions staff are to take or not take to extinguish a fire. It should also incorporate the emergency egress and relocation drill procedures set forth in 16.7.2.

A.16.7.2.1 The requirements are, of necessity, general in scope, because it is recognized that they apply to all types of day-care occupancies as well as conditions of occupancies, such as truant day-care occupancies; day-care occupancies for the mentally handicapped, vision impaired, hearing impaired, and speech impaired. It is fully recognized that no one code can meet all the conditions of the various buildings involved, and it will be necessary for site administrators to issue supplements to these requirements, but all supplements should be consistent with these requirements.

A.16.7.3.2 Particular attention should be given to keeping all doors unlocked; keeping doors that serve to protect the safety of paths of egress closed and under no conditions blocked open, such as doors on stairway enclosures; keeping outside stairs and fire escape stairs free from all obstructions and clear of snow and ice; and allowing no accumulation of snow or ice or materials of any kind outside exit doors that might prevent the opening of the door or interfere with rapid escape from the building.

A.16.7.5 It is the intent that the requirement for adequate adult staff to be awake at all times when clients are present be applied to family day-care and group day-care homes that are operated at night, as well as day-care occupancies.

A.17.1.1 Day-care occupancies do not provide for the full-time maintenance of a client. Occupancies that provide a primary place of residence are addressed in other occupancies. (See Chapter 24 through Chapter 33.)

The requirements of Chapter 17 are based on the need to adequately protect the occupants in case of fire. The requirements assume that adequate staffing will be available and are based on staffing similar to that outlined in Table A.17.1.1.

Table A.17.1.1 Staffing

Staff-to-Client Ratio	Age (months)
1:3	0-24
1:4	25-36
1:7	37-60
1:10	61-96
1:12	≥97
1:3	Clients incapable of self-preservation

If staff-to-client ratios fall below that suggested by Table A.17.1.1, it is the responsibility of the authority having jurisdiction to determine what additional safeguards beyond the requirements of Chapter 17 are necessary. Typical additional provisions might include restricting the day-care occupancy to the level of exit discharge, requiring additional smoke detection, requiring automatic sprinkler protection, requiring better or additional means of egress, and similar types of items, depending on the situation.

A.17.1.4.3 A conversion from a day-care occupancy with more than 12 clients to a day-care home is not considered a change of occupancy. The resulting day-care home should be permitted to meet the requirements of Chapter 17 for existing day-care homes.

A.17.2.2.2.4 The purpose of this requirement is to prevent arrangements where a client can be trapped in a closet. It is intended that this provision be broadly interpreted by the authority having jurisdiction to include equipment such as refrigerators and freezers.

A.17.2.2.3 See A.7.2.2.4.4.4 regarding additional handrails on stairs that are used extensively by children 5 years of age and under.

A.17.3.2.1(2)(a) It is not the intent to classify a room with a domestic-type clothes washer and a domestic-type clothes dryer as a laundry.

A.17.6.1.1.2 Day-care homes do not provide for the full-time maintenance of a client. Day-care occupancies that provide a primary place of residence are addressed in other day-care occupancy chapters. (See Chapter 24 through Chapter 33.)

A.17.6.1.4.2 A conversion from a day-care occupancy with more than 12 clients to a day-care home is not considered a change of occupancy. The resulting day-care home should be permitted to meet the requirements of Chapter 17 for existing day-care homes.

A.17.7.1 The requirements are, of necessity, general in scope, because it is recognized that they apply to all types of day-care occupancies as well as conditions of occupancies, such as truant day-care occupancies; occupancies for the mentally handicapped, vision impaired, hearing impaired, and speech impaired; adult day-care; care of infants; and day-care occupancies. It is fully recognized that no one code can meet all the conditions of the various buildings involved, and it will be necessary for site administrators, through the written fire emergency response plan, to issue supplements to these requirements; however, all supplements should be consistent with these requirements. Additionally, it is recommended that fire safety be a part of the educational programs of the occupancy for clients.

Fire emergency response plans need to be written and made available to all employees, including temporary or substitute staff, so that all employees know what is expected of them during a fire emergency. The elements needed in the written plan should be identified in coordination with the authority having jurisdiction.

The facility fire emergency response plan might be a module of a facility disaster plan that covers other emergencies.

The proper safeguarding of clients during a fire emergency requires prompt and effective response by the facility employees in accordance with the fire emergency response plan. Duties covered under the plan should be assigned by position rather than by employee name. Such assignment ensures that, in the absence of an employee, the duties of the position will be performed by a substitute or temporary employee assigned to the position. Temporary or substitute employees should be instructed in advance regarding their duties under the plan for the position to which they are assigned.

Written fire emergency response plans should include, but should not be limited to, information for employees about methods and devices available for alerting occupants of a fire emergency. Employees should know how the fire department is to be alerted. Even where automatic systems are expected to

alert the fire department, the written plan should provide for backup alerting procedures by staff. Other responses of employees to a fire emergency should include the following:

- (1) Removal of clients in immediate danger to areas of safety, as set forth in the plan
- (2) Methods of using building features to confine the fire and its byproducts to the room or area of origin
- (3) The control of actions and behaviors of clients during removal or evacuation activities and at predetermined safe assembly areas

The written plan should state clearly the facility policy regarding the actions staff are to take or not take to extinguish a fire. It should also incorporate the emergency egress and relocation drill procedures set forth in 17.7.2.

A.17.7.2.1 The requirements are, of necessity, general in scope, because it is recognized that they apply to all types of day-care occupancies as well as conditions of occupancies, such as truant day-care occupancies; day-care occupancies for the mentally handicapped, vision impaired, hearing impaired, and speech impaired. It is fully recognized that no one code can meet all the conditions of the various buildings involved, and it will be necessary for site administrators to issue supplements to these requirements, but all supplements should be consistent with these requirements.

A.17.7.3.2 Particular attention should be given to keeping all doors unlocked; keeping doors that serve to protect the safety of paths of egress closed and under no conditions blocked open, such as doors on stairway enclosures; keeping outside stairs and fire escape stairs free from all obstructions and clear of snow and ice; and allowing no accumulation of snow or ice or materials of any kind outside exit doors that might prevent the opening of the door or interfere with rapid escape from the building.

A.17.7.5 It is the intent that the requirement for adequate adult staff to be awake at all times when clients are present be applied to family day-care and group day-care homes that are operated at night, as well as day-care occupancies.

A.18.1.1.1.1(4) In determining equivalency for conversions, modernizations, renovations, or unusual design concepts of hospitals or nursing homes, the authority having jurisdiction is permitted to accept evaluations based on the health care occupancies fire safety evaluation system (FSSES) of NFPA 101A, *Guide on Alternative Approaches to Life Safety*, utilizing the parameters for new construction.

A.18.1.1.1.8 The *Code* recognizes that certain functions necessary for the life safety of building occupants — such as the closing of corridor doors, the operation of manual fire alarm devices, and the removal of patients from the room of fire origin — require the intervention of facility staff. It is not the intent of 18.1.1.1.8 to specify the levels or locations of staff necessary to meet this requirement.

A.18.1.1.2 This objective is accomplished in the context of the physical facilities, the type of activities undertaken, the provisions for the capabilities of staff, and the needs of all occupants through requirements directed at the following:

- (1) Prevention of ignition
- (2) Detection of fire
- (3) Control of fire development
- (4) Confinement of the effects of fire
- (5) Extinguishment of fire

- (6) Provision of refuge or evacuation facilities, or both
- (7) Staff reaction

A.18.1.1.4.6.3 For the purpose of this requirement, a floor that is not divided by a smoke barrier is considered one smoke compartment.

A.18.1.1.4.6.4 In minor rehabilitation, only the rehabilitation itself — not the entire smoke compartment or building — is required to be brought up to the requirements for new non-sprinklered facilities.

A.18.1.2.2 Doctors' offices and treatment and diagnostic facilities that are intended solely for outpatient care and are physically separated from facilities for the treatment or care of inpatients, but that are otherwise associated with the management of an institution, might be classified as business occupancies rather than health care occupancies.

A.18.1.2.3 It is the intent that these requirements apply to mobile, transportable, and relocatable structures (in accordance with 1.3.2) where such structures are used to provide shared medical services on an extended or a temporary basis. Where properly separated from the health care occupancy and intended to provide services simultaneously for three or fewer health care patients who are litterborne, the level of protection for such structures should be based on the appropriate occupancy classification of other chapters of this *Code*. Mobile, transportable, or relocatable structures that are not separated from a contiguous health care occupancy or that are intended to provide services simultaneously for four or more health care patients who are litterborne should be classified and designed as health care occupancies.

A.18.2.2 In planning egress, arrangements should be made to transfer patients from one section of a floor to another section of the same floor that is separated by a fire barrier or smoke barrier in such a manner that patients confined to their beds can be transferred in their beds. Where the building design will allow, the section of the corridor containing an entrance or elevator lobby should be separated from corridors leading from it by fire or smoke barriers. Such arrangement, where the lobby is centrally located, will, in effect, produce a smoke lock, placing a double barrier between the area to which patients might be taken and the area from which they need to be evacuated because of threatening smoke and fire.

A.18.2.2.4(2) The intent of the provision is that a person following the natural path of the means of egress not encounter more than one delayed release device along that path of travel to an exit. Thus, each door from the multiple floors of a building that opens into an enclosed stair is permitted to have its own delayed release device, but an additional delayed release device is not permitted at the level of exit discharge on the door that discharges people from the enclosed stair to the outside.

A.18.2.2.6 It is desirable to keep doors in exit passageways, stair enclosures, horizontal exits, smoke barriers, and required enclosures around hazardous areas closed at all times to impede the travel of smoke and fire gases. Functionally, however, this involves decreased efficiency and limits patient observation by the staff of an institution. To accommodate such needs, it is practical to presume that such doors will be kept open, even to the extent of employing wood chocks and other makeshift devices. Doors in exit passageways, horizontal exits, and smoke barriers should, therefore, be equipped with automatic hold-open devices activated by the methods described, regardless of whether the original installation of the doors was predicated on a policy of keeping them closed.

A.18.2.3.4 It is not the intent that the required corridor width be maintained clear and unobstructed at all times. Projections into the required width are permitted by 7.3.2.2. It is not the intent that 18.2.3.4 supersede 7.3.2.2. Also, it is recognized that wheeled items in use (such as food service carts, house-keeping carts, gurneys, beds, and similar items) and wheeled crash carts not in use (because they need to be immediately accessible during a clinical emergency) are encountered in health care occupancy corridors. The health care occupancy's fire plan and training program should address the relocation of these items during a fire. Note that "not in use" is not the same as "in storage." Storage is not permitted to be open to the corridor unless it meets one of the provisions permitted by 18.3.6.1 and is not a hazardous area.

A.18.2.3.4(1) Occupant characteristics are an important factor to be evaluated in setting egress criteria. Egress components in nonpatient use areas, such as administrative office spaces, should be evaluated based on actual use. A clear corridor width of not less than 112 cm (44 in.) is specified, assuming occupants in nonpatient areas will be mobile and capable of evacuation without assistance.

A.18.2.3.4(2) Exit access should be arranged to avoid any obstructions to the convenient removal of nonambulatory persons carried on stretchers or on mattresses serving as stretchers.

A.18.2.3.5(1) See A.18.2.3.4(1).

A.18.2.3.5(2) See A.18.2.3.4(2).

A.18.2.4.4 An exit is not necessary for each individual smoke compartment if there is access to an exit through other smoke compartments without passing through the smoke compartment of fire origin.

A.18.3.2.1 Provisions for the enclosure of rooms used for charging linen chutes and waste chutes or for rooms into which these chutes empty are provided in Section 9.5.

A.18.3.2.2 The hazard level of a laboratory is considered severe if quantities of flammable, combustible, or hazardous materials are present that are capable of sustaining a fire of sufficient magnitude to breach a 1-hour fire separation. See the NFPA *Fire Protection Handbook* for guidance.

A.18.3.2.5.2 This exception is intended to permit small appliances used for reheating, such as microwave ovens, hot plates, toasters, and nourishment centers to be exempt from the requirements for commercial cooking equipment.

A.18.3.3.2 The reductions in class of interior finish prescribed by 10.2.8.1 are permitted to be used.

A.18.3.4.2 It is not the intent of this *Code* to require single-station smoke detectors that might be required by local codes to be connected to or to initiate the building fire alarm system.

A.18.3.4.3.1(2) It is the intent of this provision to permit a visible fire alarm signal instead of an audible signal to reduce interference between the fire alarm and medical equipment monitoring alarms.

A.18.3.4.5.3 The requirement for smoke detectors in spaces open to the corridors eliminates the requirements of 18.3.6.1(1)(c), 18.3.6.1(2)(b), and 18.3.6.1(5)(b) for direct supervision by the facility staff of nursing homes.

A.18.3.5.1 In areas where the replenishment of water supplies is not immediately available from on-site sources, alternate provisions for the water-fill rate requirements of NFPA 13,

Standard for the Installation of Sprinkler Systems, and NFPA 22, *Standard for Water Tanks for Private Fire Protection*, that are acceptable to the authority having jurisdiction should be provided. Appropriate means for the replenishment of these supplies from other sources, such as fire department tankers, public safety organizations, or other independent contractors should be incorporated into the overall fire safety plan of the facility.

With automatic sprinkler protection required throughout new health care facilities and quick-response sprinklers required in smoke compartments containing patient sleeping rooms, a fire and its life-threatening byproducts can be reduced, thereby allowing the defend-in-place concept to continue. The difficulty in maintaining the proper integrity of life safety elements has been considered and it has been judged that the probability of a sprinkler system operating as designed is equal to or greater than other life safety features.

A.18.3.5.4 The requirements for use of quick-response sprinklers intend that quick-response sprinklers be the predominant type of sprinkler installed in the smoke compartment. It is recognized, however, that quick-response sprinklers might not be approved for installation in all areas such as those where NFPA 13, *Standard for the Installation of Sprinkler Systems*, requires sprinklers of the intermediate- or high-temperature classification. It is not the intent of the 18.3.5.5 requirements to prohibit the use of standard sprinklers in limited areas of a smoke compartment where intermediate- or high-temperature sprinklers are required.

Where the installation of quick-response sprinklers is impracticable in patient sleeping room areas, appropriate equivalent protection features acceptable to the authority having jurisdiction should be provided. It is recognized that the use of quick-response sprinklers might be limited in facilities housing certain types of patients or by the installation limitations of quick-response sprinklers.

A.18.3.5.6 For the proper operation of sprinkler systems, cubicle curtains and sprinkler locations need to be coordinated. Improperly designed systems might obstruct the sprinkler spray from reaching the fire or might shield the heat from the sprinkler. Many options are available to the designer including, but not limited to, hanging the cubicle curtains 46 cm (18 in.) below the sprinkler deflector; using a 1.3-cm (½-in.) diagonal mesh or a 70 percent open weave top panel that extends 46 cm (18 in.) below the sprinkler deflector; or designing the system to have a horizontal and minimum vertical distance that meets the requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*. The test data that form the basis of the NFPA 13 requirements are from fire tests with sprinkler discharge that penetrated a single privacy curtain.

A.18.3.6.1(3) A typical nurses' station would normally contain one or more of the following with associated furniture and furnishings:

- (1) Charting area
- (2) Clerical area
- (3) Nourishment station
- (4) Storage of small amounts of medications, medical equipment and supplies, clerical supplies, and linens
- (5) Patient monitoring and communication equipment

A.18.3.6.2 It is the *Code's* intent that there be no required fire resistance or area limitations for vision panels in corridor walls and doors.

An architectural, exposed, suspended-grid acoustical tile ceiling with penetrating items such as sprinkler piping and

sprinklers; ducted HVAC supply and return-air diffusers; speakers; and recessed lighting fixtures is capable of limiting the transfer of smoke.

A.18.3.6.3 While it is recognized that closed doors serve to maintain tenable conditions in a corridor and adjacent patient rooms, such doors, which under normal or fire conditions are self-closing, might create a special hazard for the personal safety of a room occupant. These closed doors might present a problem of delay in discovery, confining fire products beyond tenable conditions.

Because it is critical for responding staff members to be able to immediately identify the specific room involved, it is suggested that approved automatic smoke detection that is interconnected with the building fire alarm be considered for rooms having doors equipped with closing devices. Such detection is permitted to be located at any approved point within the room. When activated, the detector is required to provide a warning that indicates the specific room of involvement by activation of a fire alarm annunciator, nurse call system, or any other device acceptable to the authority having jurisdiction.

A.18.3.6.3.1 Gasketing of doors should not be necessary to achieve resistance to the passage of smoke if the door is relatively tight-fitting.

A.18.3.6.3.8 Doors should not be blocked open by furniture, door stops, chocks, tie-backs, drop-down or plunger-type devices, or other devices that necessitate manual unlatching or releasing action to close. Examples of hold-open devices that release when the door is pushed or pulled are friction catches or magnetic catches.

A.18.3.6.3.10 It is not the intent of 18.3.6.3.10 to prohibit the application of push-plates, hardware, or other attachments on corridor doors in health care occupancies.

A.18.3.7 See A.18.2.2.

A.18.3.7.4(2) Where the smoke control system design requires dampers so that the system will function effectively, it is not the intent of the provision to permit the damper to be omitted.

This provision is not intended to prevent the use of plenum returns where ducting is used to return air from a ceiling plenum through smoke barrier walls. Short stubs or jumper ducts are not acceptable. Ducting is required to connect at both sides of the opening and to extend into adjacent spaces away from the wall. The intent is to prohibit open-air transfers at or near the smoke barrier walls.

A.18.3.7.7 Smoke barrier doors are intended to provide access to adjacent zones. The pair of cross-corridor doors are required to be opposite swinging. Access to both zones is required.

It is not the intent of 18.3.7.7 to prohibit the application of push-plates, hardware, or other attachments on some barrier doors in health care occupancies.

A.18.3.7.8 Smoke barriers might include walls having door openings other than cross-corridor doors. There is no restriction in the *Code* regarding which doors or how many doors form part of a smoke barrier. For example, doors from the corridor to individual rooms are permitted to form part of a smoke barrier.

A.18.3.7.9 It is not the intent to require the frame to be a listed assembly.

A.18.3.8 Individual sleeping cubicles within sleeping suites, as permitted by 18.2.5.4, are not required to have an outside

window or outside door in each cubicle, provided that not less than one outside window or outside door is provided in the suite or that the requirements of 18.3.8.1(2) are met.

A.18.4.3.1 For example, the provisions of 18.1.1.4.6.1(2) and 18.1.1.4.6.4 do not require the installation of sprinklers if the modification involves less than 50 percent of the area of the smoke compartment and less than 420 m²(4500 ft²) of the area of the smoke compartment.

A.18.5.2.2 For both new and existing buildings, it is the intent to permit the installation and use of fireplace stoves and room heaters utilizing solid fuel as defined in NFPA 211, *Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances*, provided that all such devices are installed, maintained, and used in accordance with the appropriate provisions of that standard and all manufacturers' specifications. These requirements are not intended to permit freestanding solid fuel-burning appliances such as freestanding wood-burning stoves.

A.18.7 Health care occupants have, in large part, varied degrees of physical disability, and their removal to the outside or even their disturbance caused by moving is inexpedient or impractical in many cases, except as a last resort. Similarly, recognizing that there might be an operating necessity for the restraint of the mentally ill, often by use of barred windows and locked doors, fire exit drills are usually extremely disturbing, detrimental, and frequently impracticable.

In most cases, fire exit drills, as ordinarily practiced in other occupancies, cannot be conducted in health care occupancies. Fundamentally, superior construction, early discovery and extinguishment of incipient fires, and prompt notification need to be relied on to reduce the occasion for evacuation of buildings of this class to a minimum.

A.18.7.1.4 Many health care occupancies conduct fire drills without disturbing patients by choosing the location of the simulated emergency in advance and by closing the doors to patients' rooms or wards in the vicinity prior to initiation of the drill. The purpose of a fire drill is to test and evaluate the efficiency, knowledge, and response of institutional personnel in implementing the facility fire emergency plan. Its purpose is not to disturb or excite patients. Fire drills should be scheduled on a random basis to ensure that personnel in health care facilities are drilled not less than once in each 3-month period.

Drills should consider the ability to move patients to an adjacent smoke compartment. Relocation can be practiced using simulated patients or empty wheelchairs.

A.18.7.2.1 Each facility has specific characteristics that vary sufficiently from other facilities to prevent the specification of a universal emergency procedure. The following recommendations, however, contain many of the elements that should be considered and adapted as appropriate to the individual facility.

Upon discovery of fire, personnel should immediately take the following action:

- (1) If any person is involved in the fire, the discoverer should go to the aid of that person, calling aloud an established code phrase. The use of a code provides for both the immediate aid of any endangered person and the transmission of an alarm. Any person in the area, upon hearing the code called aloud, should activate the building fire alarm using the nearest manual fire alarm box.
- (2) If a person is not involved in the fire, the discoverer should activate the building fire alarm using the nearest manual fire alarm box.

- (3) Personnel, upon hearing the alarm signal, should immediately execute their duties as outlined in the facility fire safety plan.
- (4) The telephone operator should determine the location of the fire as indicated by the audible signal. In a building equipped with an uncoded alarm system, a person on the floor of fire origin should be responsible for promptly notifying the facility telephone operator of the fire location.
- (5) If the telephone operator receives a telephone alarm reporting a fire from a floor, the operator should regard that alarm in the same fashion as an alarm received over the fire alarm system. The operator should immediately notify the fire department and alert all facility personnel of the place of fire and its origin.
- (6) If the building fire alarm system is out of order, any person discovering a fire should immediately notify the telephone operator by telephone. The operator should then transmit this information to the fire department and alert the building occupants.

A.18.7.4 The most rigid discipline with regard to prohibition of smoking might not be nearly as effective in reducing incipient fires from surreptitious smoking as the open recognition of smoking, with provision of suitable facilities for smoking. Proper education and training of the staff and attendants in the ordinary fire hazards and their abatement is unquestionably essential. The problem is a broad one, varying with different types and arrangements of buildings; the effectiveness of rules of procedure, which need to be flexible, depends in large part on the management.

A.18.7.5.1 In addition to the provisions of 10.3.1, which deal with ignition resistance, additional requirements with respect to the location of cubicle curtains relative to sprinkler placement are included in NFPA 13, *Standard for the Installation of Sprinkler Systems*.

A.18.7.7 Two documents that provide recognized engineering principles for the testing of smoke control systems are NFPA 92A, *Recommended Practice for Smoke-Control Systems*, and NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*.

A.19.1.1.1.1 In determining equivalency for existing hospitals or nursing homes, the authority having jurisdiction is permitted to accept evaluations based on the health care occupancies fire safety evaluation system (FSES) NFPA 101A, *Guide on Alternative Approaches to Life Safety*, utilizing the parameters for existing buildings.

A.19.1.1.1.8 The *Code* recognizes that certain functions necessary for the life safety of building occupants — such as the closing of corridor doors, the operation of manual fire alarm devices, and the removal of patients from the room of fire origin — require the intervention of facility staff. It is not the intent of 19.1.1.1.8 to specify the levels or locations of staff necessary to meet this requirement.

A.19.1.1.2 This objective is accomplished in the context of the physical facilities, the type of activities undertaken, the provisions for the capabilities of staff, and the needs of all occupants through requirements directed at the following:

- (1) Prevention of ignition
- (2) Detection of fire
- (3) Control of fire development
- (4) Confinement of the effects of fire
- (5) Extinguishment of fire

- (6) Provision of refuge or evacuation facilities, or both
- (7) Staff reaction

A.19.1.1.4.6.3 For the purpose of this requirement, a floor that is not divided by a smoke barrier is considered one smoke compartment.

A.19.1.1.4.6.4 In minor rehabilitation, only the rehabilitation itself is required to be brought up to the requirements for new nonsprinklered facilities, not the entire smoke compartment or building.

A.19.1.2.2 Doctors' offices and treatment and diagnostic facilities that are intended solely for outpatient care and are physically separated from facilities for the treatment or care of inpatients, but that are otherwise associated with the management of an institution, might be classified as business occupancies rather than health care occupancies.

A.19.1.2.3 It is the intent that these requirements apply to mobile, transportable, and relocatable structures (in accordance with 1.3.2) when such structures are used to provide shared medical services on an extended or a temporary basis. When properly separated from the health care occupancy and intended to provide services simultaneously for three or fewer health care patients who are litterborne, the level of protection for such structures should be based on the appropriate occupancy classification of other chapters of this *Code*. Mobile, transportable, or relocatable structures that are not separated from a contiguous health care occupancy or that are intended to provide services simultaneously for four or more health care patients who are litterborne should be classified and designed as health care occupancies.

A.19.1.6.5 Unoccupied space, for the purposes of 19.1.6.5(3), is space not normally occupied by persons, fuel-fired equipment, or hazardous contents.

A.19.1.6.7 There is a finish capacity in a 1-hour fire-rated partition that would be expected to prevent the generation of smoke and gases from fire retardant-treated wood studs for an extended time during fire exposure. This *Code* does not intend to permit the use of fire-retardant wood studs and partitions of only 20-minute fire resistance.

A.19.2.2.2.4(2) The intent of the provision is that a person following the natural path of the means of egress not encounter more than one delayed release device along that path of travel to an exit. Thus, each door from the multiple floors of a building that opens into an enclosed stair is permitted to have its own delayed release device, but an additional delayed release device is not permitted at the level of exit discharge on the door that discharges people from the enclosed stair to the outside.

A.19.2.2.2.6 It is desirable to keep doors in exit passageways, stair enclosures, horizontal exits, smoke barriers, and required enclosures around hazardous areas closed at all times to impede the travel of smoke and fire gases. Functionally, however, this involves decreased efficiency and limits patient supervision by the staff of a facility. To accommodate such needs, it is practical to presume that such doors will be kept open, even to the extent of employing wood chocks and other makeshift devices. Doors in exit passageways, horizontal exits, and smoke barriers should, therefore, be equipped with automatic hold-open devices actuated by the methods described regardless of whether the original installation of the doors was predicated on a policy of keeping them closed.

A.19.2.2.2.8 Doors to the enclosures of interior stair exits should be arranged to open from the stair side at not less than

every third floor so that it will be possible to leave the stairway at such floor if fire renders the lower part of the stair unusable during egress or if occupants seek refuge on another floor.

A.19.2.2.5.3 The waiver of the requirement for doors to swing in the direction of egress travel is based on the assumption that, in this occupancy, there is no possibility of a panic rush that might prevent the opening of doors that swing against egress travel.

A desirable arrangement, which is possible with corridors 2.4 m (8 ft) or more in width, is to have two 107-cm (42-in.) doors, normally closed, each swinging with the egress travel (in opposite directions).

A.19.2.3.4 It is not the intent that the required corridor width be maintained clear and unobstructed at all times. Projections into the required width are permitted by 7.3.2.2. It is not the intent that 19.2.3.4 supersede 7.3.2.2. Also, it is recognized that wheeled items in use (such as food service carts, house-keeping carts, gurneys, beds, and similar items) and wheeled crash carts not in use (because they need to be immediately accessible during a clinical emergency) are encountered in health care occupancy corridors. The health care occupancy's fire plan and training program should address the relocation of these items during a fire. Note that "not in use" is not the same as "in storage." Storage is not permitted to be open to the corridor unless it meets one of the provisions permitted by 19.3.6.1 and is not a hazardous area.

A.19.2.4.4 An exit is not necessary for each individual smoke compartment if there is access to an exit through other smoke compartments without passing through the smoke compartment of fire origin.

A.19.2.5.10 Every exit or exit access should be arranged, if practical and feasible, so that no corridor, passageway, or aisle has a pocket or dead end exceeding 30 ft (9.1 m). (See also Table A.7.6.)

A.19.3.2.2 The hazard level of a laboratory is considered severe if quantities of flammable, combustible, or hazardous materials are present that are capable of sustaining a fire of sufficient magnitude to breach a 1-hour fire separation. See NFPA *Fire Protection Handbook* for guidance.

A.19.3.2.5.2 This provision is intended to permit small appliances used for reheating, such as microwave ovens, hot plates, toasters, and nourishment centers, to be exempt from the requirements for commercial cooking equipment.

A.19.3.3.2 The reduction in class of interior or finish prescribed by 10.2.8.1 is permitted to be used.

A.19.3.4.2 It is not the intent of this *Code* to require single-station smoke detectors, which might be required by local codes, to be connected to or to initiate the building fire alarm system.

A.19.3.4.3.1(1) It is the intent of this provision to permit a visible fire alarm signal instead of an audible signal to reduce interference between the fire alarm and medical equipment monitoring alarms.

A.19.3.5.3 It is intended that any valve that controls automatic sprinklers in the entire building or portions of the building, including sectional and floor control valves, be electrically supervised. Valves that control isolated sprinkler heads, such as in laundry and trash chutes, are not required to be electrically supervised. Appropriate means should be taken to ensure that valves that are not electrically supervised remain open.

A.19.3.5.4 The provisions of 19.3.5.4(6) and 19.3.5.4(7) are not intended to supplant NFPA 13, *Standard for the Installation of Sprinkler Systems*, which requires that residential sprinklers with more than a 5.6°C (10°F) difference in temperature rating not be mixed within a room. Currently there are no additional prohibitions in NFPA 13 on the mixing of sprinklers having different thermal response characteristics. Conversely, there are no design parameters to make practical the mixing of residential and other types of sprinklers.

A.19.3.5.6 For the proper operation of sprinkler systems, cubicle curtains and sprinkler locations need to be coordinated. Improperly designed systems might obstruct the sprinkler spray from reaching the fire or might shield the heat from the sprinkler. Many options are available to the designer including, but not limited to, hanging the cubicle curtains 46 cm (18 in.) below the sprinkler deflector; using 1.3-cm (½-in.) diagonal mesh or a 70 percent open weave top panel that extends 46 cm (18 in.) below the sprinkler deflector; or designing the system to have a horizontal and minimum vertical distance that meets the requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*. The test data that forms the basis of the NFPA 13 requirements is from fire tests with sprinkler discharge that penetrated a single privacy curtain.

A.19.3.6.1(3) A typical nurses' station would normally contain one or more of the following with associated furniture and furnishings:

- (1) Charting area
- (2) Clerical area
- (3) Nourishment station
- (4) Storage of small amounts of medications, medical equipment and supplies, clerical supplies, and linens
- (5) Patient monitoring and communication equipment

A.19.3.6.1(6)(b) A fully developed fire (flashover) occurs if the rate of heat release of the burning materials exceeds the capability of the space to absorb or vent that heat. The ability of common lining (wall, ceiling, and floor) materials to absorb heat is approximately 0.07 kJ per m² (0.75 Btu per ft²) of lining. The venting capability of open doors or windows is in excess of 1.95 kJ per m² (20 Btu per ft²) of opening. In a fire that has not reached flashover conditions, fire will spread from one furniture item to another only if the burning item is close to another furniture item. For example, if individual furniture items have heat release rates of 525 kW per second (500 Btu per second) and are separated by 305 mm (12 in.) or more, the fire is not expected to spread from item to item, and flashover is unlikely to occur. (See also the NFPA Fire Protection Handbook.)

A.19.3.6.1(7) This provision permits waiting areas to be located across the corridor from each other, provided that neither area exceeds the 55.7-m² (600-ft²) limitation.

A.19.3.6.2.2 The intent of the ½-hour fire resistance rating for corridor partitions is to require a nominal fire rating, particularly where the fire rating of existing partitions cannot be documented. Examples of acceptable partition assemblies would include, but are not limited to 1.3-cm (½-in.) gypsum board, wood lath and plaster, gypsum lath, or metal lath and plaster.

A.19.3.6.2.3 An architectural, exposed, suspended-grid acoustical tile ceiling with penetrating items such as sprinkler piping and sprinklers; ducted HVAC supply and return-air diffusers; speakers; and recessed lighting fixtures is capable of limiting the transfer of smoke.

A.19.3.6.2.5 Monolithic ceilings are continuous horizontal membranes composed of noncombustible or limited-combustible materials, such as plaster or gypsum board, with seams or cracks permanently sealed.

A.19.3.6.2.6 The purpose of extending a corridor wall above a lay-in ceiling or through a concealed space is to provide a barrier to limit the passage of smoke. The intent of 19.3.6.2.6 is not to require light-tight barriers above lay-in ceilings or to require an absolute seal of the room from the corridor. Small holes, penetrations or gaps around items such as ductwork, conduit, or telecommunication lines should not affect the ability of this barrier to limit the passage of smoke.

A.19.3.6.3.1 Gasketing of doors should not be necessary to achieve resistance to the passage of smoke if the door is relatively tight-fitting.

A.19.3.6.3.5 While it is recognized that closed doors serve to maintain tenable conditions in a corridor and adjacent patient rooms, such doors, which under normal or fire conditions are self-closing, might create a special hazard for the personal safety of a room occupant. These closed doors might present a problem of delay in discovery, confining fire products beyond tenable conditions.

Because it is critical for responding staff members to be able to immediately identify the specific room involved, it is suggested that approved automatic smoke detection that is interconnected with the building fire alarm be considered for rooms having doors equipped with closing devices. Such detection is permitted to be located at any approved point within the room. When activated, the detector is required to provide a warning that indicates the specific room of involvement by activation of a fire alarm annunciator, nurse call system, or any other device acceptable to the authority having jurisdiction.

In existing buildings, use of the following options reasonably ensures that patient room doors will be closed and remain closed during a fire:

- (1) Doors should have positive latches and a suitable program that trains staff to close the doors in an emergency should be established.
- (2) It is the intent of the *Code* that no new installations of roller latches be permitted; however, repair or replacement of roller latches is not considered a new installation.
- (3) Doors protecting openings to patient sleeping or treatment rooms, or spaces having a similar combustible loading might be held closed using a closer exerting a closing force of not less than 22 N (5 lbf) on the door latch stile.

A.19.3.6.3.8 Doors should not be blocked open by furniture, door stops, chocks, tie-backs, drop-down or plunger-type devices, or other devices that necessitate manual unlatching or releasing action to close. Examples of hold-open devices that release when the door is pushed or pulled are friction catches or magnetic catches.

A.19.3.6.3.10 It is not the intent of 19.3.6.3.10 to prohibit the application of push-plates, hardware, or other attachments on corridor doors in health care occupancies.

A.19.3.7.3(2) Where the smoke control system design requires dampers in order that the system functions effectively, it is not the intent of the exception to permit the damper to be omitted.

This provision is not intended to prevent the use of plenum returns where ducting is used to return air from a ceiling plenum through smoke barrier walls. Short stubs or jumper ducts

are not acceptable. Ducting is required to connect at both sides of the opening and to extend into adjacent spaces away from the wall. The intent is to prohibit open-air transfers at or near the smoke barrier walls.

A.19.3.7.5.1 It is not the intent of 19.3.7.5.1 to prohibit the application of push-plates, hardware, or other attachments on smoke barrier doors in health care occupancies.

A.19.3.7.6 Smoke barriers might include walls having door openings other than cross-corridor doors. There is no restriction in the *Code* regarding which doors or how many doors form part of a smoke barrier. For example, doors from the corridor to individual rooms are permitted to form part of a smoke barrier.

A.19.3.8 Individual sleeping cubicles within sleeping suites, as permitted by 19.2.5.4 are not required to have an outside window or outside door in each cubicle, provided that not less than an outside window or outside door is provided in the suite or that the requirements of 19.3.8(2) are met.

A.19.5.2.2 For both new and existing buildings, it is the intent to permit the installation and use of fireplace stoves and room heaters using solid fuel as defined in NFPA 211, *Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances*, provided that all such devices are installed, maintained, and used in accordance with the appropriate provisions of that standard and all manufacturers' specifications. These requirements are not intended to permit freestanding solid fuel-burning appliances such as freestanding wood-burning stoves.

A.19.7 Health care occupants have, in large part, varied degrees of physical disability, and their removal to the outside or even their disturbance caused by moving is inexpedient or impractical in many cases, except as a last resort. Similarly, recognizing that there might be an operating necessity for the restraint of the mentally ill, often by use of barred windows and locked doors, fire exit drills are usually extremely disturbing, detrimental, and frequently impracticable.

In most cases, fire exit drills, as ordinarily practiced in other occupancies, cannot be conducted in health care occupancies. Fundamentally, superior construction, early discovery and extinguishment of incipient fires, and prompt notification needs to be relied on to reduce the occasion for evacuation of buildings of this class to a minimum.

A.19.7.1.4 Many health care occupancies conduct fire drills without disturbing patients by choosing the location of the simulated emergency in advance and by closing the doors to patients' rooms or wards in the vicinity prior to initiation of the drill. The purpose of a fire drill is to test and evaluate the efficiency, knowledge, and response of institutional personnel in implementing the facility fire emergency plan. Its purpose is not to disturb or excite patients. Fire drills should be scheduled on a random basis to ensure that personnel in health care facilities are drilled not less than once in each 3-month period.

Drills should consider the ability to move patients to an adjacent smoke compartment. Relocation can be practiced using simulated patients or empty wheelchairs.

A.19.7.2.1 Each facility has specific characteristics that vary sufficiently from other facilities to prevent the specification of a universal emergency procedure. The following recommendations, however, contain many of the elements that should be considered and adapted as appropriate to the individual facility.

Upon discovery of fire, personnel should immediately take the following action:

- (1) If any person is involved in the fire, the discoverer should go to the aid of that person, calling aloud an established code phrase. The use of a code provides for both the immediate aid of any endangered person and the transmission of an alarm. Any person in the area, upon hearing the code called aloud, should activate the building fire alarm using the nearest manual fire alarm box.
- (2) If a person is not involved in the fire, the discoverer should activate the building fire alarm using the nearest manual fire alarm box.
- (3) Personnel, upon hearing the alarm signal, should immediately execute their duties as outlined in the facility fire safety plan.
- (4) The telephone operator should determine the location of the fire as indicated by the audible signal. In a building equipped with an uncoded alarm system, a person on the floor of fire origin should be responsible for promptly notifying the facility telephone operator of the fire location.
- (5) If the telephone operator receives a telephone alarm reporting a fire from a floor, the operator should regard that alarm in the same fashion as an alarm received over the fire alarm system. The operator should immediately notify the fire department and alert all facility personnel of the place of fire and its origin.
- (6) If the building fire alarm system is out of order, any person discovering a fire should immediately notify the telephone operator by telephone. The operator should then transmit this information to the fire department and alert the building occupants.

A.19.7.4 The most rigid discipline with regard to prohibition of smoking might not be nearly as effective in reducing incipient fires from surreptitious smoking as the open recognition of smoking, with provision of suitable facilities for smoking. Proper education and training of the staff and attendants in the ordinary fire hazards and their abatement is unquestionably essential. The problem is a broad one, varying with different types and arrangements of buildings; the effectiveness of rules of procedure, which need to be flexible, depends in large part on the management.

A.19.7.5.1 In addition to the provisions of 10.3.1, which deal with ignition resistance, additional requirements with respect to the location of cubicle curtains relative to sprinkler placement are included in NFPA 13, *Standard for the Installation of Sprinkler Systems*.

A.19.7.7 Two documents that provide recognized engineering principles for the testing of smoke control systems are NFPA 92A, *Recommended Practice for Smoke-Control Systems*, and NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*.

A.20.1.1.1.6 The *Code* recognizes that certain functions necessary for the life safety of building occupants, such as the closing of corridor doors, the operation of manual fire alarm devices, and the removal of patients from the room of fire origin, require the intervention of facility staff. It is not the intent of 20.1.1.1.6 to specify the levels or locations of staff necessary to meet this requirement.

A.20.1.1.2 This objective is accomplished in the context of the physical facilities, the type of activities undertaken, the provisions for the capabilities of staff, and the needs of all occupants through requirements directed at the following:

- (1) Prevention of ignition
- (2) Detection of fire
- (3) Control of fire development
- (4) Confinement of the effects of fire
- (5) Extinguishment of fire
- (6) Provision of refuge or evacuation facilities, or both
- (7) Staff reaction

A.20.1.2.2 Doctors' offices and treatment and diagnostic facilities that are intended solely for outpatient care that are physically separated from facilities for the treatment or care of inpatients, but are otherwise associated with the management of an institution, might be classified as business occupancies rather than health care occupancies.

A.20.3.7.9 Smoke barriers might include walls having door openings other than cross-corridor doors. There is no restriction in the *Code* regarding which doors or how many doors form part of a smoke barrier. For example, doors from the corridor to individual rooms are permitted to form part of a smoke barrier.

A.20.7 Health care occupants have, in large part, varied degrees of physical disability, and their removal to the outside or even their disturbance caused by moving is inexpedient or impractical in many cases, except as a last resort. Similarly, recognizing that there might be an operating necessity for the restraint of the mentally ill, often by use of barred windows and locked doors, fire exit drills are usually extremely disturbing, detrimental, and frequently impracticable.

In most cases, fire exit drills, as ordinarily practiced in other occupancies, cannot be conducted in health care occupancies. Fundamentally, superior construction, early discovery and extinguishment of incipient fires, and prompt notification need to be relied on to reduce the occasion for evacuation of buildings of this class to a minimum.

A.20.7.1.4 Many health care occupancies conduct fire drills without disturbing patients by choosing the location of the simulated emergency in advance and by closing the doors to patients' rooms or wards in the vicinity prior to the initiation of the drill. The purpose of a fire drill is to test and evaluate the efficiency, knowledge, and response of institutional personnel in implementing the facility fire emergency plan. Its purpose is not to disturb or excite patients. Fire drills should be scheduled on a random basis to ensure that personnel in health care facilities are drilled not less than once in each 3-month period.

Drills should consider the ability to move patients to an adjacent smoke compartment. Relocation can be practiced using simulated patients or empty wheelchairs.

A.20.7.2.1 Each facility has specific characteristics that vary sufficiently from other facilities to prevent the specification of a universal emergency procedure. The following recommendations, however, contain many of the elements that should be considered and adapted as appropriate to the individual facility.

Upon discovery of fire, personnel should immediately take the following action:

- (1) If any person is involved in the fire, the discoverer should go to the aid of that person, calling aloud an established code phrase. The use of a code provides for both the immediate aid of any endangered person and the transmission of an alarm. Any person in the area, upon hearing the code called aloud, should activate the building fire alarm using the nearest manual fire alarm box.
- (2) If a person is not involved in the fire, the discoverer should activate the building fire alarm using the nearest manual fire alarm box.
- (3) Personnel, upon hearing the alarm signal, should immediately execute their duties as outlined in the facility fire safety plan.

- (4) The telephone operator should determine the location of the fire as indicated by the audible signal. In a building equipped with an uncoded alarm system, a person on the floor of fire origin should be responsible for promptly notifying the facility telephone operator of the fire location.
- (5) If the telephone operator receives a telephone alarm reporting a fire from a floor, the operator should regard that alarm in the same fashion as an alarm received over the fire alarm system. The operator should immediately notify the fire department and alert all facility personnel of the place of fire and its origin.
- (6) If the building fire alarm system is out of order, any person discovering a fire should immediately notify the telephone operator by telephone. The operator should then transmit this information to the fire department and alert the building occupants.

A.20.7.4 The most rigid discipline with regard to prohibition of smoking might not be nearly as effective in reducing incipient fires from surreptitious smoking as the open recognition of smoking, with provision of suitable facilities for smoking. Proper education and training of the staff and attendants in the ordinary fire hazards and their abatement is unquestionably essential. The problem is a broad one, varying with different types and arrangements of buildings; the effectiveness of rules of procedure, which need to be flexible, depends in large part on the management.

A.20.7.5.1 In addition to the provisions of 10.3.1, which deal with ignition resistance, additional requirements with respect to the location of cubicle curtains relative to sprinkler placement are included in NFPA 13, *Standard for the Installation of Sprinkler Systems*.

A.20.7.7 Two documents that provide recognized engineering principles for the testing of smoke control systems are NFPA 92A, *Recommended Practice for Smoke-Control Systems*, and NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*.

A.21.1.1.1.6 The *Code* recognizes that certain functions necessary for the life safety of building occupants, such as the closing of corridor doors, the operation of manual fire alarm devices, and the removal of patients from the room of fire origin, require the intervention of facility staff. It is not the intent of 21.1.1.1.6 to specify the levels or locations of staff necessary to meet this requirement.

A.21.1.1.2 This objective is accomplished in the context of the physical facilities, the type of activities undertaken, the provisions for the capabilities of staff, and the needs of all occupants through requirements directed at the following:

- (1) Prevention of ignition
- (2) Detection of fire
- (3) Control of fire development
- (4) Confinement of the effects of fire
- (5) Extinguishment of fire
- (6) Provision of refuge or evacuation facilities, or both
- (7) Staff reaction

A.21.1.2.2 Doctors' offices and treatment and diagnostic facilities that are intended solely for outpatient care and are physically separated from facilities for the treatment or care of inpatients, but that are otherwise associated with the management of an institution, might be classified as business occupancies rather than health care occupancies.

A.21.3.7.9 Smoke barriers might include walls having door openings other than cross-corridor doors. There is no restriction in the *Code* regarding which doors or how many doors form part of a smoke barrier. For example, doors from the corridor to individual rooms are permitted to form part of a smoke barrier.

A.21.7 Health care occupants have, in large part, varied degrees of physical disability, and their removal to the outside or even their disturbance caused by moving is inexpedient or impractical in many cases, except as a last resort. Similarly, recognizing that there might be an operating necessity for the restraint of the mentally ill, often by use of barred windows and locked doors, fire exit drills are usually extremely disturbing, detrimental, and frequently impracticable.

In most cases, fire exit drills, as ordinarily practiced in other occupancies, cannot be conducted in health care occupancies. Fundamentally, superior construction, early discovery and extinguishment of incipient fires, and prompt notification needs to be relied on to reduce the occasion for evacuation of buildings of this class to a minimum.

A.21.7.1.4 Many health care occupancies conduct fire drills without disturbing patients by choosing the location of the simulated emergency in advance and by closing the doors to patients' rooms or wards in the vicinity prior to initiation of the drill. The purpose of a fire drill is to test and evaluate the efficiency, knowledge, and response of institutional personnel in implementing the facility fire emergency plan. Its purpose is not to disturb or excite patients. Fire drills should be scheduled on a random basis to ensure that personnel in health care facilities are drilled not less than once in each 3-month period.

Drills should consider the ability to move patients to an adjacent smoke compartment. Relocation can be practiced using simulated patients or empty wheelchairs.

A.21.7.2.1 Each facility has specific characteristics that vary sufficiently from other facilities to prevent the specification of a universal emergency procedure. The following recommendations, however, contain many of the elements that should be considered and adapted as appropriate to the individual facility.

Upon discovery of fire, personnel should immediately take the following action:

- (1) If any person is involved in the fire, the discoverer should go to the aid of that person, calling aloud an established code phrase. The use of a code provides for both the immediate aid of any endangered person and the transmission of an alarm. Any person in the area, upon hearing the code called aloud, should activate the building fire alarm using the nearest manual fire alarm box.
- (2) If a person is not involved in the fire, the discoverer should activate the building fire alarm using the nearest manual fire alarm box.
- (3) Personnel, upon hearing the alarm signal, should immediately execute their duties as outlined in the facility fire safety plan.
- (4) The telephone operator should determine the location of the fire as indicated by the audible signal. In a building equipped with an uncoded alarm system, a person on the floor of fire origin should be responsible for promptly notifying the facility telephone operator of the fire location.

- (5) If the telephone operator receives a telephone alarm reporting a fire from a floor, the operator should regard that alarm in the same fashion as an alarm received over the fire alarm system. The operator should immediately notify the fire department and alert all facility personnel of the place of fire and its origin.
- (6) If the building fire alarm system is out of order, any person discovering a fire should immediately notify the telephone operator by telephone. The operator should then transmit this information to the fire department and alert the building occupants.

A.21.7.4 The most rigid discipline with regard to prohibition of smoking might not be nearly as effective in reducing incipient fires from surreptitious smoking as the open recognition of smoking, with provision of suitable facilities for smoking. Proper education and training of the staff and attendants in the ordinary fire hazards and their abatement is unquestionably essential. The problem is a broad one, varying with different types and arrangements of buildings; the effectiveness of rules of procedure, which need to be flexible, depends in large part on the management.

A.21.7.5.1 In addition to the provisions of 10.3.1, which deal with ignition resistance, additional requirements with respect to the location of cubicle curtains relative to sprinkler placement are included in NFPA 13, *Standard for the Installation of Sprinkler Systems*.

A.21.7.7 Two documents that provide recognized engineering principles for the testing of smoke control systems are NFPA 92A, *Recommended Practice for Smoke-Control Systems* and NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*.

A.22.1.1.1.2(2) In determining equivalency for conversions, modernizations, renovations, or unusual design concepts of detention and correctional facilities, the authority having jurisdiction is permitted to accept evaluations based on the detention and correctional occupancies fire safety evaluation system (FSSES) of NFPA 101A, *Guide on Alternative Approaches to Life Safety*, utilizing the parameters for new construction.

A.22.1.2 Detention and correctional facilities are a complex of structures, each serving a definite and usually different purpose. In many institutions, all, or almost all, the occupancy-type classifications found in this *Code* are represented. Means of egress and other features are governed by the type of occupancy classification and the hazard of occupancy, unless specific exemptions are made.

All buildings and structures are to be classified using Chapter 22 and Section 6.1 as a guide, subject to the ruling of the authority having jurisdiction where a question arises concerning the proper classification of any individual building or structure.

Use condition classification of the institution, as well as individual areas within the complex, is always to be considered by the authority having jurisdiction.

A.22.1.2.2.2 Key-operated locking hardware of a lesser grade than institutional grade hardware might not be suitable for the heavy use that these locks are expected to receive.

A.22.1.4.1 Users and occupants of detention and correctional facilities at various times can be expected to include staff, visitors, and residents. The extent and nature of facility utilization vary according to the type of facility, its function, and its programs.

Figure A.22.1.4.1 illustrates the five use conditions.




FIGURE A.22.1.4.1 Detention and Correctional Use Conditions.

A.22.1.4.2 Prompt operation is intended to be accomplished in the period of time between detection of fire by either the smoke detector(s) required by 22.3.4.4 or by other means, whichever comes first, and the advent of intolerable conditions forcing emergency evacuation. Fire tests have indicated that the time available is a function of the volume and height of the space involved and the rate of fire development. In traditional single-story corridor arrangements, the time between detection by smoke detectors and the advent of lethal conditions down to head height can be as short as approximately 3 minutes. In addition, it should be expected that approximately 1 minute will be required to evacuate all the occupants of a threatened smoke compartment once the locks are released. In such a case, a prompt release time would be 2 minutes.

A.22.1.4.3(2) If the Use Condition I facility conforms to the requirements of residential occupancies under this *Code*, there are no staffing requirements. If the Use Condition I facility conforms to the requirements of Use Condition II facilities as permitted by this provision, staffing is required in accordance with Section 22.7.1.

A.22.2.2.5.2 An exit is not necessary from each individual fire compartment or smoke compartment if there is access to an exit through other fire compartments or smoke compart-

ments without passing through the fire compartment or smoke compartment of fire origin.

A.22.2.11.3 It might be necessary to provide a certain number of resident sleeping rooms with doors providing a clear width of not less than 810 mm (32 in.) (see 7.2.1.2) in order to comply with the requirements for the physically handicapped. Such sleeping rooms should be located where there is a direct accessible route to the exterior or to an area of safe refuge. (See 22.3.7.)

A.22.2.11.7 A remote position is generally a control point where a number of doors can be unlocked simultaneously, either mechanically or electrically. In areas where there are a number of sleeping rooms, it is impractical for attendants to unlock doors individually. Doors in an exit should be unlocked prior to unlocking sleeping room doors. Sight and sound supervision of resident living areas can be by means of camera and communications systems.

This section of the *Code* does not intend to prohibit Use Condition V facilities, nor does it intend to limit Use Condition V facilities to 10 manually released locks.

A.22.3.1(2) For purposes of providing control valves and waterflow devices, multilevel residential housing areas complying with this provision are considered to be single story.

A.22.3.2.1 Furnishings are usually the first items ignited in a detention and correctional environment. The type, quantity, and arrangement of furniture and other combustibles are important factors in determining how fast the fire will develop. Furnishings, including upholstered items and wood items such as wardrobes, desks, and bookshelves, might provide sufficient fuel to result in room flashover, which is the full fire involvement of all combustibles within a room once sufficient heat has been built up within the room.

Combustible loading in any room opening onto a residential housing area should be limited to reduce the potential for room flashover. Rooms in which fuel loads are not controlled, thereby creating a potential for flashover, should be considered hazardous areas. Where fire-rated separation is provided, doors to such rooms, including sleeping rooms, should be self-closing.

It is strongly recommended that padded cells not be used due to their fire record. However, recognizing that they will be used in some cases, provisions for the protection of padded cells are provided. It is recognized that the $\frac{3}{4}$ -hour fire door will be violated with the "plant on" of the padding, but a $\frac{3}{4}$ -hour fire door should be the base of the assembly.

A.22.3.4.3.1(2) The staff at the constantly attended location should have the capability to promptly initiate the general alarm function and contact the fire department or have direct communication with a control room or other location that can initiate the general alarm function and contact the fire department.

A.22.3.4.4 Examples of contiguous common spaces are galleries and corridors.

A.22.3.4.4.3 An open dormitory is a dormitory that is arranged to allow staff to observe the entire dormitory area at one time.

A.22.3.5.4(1) Where access to portable fire extinguishers is locked, staff should be present on a 24-hour basis and should have keys readily available to unlock access to the extinguishers. Where supervision of sleeping areas is from a 24-hour attended staff location, portable fire extinguishers are permitted to be provided at the staff location in lieu of the sleeping area.

A.22.3.7.1(2) A door to the outside, by itself, does not meet the intent of this provision if emergency operating procedures do not provide for the door to be unlocked when needed. In cases where use of the door is not ensured, a true smoke barrier per the base requirement of 22.3.7.1 would be needed.

A.22.3.7.5 Structural fire resistance is defined as the ability of the assembly to stay in place and maintain structural integrity without consideration of heat transmission. Twelve-gauge steel plate suitably framed and stiffened meets this requirement.

A.22.3.7.6(1) As an example, a smoke barrier is permitted to consist of fire-rated glazing panels mounted in a security grille arrangement.

A.22.3.8 The requirements in Table 22.3.8 for smoke-resistant separations include taking the necessary precautions to restrict the spread of smoke through the air-handling system. However, the intent is not that smoke dampers are required to be provided for each opening. Smoke dampers would be one acceptable method; however, other techniques, such as allowing the fans to continue to run with 100 percent supply and 100 percent exhaust, would be acceptable.

A.22.4.4.3 This provision is intended to promote the use of horizontal exits in detention and correctional occupancies. Horizontal exits provide an especially effective egress system for an occupancy in which the occupants, due to security concerns, are not commonly released to the outside. This provision offers a *Codespecified* equivalent alternative to the requirement of 7.2.4.3.4 that horizontal exits are not to be penetrated by ducts in nonsprinklered buildings. The intended continuity of the fire resistance-rated and smoke-resisting barrier is maintained by requiring that duct penetrations of horizontal exits be protected by combination fire damper/smoke leakage-rated dampers that will close upon activation of a smoke detector and a heat-actuated mechanism before the barrier's ability to resist the passage of smoke and fire is compromised.

A.22.4.4.6.2 It is not the intent of this requirement to restrict room face separations, which restrict visibility from the common space into individual sleeping rooms.

A.22.4.4.6.4 The vertical separation between the lowest floor level and the uppermost floor level is not to exceed 3960 mm (156 in.). Figure A.22.4.4.6.4 illustrates how the height is to be determined.




FIGURE A.22.4.4.6.4 Vertical Height Measurement.

A.22.4.4.11 The requirements in Table 22.4.4.11 for smoke-resistant and fire-rated separations include taking the necessary precautions to restrict the spread of smoke through the air-handling system. However, the intent is that smoke dampers are

required to be provided for each opening. Smoke dampers would be one acceptable method; however, other techniques, such as allowing the fans to continue to run with 100 percent supply and 100 percent exhaust, would be acceptable.

A.22.4.4.12.2(2) The automatic smoke venting should be in accordance with NFPA 204, *Guide for Smoke and Heat Venting*, for light hazard occupancies.

A.22.4.4.13 Personal property provides combustible contents for fire development. Therefore, adequate controls are needed to limit the quantity and combustibility of fuels available to burn to reduce the probability of room flashover. The provisions of 22.4.4.13 will not, by themselves, prevent room flashover if personal property controls are not provided.

A.22.4.4.13.2 Mattresses used in detention and correctional facilities should be evaluated with regard to the fire hazards of the environment. The potential for vandalism and excessive wear and tear also should be taken into account when evaluating the fire performance of the mattress.

A.22.7.1.2 This requirement is permitted to be met by electronic or oral monitoring systems, visual monitoring, call signals, or other means.

A.22.7.1.3 Periodic, coordinated training should be conducted and should involve detention and correctional facility personnel and personnel of the fire department legally committed to serving the facility.

A.22.7.4 Personal property provides combustible contents for fire development. Therefore, adequate controls are needed to limit the quantity and combustibility of the fuels available to burn to reduce the probability of room flashover. The provisions of 22.7.4 will not, by themselves, prevent room flashover if personal property controls are not provided.

A.23.1.1.2(2) In determining equivalency for existing detention and correctional facilities, the authority having jurisdiction is permitted to accept evaluations based on the detention and correctional occupancies fire safety evaluation system (FSSES) of NFPA 101A, *Guide on Alternative Approaches to Life Safety*, utilizing the parameters for existing buildings.

A.23.1.2 Detention and correctional facilities are a complex of structures, each serving a definite and usually different purpose. In many institutions all, or almost all, of the occupancy-type classifications found in this *Code* are represented. Means of egress and other features are governed by the type of occupancy classification and the hazard of occupancy, unless specific exemptions are made.

All buildings and structures are to be classified using Chapter 23 and Section 6.1 as a guide, subject to the ruling of the authority having jurisdiction where there is a question as to the proper classification of any individual building or structure.

Use condition classification of the institution, as well as individual areas within the complex, is always to be considered by the authority having jurisdiction.

A.23.1.2.2.1 Key-operated locking hardware should be of institutional grade. Lesser grade hardware might not be suitable for the heavy use that these locks are expected to receive.

A.23.1.4.1 Users and occupants of detention and correctional facilities at various times can be expected to include staff, visitors, and residents. The extent and nature of facility utilization will vary according to the type of facility, its function, and its programs.

Figure A.23.1.4.1 illustrates the five use conditions.




FIGURE A.23.1.4.1 Detention and Correctional Use Conditions.

A.23.1.4.2 Prompt operation is intended to be accomplished in the period of time between detection of fire by either the smoke detector(s) required by 23.3.4.4 or by other means, whichever comes first, and the advent of intolerable conditions forcing emergency evacuation. Fire tests have indicated that the time available is a function of the volume and height of the space involved and the rate of fire development. In traditional single-story corridor arrangements, the time between detection by smoke detectors and the advent of lethal conditions down to head height can be as short as approximately 3 minutes. In addition, it should be expected that approximately 1 minute will be required to evacuate all the occupants of a threatened smoke compartment once the locks are released. In such a case, a prompt release time would be 2 minutes.

A.23.1.4.3(2) If the Use Condition I facility conforms to the requirements of residential occupancies under this *Code*, there are no staffing requirements. If the Use Condition I facility conforms to the requirements of Use Condition II facilities as permitted by this exception, staffing is required in accordance with 23.7.1.

A.23.2.2.5.2 An exit is not necessary from each individual fire compartment if there is access to an exit through other fire

compartments without passing through the fire compartment of fire origin.

A.23.2.2.5.3 This provision is intended to promote the use of horizontal exits in detention and correctional occupancies. Horizontal exits provide an especially effective egress system for an occupancy in which the occupants, due to security concerns, are not commonly released to the outside. This provision offers a *Code*-specified equivalent alternative to the requirement of 7.2.4.3.4 that horizontal exits are not to be penetrated by ducts. The intended continuity of the fire resistance-rated and smoke-resisting barrier is maintained by requiring that duct penetrations of horizontal exits be protected by combination fire damper/smoke leakage-rated dampers that close upon activation of a smoke detector and a heat-actuated mechanism before the barrier's ability to resist the passage of smoke and fire is compromised.

A.23.2.4.1 Multilevel and multitiered residential housing areas meeting the requirements of 23.3.1.2 and 23.3.1.3 are considered single story. Therefore, two exits are not required from each level; only access to two exits is required.

A.23.2.4.2 An exit is not necessary from each individual fire compartment and smoke compartment if there is access to an exit through other fire compartments or smoke compartments without passing through the fire compartment or smoke compartment of fire origin.

A.23.2.5.2 Every exit or exit access should be arranged, if feasible, so that no corridor or aisle has a pocket or dead end exceeding 15 m (50 ft) for Use Conditions II, III, and IV and 6100 mm (240 in.) for Use Condition V.

A.23.2.5.3(3) In determining whether to approve the existing common path of travel that exceeds 15 m (50 ft), the authority having jurisdiction should assure that the common path is not in excess of the travel distance permitted by 23.2.6.

A.23.2.11.3 It might be necessary to provide a certain number of resident sleeping rooms with doors providing a clear width of not less than 810 mm (32 in.) (see 7.2.1.2) in order to comply with the requirements for the physically handicapped. Such sleeping rooms should be located where there is a direct accessible route to the exterior or to an area of safe refuge. (See 23.3.7.)

A.23.2.11.7 A remote position is generally a control point where a number of doors can be unlocked simultaneously, either mechanically or electrically. In areas where there are a number of sleeping rooms, it is impractical for attendants to unlock doors individually. Doors in an exit should be unlocked prior to unlocking sleeping room doors. Sight and sound supervision of resident living areas can be by means of camera and communications systems.

This section of the *Code* does not intend to prohibit Use Condition V facilities, nor does it intend to limit Use Condition V facilities to 10 manually released locks.

A.23.3.1.2.1 It is not the intent of this requirement to restrict room face separations, which restrict visibility from the common space into individual sleeping rooms.

A.23.3.1.2.3 The vertical separation between the lowest floor level and the uppermost floor level is not to exceed 3960 mm (156 in.). Figure A.23.3.1.2.3 illustrates how the height is to be determined.




FIGURE A.23.3.1.2.3 Vertical Height Measurement.

A.23.3.1.3 A recommended method of calculating the expected level of smoke in a smoke removal-equipped cell block follows.

This method for calculating the expected level of smoke has been developed from data experimentally produced in full-scale burnouts of test cells. The test cells were sized, loaded with fuel, and constructed to represent severe conditions of heavily fuel-loaded [approximately 29 kg/m² (6 lb/ft²)] cells as found in prison locations. The filling rate and temperature of the effluent gas and smoke have been calculated using the data from these tests and established formulae from plume dynamics.

The application of the method described in A.23.3.1.3 should be limited to situations where there is not less than 3050 mm (120 in.) from the floor level to the lowest acceptable level of smoke accumulation (*Z*); the reservoir above the lowest acceptable level for *Z* is at least 20 percent of the *Z* dimension, the length of the cell block is not less than *Z*, and the fan is not less than 3050 mm (120 in.) higher than the floor of the highest cell.

The determination of smoke removal requirements is based on the dimensions of the cell opening. Where more than one cell opening is involved, the larger size on the level being calculated should be used.

The fan size, temperature rating, and operations means can be determined by the following procedure:

- (1) *Acceptable Smoke Level.* Determine the lowest acceptable level of smoke accumulation in accordance with 23.3.1.3. The vertical distance between that level and the floor level of the lowest open cell is the value of *Z* to be used in connection with Figure A.23.3.1.3(a).
- (2) *Characteristic Cell Opening.* Determine the opening of the cell face. Where there is more than one size of cell opening, use the largest. Match the actual opening to those shown in Figure A.23.3.1.3(b), and use the corresponding curve from Figure A.23.3.1.3(a). If there is no match between the size and shape of the opening and Figure A.23.3.1.3(a), interpolate between the curves. If the opening exceeds 1830 mm × 1830 mm (72 in. × 72 in.), use the curve for a 1830 mm × 1830 mm (72 in. × 72 in.) opening. This curve represents the maximum burning situation, and increasing the size of the opening will not increase the actual burning rate.
- (3) *Exhaust Fan Rate.* Determine the exhaust fan capacity needed to extract smoke at a rate that will maintain the smoke level at a point higher than *Z*. This is the rate shown on the baseline of Figure A.23.3.1.3(a) corresponding to the level of *Z* on the vertical axis for the solid line (ventilation rate) curve appropriate to the cell door size. This exhaust capability needs to be provided at a point higher than *Z*.

- (4) *Intake Air.* Provide intake air openings that either exist or are automatically provided at times of emergency smoke removal. These openings are to be located at or near the baseline of the cell block to allow for intake air at the rate to be vented by the fan. The openings provided shall be sufficient to avoid a friction load that can reduce the exhaust efficiency. Standard air-handling design criteria are used in making this calculation.
- (5) *Fan Temperature Rating.* Determine the potential temperature of gases that the fan might be required to handle by measuring the distance from the floor of the highest cell to the centerline of the fan, or fan ports if the fan is in a duct or similar arrangement. Determine the intersection of the new *Z* value with the appropriate ventilation rate curve (solid line) from Figure A.23.3.1.3(a). Estimate the temperature rise by interpolating along the appropriate ventilation rate curve and between the constant temperature rise curves (dashed lines) from Figure A.23.3.1.3(a). Provide all elements of the exhaust system that are to be above the acceptable smoke level with the capability to effectively operate with the indicated increase in temperature.
- (6) *Operation of Exhaust System.* The emergency exhaust system should be arranged to initiate automatically on detection of smoke, on operation of a manual fire alarm system, or by direct manual operation. The capability to manually start the automatic exhaust system should be provided in a guard post in the cell block, at another control location, or both. Where appropriate, the emergency exhaust fans are permitted to be used for comfort ventilation as well as serving their emergency purposes.

A.23.3.2.1 It is strongly recommended that padded cells not be used due to their fire record. However, recognizing that they will be used in some cases, provisions for the protection of padded cells are provided. It is recognized that the ¾-hour fire door will be violated with the “plant on” of the padding, but a ¾-hour fire door should be the base of the assembly.

A.23.3.4.3.1(2) The staff at the constantly attended location should have the capability to promptly initiate the general alarm function and contact the fire department or have direct communication with a control room or other location that can initiate the general alarm function and contact the fire department.

A.23.3.4.4.3 An open dormitory is a dormitory that is arranged to allow staff to observe the entire dormitory area at one time.

A.23.3.5.2 Where the openings in ceilings or partitions are ¼ in. (0.6 cm) or larger in the smallest dimension, where the thickness or depth of the material does not exceed the smallest dimension of the openings, and where such openings constitute not less than 70 percent of the area of the ceiling or partition material, the disruption of sprinkler spray patterns is permitted to be disregarded.

A.23.3.5.4(1) Where access to portable fire extinguishers is locked, staff should be present on a 24-hour basis and should have keys readily available to unlock access to the extinguishers. Where supervision of sleeping areas is from a 24-hour attended staff location, portable fire extinguishers are permitted to be provided at the staff location in lieu of the sleeping area.

A.23.3.7.1 Consideration can be given for large open areas that might be permitted to function as smoke sinks as an alternative to the installation of more than one smoke barrier as required by 23.3.7.1. Vertical movement downward to an area of refuge might be permitted by the authority having jurisdiction in lieu of horizontal movement.




FIGURE A.23.3.1.3(a) Cell Block Smoke Control Ventilation Curves.




FIGURE A.23.3.1.3(b) Typical Cell Openings.

A.23.3.7.1(2) A door to the outside, by itself, does not meet the intent of this provision if emergency operating procedures do not provide for the door to be unlocked when needed. In cases where use of the door is not ensured, a true smoke barrier per the base requirement of 23.3.7.1 would be needed.

A.23.3.7.3(2) Consideration should be given to increasing the travel distance to a smoke barrier to coincide with existing range lengths and exits.

A.23.3.7.5 Structural fire resistance is defined as the ability of the assembly to stay in place and maintain structural integrity without consideration of heat transmission. Twelve-gauge steel plate suitably framed and stiffened meets this requirement.

A.23.3.7.6(1) As an example, a smoke barrier is permitted to consist of fire-rated glazing panels mounted in a security grille arrangement.

A.23.3.8 The requirements in Table 23.3.8 for smoke-resistant and fire-rated separations include taking the necessary precautions to restrict the spread of smoke through the air-handling system. However, the intent is not that smoke dampers are required to be provided for each opening. Smoke dampers would be one acceptable method; however, other techniques, such as allowing the fans to continue to run with 100 percent supply and 100 percent exhaust, would be acceptable.

A.23.4.1.2(2) The automatic smoke venting should be in accordance with NFPA 204, *Standard for Smoke and Heat Venting*, for light hazard occupancies.

A.23.7.1.2 This requirement is permitted to be met by electronic or oral monitoring systems, visual monitoring, call signals, or other means.

A.23.7.1.3 Periodic, coordinated training should be conducted and should involve detention and correctional facility personnel and personnel of the fire department legally committed to serving the facility.

A.23.7.4 Personal property provides combustible contents for fire development. Therefore, adequate controls are needed to limit the quantity and combustibility of the fuels available to burn to reduce the probability of room flashover. The provisions of 23.7.4 will not, by themselves, prevent room flashover if personal property controls are not provided.

A.23.7.4.3 Mattresses used in detention and correctional facilities should be evaluated with regard to the fire hazards of the environment. The potential for vandalism and excessive wear and tear also should be taken into account when evaluating the fire performance of the mattress.

A.24.1.1.1 The *Code* specifies that wherever there are three or more living units in a building, the building is considered an apartment building and is required to comply with either Chapter 30 or Chapter 31, as appropriate. A townhouse unit is considered to be an apartment building if there are three or more units in the building. The type of wall required between units in order to consider them as separate buildings is normally established by the authority having jurisdiction. If the units are separated by a wall of sufficient fire resistance and structural integrity to be considered as separate buildings, then the provisions of Chapter 24 apply to each townhouse. Condominium is a form of ownership, not occupancy; for example, there are condominium warehouses, condominium apartments, and condominium offices.

The provisions of 24.1.1.1 state that, in one- and two-family dwellings, each dwelling unit can be "occupied by members of a single family with not more than three outsiders." The *Code* does not define the term *family*. The definition of *family* is subject to federal, state, and local regulations and might not be restricted to a person or a couple (two people) and their children. The following examples aid in differentiating between a single-family dwelling and a lodging or rooming house:

- (1) An individual or a couple (two people) who rent a house from a landlord and then sublease space for up to three individuals should be considered a family renting to a maximum of three outsiders, and the house should be regulated as a single-family dwelling in accordance with Chapter 24.
- (2) A house rented from a landlord by an individual or a couple (two people) in which space is subleased to four or more individuals, but not more than 16, should be considered and regulated as a lodging or rooming house in accordance with Chapter 26.
- (3) A residential building that is occupied by four or more individuals, but not more than 16, each renting from a landlord, without separate cooking facilities, should be considered and regulated as a lodging or rooming house in accordance with Chapter 26.

A.24.2 The phrase "means of escape" indicates a way out of a residential unit that does not conform to the strict definition of means of egress but does meet the intent of the definition by providing an alternative way out of a building. (See *means of escape* in 3.3.137.)

A.24.2.2.3 For use of emergency escape devices, refer to A.7.1.1.

A.24.2.2.3(C) A window with dimensions of 510 mm × 610 mm (20 in. × 24 in.) has an opening of 0.31 m² (3.3 ft²), which is less than the required 0.53 m² (5.7 ft²). Therefore, either the height or width needs to exceed the minimum requirement to provide the required clear area. [See Figure A.24.2.2.3(C)].

A.24.2.4.7 It is the intent of this requirement that security measures, where installed, do not prevent egress.

A.24.3.5 While automatic sprinklers are not required by this *Code*, they are recognized as an excellent addition to homes to enhance life safety and property protection. Automatic sprinklers can be part of a comprehensive package of fire protection and can assist in the overall master planning of a community. Where all of the buildings within an area are sprinklered, including the single-family dwellings, the response times and personnel of local fire departments can be established at different levels than if the buildings were not sprinklered, saving considerable amounts of tax dollars. When whole developments are sprinklered, water mains, hydrant spacing, road widths, and building density can be altered to help alleviate the economic impact of the sprinklers.

A.26.1.1.1 Bed and breakfast occupancies with more than 3, but fewer than 16, occupants are considered lodging and rooming houses.

A.26.2.3.5.1 It is the intent of this requirement that security measures, where installed, do not prevent egress.

A.26.3.1.2 Such protection can be accomplished by separation by physical distance, arrangement of the stairs, protection of the openings exposing the stairs, or a combination thereof.





FIGURE A.24.2.2.3(C) Escape Window Utilizing a Window Well.

A.26.3.3.3.1 The proprietor is the owner or owner's agent with responsible charge.

A.26.3.5.3.3 The decision to permit the use of the criteria from NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, in these occupancies is based on the following:

- (1) The desire to obtain a level of fire suppression and control that is approximately equivalent to that delivered by residential facilities protected by such systems (see the annex statement in NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*)
- (2) The fact that potential fire exposure and challenge to the suppression system in a small lodging and rooming occupancy is of the same nature and no more severe than that found in residences

A.28.2.2.12.2 The provision of 28.2.2.12.2 permits the entire floor to serve as an area of refuge where it is protected in accordance with 28.3.5. The provision is acceptable because supervised automatic sprinkler systems have built-in signals for monitoring features of the system, such as the opening and closing of water control valves. Such systems also monitor pump power supplies, water tank levels, and conditions that will impair the satisfactory operation of the sprinkler system. Because of these monitoring features, supervised automatic sprinkler systems have a high level of satisfactory performance and response to fire conditions.

A.28.2.3.3 The exemption contained in 28.2.3.3 applies to corridors within an individual room or suite and does not apply where a suite can be subdivided and rented separately.

A.28.2.7.2 Where open stairways are permitted, they are considered as exit access to exits rather than as exits, and the requirements for travel distance to exits include the travel on such stairs. (See 7.6.2.)

A.28.3.3.4 In nonsprinklered hotels, dormitories, or apartment buildings, new upholstered furniture located in corridors or areas not separated from corridors by corridor walls, as specified in the *Code*, should be tested in accordance with NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*. The char length is not to exceed 38 mm (1½ in.) and should be labeled to indicate such compliance.

A.28.3.4.3.1 Visible signaling appliances might be governed by provisions of federal regulations in 28 CFR 36, Appendix A (Americans with Disabilities Act Accessibility Guidelines — ADAAG), Section 4.28, Alarms.

A.28.3.4.3.3 A quantity of such rooms and suites might be required to be equipped to accommodate hearing impaired individuals based on the total number of rooms in a transient lodging facility. [See 28 CFR 36, Appendix A (Americans with Disabilities Act Accessibility Guidelines — ADAAG), Sections 9.1.3, 9.1.5, and 9.2.2(8).]

A.28.3.4.3.6 The provision for immediate notification of the public fire department is intended to include, but is not limited to, all of the arrangements in 9.6.4.2. Other arrangements that depend on a clerk or other member of the staff to notify the fire department might also be permitted. In such cases, however, it is essential that a trained staff member and an immediately available means of calling the fire department are continuously available. If a telephone is to be used, it should not be of any type or arrangement that requires a coin or the unlocking of a device to contact the fire department.

A.28.3.4.5 Caution needs to be exercised in locating smoke alarms with regard to their proximity to bathrooms, cooking facilities, and HVAC outlets in order to prevent nuisance alarms.

A.28.5.3.2 “Protected power supply” means a source of electrical energy of sufficient capacity to allow proper operation of the elevator and its associated control and communications systems. The power supply’s point of origin, system of distribution, type and size of overcurrent protection, degree of isolation from other portions of the building electrical system, and degree of mechanical protection should be such that it is unlikely that the supply would be disrupted at any but the advanced stages of building fire involvement or by structural collapse.

A protected power supply might consist of, and should provide, not less than the level of reliability associated with an electrical distribution system with service equipment located and installed in accordance with 230.72(B) and 230.82(5) of NFPA 70, *National Electrical Code*®. The distribution system is not to have any other connection to the building electrical distribution system. A protected power supply is not required to incorporate two sources of energy or automatic transfer capability from a normal to an emergency source, for example, an alternate set of service conductors.

The number and type of elevators to be connected to a protected power supply should be limited, or the characteristics of the protected power supply should be selected to ensure conformance with 230.95 of NFPA 70, *National Electrical Code*®, without the provision of ground fault protection for the supply.

An elevator installation supplied by a protected power supply should comply with Article 620 of NFPA 70, *National Electrical Code*®, except that the energy absorption means required by 620.91 should always be connected on the load side of the disconnecting means. The energy absorption means should not consist of loads likely to become inoperative or disconnected under the conditions assumed to exist when the elevator is under the control of fire department personnel. Examples of such loads include light and power loads external to the elevator equipment room.

A.28.7.1.1 Employers are obligated to determine the degree to which employees are to participate in emergency activities. Regulations of the U.S. Department of Labor (OSHA) govern these activities and provide options for employers, from total evacuation to aggressive structural fire fighting by employee brigades. (For additional information, see *OSHA Regulations for Emergency Procedures and Fire Brigades*, 29 CFR 1910, E and L.)

A.28.7.1.2 Emergencies should be assumed to have arisen at various locations in the occupancy in order to train employees in logical procedures.

A.28.7.4.1 Floor diagrams should reflect the actual floor arrangement and should be oriented with the actual direction to the exits.

A.28.7.4.2 Factors for developing the fire safety information include such items as construction type, suppression systems, alarm and detection systems, building layout, and building HVAC systems.

A.29.2.2.8 Due to the nature of escalators, they are no longer acceptable as a component in a means of egress. However, because many escalators have been used for exit access and exit discharge in the past, they are permitted to continue to be considered in compliance. Very few escalators have ever been installed in a manner to qualify as an exit. For information on escalator protection and requirements, see previous editions of the *Code*.

A.29.2.2.12.2 The provision of 29.2.2.12.2 permits the entire floor to serve as an area of refuge where it is protected in accordance with 29.3.5. The provision is acceptable because supervised automatic sprinkler systems have built-in signals for monitoring features of the system, such as the opening and closing of water control valves. Such systems also monitor pump power supplies, water tank levels, and conditions that will impair the satisfactory operation of the sprinkler system. Because of these monitoring features, supervised automatic sprinkler systems have a high level of satisfactory performance and response to fire conditions.

A.29.2.7.2 Where open stairways or escalators are permitted, they are considered as exit access to exits rather than as exits, and the requirements for travel distance to exits include the travel on such stairs and escalators. (See 7.6.2.)

A.29.3.3.4 In nonsprinklered hotels, dormitories, or apartment buildings, new upholstered furniture located in corridors or areas not separated from corridors by corridor walls, as specified in the *Code*, should be tested in accordance with NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*. The char length is not to exceed 38 mm (1½ in.), and should be labeled to indicate such compliance.

A.29.3.4.3.6 The provision for immediate notification of the public fire department is intended to include, but is not limited to, all of the arrangements in 9.6.4.2. Other arrangements that depend on a clerk or other member of the staff to notify the fire department might also be permitted. In such cases, however, it is essential that a trained staff member and an immediately available means of calling the fire department are continuously available. If a telephone is to be used, it should not be of any type or arrangement that requires a coin or the unlocking of a device to contact the fire department.

A.29.3.4.5 Caution needs to be exercised in locating smoke alarms with regard to their proximity to bathrooms, cooking facilities, and HVAC outlets in order to prevent nuisance alarms.

A.29.3.5.3 Although not required by the *Code*, the use of residential sprinklers or quick-response sprinklers is encouraged for new installations of sprinkler systems within dwelling units, apartments, and guest rooms. Caution should be exercised, as the system needs to be designed for the sprinkler being used.

A.29.7.1.1 Employers are obligated to determine the degree to which employees are to participate in emergency activities. Regulations of the U.S. Department of Labor (OSHA) govern these activities and provide options for employers, from total evacuation to aggressive structural fire fighting by employee brigades. (For additional information, see *OSHA Regulations for Emergency Procedures and Fire Brigades*, 29 CFR 1910, E and L.)

A.29.7.1.2 Emergencies should be assumed to have arisen at various locations in the occupancy in order to train employees in logical procedures.

A.29.7.4.1 Floor diagrams should reflect the actual floor arrangement and should be oriented with the actual direction to the exits.

A.29.7.4.2 Factors for developing the fire safety information include such items as construction type, suppression systems, alarm and detection systems, building layout, and building HVAC systems.

A.30.2.2.2.2.1 It is the intent of this requirement that security measures, where installed, should not prevent egress.

A.30.2.2.12.2 The provision of 30.2.2.12.2 permits the entire floor to serve as an area of refuge where it is protected in accordance with 31.3.5. The provision is acceptable because supervised automatic sprinkler systems have built-in signals for monitoring features of the system, such as the opening and closing of water control valves. Such systems also monitor pump power supplies, water tank levels, and conditions that will impair the satisfactory operation of the sprinkler system. Because of these monitoring features, supervised automatic sprinkler systems have a high level of satisfactory performance and response to fire conditions.

A.30.3.4.5.1 Previous editions of the *Code* permitted the single-station smoke alarm required by 30.3.4.5.1 to be omitted from each apartment where a complete automatic smoke detection system was installed throughout the building. With such a system, when one detector is activated, an alarm is sounded throughout the building. Experience with complete smoke detection systems in apartment buildings has shown that numerous nuisance alarms are likely to occur. Where there is a problem with frequent nuisance alarms, occupants ignore the alarm, or the system is either disconnected or otherwise rendered inoperative.

A.31.1 See Table A.31.1.

A.31.2.2.8 Due to the nature of escalators, they are no longer acceptable as a component in a means of egress. However, because many escalators have been used for exit access and exit discharge in the past, they are permitted to continue to be considered in compliance. Very few escalators have ever been installed in a manner to qualify as an exit. For information on escalator protection and requirements, see previous editions of the *Code*.

A.31.2.2.12.2 The provision of 31.2.2.12.2 permits the entire floor to serve as an area of refuge where it is protected in accordance with 31.3.5. The provision is acceptable because supervised automatic sprinkler systems have built-in signals for monitoring features of the system, such as the opening and closing of water control valves. Such systems also monitor pump power supplies, water tank levels, and conditions that will impair the satisfactory operation of the sprinkler system. Because of these monitoring features, supervised automatic sprinkler systems have a high level of satisfactory performance and response to fire conditions.

A.31.2.11 The provision of 31.2.11 recognizes the need to provide smoke control in existing buildings. Smokeproof enclosures can be accomplished without the use of a vestibule in accordance with 7.2.3.

A.31.3.5.3 Although not required by the *Code*, the use of residential sprinklers or quick-response sprinklers is encouraged for new installations of sprinkler systems within dwelling units, apartments, and guest rooms. Caution should be exercised, because the system needs to be designed for the sprinkler being used.

A.31.3.5.10.2 This system might consist of a combination of any or all of the following systems:

- (1) Partial automatic sprinkler protection
- (2) Smoke detection alarms
- (3) Smoke control
- (4) Compartmentation or other approved systems, or both

A.31.3.6.1 The intent is to recognize that existing partitions of sound wood lath and plaster, wire lath and plaster, or gypsum lath and plaster construction have demonstrated the ability to contain most room fires. Recent data on archaic construction methods have established the fire resistance rating of such construction at about 20 minutes. Such construction meets the intent of 31.3.6.1.

A.32.1.1 The requirements of Chapter 32 are designed to accommodate typical changes in the capabilities of the resident, such as those due to accidents, temporary illness, cyclical variations in capabilities, and gradual aging. This approach is based on the assumption that the capabilities of the resident will be evaluated not less than annually, and for residents with

Table A.31.1 Alternate Requirements for Existing Apartment Buildings According to Protection Provided

	No Suppression or Detection System Option No. 1	Total Automatic Fire Detection Option No. 2	Sprinkler Protection in Selected Areas Option No. 3	Auto Extinguishing per NFPA 13 (with exceptions) Option No. 4
Exit Access				
Travel distance from apartment door to exit	30 m (100 ft)	45 m (150 ft)	45 m (150 ft)	60 m (200 ft)
Travel distance within apartment	23 m (75 ft)	38 m (125 ft)	23 m (75 ft)	38 m (125 ft)
Smoke barrier req. (See 31.3.7.)	R	R	R	NR
Max. single path corridor distance	10.7 m (35 ft)	10.7 m (35 ft)	10.7 m (35 ft)	10.7 m (35 ft)
Max. dead end	15 m (50 ft)	15 m (50 ft)	15 m (50 ft)	15 m (50 ft)
Corridor fire resistance				
Walls	½ hr	½ hr	½ hr	½ hr
Doors (fire protection rating)	20 min. or 4.4 cm (1¾-in.) thick	20 min. or 4.4 cm (1¾-in.) thick	Smoke-resisting	Smoke-resisting
Interior Finish				
Lobbies and corridors	A or B	A or B	A or B	A, B, or C
Other spaces	A, B, or C	A, B, or C	A, B, or C	A, B, or C
Floors in corridors	I or II	I or II	NR	NR
Exits				
Wall fire resistance				
1-3 stories	1 hr	1 hr	1 hr	1 hr
>3 stories	2 hr	2 hr	2 hr	1 hr
Smokeproof enclosures				
Not high-rise	NR	NR	NR	NR
High-rise	R	R	R	NR
Door fire resistance				
1-3 stories	1 hr	1 hr	1 hr	1 hr
>3 stories	1½ hr	1½ hr	1½ hr	1 hr
Interior finish				
Walls and ceilings	A or B	A or B	A or B	A, B, or C
Floors	I or II	I or II	I or II	NR
Within Living Unit (Apartment)				
Escape windows, per Section 24.2 (See 31.2.1.)	R	R	R	NR
Alarm System				
>3 stories or >11 units	Manual initiation	Manual & auto initiation	Manual & auto initiation	Manual & auto initiation
>2 stories or >50 units	Annunciator panel	Annunciator panel	Annunciator panel	Annunciator panel

R: Required (see Code for details and exemptions).

NR: No requirements.

geriatric problems or degenerative diseases, not less than every 6 months. Also, residents should be re-evaluated after each accident or illness that requires hospitalization.

The requirements of Chapter 32 were developed on the assumption that the occupants will normally evacuate the building in fire emergencies. During fire exit drills, all occupants should evacuate the building with staff assistance as needed. Exceptions can be made in facilities where the resi-

dents cannot be evacuated practically. Managers of board and care homes with nursing home backgrounds sometimes are not aware of the differences between the requirements of 18.7.1 and 32.7.3.

A.32.1.5 The provisions of 8.3.1(3) address a ½-hour fire resistance rating. The information in A.8.3.1(3) addresses common materials used in ½-hour fire resistance-rated barriers.

A.32.2.2.3.1(3) A window with dimensions of 510 mm × 610 mm (20 in. × 24 in.) has an opening of 0.31 m² (3.3 ft²), which is less than the required 0.53 m² (5.7 ft²). Therefore, either the height or width needs to exceed the minimum requirement to provide the required clear area.

A.32.2.2.6.3 Exterior stair protection can be accomplished through separation by physical distance, arrangement of the stairs, protection of the openings exposing the stairs, or other means acceptable to the authority having jurisdiction.

A.32.2.3.2.1 Spaces containing approved, properly installed and maintained furnaces and heating equipment, furnace rooms, and cooking and laundry facilities should not be classified as hazardous areas solely on the basis of such equipment.

A.32.2.3.5.1 Where any provision requires the use of an automatic sprinkler system in accordance with 32.2.3.5, the provision of 32.2.3.5.2 is not permitted to be used.

A.32.2.3.5.2 Where a facility utilizing 32.2.3.5.2 contains residents who can no longer comply with the 3-minute evacuation response, 33.1.7 requires the facility to comply with the requirements for new construction, including automatic sprinkler protection. See also A.33.1.7.

A.32.2.3.5.3.2 The decision to permit the use of the criteria from NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, in these occupancies is based on the following:

- (1) The desire to obtain a level of fire suppression and control approximately equivalent to that delivered by residential facilities protected by such systems (see the appendix statement in NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*)
- (2) The fact that potential fire exposure and challenge to the suppression system in a small board and care facility are of the same nature and are no more severe than those found in residences

Chapter 32 permits the use of NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, and NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, outside of their scopes. This permission is based on a review of the occupancy and a recognition that the fires in board and care facilities are similar to those of other residential occupancies and that the level of protection is appropriate. The requirements of NFPA 13D and NFPA 13R have been supplemented with requirements for additional water supplies to compensate for the special needs of the board and care occupancy.

NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, contains additional requirements for a piping system serving both sprinkler and domestic needs.

A.32.3.3.3 The provisions in 10.2.8 to allow modifications to interior finish requirements where automatic sprinklers are provided are intended to be permitted.

A.32.3.3.6 It is not intended to prohibit furniture in corridors and spaces open to corridors provided the minimum required width is maintained. Storage is not permitted in corridors or spaces open to corridors.

A.32.3.3.7.10 Where the smoke control system design requires dampers in order that the system functions effectively, it is not the intent of 32.3.3.7.10 to permit the damper to be omitted.

This provision is not intended to prevent the use of plenum returns where ducting is used to return air from a ceiling plenum through smoke barrier walls. Short stubs or jumper ducts are not acceptable. Ducting is required to connect at both sides of the opening and to extend into adjacent spaces away from the wall. The intent is to prohibit open-air transfers at or near the smoke barrier walls.

A.32.3.3.7.13 Smoke barrier doors are intended to provide access to adjacent zones. The pair of cross-corridor doors are required to be opposite swinging. Access to both zones is required.

A.32.3.3.7.17 Smoke barriers might include walls having door openings other than cross-corridor doors. There is no restriction in the *Code* regarding which doors or how many doors form part of a smoke barrier. For example, doors from the corridor to individual rooms are permitted to form part of a smoke barrier.

A.32.3.3.7.18 It is not the intent to require the frame to be a listed assembly.

A.32.3.3.8 The scope of NFPA 96 is limited to appliances that produce grease-laden vapors, and not to domestic cooking equipment used for food warming or limited cooking.

A.32.3.6.3.2 "Protected power supply" means a source of electrical energy of sufficient capacity to allow proper operation of the elevator and its associated control and communications systems. The power supply's point of origin, system of distribution, type and size of overcurrent protection, degree of isolation from other portions of the building electrical system, and degree of mechanical protection should be such that it is unlikely that the supply would be disrupted at any but the advanced stages of building fire involvement or by structural collapse.

A protected power supply might consist of, and should provide, not less than the level of reliability associated with an electrical distribution system with service equipment located and installed in accordance with 230.72(B) and 230.82(5) of NFPA 70, *National Electrical Code*®. The distribution system is not to have any other connection to the building electrical distribution system. A protected power supply is not required to incorporate two sources of energy or automatic transfer capability from a normal to an emergency source, for example, an alternate set of service conductors.

The number and type of elevators to be connected to a protected power supply should be limited, or the characteristics of the protected power supply should be selected to ensure conformance with 230.95 of NFPA 70, *National Electrical Code*®, without the provision of ground fault protection for the supply.

An elevator installation supplied by a protected power supply should comply with Article 620 of NFPA 70, *National Electrical Code*®, except that the energy absorption means required by 620.91 should always be connected on the load side of the disconnecting means. The energy absorption means should not consist of loads likely to become inoperative or disconnected under the conditions assumed to exist when the elevator is under the control of fire department personnel. Examples of such loads include light and power loads external to the elevator equipment room.

A.32.4 Board and care occupancies in apartment buildings will usually be small facilities housing 16 or fewer residents. It is intended that the board and care occupancy conform to the requirements of Section 32.2 for small board and care facilities. In the unusual case where an apartment houses a large board and care facility, it would be reasonable for the authority having jurisdiction, using 4.6.1, to apply the provisions of Section 32.3 to the apartment. In addition, the apartment building in which the facility is housed needs to comply with the requirements for apartment buildings in Chapter 30 and Chapter 31 and the additional criteria presented in Section 32.4.

A.32.4.1.3 In determining equivalency for conversions, modernizations, renovations, or unusual design concepts, the authority having jurisdiction might permit evaluations based on the residential board and care occupancies fire safety evaluation system (FSES) in NFPA 101A, *Guide on Alternative Approaches to Life Safety*.

A.32.7.4.1 Smoking regulations should include the following:

- (1) Smoking should be prohibited in any room, compartment, or area where flammable or combustible liquids, combustible gases, or oxygen is used or stored and in any other hazardous location. Such areas should be posted with signs that read NO SMOKING or the international symbol for no smoking. In residential board and care facilities where smoking is totally prohibited and signs so indicating are placed at all major entrances, secondary signs with language that prohibits smoking are not required.
- (2) Smoking by residents classified as not responsible with regard to their ability to safely use and dispose of smoking materials should be prohibited. Where the resident is under direct supervision by staff or by a person approved by the administration, smoking might be permitted.
- (3) Smoking materials should not be provided to residents or maintained by residents without the approval of the administration.
- (4) Areas where smoking is permitted should be clearly identified.
- (5) Ashtrays of noncombustible material and safe design should be provided and required to be used in all areas where smoking is permitted.
- (6) Self-closing cover devices into which ashtrays can be emptied should be made available to all areas where smoking is permitted and should be required to be used.

A.32.7.5 The requirements applicable to draperies/curtains, upholstered furniture, and mattresses apply only to new draperies/curtains, new upholstered furniture, and new mattresses. The word *new* means unused, normally via procurement from the marketplace, either by purchase or donation, of items not previously used. Many board and care facilities allow residents to bring into the board and care home upholstered furniture items from the resident's previous residence. Such an item is not new and, thus, is not regulated. On the other hand, some of the larger board and care homes purchase contract furniture, as is done in hotels. Such new, unused furniture, whether purchased or received as a donation, is regulated by the requirements of 32.7.5.2. By federal law, mattresses manufactured and sold within the United States must pass testing per FF4-72, *Standard for the Flammability of Mattresses*.

A.32.7.5.2 New upholstered furniture within board and care homes should be tested for rates of heat release in accordance with 10.3.3.

A.32.7.5.3 New mattresses within board and care homes should be tested for rates of heat release in accordance with 10.3.4.

A.33.1.1 The requirements of Chapter 33 are designed to accommodate typical changes in the capabilities of the resident, such as those due to accidents, temporary illness, cyclical variations in capabilities, and gradual aging. This approach is based on the assumption that the capabilities of the resident will be evaluated not less than annually, and for residents with geriatric problems or degenerative diseases, not less than every 6 months. Also, residents should be re-evaluated after each accident or illness that requires hospitalization.

The requirements of Chapter 33 were developed on the assumption that the occupants will normally evacuate the building in fire emergencies. During fire exit drills, all occupants should evacuate the building with staff assistance as needed. Exceptions can be made in facilities with an evacuation capability rating of impractical. Managers of board and care homes with nursing home backgrounds sometimes are not aware of the differences between the requirements of 19.7.1 and 33.7.3.

A.33.1.1.2 The provision of 33.1.1.2 was added after Chapter 32 was revised in its entirety to avoid potential conflicts between the two chapters. Occupancies meeting Chapter 32 are deemed to comply with Chapter 33.

A.33.1.5 The provisions of 8.3.1(3) address a ½-hour fire resistance rating. The information in A.8.3.1(3) addresses common materials used in ½-hour fire resistance-rated barriers.

A.33.1.7 When the group evacuation capability changes to a level of greater risk, the owner/operator of the facility needs to take such action as is necessary, within a reasonable time frame, to restore the evacuation capability of the facility to that for which it was approved. If subsequent evaluations indicate that the original evacuation capability of the facility cannot or is not being maintained at the original level of risk, the facility would be considered as having changed the occupancy sub-classification to one of greater risk, and the safeguards required for the level of greater risk would apply. If a facility improves its original evacuation capability to one of less risk, a re-evaluation and upgrading to the requirements for new construction is not needed.

A.33.2.1.2.1.1 In determining equivalency for existing buildings, conversions, modernizations, renovations, or unusual design concepts, the authority having jurisdiction might permit evaluations based on residential board and care occupancies fire safety evaluation system (FSES) in NFPA 101A, *Guide on Alternative Approaches to Life Safety*.

A.33.2.2.3(3) A window with dimensions of 510 mm × 610 mm (20 in. × 24 in.) has an opening of 0.31 m² (3.3 ft²), which is less than the required 0.53 m² (5.7 ft²). Therefore, either the height or width needs to exceed the minimum requirement to provide the required clear area.

A.33.2.2.6.3 Exterior stair protection can be accomplished through separation by physical distance, arrangement of the stairs, protection of the openings exposing the stairs, or other means acceptable to the authority having jurisdiction.

A.33.2.3.4.3 Most often smoke alarms sounding an alarm at 85 dBA or greater, installed outside the bedroom area, will meet the intent of this requirement. Smoke alarms remotely located from the bedroom might not be loud enough to awaken the average person. In such cases, it is recommended that smoke alarms be interconnected so that the activation of any smoke alarm will cause all smoke alarms to activate.

A.33.2.3.5.2.1 The decision to permit the use of the criteria from NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes* in these occupancies is based on the following:

- (1) The desire to obtain a level of fire suppression and control approximately equivalent to that delivered by residential facilities protected by such systems NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*
- (2) The fact that potential fire exposure and challenge to the suppression system in a small board and care facility are of the same nature and are no more severe than those found in residences.

Chapter 33 permits the use of NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes* and NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, outside of their scopes. This permission is based on a review of the occupancy and a recognition that the fires in board and care facilities are similar to those of other residential occupancies and that the level of protection is appropriate. In some circumstances, such as those for impractical evacuation capabilities, the requirements of NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes* and NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height* have been supplemented with requirements for additional water supplies to compensate for the special needs of the board and care occupancy.

A.33.3.1.2.1.1 In determining equivalency for existing buildings, conversions, modernizations, renovations, or unusual design concepts, the authority having jurisdiction might permit evaluations based on the residential board and care occupancies fire safety evaluation system (FSSES) in NFPA 101A, *Guide on Alternative Approaches to Life Safety*.

A.33.3.1.2.2 In determining equivalency for existing buildings, the authority having jurisdiction might permit evaluations based on the health care occupancies fire safety evaluation system (FSSES) in NFPA 101A, *Guide on Alternative Approaches to Life Safety*, substituting Table A.33.3.1.2.2 mandatory safety requirements values for those contained in NFPA 101A, *Guide on Alternative Approaches to Life Safety*.

Table A.33.3.1.2.2 Substitute Mandatory Safety Requirements Values

Zone Location	Containment S_a	Extinguishment S_b	People Movement S_c
First floor	5	6	3
Above or below first floor	9	8	5
Over 75 ft (23 m) in height	9	8	5

A.33.3.3.4.6 See A.29.3.4.3.6.

A.33.3.3.5.1 It is intended that this requirement apply to existing small facilities that are converted to large facilities.

Chapter 33 permits the use of NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, and NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, outside of their scopes. This permission is based on a review of the occupancy and a recognition that the fires in board and care facilities are similar to those of other residential occupancies and that the level of protection is appropriate. In some circumstances, such as those for impractical evacuation capabilities, the requirements of NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes* and NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height* have been supplemented with requirements for additional water supplies to compensate for the special needs of the board and care occupancy.

A.33.4 Board and care occupancies in apartment buildings will usually be small facilities housing 16 or fewer residents. It is intended that the board and care occupancy conform to the requirements of Section 33.2 for small board and care facilities. In the unusual case where an apartment houses a large board and care facility, it would be reasonable for the authority having jurisdiction, using 4.6.1, to apply the provisions of Section 33.3 to the apartment. In addition, the apartment building in which the facility is housed needs to comply with the requirements for apartment buildings in Chapters 30 and 31 and the additional criteria presented in Section 33.4.

A.33.4.1.3.1 In determining equivalency for existing buildings, conversions, modernizations, renovations, or unusual design concepts, the authority having jurisdiction might permit evaluations based on the residential board and care occupancies fire safety evaluation system (FSSES) in NFPA 101A, *Guide on Alternative Approaches to Life Safety*.

A.33.7.4.1 Smoking regulations should include the following:

- (1) Smoking should be prohibited in any room, compartment or area where flammable or combustible liquids, combustible gases, or oxygen is used or stored and in any other hazardous location. Such areas should be posted with signs that read NO SMOKING or the international symbol for no smoking. In residential board and care facilities where smoking is totally prohibited and signs so indicating are placed at all major entrances, secondary signs with language that prohibits smoking are not required.
- (2) Smoking by residents classified as not responsible with regard to their ability to safely use and dispose of smoking materials should be prohibited. Where the resident is under direct supervision by staff or by a person approved by the administration, smoking might be permitted.
- (3) Smoking materials should not be provided to residents or maintained by residents without the approval of the administration.
- (4) Areas where smoking is permitted should be clearly identified.
- (5) Ashtrays of noncombustible material and safe design should be provided and required to be used in all areas where smoking is permitted.
- (6) Self-closing cover devices into which ashtrays can be emptied should be made available to all areas where smoking is permitted and should be required to be used.

A.33.7.5 The requirements applicable to draperies/curtains, upholstered furniture, and mattresses apply only to new draperies/curtains, new upholstered furniture, and new mattresses. The word *new* means unused, normally via procurement from the marketplace, either by purchase or donation, of items not previously used. Many board and care facilities allow residents to bring into the board and care home upholstered furniture items from the resident's previous residence. Such an item is not new and, thus, is not regulated. On the other hand, some of the larger board and care homes purchase contract furniture, as is done in hotels. Such new, unused furniture, whether purchased or received as a donation, is regulated by the requirements of 33.7.5.2. By federal law, mattresses manufactured and sold within the United States must pass testing per FF4-72, *Standard for the Flammability of Mattresses*.

A.33.7.5.2 New upholstered furniture within board and care homes should be tested for rates of heat release in accordance with 10.3.3.

A.33.7.5.3 New mattresses within board and care homes should be tested for rates of heat release in accordance with 10.3.4.

A.36.1.2.2.2(4) Means to prevent spilled fuel from accumulating and entering the mercantile occupancy building can be by curbs, scuppers, special drainage systems, sloping the floor away from the door openings, or floor elevation differences of not less than 102 mm (4 in.).

A.36.2.2.2.2 The words "principal entrance/exit doors" describe doors that the authority having jurisdiction can reasonably expect to be unlocked in order for the facility to do business.

A.36.2.2.7.2 To design egress from a covered mall building, the following steps should be used:

- (1) The covered mall/pedestrian way has been assigned no occupant load, but it is required to be provided with means of egress sized to accommodate the total occupant load of the covered mall building based on the gross leasable area. The exits for the covered mall/pedestrian way are permitted to be provided by a combination of exterior exit doors and exit passageways.
- (2) After completion of step (a), each tenant space is to be judged individually for occupant load and egress capacity. This step normally sends a portion or all (per 36.4.4.3.4) of the tenant space's occupant load into the covered mall. Any remaining occupants are sent through the back of the tenant space into an exit passageway that might serve multiple tenant spaces and the covered mall.
- (3) The width of the exit passageway is required to be sized for the most restrictive of the following:
 - (a) For a width of not less than 1675 mm (66 in.) per 36.4.4.2.2(3)
 - (b) For the portion of the egress capacity from the largest single tenant space being served by the exit passageway
 - (c) For the portion of the egress capacity from the covered mall being provided by the exit passageway

The concepts used in steps (a) through (c) include the following:

- (1) After proper egress capacity is provided for the covered mall/pedestrian way, each tenant space is then required to independently provide egress capacity for its occupants.
- (2) The covered mall required exit passageway width and the tenant space required exit passageway width are not required to be added together.

- (3) The required exit passageway width for a tenant space is not required to be added to that of other tenant spaces using the same exit passageway.

A.36.2.5.10 To eliminate the obstruction to the means of egress of the interior exit access and the exterior exit discharge, it is the intent to provide adequate area for transit and parking of wheeled carts or buggies used by customers. This area includes corral areas adjacent to exits that are constructed to restrict the movement of wheeled carts or buggies therefrom.

A.36.2.7.2 The basis for the exemption to the general rule on complete enclosure of exits up to their point of discharge to the outside of the building is that, with the specified safeguards, reasonable safety is maintained.

A stairway is not considered to discharge through the street floor area if it leads to the street through a fire resistance-rated enclosure (exit passageway) separating it from the main area, even though there are doors between the first floor stairway landing and the main area.

The provisions of 36.2.7.2 should not be confused with those for open stairways as permitted by 36.3.1(1).

A.36.3.2.1 It is the intent to permit a suspended natural gas-fired unit heater that complies with the requirements of 9.2.2 to be installed and used in a mercantile occupancy without classifying the area in which it is located as hazardous.

A.36.3.2.1.1 These areas can include, but are not limited to, areas used for general storage, boiler or furnace rooms, and maintenance shops that include woodworking and painting areas.

A.36.3.2.2 The requirement for separating high hazard contents areas from other parts of the building is intended to isolate the hazard, and 8.2.3.3 is applicable.

A.36.3.6.1 The intent of 36.3.6.1(2) and 36.3.6.1(3) is to permit spaces within single tenant spaces, or within buildings protected throughout by an approved, supervised automatic sprinkler system, to be open to the exit access corridor without separation.

A.36.4.4.2.2(3) The minimum requirement for terminating mall exit access in not less than 1675 mm (66 in.) of egress width relates to the minimum requirement for not less than one aisle in Class A mercantile occupancies with 2800 m² (30,000 ft²) or greater sales area to be 1525 mm (60 in.) in width.

A.36.4.4.2.2(6) Fire experience in covered mall shopping centers indicates that the most likely place of fire origin is in the tenant space where the combustible fire load is far greater than in the covered mall proper.

Furthermore, any fires resulting from the comparatively low fire load in the covered mall proper are more likely to be detected and extinguished in their incipient stages. Early detection is likely due to the nature of the covered mall proper as a high traffic pedestrian way. Such fires produce less smoke development in a greater volume of space than fires in the more confined adjacent tenant space.

Smoke control systems that address fire experience in covered malls are necessary in order to achieve the following:

- (1) Ensure the integrity of the covered mall as a pedestrian way by maintaining it reasonably free of the products of combustion for a duration not less than that required to evacuate the building
- (2) Confine the products of combustion to the area of origin

- (3) Remove the products of combustion with a minimum of migration of such products of combustion from one tenant to another

Systems, or combinations of systems, that can be engineered to address fires in covered malls include the following:

- (1) Separate mechanical exhaust or control systems
- (2) Mechanical exhaust or control systems in conjunction with heating, ventilating, and air conditioning systems
- (3) Automatically or manually released gravity roof vent devices, such as skylights, relief dampers, or smoke vents
- (4) Combinations of items (1), (2), and (3) in this list, or any other engineered system designed to accomplish the purpose of this section

A.36.4.4.3.5 It is not the intent of 36.4.4.3.5 to require that large tenant spaces be considered anchor stores. A tenant space not considered in determining the occupant load of the mall is required to be arranged so that all of its means of egress will be independent of the covered mall.

A.36.4.4.3.7 Rooms opening onto the exit passageway are intended to include building service elevators, elevator machine rooms, electrical rooms, telephone rooms, janitor closets, restrooms, and similar normally unoccupied spaces not requiring hazardous area protection in accordance with Section 8.7.

A.37.1.2.2.2(4) Means to prevent spilled fuel from accumulating and entering the mercantile occupancy building can be by curbs, scuppers, special drainage systems, sloping the floor away from the door openings, or elevation differences of not less than 102 mm (4 in.).

A.37.2.2.2.2 The words "principal entrance/exit doors" describe doors that the authority having jurisdiction can reasonably expect to be unlocked in order for the facility to do business.

A.37.2.2.7.2 To design egress from a mall building, the following steps should be used:

- (1) The mall/pedestrian way has been assigned no occupant load, but it is required to be provided with means of egress sized to accommodate the total occupant load of the covered mall building based on the gross leasable area. The exits for the mall/pedestrian way are permitted to be provided by a combination of exterior exit doors and exit passageways.
- (2) After completion of step (a), each tenant space is to be judged individually for occupant load and egress capacity. This step normally sends a portion or all (per 37.4.4.3.4) of the tenant space's occupant load into the covered mall. Any remaining occupants are sent through the back of the tenant space into an exit passageway that might serve multiple tenant spaces and the covered mall.
- (3) The width of the exit passageway is required to be sized for the most restrictive of the following:
 - (a) For a width of not less than 1675 mm (66 in.) per 37.4.4.2.2(3)
 - (b) For the portion of the egress capacity from the largest single tenant space being served by the exit passageway
 - (c) For the portion of the egress capacity from the covered mall being provided by the exit passageway

The concepts used in steps (a) through (c) include the following:

- (1) After proper egress capacity is provided for the mall/pedestrian way, each tenant space is then required to independently provide egress capacity for its occupants.

- (2) The mall required exit passageway width and the tenant space required exit passageway width are not required to be added together.
- (3) The required exit passageway width for a tenant space is not required to be added to that of other tenant spaces using the same exit passageway.

A.37.2.5.2 The purpose of 37.2.5.2 is to avoid pockets or dead ends of such size that they pose an undue danger of persons becoming trapped in case of fire.

It is recognized that dead ends exceeding the permitted limits exist and, in some cases, are impractical to eliminate. The authority having jurisdiction might permit such dead ends to continue to exist, taking into consideration any or all of the following:

- (1) Tenant arrangement
- (2) Automatic sprinkler protection
- (3) Smoke detection
- (4) Exit remoteness

A.37.2.5.3 It is recognized that common paths of travel exceeding the permitted limits exist and, in some cases, are impractical to eliminate. The authority having jurisdiction might permit such paths of travel to continue to exist, taking into consideration any or all of the following:

- (1) Tenant arrangement
- (2) Automatic sprinkler protection
- (3) Smoke detection
- (4) Exit remoteness

A.37.2.5.10 To eliminate the obstruction to the means of egress of the interior exit access and the exterior exit discharge, it is the intent to provide adequate area for transit and parking of wheeled carts or buggies used by customers. This area includes corral areas adjacent to exits that are constructed to restrict the movement of wheeled carts or buggies therefrom.

A.37.2.7.2 The basis for the exemption to the general rule on complete enclosure of exits up to their point of discharge to the outside of the building is that, with the specified safeguards, reasonable safety is maintained.

A stairway is not considered to discharge through the street floor area if it leads to the street through a fire resistance-rated enclosure (exit passageway) separating it from the main area, even though there are doors between the first floor stairway landing and the main area.

The provisions of 37.2.7.2 should not be confused with those for open stairways as permitted by 37.3.1(1) and 37.3.1(2).

A.37.3.2.1 It is the intent to permit a suspended natural gas-fired unit heater that complies with the requirements of 9.2.2 to be installed and used in a mercantile occupancy without classifying the area in which it is located as hazardous.

A.37.3.2.1.1 These areas can include, but are not limited to, areas used for general storage, boiler or furnace rooms, and maintenance shops that include woodworking and painting areas.

A.37.3.2.2 The requirement for separating high hazard contents areas from other parts of the building is intended to isolate the hazard, and 8.2.3.3 is applicable.

A.37.4.4.2.2(3) The minimum requirement for terminating mall exit access in not less than 1675 mm (66 in.) of egress width relates to the minimum requirement for not less than

one aisle in Class A mercantile occupancies [2800 m² (30,000 ft²) or greater sales area] to be 1525 mm (60 in.) in width.

A.37.4.4.2.2(6) Fire experience in mall shopping centers indicates that the most likely place of fire origin is in the tenant space where the combustible fire load is far greater than in the mall proper.

Furthermore, any fires resulting from the comparatively low fire load in the covered mall proper are more likely to be detected and extinguished in their incipient stages. Early detection is likely due to the nature of the covered mall proper as a high traffic pedestrian way. Such fires produce less smoke development in a greater volume of space than in the more confined adjacent tenant space.

Smoke control systems that address fire experience in covered malls are necessary in order to achieve the following:

- (1) Ensure the integrity of the covered mall as a pedestrian way by maintaining it reasonably free of the products of combustion for a duration not less than that required to evacuate the building
- (2) Confine the products of combustion to the area of fire origin
- (3) Remove the products of combustion with a minimum of migration of such products of combustion from one tenant to another

Systems, or combinations of systems, that can be engineered to address fires in covered malls include the following:

- (1) Separate or mechanical exhaust or control systems
- (2) Mechanical exhaust or control systems in conjunction with heating, ventilating, and air conditioning systems
- (3) Automatically or manually released gravity roof vent devices, such as skylights, relief dampers, or smoke vents
- (4) Combinations of items (1), (2), and (3) in this list, or any other engineered system designed to accomplish the purpose of this section

A.37.4.4.3.5 It is not the intent of 37.4.4.3.5 to require that large tenant spaces be considered anchor stores. A tenant space not considered in determining the occupant load of the mall is required to be arranged so that all of its means of egress will be independent of the covered mall.

A.37.4.4.3.7 Rooms opening onto the exit passageway are intended to include building service elevators, elevator machine rooms, electrical rooms, telephone rooms, janitor closets, restrooms, and similar normally unoccupied spaces not requiring hazardous area protection in accordance with Section 8.7.

A.38.1.2.2.2(4) Means to prevent spilled fuel from accumulating and entering the business occupancy building can be by curbs, scuppers, special drainage systems, sloping the floor away from the door openings, or elevation differences not less than 102 mm (4 in.).

A.38.2.2.2.2 The words "principal entrance/exit doors" describe doors that the authority having jurisdiction can reasonably expect to be unlocked in order for the facility to do business.

A.38.2.3.2 It is not the intent that this provision apply to non-corridor or nonpassageway areas of exit access, such as the spaces between rows of desks created by office layout or low-height partitions.

A.38.3.2.1 It is not the intent of this provision that rooms inside individual tenant spaces, used to store routine office

supplies for that tenant, be required to be either separated or sprinklered.

A.38.3.2.2 The requirement for separating high hazard contents areas from other parts of the building is intended to isolate the hazard, and 8.2.3.3 is applicable.

A.38.3.6.1 The intent of 38.3.6(1) through 38.3.6(3) is to permit spaces to be open to the exit access corridor without separation.

A.38.3.6.1(1) Where exits are available from an open floor area, such as open plan buildings, corridors are not required to be separated. An example of an open plan building is a building in which the work spaces and accesses to exits are delineated by the use of tables, desks, bookcases, or counters or by partitions that are less than floor-to-ceiling height.

A.38.3.6.1(2) It is the intent of this provision that a single tenant be limited to an area occupied under a single management and work the same hours. The concept is that people under the same employ working the same hours would likely be familiar with their entire tenant space. It is not the intent to apply this provision simply because tenants are owned by the same organization. For example, in a government-owned office building, the offices of different federal agencies would be considered multiple tenants because an employee normally works for one agency. The agencies might work various hours. Another example of multiple tenancy would be a classroom building of a university because some classrooms might be in use at times when other classrooms are not being used.

A.38.4.2 In the design of high-rise buildings, special consideration should also be given to a life safety system including, but not limited to, the following features:

- (1) Movement of occupants to safety
- (2) Control of fire and smoke
- (3) Psychological features
- (4) Communications systems
- (5) Elevators
- (6) Emergency planning
- (7) Overall system reliability

A.39.1.2.2.2(4) Means to prevent spilled fuel from accumulating and entering the business occupancy building can be by curbs, scuppers, special drainage systems, sloping the floor away from the door openings, or elevation differences not less than 102 mm (4 in.).

A.39.2.2.2.2 The words "principal entrance/exit doors" describe doors that the authority having jurisdiction can reasonably expect to be unlocked in order for the facility to do business.

A.39.2.5.2 It is recognized that dead ends exceeding the permitted limits exist and, in some cases, are impractical to eliminate. The authority having jurisdiction might permit such dead ends to continue to exist, taking into consideration any or all of the following:

- (1) Tenant arrangement
- (2) Automatic sprinkler protection
- (3) Smoke detection
- (4) Exit remoteness

A.39.2.5.3 It is recognized that common paths of travel exceeding the permitted limits exist and, in some cases, are impractical to eliminate. The authority having jurisdiction might permit such common paths of travel to continue to exist, taking into consideration any or all of the following:

- (1) Tenant arrangement
- (2) Automatic sprinkler protection
- (3) Smoke detection
- (4) Exit remoteness

A.39.3.2.1 It is not the intent of this provision that rooms inside individual tenant spaces, used to store routine office supplies for that tenant, be required to be separated or sprinklered.

A.39.3.2.2 The requirement for separating high hazard contents areas from other parts of the building is intended to isolate the hazard, and 8.2.3.3 is applicable.

A.39.4.2.2 In some cases, appreciable cost might be involved in bringing an existing occupancy into compliance. Where this is true, it would be appropriate for the authority having jurisdiction to prescribe a schedule determined jointly with the facility, allowing suitable periods of time for the correction of the various deficiencies and giving due weight to the ability of the owner to secure the necessary funds.

A.40.1.4.1(3) Additional information can be found in the annex for the definition of *High Hazard Industrial Occupancy* in A.3.3.152.8.2.

A.40.1.7 In most cases, the requirements for maximum travel distance to exits will be the determining factor rather than numbers of occupants because exits provided to satisfy travel distance requirements will be sufficient to provide egress capacity for all occupants, except in cases of unusual arrangement of buildings or high occupant load of a general manufacturing occupancy.

A.40.2.2.5.2 The customary building code requirement for fire doors on both sides of an opening in a fire wall is permitted to be met by having an automatic-sliding fire door on one side, and a self-closing fire door swinging out from the other side of the wall. This arrangement qualifies only as a horizontal exit from the side of the sliding door. For further information, see A.7.2.4.3.9.

A.40.2.5.1.1 Ancillary facilities located within industrial occupancies might include administrative office, laboratory, control, and employee service facilities that are incidental to the predominant industrial function and are of such size that separate occupancy classification is not warranted.

A.40.2.5.1.2 Occupants of ancillary facilities located within special-purpose industrial occupancies might be required by administrative controls to remain in the facility when a fire occurs in the predominant industrial area so that they can perform an orderly shutdown of process equipment to control the spread of the fire and minimize damage to important equipment.

A.40.2.9 The authority having jurisdiction should review the facility and designate the stairs, aisles, corridors, ramps, and passageways that should be required to be provided with emergency lighting. In large locker rooms or laboratories using hazardous chemicals, for example, the authority having jurisdiction should determine that emergency lighting is needed in the major aisles leading through those spaces.

A.40.3.2 Emergency lighting should be considered where operations require lighting to perform orderly manual emergency operation or shutdown, maintain critical services, or provide safe start-up after a power failure.

A.40.6 For further information on aircraft hangars, see NFPA 409, *Standard on Aircraft Hangars*.

A.42.1.7 There is no occupant load factor specified for storage occupancies. Rather, the actual probable maximum num-

ber of persons present needs to be considered in determining the occupant load.

A.42.2.2.5.2 The customary building code requirement for fire doors on both sides of an opening in a fire wall is permitted to be met by having an automatic-sliding fire door on one side and a self-closing fire door swinging out from the other side of the wall. This arrangement qualifies only as a horizontal exit from the side of the sliding door. For further information, see A.7.2.4.3.9.

A.42.2.6 The travel distance to exits specified recognizes a low population density. Consideration should be given to locating areas that have a relatively high population, such as lunchrooms, meeting rooms, packaging areas, and offices, near the outside wall of the building to keep the travel distance to a minimum.

A.42.6 For further information on aircraft hangars, see NFPA 409, *Standard on Aircraft Hangars*.

A.42.7 For further information, see NFPA 61, *Standard for the Prevention of Fires and Dust Explosions in Agricultural and Food Processing Facilities*. The egress requirements for storage elevators are based on the possibility of fire and are not based on the possibility of grain dust explosions.

Annex B Informational References

B.1 The following documents or portions thereof are referenced within this *Code* for informational purposes only and are thus not considered part of the requirements of this *Code* unless also listed in Chapter 2. The edition indicated here for each reference is the current edition as of the date of the NFPA issuance of this *Code*.

B.1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2002 edition.

NFPA 11, *Standard for Low-, Medium-, and High-Expansion Foam*, 2002 edition.

NFPA 12, *Standard on Carbon Dioxide Extinguishing Systems*, 2000 edition.

NFPA 12A, *Standard on Halon 1301 Fire Extinguishing Systems*, 1997 edition.

NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2002 edition.

NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, 2002 edition.

NFPA 13R, *Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and Including Four Stories in Height*, 2002 edition.

NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*, 2003 edition.

NFPA 15, *Standard for Water Spray Fixed Systems for Fire Protection*, 2001 edition.

NFPA 17, *Standard for Dry Chemical Extinguishing Systems*, 2002 edition.

NFPA 22, *Standard for Water Tanks for Private Fire Protection*, 2003 edition.

NFPA 30, *Flammable and Combustible Liquids Code*, 2000 edition.

NFPA 58, *Liquefied Petroleum Gas Code*, 2001 edition.

NFPA 61, *Standard for the Prevention of Fires and Dust Explosions in Agricultural and Food Processing Facilities*, 2002 edition.

NFPA 68, *Guide for Venting of Deflagrations*, 2002 edition.

NFPA 70, *National Electrical Code*[®], 2002 edition.

NFPA 72[®], *National Fire Alarm Code*[®], 2002 edition.

NFPA 80, *Standard for Fire Doors and Fire Windows*, 2003 edition.

NFPA 88A, *Standard for Parking Structures*, 2001 edition.

NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, 2002 edition.

NFPA 92A, *Recommended Practice for Smoke-Control Systems*, 2000 edition.

NFPA 92B, *Guide for Smoke Management Systems in Malls, Atria, and Large Areas*, 2000 edition.

NFPA 99, *Standard for Health Care Facilities*, 2002 edition.

NFPA 101A, *Guide on Alternative Approaches to Life Safety*, 2001 edition.

NFPA 105, *Standard for the Installation of Smoke Door Assemblies*, 2003 edition.

NFPA 110, *Standard for Emergency and Standby Power Systems*, 2002 edition.

NFPA 170, *Standard for Fire Safety Symbols*, 2002 edition.

NFPA 204, *Standard for Smoke and Heat Venting*, 2002 edition.

NFPA 211, *Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances*, 2003 edition.

NFPA 220, *Standard on Types of Building Construction*, 1999 edition.

NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*, 2000 edition.

NFPA 251, *Standard Methods of Tests of Fire Endurance of Building Construction and Materials*, 1999 edition.

NFPA 253, *Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source*, 2000 edition.

NFPA 255, *Standard Method of Test of Surface Burning Characteristics of Building Materials*, 2000 edition.

NFPA 259, *Standard Test Method for Potential Heat of Building Materials*, 2003 edition.

NFPA 260, *Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture*, 1998 edition.

NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*, 1998 edition.

NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile Coverings on Full Height Panels and Walls*, 2002 edition.

NFPA 267, *Standard Method of Test for Fire Characteristics of Mattresses and Bedding Assemblies Exposed to Flaming Ignition Source*, 1998 edition.

NFPA 269, *Standard Test Method for Developing Toxic Potency Data for Use in Fire Hazard Modeling*, 2000 edition.

NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, 2000 edition.

NFPA 307, *Standard for the Construction and Fire Protection of Marine Terminals, Piers, and Wharves*, 2000 edition.

NFPA 409, *Standard on Aircraft Hangars*, 2001 edition.

NFPA 501A, *Standard for Fire Safety Criteria for Manufactured Home Installations, Sites, and Communities*, 2003 edition.

NFPA 601, *Standard for Security Services in Fire Loss Prevention*, 2000 edition.

NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*, 1999 edition.

NFPA 705, *Recommended Practice for a Field Flame Test for Textiles and Films*, 1997 edition.

NFPA 914, *Code for Fire Protection of Historic Structures*, 2001 edition.

NFPA 1221, *Standard for the Installation, Maintenance, and Use of Emergency Services Communications Systems*, 2001 edition.

NFPA 2001, *Standard on Clean Agent Fire Extinguishing Systems*, 2000 edition.

NFPA *Fire Protection Handbook*, 18th edition, 1997.

NFPA SPP-53, *Smoke Control in Fire Safety Design*, Butcher and Parnell.

SFPE *Handbook of Fire Protection Engineering*, 2nd edition, National Fire Protection Association, 1 Batterymarch Park, P. O. Box 9101, Quincy, MA 02269-9101.

B.1.2 Other Publications.

B.1.2.1 American Concrete Institute. P.O. Box 9094, Farmington Hills, MI 48333.

ACI 2/6R, *Guide for Determining the Fire Endurance of Concrete Elements*.

B.1.2.2 ADAAG Americans with Disabilities Act Accessibility Guidelines.

B.1.2.3 AISI Publications. American Iron and Steel Institute, 1011 17th Street, NW, 13th floor, Washington, DC 20036.

AISI, *Designing Fire Protection for Steel Beams*.

AISI, *Designing Fire Protection for Steel Columns*.

AISI, *Designing Fire Protection for Steel Trusses*.

B.1.2.4 AF&PA Publication. American Forest & Paper Association, 1111 19th Street, NW, Suite 800, Washington, DC 20036.

American Forest & Paper Association, *Design of Fire-Resistive Exposed Wood Members*.

B.1.2.5 ANSI Publications. American National Standards Institute, Inc., 11 West 42nd Street, 13th floor, New York, NY 10036.

ANSI/BHMA A156.10, *American National Standard for Power Operated Pedestrian Doors*.

ANSI/BHMA A156.19, *American National Standard for Power Assist & Low Energy Power Operated Doors*.

ASME/ANSI A17.1, *Safety Code for Elevators and Escalators*, 2000.

ASME A17.3, *Safety Code for Existing Elevators and Escalators*, 1993.

CABO/ANSI A117.1, *American National Standard for Accessible and Usable Buildings and Facilities*, 1992.

B.1.2.6 ASHRAE Publications. American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc., 1791 Tullie Circle, NE, Atlanta, GA 30329-2305.

ASHRAE *Guideline 5: Guideline for Commissioning Smoke Management Systems*.

ASHRAE *Handbook and Product Directory — Fundamentals*, 2000.

B.1.2.7 ASTM Publications. American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

ASTM E 814-83, *Methods for Fire Tests of Through-Penetration Fire Stops*.

ASTM E 1355, *Standard Guide for Evaluating the Predictive Capability of Fire Models*.

ASTM E 1537, *Standard Test Method of Fire Testing of Real Scale Upholstered Furniture Items*.

ASTM E 1590, *Standard Method for Fire Testing of Real Scale Mattresses*.

ASTM F 1637, *Standard Practice for Safe Walking Surfaces*.

ASTM 1472, *Standard Guide for Documenting Computer Software*.

B.1.2.8 CRSI Publication. Concrete Reinforced Steel Institute, 933 N. Plum Grove Road, Schaumburg, IL 60173-4753.

CRSI, *Reinforced Concrete Fire Resistance*.

B.1.2.9 SFPE Publication. Society of Fire Prevention Engineers, 7315 Wisconsin Avenue, Suite 122 SW, Bethesda, MD 20814

SFPE *Engineering Guide to Performance-Based Fire Protection Analysis and Design of Buildings*, 1998.

B.1.2.10 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.

UL *Fire Resistance Directory*.

UL 1975, *Standard for Fire Tests for Foamed Plastics Used for Decorative Purposes*, 1996.

UL 2079, *Test for Fire Resistance of Building Joint Systems*, 1st edition, 1998.

B.1.2.11 U.S. Government Publications. U.S. Government Printing Office, Washington, D.C. 20402.

16 CFR 1632.

16 CFR 1630, *Standard for the Surface Flammability of Carpets and Rugs*, FF 1-70.

28 CFR 31, Appendix A, Section 4.28, Alarms.

28 CFR 36, Appendix A, Sections 9.1.3, 9.1.5 and 9.2.2(8).

OSHA *Regulations for Emergency Procedures and Fire Brigades*, 29 CFR 1910, Subparts E and L, Occupational Safety & Health Association, Office of Administrative Services, 200 Constitution Ave., NW, Rm 5452, Washington, DC 20210.

B.1.3 Additional Publications.

Australian Fire Engineering Guidelines, Fire Code Perform Centre, Limited, Sydney, Australia, 1996.

British Standard Firesafety Engineering in Buildings, DD240: Part 1, British Standards Institution, London, England, 1997.

CMIFC, *Analytical Methods of Determining Fire Endurance of Concrete and Masonry Members — Model Code Approved Procedures*, Concrete and Masonry Industry Firesafety Committee, 5420 Old Orchard Road, Skokie, IL 60077-4321.

National Building Code, Building Officials and Code Administrators International, Inc., 4051 West Flossmoor Road, Country Club Hills, IL 60478-5795.

PCI, *Design for Fire Resistance of Precast Prestressed Concrete*, Precast Prestressed Concrete Institute, 175 West Jackson Blvd., Chicago, IL 60604.

Standard Building Code, Southern Building Code Congress International, Inc., 900 Montclair Road, Birmingham, AL 35213-1206.

Uniform Building Code, 5360 South Workman Mill Road, Whittier, CA 90601.

UBC, *Methods for Calculating Fire Resistance of Wood-Framed Walls, Floors and Roofs*, Uniform Building Code, 5360 South Workman Mill Road, Whittier, CA 90601.

FF4-72, *Standard for the Flammability of Mattresses*.

Gann *et al.*, *Fire and Materials*, 18:193 (1994).

Groner, N. E., and Levin, M. L. "Human Factors Considerations in the Potential for Using Elevators in Building Emergency Evacuation Plans," National Institute of Standards and Technology, NIST-GCR-92-615, 1992.

Kaplan *et al.*, *Journal of Fire Science*, 2:286-305 (1984).

Klote, J. H., and Milke, J. A., *Design of Smoke Management Systems*, American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc., 1791 Tullie Circle, NE, Atlanta, GA 30329-2305.

Levin, B. M., and Groner, N. E., "Human Behavior Aspects of Staging Areas for Fire Safety in GSA Buildings," National Institute of Standards and Technology, NIST-GCR-92-606, 1992.

Levin, B. M., and Groner, N. E., "Human Factors Considerations for the Potential Use of Elevators for Fire Evacuation of FAA Air Traffic Control Towers," National Institute of Standards and Technology, NIST-GCR-94-656, 1994.

Templer, J. A., *The Staircase: Studies of Hazards, Falls, and Safer Design*, Cambridge, MA: MIT Press, 1992.

B.2 References for Extracts. A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, Annex B lists the complete title and edition of the source documents for both mandatory and nonmandatory extracts. Editorial changes to extracted material consist of revising references to an appropriate division in this document or the inclusion of the document number with the division number when the reference is to the original document. Requests for interpretations or revisions of extracted text [shall, should] be sent to the technical committee responsible for the source document.

NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*

NFPA 72®, *National Fire Alarm Code*®

NFPA 80, *Standard for Fire Doors and Fire Windows*

NFPA 220, *Standard on Types of Building Construction*

NFPA 415, *Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways*

ASCE 7, *Minimum Design Loads for Buildings and Other Structures*, 2002.

Index

© 2003 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

-A-

- Access-controlled egress doors** 7.2.1.6.2
- Access/egress routes**
 - Existing assembly occupancies 13.2.5.4, A.13.2.5.4.2 to A.13.2.5.4.4
 - New assembly occupancies ... 12.2.5.4, A.12.2.5.4.2 to A.12.2.5.4.4
- Accessible areas of refuge** *see* Areas of refuge
- Accessible means of egress** 7.4.1.3, 7.5.4, A.7.5.4.1; *see also* Exit access; Means of egress
 - Definition 3.3.136.1
 - Elevators as 9.4.1, A.9.4.1
- Accessory rooms** 12.4.5.4
 - Definition A.12.1.3, A.13.1.3
- Additions**
 - Ambulatory health care occupancies 20.1.1.4.1, 21.1.1.4.1
 - Application of code 4.6.7
 - Definition 3.3.3
 - Detention and correctional occupancies 22.1.1.3, 23.1.1.3
 - Health care occupancies 18.1.1.4.1 to 18.1.1.4.4, 19.1.1.4.1 to 19.1.1.4.4
 - Mercantile occupancies 36.1.1.3, 37.1.1.3
- Air conditioning** *see* Heating, ventilating, and air conditioning
- Aircraft servicing hangars** 40.6, A.40.6
- Aircraft storage hangars** 42.6, A.42.6
- Air-handling ducts** *see* Ducts, openings for
- Air-inflated structures** 11.9.3, A.11.9.3.3.1
 - Definition 3.3.217.1
 - Maintenance and operation 11.9.4, 11.10.6
 - Pressurization system 11.9.3.2, 11.10.5.2
 - Standby power system 11.9.3.3, 11.10.5.3, A.11.9.3.3.1
 - Temporary 11.10.5
- Airport loading walkways** 12.4.10, 13.4.10, A.12.4.10.2(2)
 - Definition 3.3.5
- Airport terminal buildings**
 - Definition 3.3.27.1
 - Occupant load factors A.7.3.1.2
- Air-supported structures** 11.9.3, A.11.9.3.3.1
 - Definition 3.3.217.2, A.3.3.217
 - Maintenance and operation 11.9.4, 11.10.6
 - Pressurization system 11.9.3.2, 11.10.5.2
 - Standby power system 11.9.3.3, 11.10.5.3, A.11.9.3.3.1
 - Temporary 11.10.5
- Air-transfer openings** 8.4.6, 8.5.4, A.8.4.6.2; *see also* Penetrations/openings
- Aisle accessways**
 - Definition 3.3.8, A.3.3.8
 - Existing assembly occupancies 13.2.5.4.4 to 13.2.5.4.8, A.13.2.5.4.4
 - New assembly occupancies ... 12.2.5.4.4 to 12.2.5.4.8, A.12.2.5.4.4
- Aisle accessways serving seating at tables**
 - Existing assembly occupancies 13.2.5.7, A.13.2.5.7
 - New assembly occupancies 12.2.5.7, A.12.2.5.7
- Aisle accessways serving seating not at tables**
 - Existing assembly occupancies 13.2.5.5, A.13.2.5.5
 - New assembly occupancies 12.2.5.5, A.12.2.5.5
- Aisle marking, existing assembly occupancies** 13.2.5.6.8, A.13.2.5.6.8
- Aisles** *see also* Dead-end aisles
 - Bleachers 13.2.3.5
 - Existing educational occupancies 15.2.5.6, 15.2.5.7
 - Existing health care occupancies 19.2.3.4, 19.2.3.5
 - New educational occupancies 14.2.5.6, 14.2.5.7
 - New health care occupancies 18.2.3.4, 18.2.3.5
- Aisles serving seating at tables**
 - Existing assembly occupancies 13.2.5.8, A.13.2.5.8.1 to A.13.2.5.8.3
 - New assembly occupancies ... 12.2.5.8, A.12.2.5.8.1 to A.12.2.5.8.3
- Aisles serving seating not at tables**
 - Existing assembly occupancies 13.2.3.2, 13.2.3.5, 13.2.5.6, A.13.2.3.2, A.13.2.5.6
 - New assembly occupancies 12.2.3.2, 12.2.5.6, A.12.2.3.2, A.12.2.5.6
- Alarm initiation** 9.6.1.8(1), 9.6.2, A.9.6.2
 - Ambulatory health care occupancies 20.3.4.2, 21.3.4.2
 - Apartment buildings 30.3.4.2, 31.3.4.2
 - Assembly occupancies 12.3.4.2, 12.4.7.5, 13.3.4.2, 13.4.7.5, A.12.3.4.2.3, A.13.3.4.2.2
 - Business occupancies 38.3.4.2, 39.3.4.2
 - Day-care occupancies 16.3.4.2, 17.3.4.2
 - Detention and correctional occupancies 22.3.4.2, 22.4.4.9.1, 23.3.4.2
 - Educational occupancies 14.3.4.2, 15.3.4.2, A.14.3.4.2.3.1, A.14.3.4.2.3.2, A.15.3.4.2.3.1, A.15.3.4.2.3.2
 - Health care occupancies ... 18.3.4.2, 19.3.4.2, A.18.3.4.2, A.19.3.4.2
 - Hotels and dormitories 28.3.4.2, 29.3.4.2
 - Industrial occupancies 40.3.4.2
 - Lodging or rooming houses 26.3.3.2
 - Mercantile occupancies 36.3.4.2, 36.4.4.4.2, 36.4.5.4.2, 37.3.4.2, 37.4.4.4.2, 37.4.5.4.2
 - Parking structures 42.8.3.4.2
 - Residential board and care occupancies 32.3.3.4.2, 33.3.3.4.2
 - Storage occupancies 42.3.4.2
- Alarms and alarm systems** 9.6, A.9.6; *see also* Alarm initiation; Communication systems; Notification
 - Annunciation 9.6.7
 - Apartment buildings 30.3.4.3.2 to 30.3.4.3.4, 31.3.4.3.2 to 31.3.4.3.4
 - Health care occupancies 18.3.4.3.3
 - Residential board and care occupancies 32.3.3.4.3
 - Bulk merchandising retail buildings 36.4.5.4, 37.4.5.4
 - Door alarms 7.2.1.5, A.7.2.1.5
 - Door closing action initiated by *see* Self-closing
 - Emergency control 9.6.1.8(3), 9.6.5, 9.6.6
 - Existing ambulatory health care occupancies 21.3.4
 - Existing apartment buildings 31.3.4
 - Existing assembly occupancies 13.3.4, 13.4.7.5, A.13.3.4.2.2
 - Existing business occupancies 39.3.4
 - Existing day-care homes 17.6.3.4
 - Existing day-care occupancies 17.3.4
 - Existing detention and correctional occupancies 23.3.4, A.23.3.4.3.1(2), A.23.3.4.4.3
 - Existing educational occupancies 15.3.4, A.15.3.4
 - Existing health care occupancies 19.3.4, A.19.3.4.2, A.19.3.4.3.1(1)
 - Existing hotels and dormitories 29.3.4, A.29.3.4.3.6, A.29.3.4.5
 - Existing mercantile occupancies 37.3.4, 37.4.4.4, 37.4.5.4
 - Existing residential board and care occupancies 33.2.3.4, 33.3.3.4, A.33.2.3.4.3
 - High-rise buildings 11.8.3, A.11.8.3.1
 - Industrial occupancies 40.3.4
 - Lodging houses 26.3.3, A.26.3.3.3.1
 - Maintenance/testing 9.6.1.3, 9.6.1.6, 9.6.1.9, 9.6.1.10, A.9.6.1.6

- Mall buildings 36.4.4.4, 37.4.4.4
 Manual alarms 9.6.2.1 to 9.6.2.6, A.9.6.2.6
 Multiple station alarm device 9.6.2.10.1, 16.6.3.4.3(1), 17.6.3.4.3(1)
 Definition 3.3.146
 New ambulatory health care occupancies 20.3.4
 New apartment buildings 30.3.4, A.30.3.4.5.1
 New assembly occupancies 12.3.4, 12.4.7.5, A.12.3.4.2.3
 New business occupancies 38.3.4
 New day-care homes 16.6.3.4
 New day-care occupancies 16.3.4
 New detention and correctional occupancies 22.3.4, 22.4.4.9, A.22.3.4
 New educational occupancies 14.3.4, A.14.3.4
 New health care occupancies 18.3.4, 18.7.2.3.3, A.18.3.4
 New hotels and dormitories 28.3.4, A.28.3.4.5
 New mercantile occupancies 36.3.4, 36.4.4.4, 36.4.5.4
 New residential board and care occupancies 32.2.3.4, 32.3.3.4
 One- and two-family dwellings 24.3.4
 Parking structures 42.8.3.4
 Rooming houses 26.3.3, A.26.3.3.3.1
 Shutdown 9.6.1.7
 Signal transmission 9.7.2.2
 Single station alarm 9.6.2.10.1
 Apartment buildings 30.3.4.5.1, 31.3.4.5, A.30.3.4.5.1
 Day-care homes 16.6.3.4.3(1), 17.6.3.4.3(1)
 Definition 3.3.9.1
 Hotels and dormitories 28.3.4.5, 29.3.4.5, A.28.3.4.5, A.29.3.4.5
 Lodging or rooming houses 26.3.3.5.1
 Smoke alarms 9.6.2.10, A.9.6.2.10.3
 Apartment buildings 30.3.4.5, 31.3.4.5, A.30.3.4.5.1
 Day-care homes 16.6.3.4, 17.6.3.4
 Definition 3.3.9.2
 Hotels and dormitories 28.3.4.5, 29.3.4.5, A.28.3.4.5, A.29.3.4.5
 Lodging or rooming houses 26.3.3.5
 One- and two-family dwellings 24.3.4
 Residential board and care occupancies 32.2.3.4.3, 32.3.3.4.7, 33.2.3.4.3, 33.3.3.4.7, A.33.2.3.4.3
 Special structures 11.2.3.4, 11.3.3.4, 11.4.3.4
 Storage occupancies 42.3.4
 Supervisory signals 9.7.2.1, 9.7.2.2, A.9.7.2.1
 Waterflow alarms 9.6.2.5, 9.6.2.7, 9.7.2.2
Alterations, ambulatory health care occupancies 20.1.1.4.3, 21.1.1.4.3; *see also* Construction
Alternating tread devices 7.2.11, A.7.2.11
 Apartment buildings 30.2.2.11, 31.2.2.11
 Assembly occupancies 12.2.2.11, 12.2.4.8, 13.2.2.11, 13.2.4.8
 Business occupancies 38.2.2.11, 39.2.2.11
 Day-care occupancies 16.2.2.9, 17.2.2.9
 Detention and correctional occupancies 22.2.2.10, 23.2.2.10
 Educational occupancies 14.2.2.9, 15.2.2.9
 Health care occupancies 18.2.2.9, 19.2.2.9
 Hotels and dormitories 28.2.2.11, 29.2.2.11
 Industrial occupancies 40.2.2.12
 Mercantile occupancies 36.2.2.11, 37.2.2.11
 One- and two-family dwellings 24.2.5.6
 Performance-based design option 5.3.2(7)
 Residential board and care occupancies 32.3.2.2.9, 33.3.2.2.9
 Storage occupancies 42.2.2.11
Alternative calculation procedure (definition) 3.3.10
Ambulatory health care occupancies *see also* Existing ambulatory health care occupancies; New ambulatory health care occupancies
 Changes of occupancy 18.1.1.4.5(4), 19.1.1.4.5(4)
 Classification of occupancy 6.1.6, 18.1.2.3, 19.1.2.3, A.6.1.6.1
 Definition 3.3.152.1, 6.1.6.1, A.3.3.152.1, A.6.1.6.1
Analysis *see also* Life safety evaluation
 Sensitivity analysis 5.4.2.2, 5.4.2.3, 5.5.4.2, 5.5.4.3, A.5.7
 Definition 3.3.12.1
 Uncertainty analysis 5.6.3.3, 5.7, A.5.6.3.3, A.5.7
 Definition 3.3.12.2
Anchor buildings 36.4.4.3.5, 37.4.4.3.5, A.36.4.4.3.5, A.37.4.4.3.5
 Definition 3.3.27.2
Anesthetizing locations 18.3.2.3, 19.3.2.3, 20.3.2.3, 21.3.2.3
Apartment buildings *see also* Existing apartment buildings; New apartment buildings
 Board and care occupancies, suitability as 32.4, 33.4, A.32.4, A.33.4
 Classification of occupancy 30.1.4, 31.1.4
 Day-care occupancies in 16.1.2.2(2), 17.1.2.2(2)
 Definition 3.3.27.3, 6.1.8.1.5, A.3.3.27.3
 Occupant load factor Table 7.3.1.2
Application of code 1.3, A.1.3
Appropriateness of safeguards 4.5.2
Approved
 Definition 3.2.1, A.3.2.1
 Existing (definition) 3.3.60.1
 Previously approved 4.6.2
 Definition 3.3.169
Area *see also* Detention and correctional residential housing area; Floor area; Hazardous areas
 Gross leasable area A.7.3.1.2
 Definition 3.3.16.3
 Living area (definition) 3.3.16.5
 Relocation 4.7.5
Areas of refuge 7.2.12, A.7.2.12
 Accessible areas of refuge 7.2.12.2, A.7.2.12.2
 Definition 3.3.17.1
 Accessible means of egress accessed from 7.5.4.4
 Apartment buildings 30.2.2.12, 31.2.2.12, A.30.2.2.12.2, A.31.2.2.12
 Assembly occupancies 12.2.2.12, 13.2.2.12
 Business occupancies 38.2.2.12, 39.2.2.12
 Day-care occupancies 16.2.2.10, 17.2.2.5.2, 17.2.2.10
 Definition 3.3.17, A.3.3.17
 Details 7.2.12.3, A.7.2.12.3
 Detention and correctional occupancies 22.2.2.11, 23.2.2.11
 Educational occupancies 14.2.2.10, 15.2.2.10
 Health care occupancies 18.2.2.10, 18.7.1.1, 19.2.2.10
 Hotels and dormitories 28.2.2.12, 29.2.2.12, A.28.2.2.12.2, A.29.2.2.12.2
 Industrial occupancies 40.2.2.13
 Mercantile occupancies 36.2.2.12, 37.2.2.12
 Parking structures 42.8.2.2.9
 Residential board and care occupancies 32.3.2.2.10, 33.3.2.2.10
 Roof as 7.2.8.3.3
 Separation 7.2.12.3.4, A.7.2.12.3.4
 Storage occupancies 42.2.2.12
Assembly
 Fire door assemblies 8.2.2.4, 8.3.3, Table 8.3.4.2, 8.3.4.3, A.8.3.3.2, A.8.3.4.2
 Definition 3.3.18.1
 Fire window assemblies 8.3.3, Table 8.3.4.2, 8.5.3.5, 19.3.6.2.7, 20.3.7.1(4), 20.3.7.7, 21.3.7.1(4), A.8.3.3.6, A.8.3.4.2
 Definition 3.3.18.2
 Floor fire door assemblies 8.3.3.4
 Definition 3.3.18.1.1
Assembly occupancies *see also* Existing assembly occupancies; New assembly occupancies; Seating
 Classification of occupancy 6.1.2, 12.1.4, 13.1.4, A.6.1.2.1, A.12.1.4, A.13.1.4
 Clothing storage 12.7.11, 13.7.11
 Combined, educational 14.1.2.2, 15.1.2.2
 Crowd movement 4.1.2, A.4.1.2
 Definition 3.3.152.2, 6.1.2.1, A.3.3.152.2, A.6.1.2.1
 Mall buildings, assembly and mercantile occupancies in 12.1.2.3, 13.1.2.3; *see also* Mall buildings
 Multilevel play structures *see* Multilevel play structures
 Multipurpose (definition) 3.3.152.2.1

Occupant load factor	Table 7.3.1.2
Small assembly uses	6.1.2.2
Atmosphere	
Common (definition)	3.3.20.1
Separate (definition)	3.3.20.2
Atriums	
Ambulatory health care occupancies	20.3.7.4
Definition	3.3.21, A.3.3.21
Fire protection features	8.6.7, A.8.6.7
Health care occupancies	18.3.7.1(3), 18.3.7.4(1), 19.3.7.1(3)
Residential board and care occupancies	32.3.3.7.9
Attendants	<i>see</i> Staff
Authority having jurisdiction	4.6.1
Definition	3.2.2, A.3.2.2
Automatic (definition)	3.3.22
Automatic sprinkler systems	<i>see</i> Sprinkler systems

-B-

Balanced doors	7.2.1.13
Balconies	7.2.3.6, 7.5.3.1 to 7.5.3.3
Assembly occupancies	12.2.4.5 to 12.2.4.7, 13.2.4.5 to 13.2.4.7, 13.2.11.1
Day-care occupancies	16.3.6(1), 17.3.6(1)
Educational occupancies	14.2.5.4(1), 14.2.5.8, 14.3.6(1), 15.2.5.4(1), 15.2.5.8, 15.3.6(1), A.14.2.5.8, A.15.2.5.8
Exit discharge	7.7.4
Exits, horizontal	7.2.4.4
Means of egress, number of	7.4.1.1
One- and two-family dwellings	24.2.5.4
Open stairways between	A.7.6.2
Barriers	<i>see also</i> Fire barriers; Smoke barriers
Thermal (definition)	3.3.23.3, A.3.3.23.2
Bedding	
Existing ambulatory health care occupancies	21.7.5, A.21.7.5.1
Existing detention and correctional occupancies	23.7.4, A.23.7.4
Existing health care occupancies	19.7.5, A.19.7.5.1
Existing residential board and care occupancies	33.7.5, A.33.7.5
New ambulatory health care occupancies	20.7.5, A.20.7.5.1
New detention and correctional occupancies	22.4.4.13, 22.7.4, A.22.4.4.13, A.22.7.4
New health care occupancies	18.7.5, A.18.7.5.1
New residential board and care occupancies	32.7.5, A.32.7.5
Birth centers (definition)	3.3.24, A.3.3.24
Bleachers	<i>see also</i> Grandstands
Aisles	13.2.3.5
Definition	3.3.25
Board and care occupancies	<i>see</i> Residential board and care occupancies
Boiler rooms, means of egress	7.2.11.1(4), 7.12
Boxes, guards/railings	13.2.11.1
Bridges	
Exit discharge	7.7.4
Horizontal exits	7.2.4.4
Buildings	<i>see also</i> Airport terminal buildings; Anchor buildings; Apartment buildings; Bulk merchandising retail buildings; Existing buildings; Flexible plan education buildings; High-rise buildings; Historic buildings; Limited access structures; Mall buildings; Open plan education buildings; Special amusement buildings; Underground structures
Under construction	4.6.11, A.4.6.11.1, A.4.6.11.2
Definition	3.3.27, A.3.3.27
Building services	Chap. 9; <i>see also</i> Chutes, laundry or rubbish; Elevators; Escalators; Heating, ventilating, and air conditioning; Incinerators; Moving walks; Smoke control; Utilities
Ambulatory health care occupancies	20.5, 21.5
Apartment buildings	30.5, 31.5
Assembly occupancies	12.5, 13.5
Business occupancies	38.5, 39.5
Day-care occupancies	16.5, 17.5

Detention and correctional occupancies	22.5, 23.5
Educational occupancies	14.5, 15.5
Health care occupancies	18.5, 19.5, A.18.5.2.2, A.19.5.2.2
Hotels and dormitories	28.5, 29.5, A.28.5.3.2
Industrial occupancies	40.5
Lodging houses	26.5
Mercantile occupancies	36.5, 37.5
One- and two-family dwellings	24.5
Parking structures	42.8.5
Residential board and care occupancies	32.2.5, 32.3.6, 33.2.5, 33.3.6
Rooming houses	26.5
Storage occupancies	42.5
Building spaces, subdivision of	
Existing ambulatory health care occupancies	21.3.7, A.21.3.7.9
Existing apartment buildings	31.3.7
Existing detention and correctional occupancies	23.3.7, A.23.3.7, A.23.3.7.1, A.23.3.7.3(2), A.23.3.7.5
Existing educational occupancies	15.3.7
Existing health care occupancies	19.3.7, A.19.3.7.3(2)
Existing hotels and dormitories	29.3.7
Existing residential board and care occupancies	33.3.3.7, 33.4.3.3
New ambulatory health care occupancies	20.3.7, A.20.3.7.9
New apartment buildings	30.3.7
New detention and correctional occupancies	22.3.7, 22.4.4.10, 22.4.4.11, A.22.3.7, A.22.3.8, A.22.4.4.11
New educational occupancies	14.3.7
New health care occupancies	18.3.7, 18.4.3.8, A.18.3.7
New hotels and dormitories	28.3.7
New residential board and care occupancies	32.3.3.7
Bulkheads	24.2.7
Bulk merchandising retail buildings	36.4.5, 37.4.5
Construction, minimum requirements	36.4.5.1
Definition	3.3.27.4
Detection/alarm/communication systems	36.4.5.4, 37.4.5.4
Emergency plans	36.4.5.6, 37.4.5.6
Extinguishment requirements	36.4.5.5, 37.4.5.5
Means of egress requirements	36.4.5.2, 37.4.5.2
Staff training	36.4.5.6, 37.4.5.6
Storage, arrangement, protection, and quantities of hazardous commodities	36.4.5.3, 37.4.5.3
Bulk storage elevators	7.2.11.1(2), 42.7, A.42.7
Business occupancies	<i>see also</i> Existing business occupancies; New business occupancies
Classification of occupancy	6.1.11, 38.1.4, 39.1.4, A.6.1.11.1
Combined, parking structures	38.1.2.2, 39.1.2.2, A.38.1.2.2(4), A.39.1.2.2(4)
Definition	3.3.152.3, 6.1.11.1, A.3.3.152.3, A.6.1.11.1
Occupant load factor	Table 7.3.1.2

-C-

Calculation, alternative procedure (definition)	3.3.10
Capacity of means of egress	<i>see</i> Means of egress capacity
Catwalks	
Existing assembly occupancies	13.2.2.3.2, 13.2.3.4, 13.2.4.8, 13.4.5.9
New assembly occupancies	12.2.2.3.2, 12.2.3.4, 12.2.4.8, 12.4.5.9
Stairs	12.2.2.3.2, 13.2.2.3.2
Ceilings	<i>see</i> Interior wall/ceiling finish
Cellular or foamed plastic	10.2.4.3, 10.3.7, A.10.3.7
Definition	3.3.30, A.3.3.30
Existing assembly occupancies, use in	13.4.5.11.2, 13.7.3.3, 13.7.3.4, 13.7.4.3.4(6), 13.7.4.3.6.2, A.13.7.3.3
New assembly occupancies, use in	12.4.5.11.2, 12.4.5.11.4, 12.7.3.3, 12.7.3.4, 12.7.4.3.4(6), 12.7.4.3.6.2, A.12.7.3.3
Central control station, high rise buildings	11.8.5, A.11.8.5
Chutes, laundry or rubbish	9.5
Ambulatory health care occupancies	20.5.4, 21.5.4
Apartment buildings	30.5.4, 31.5.4

- Assembly occupancies 12.5.4, 13.5.4
- Business occupancies 38.5.4, 39.5.4
- Day-care occupancies 16.5.4, 17.5.4
- Detention and correctional occupancies 22.5.4, 23.5.4
- Educational occupancies 14.5.4, 15.5.4
- Health care occupancies 18.5.4, 19.5.4
- Hotels and dormitories 28.5.4, 29.5.4
- Industrial occupancies 40.5.4
- Mercantile occupancies 36.5.4, 37.5.4
- Parking structures 42.8.5.4
- Residential board and care occupancies 32.3.6.4, 33.3.6.4
- Storage occupancies 42.5.4
- Chutes, mail** 8.6.3(5)
- Classes A to C mercantile occupancies** 36.1.4.2.1, 36.1.4.2.2, 37.1.4.2.1, 37.1.4.2.2
- Classification of occupancy** 6.1, A.6.1;
see also Assembly occupancies; Business occupancies;
 Educational occupancies; Health care occupancies;
 Industrial occupancies; Mercantile occupancies; Mixed
 occupancies; Residential occupancies
- Classrooms, multiple occupancies** 14.1.2.3, 15.1.2.3
- Clothing storage**
 - Assembly occupancies 12.7.11, 13.7.11
 - Day-care occupancies 16.7.4.2, 17.7.4.2
 - Educational occupancies 14.7.4.2, 15.7.4.2
- Code** *see also* Performance-based design option
 - Definition 3.2.3, A.3.2.3
 - Enforcement 1.6
 - Equivalency to 1.4, A.1.4
 - Fundamental requirements 4.5, A.4.5.4
 - Goals 4.1, A.4.1
 - Objectives 4.2
 - Provisions in excess of code requirements 4.6.9
 - Purpose of 1.2, A.1.2
 - Scope of 1.1, A.1.1
 - Title of 1.1.1
- Combustible (material) (definition)** 3.3.135.1
- Combustion (definition)** 3.3.32
- Commercial cooking equipment** *see* Cooking equipment/facilities
- Common atmosphere (definition)** 3.3.20.1
- Common path of travel** A.7.5.1.6, Table A.7.6
 - Apartment buildings 30.2.5.3
 - Definition 3.3.34, A.3.3.34
 - Detention and correctional occupancies 22.2.5.3, 22.4.4.4, 23.2.5.3, A.23.2.5.3(3)
 - Educational occupancies 14.2.5.3, 15.2.5.3
 - Hotels and dormitories 28.2.5.3, 29.2.5.3, 29.2.5.4
 - Residential board and care occupancies 32.3.2.5.2, 33.3.2.5.2
- Communicating spaces** 8.6.6, A.8.2.6.6(7)
- Communication systems** 9.6, A.9.6
 - Areas of refuge 7.2.12.2.5
 - Bulk merchandising retail buildings 36.4.5.4, 37.4.5.4
 - Elevators 7.2.13.8, A.7.2.13.8
 - Emergency control A.9.6.5.4
 - Existing ambulatory health care occupancies 21.3.4
 - Existing apartment buildings 31.3.4
 - Existing assembly occupancies 13.3.4, A.13.3.4.2.2
 - Existing business occupancies 39.3.4
 - Existing day-care homes 17.6.3.4
 - Existing day-care occupancies 17.3.4
 - Existing detention and correctional occupancies 23.3.4, A.23.3.4.3.1(2), A.23.3.4.4.3
 - Existing educational occupancies 15.3.4, A.15.3.4
 - Existing health care occupancies 19.3.4, A.19.3.4.2, A.19.3.4.3.1(1)
 - Existing hotels and dormitories 29.3.4, A.29.3.4.3.6
 - Existing mercantile occupancies 37.3.4, 37.4.4.4, 37.4.5.4
 - Existing residential board and care occupancies 33.2.3.4, 33.3.3.4
 - High-rise buildings 11.8.3, A.11.8.3.1
 - Industrial occupancies 40.3.4
 - Lodging houses 26.3.3, A.26.3.3.3.1
 - Mall buildings 36.4.4.4, 37.4.4.4
- New ambulatory health care occupancies 20.3.4
- New apartment buildings 30.3.4
- New assembly occupancies 12.3.4, A.12.3.4.2.3
- New business occupancies 38.3.4
- New day-care homes 16.6.3.4
- New day-care occupancies 16.3.4
- New detention and correctional occupancies 22.3.4, 22.4.4.9, A.22.3.4
- New educational occupancies 14.3.4, A.14.3.4
- New health care occupancies 18.3.4, A.18.3.4
- New hotels and dormitories 28.3.4
- New mercantile occupancies 36.3.4, 36.4.4.4, 36.4.5.4
- New residential board and care occupancies 32.2.3.4, 32.3.3.4
- One- and two-family dwellings 24.3.4
- Parking structures 42.8.3.4
- Rooming houses 26.3.3, A.26.3.3.3.1
- Special structures 11.2.3.4, 11.3.3.4, 11.4.3.4
- Storage occupancies 42.3.4
- Compartmentation** 8.2.2, 8.6.1(1), A.8.2.2.3
- Compartmentments**
 - Fire 8.2.2, 8.2.2.3
 - Definition 3.3.35.1, A.3.3.35.1
 - Detention and correctional occupancies 22.2.4.2, 23.2.4.2, A.23.2.4.2
 - Horizontal exits 7.2.4.2
 - Smoke 8.2.2.1
 - Definition 3.3.35.2, A.3.3.35.2
 - Existing ambulatory health care occupancies 21.3.7.2
 - Existing detention and correctional occupancies 23.2.4.2, 23.4.1.2, A.23.2.4.2, A.23.4.1.2(2)
 - Existing educational occupancies 15.3.7
 - Existing health care occupancies 19.1.1.4.6, 19.3.6.1, A.19.1.1.4.6.3, A.19.1.1.4.6.4
 - Existing hotels and dormitories 29.3.7
 - Existing residential board and care occupancies 33.3.3.7.1
 - New ambulatory health care occupancies 20.2.4.3, 20.2.4.4, 20.3.7.2, 20.3.7.3
 - New detention and correctional occupancies 22.2.4.2, 22.4.4.12.2, A.22.4.4.12.2(2)
 - New educational occupancies 14.3.7
 - New health care occupancies 18.1.1.4.6, 18.3.4.5.3, 18.3.5.4, 18.3.7.1, 18.4.3, A.18.1.1.4.6.3, A.18.1.1.4.6.4, A.18.3.5.4, A.18.4.3.1
 - New hotels and dormitories 28.3.7
 - New residential board and care occupancies 32.3.3.7.1, 32.3.3.7.2
- Concealed spaces** 8.6.10
- Construction** *see also* Corridor wall construction
 - Apartment buildings as board and care occupancies 32.4.1.4, 33.4.1.4
 - Existing ambulatory health care occupancies 21.1.6, 21.7.9
 - Existing assembly occupancies 13.1.6
 - Existing day-care homes 17.6.1.6
 - Existing day-care occupancies 17.1.6
 - Existing detention and correctional occupancies 23.1.6
 - Existing health care occupancies 19.1.1.4.7, 19.1.6, 19.7.9, A.19.1.6.5, A.19.1.6.7
 - Existing residential board and care occupancies 33.2.1.3, 33.3.1.3, 33.4.1.4
 - Fire escape ladders 7.2.9.2
 - Fire protection features 8.2.1, A.8.2.1.2
 - New ambulatory health care occupancies 20.1.1.4.4, 20.1.6, 20.7.9
 - New assembly occupancies 12.1.6
 - New day-care homes 16.6.1.6
 - New day-care occupancies 16.1.6
 - New detention and correctional occupancies 22.1.6, 22.4.4.2
 - New health care occupancies 18.1.1.4, 18.1.6, 18.4.3.2, 18.7.9, A.18.1.1.4.6.3, A.18.1.1.4.6.4
 - New mercantile occupancies 36.4.5.1
 - New residential board and care occupancies 32.3.1.3, 32.4.1.4
 - Operations 4.6.11, A.4.6.11.1, A.4.6.11.2

Platforms	12.4.5.2
Ramps	7.2.5.3.1
Stages	12.4.5.3
Stairs	7.2.2.3.1
Contained, Use Condition V	
Existing detention and correctional occupancies	23.1.4.1(5), A.23.1.4.1
New detention and correctional occupancies	22.1.4.1(5), A.22.1.4.1
Contents	10.3, A.10.3; <i>see also</i> Furnishings; Hazard of contents
Definition	3.3.36
Control systems	<i>see</i> Emergency control
Conversions	
Existing ambulatory health care occupancies	21.1.1.4.2
Existing day-care occupancies	17.1.4.3, 17.6.1.4.2, A.17.1.4.3, A.17.6.1.4.2
Existing health care occupancies	19.1.1.4.5
Existing residential board and care occupancies	33.1.1.4
New ambulatory health care occupancies	20.1.1.4.2
New day-care occupancies	16.1.4.3, 16.6.1.4.2, A.16.1.4.3, A.16.6.1.4.2
New health care occupancies	18.1.1.4.5
New residential board and care occupancies	32.1.1.4
Conveyors	8.6.3(1), 8.6.8.4, 9.4.7
Ambulatory health care occupancies	20.5.3, 21.5.3
Apartment buildings	30.5.3, 31.5.3
Assembly occupancies	12.5.3, 13.5.3
Business occupancies	38.5.3, 39.5.3
Day-care occupancies	16.5.3, 17.5.3
Detention and correctional occupancies	22.5.3, 23.5.3
Educational occupancies	14.5.3, 15.5.3
Health care occupancies	18.5.3, 19.5.3
Hotels and dormitories	28.5.3, 29.5.3, A.28.5.3.2
Industrial occupancies	40.5.3
Lodging houses	26.5.3
Mercantile occupancies	36.5.3, 37.5.3
Parking structures	42.8.5.3
Residential board and care occupancies	32.2.5.3, 32.3.6.3, 33.3.6.3
Rooming houses	26.5.3
Storage occupancies	42.5.3
Cooking equipment/facilities	9.2.3
Exhibits	12.7.4.3.9, 13.7.4.3.9
Existing ambulatory health care occupancies	21.3.2.4, 21.3.2.5
Existing assembly occupancies	13.7.1, 13.7.4.3.9, A.13.7.1.4(5)
Existing business occupancies	39.7.3
Existing day-care occupancies	17.3.2.3 to 17.3.2.5
Existing detention and correctional occupancies	23.3.2.3
Existing educational occupancies	15.3.2.2
Existing health care occupancies	19.3.2.5, A.19.3.2.5.2
Existing mercantile occupancies	37.7.3
LP-Gas appliances, use of	12.7.1.4(5), 13.7.1.4(5), A.8.7.3.2, A.12.7.1.4(5), A.13.7.1.4(5)
New ambulatory health care occupancies	20.3.2.4, 20.3.2.5
New assembly occupancies	12.7.1, 12.7.4.3.9, A.12.7.1.4(5)
New business occupancies	38.7.3
New day-care occupancies	16.3.2.3 to 16.3.2.5
New detention and correctional occupancies	22.3.2.3
New educational occupancies	14.3.2.2
New health care occupancies	18.3.2.5, A.18.3.2.5.2
New mercantile occupancies	36.7.3
New residential board and care facilities	32.3.3.8, A.32.3.3.8
Portable	12.7.1.4, 12.7.4.3.9, 13.7.1.4, 13.7.4.3.9, A.8.7.3.2, A.12.7.1.4(5), A.13.7.1.4(5)
Correctional occupancies	<i>see</i> Detention and correctional occupancies
Corridor doors	
Apartment buildings	30.3.6.2 to 30.3.6.5, 31.3.6.2 to 31.3.6.7
Health care occupancies	18.3.6.3, 18.4.3.7.2, 19.3.6.3, A.18.3.6.3, A.19.3.6.3
Hotels and dormitories	28.3.6.2 to 28.3.6.5, 29.3.6.2 to 29.3.6.5

Corridors

Ambulatory health care occupancies	20.2.3.2, 21.2.3.2
Existing apartment buildings	31.3.6, A.31.3.6.1
Existing day-care occupancies	17.2.11.1.2(5), 17.3.6
Existing detention and correctional occupancies	23.3.6
Existing educational occupancies	15.2.3.2, 15.2.5.4(1), 15.2.5.8, 15.3.6, A.15.2.5.8, A.15.3.6(2)
Existing health care occupancies	19.2.3.4, 19.2.3.5, 19.3.4.5.1, 19.3.4.5.2, 19.3.6, A.19.3.6
Existing hotels and dormitories	29.3.6
Existing residential board and care occupancies	33.3.3.6
Exit access	
Ambulatory health care occupancies	20.2.3.2, 21.2.3.2
Apartment buildings	30.3.6.1
Day-care occupancies	16.3.6(1), 17.3.6(1)
Educational occupancies ...	14.2.5.4, 14.2.5.5, 15.2.5.4, 15.2.5.5
Existing apartment buildings	31.3.6.1, A.31.3.6.1
Health care occupancies	18.2.3.4, 18.2.3.5
Hotels and dormitories	28.3.6.1, 29.3.6.1
Means of egress and	7.1.3.1
Opening protectives, fire protection ratings for	Table 8.3.4.2
Exit discharge	7.7.4
Exterior	
Existing educational occupancies	15.2.5.4(1), 15.2.5.8, 15.3.6(1), A.15.2.5.8
New educational occupancies	14.2.5.4(1), 14.2.5.8, 14.3.6(1), A.14.2.5.8
Industrial occupancies	40.3.6
New ambulatory health care occupancies	20.3.6
New apartment buildings	30.3.6
New assembly occupancies	12.3.6
New business occupancies	38.3.6, A.38.3.6.1
New day-care occupancies	16.3.6
New detention and correctional occupancies	22.3.6
New educational occupancies	14.2.3.2, 14.2.5.4(1), 14.2.5.8, 14.3.6, A.14.2.5.8
New health care occupancies	18.2.3.4, 18.2.3.5, 18.3.4.5.2, 18.3.4.5.3, 18.3.6, 18.4.3.7, A.18.3.6
New hotels and dormitories	28.3.6
New mercantile occupancies	36.3.6, A.36.3.6.1
New residential board and care occupancies	32.3.3.6, A.32.3.3.6
Parking structures	42.8.3.6
Special structures	11.3.3.6, 11.4.3.6
Storage occupancies	42.3.6
Corridor wall construction	
Apartment buildings	30.3.6.1, 31.3.6.1, A.31.3.6.1
As board and care occupancies	32.4.3.2, 33.4.3.2
Health care occupancies	18.3.6.2, 18.4.3.7.1, 19.3.6.2, A.18.3.6.2, A.19.3.6.2
Hotels and dormitories	28.3.6.1, 29.3.6.1
Residential board and care occupancies	32.2.3.6, 32.4.3.2, 33.2.3.6, 33.4.3.2
Courts	
Definition	3.3.37
Enclosed (definition)	3.3.37.1
Exit discharge	7.7.1.1, 22.2.7.1, 22.2.7.2, 23.2.7.1, 23.2.7.2, A.7.7.1
Food court (definition)	3.3.37.2
Critical radiant flux (definition)	3.3.38, A.3.3.38
Crowd managers	12.7.5, 13.7.5, A.12.7.5, A.13.7.5
Crowd movement	4.1.2, A.4.1.2
Curtains	10.3.1, A.10.3.1
Across means of egress	7.5.2.2.1, 7.5.2.2.2
Ambulatory health care occupancies	20.7.5.1, 21.7.5.1, A.20.7.5.1, A.21.7.5.1
Assembly occupancies ...	12.4.5.7, 12.4.5.10.2, 12.7.3.1, 12.7.4.3.5, 13.4.5.7, 13.4.5.10.2, 13.7.3.1, 13.7.4.3.5, A.12.4.5.7
Day-care occupancies	16.7.4.1, 17.7.4.1
Detention and correctional occupancies	22.7.4.1, 23.7.4.1
Educational occupancies	14.7.4.1, 15.7.4.1

- Health care occupancies 18.3.5.6, 18.7.5.1, 19.3.5.6,
A.18.3.5.6, A.18.7.5.1, A.19.3.5.6
- Residential board and care occupancies 32.7.5.1, 33.7.5.1,
A.32.7.5, A.33.7.5
- Curved stairs** 7.2.2.2.2
- D-**
- Dampers, smoke** 8.4.6.2 to 8.4.6.4,
8.5.4.2 to 8.5.4.7, A.8.4.6.2
- Detention and correctional occupancies 22.3.7.11, 23.3.7.11
- Health care occupancies 18.3.7.4(2), 19.3.7.3(2),
20.3.7.6, 21.3.7.6, A.18.3.7.4(2), A.19.3.7.3(2)
- Residential board and care occupancies 32.3.3.7.10,
A.32.3.3.7.10
- Data conversion (definition)** 3.3.39
- Day-care homes** 16.6; *see also* Existing day-care homes;
Family day-care homes; Group day-care homes; New
day-care homes
- Definition 3.3.110.1, A.3.3.110.1
- Day-care occupancies** *see also* Existing day-care occupancies;
Family day-care homes; Group day-care homes; New
day-care occupancies
- Classification of occupancy 6.1.4, 16.1.4, 16.6.1.4,
17.1.4, 17.6.1.4, A.6.1.4.1, A.16.1.4.3, A.16.6.1.4.2,
A.17.1.4.3, A.17.6.1.4.2
- Definition 3.3.152.4, 6.1.4.1, A.3.3.152.4, A.6.1.4.1
- Occupant load factor Table 7.3.1.2
- Dead-end aisles**
- Existing assembly occupancies 13.2.5.6.2, 13.4.2.7
- New assembly occupancies 12.2.5.6.2, 12.4.2.7
- Dead-end limits** 7.5.1.5, 7.5.3.4, A.7.5.1.5, Table A.7.6
- Decorations** 10.2.4.5
- Existing ambulatory health care occupancies 21.7.5, A.21.7.5.1
- Existing assembly occupancies 13.7.3, 13.7.4.3.5,
13.7.4.3.6, A.13.7.4.3.4(3), A.13.7.4.3.7.1(3)
- Existing day-care occupancies 17.7.4
- Existing detention and
correctional occupancies 23.7.4, A.23.7.4
- Existing educational occupancies 15.7.4
- Existing health care occupancies 19.7.5, A.19.7.5.1
- Existing hotels and dormitories 29.3.3.4, A.29.3.3.4
- Existing residential board and care occupancies 33.7.5, A.33.7.5
- Fire protection features 10.3.1, A.10.3.1
- Health care occupancies 18.7.5, A.18.7.5.1
- Means of egress 7.1.10.2
- New ambulatory health care occupancies 20.7.5, A.20.7.5.1
- New assembly occupancies 12.7.3, 12.7.4.3.5,
12.7.4.3.6, A.12.7.3.3
- New day-care occupancies 16.7.4
- New detention and correctional occupancies 22.4.4.13, 22.7.4,
A.22.4.4.13, A.22.7.4
- New educational occupancies 14.7.4
- New hotels and dormitories 28.3.3.4, A.28.3.3.4
- New residential board and care occupancies 32.7.5, A.32.7.5
- Definitions** Chap. 3, 6.1.2 to 6.1.14.2, A.6.1.2 to 6.1.13
- Delayed egress locks** 7.2.1.6.1, A.7.2.1.6.1(3), A.7.2.1.6.1(4)
- Design** *see* Performance-based design option; Proposed design
- Design fire scenarios** *see* Fire scenarios
- Design specifications** 5.4, 5.8.3, A.5.4
- Definition 3.3.208.1, A.3.3.208.1
- Design team (definition)** 3.3.44
- Detection systems** 9.6, A.9.6;
see also Smoke detectors and detection systems
- Bulk merchandising retail buildings 36.4.5.4, 37.4.5.4
- Door closing action initiated by *see* Self-closing
- Existing ambulatory health care occupancies 21.3.4
- Existing apartment buildings 31.3.4
- Existing assembly occupancies 13.3.4, A.13.3.4.2.2
- Existing business occupancies 39.3.4
- Existing day-care homes 17.6.3.4
- Existing day-care occupancies 17.3.4
- Existing detention and correctional occupancies 23.3.4,
A.23.3.4.3.1(2), A.23.3.4.4.3
- Existing educational occupancies 15.3.4, A.15.3.4
- Existing health care occupancies 19.3.4, A.19.3.4.2,
A.19.3.4.3.1(1)
- Existing hotels and dormitories 29.3.4, A.29.3.4.3.6
- Existing mercantile occupancies 37.3.4, 37.4.4.4, 37.4.5.4
- Existing residential board and care occupancies 33.2.3.4,
33.3.3.4
- High-rise buildings 11.8.3, A.11.8.3.1
- Industrial occupancies 40.3.4
- Lodging houses 26.3.3, A.26.3.3.3.1
- Mall buildings 36.4.4.4, 37.4.4.4
- New ambulatory health care occupancies 20.3.4
- New apartment buildings 30.3.4
- New assembly occupancies 12.3.4, A.12.3.4.2.3
- New business occupancies 38.3.4
- New day-care homes 16.6.3.4
- New day-care occupancies 16.3.4
- New detention and correctional occupancies 22.3.4,
22.4.4.9, A.22.3.4
- New educational occupancies 14.3.4, A.14.3.4
- New health care occupancies 18.3.4, A.18.3.4
- New hotels and dormitories 28.3.4
- New mercantile occupancies 36.3.4, 36.4.4.4, 36.4.5.4
- New residential board and care occupancies 32.2.3.4, 32.3.3.4
- One- and two-family dwellings 24.3.4
- Parking structures 42.8.3.4
- Rooming houses 26.3.3, A.26.3.3.3.1
- Special structures 11.2.3.4, 11.3.3.4, 11.4.3.4
- Storage occupancies 42.3.4
- Detention and correctional occupancies** *see also* Existing detention
and correctional occupancies; New detention and
correctional occupancies
- Classification of occupancy 6.1.7, 22.1.4, 23.1.4,
A.6.1.7.1, A.6.1.7.2
- Crowd control A.4.1.2
- Definition 3.3.152.5, 6.1.7.1, A.3.3.152.5, A.6.1.7.1
- Nonresidential uses 6.1.7.2, A.6.1.7.2
- Occupant load factor Table 7.3.1.2
- Detention and correctional residential housing area** 8.6.9.1.2,
22.3.8, Table 22.3.8, 22.4.4.11, 23.3.8, A.6.1.7.2,
A.23.2.4.1
- Definition 3.3.16.1
- Directional signs and indicators** 7.10.2, 7.10.6.2, A.7.10.2,
A.7.10.6.2, A.10.7.10.6.2
- Discharge from exits** *see* Exit discharge
- Doors** *see also* Corridor doors; Smoke barriers
- Airport loading walkways 12.4.10.2, 13.4.10.2,
A.12.4.10.2(2), A.13.4.10.2(2)
- Alarm devices 7.2.1.5, A.7.2.1.5
- Atriums 8.6.7(1)
- Balanced 7.2.1.13
- Dutch 18.3.6.3.11, 19.3.6.3.11
- Egress width 7.2.1.2, A.7.2.1.2.1, A.7.2.1.2.3
- Elevator lobby *see* Elevator lobby doors
- Elevators 7.4.1.5
- Existing ambulatory health
care occupancies 21.1.1.4.1.2, 21.1.1.4.1.3,
21.2.2.2 to 21.2.2.4, 21.2.3.3, 21.3.2.1, 21.3.7.1, 21.3.7.9
to 21.3.7.11, A.21.3.7.9
- Existing apartment buildings 31.2.2.2, 31.3.6.2 to 31.3.6.7
- Existing assembly occupancies 13.2.2.2
- Existing business occupancies 39.2.2.2, A.39.2.2.2
- Existing day-care occupancies 17.2.2.2,
17.2.11.1.2(5), 17.3.6, 17.7.3.2, A.17.2.2.2.4, A.17.7.3.2
- Existing detention and correctional occupancies 23.2.2.2,
23.2.11, 23.3.7.2, 23.3.7.6, 23.3.7.8, 23.3.7.9, A.23.2.11.3,
A.23.2.11.7, A.23.3.7.1(2), A.23.3.7.6(1)
- Existing educational occupancies 15.2.2.2,
15.2.5.4, 15.2.5.5, 15.3.6, 15.7.3.1, A.15.7.3.1

Existing health care occupancies	19.2.2.2, 19.2.2.5.3, 19.2.2.5.4, 19.2.3.2, 19.2.3.6, 19.2.3.7, 19.3.2.1.3, 19.3.2.1.4, 19.3.6.3, 19.3.7.5 to 19.3.7.8, 19.3.8, A.19.2.2.2.4(2), A.19.2.2.2.6, A.19.2.2.2.8, A.19.3.6.3, A.19.3.7.5.1, A.19.3.7.6
Existing hotels and dormitories	29.2.2.2, 29.3.6.2 to 29.3.6.5
Existing mercantile occupancies	37.2.2.2, A.37.2.2.2.2
Existing residential board and care occupancies	33.2.2.5, 33.2.3.6, 33.3.2.2.2, 33.3.3.6.4 to 33.3.3.6.6
Exit discharge	7.7.4
In fire barriers	8.3.3, 8.3.4.3, 8.3.4.4, 8.7.1.3, A.8.3.3.2, A.8.3.4.2
Fire (definition)	3.3.47.2
Fire door assemblies	8.2.2.4, 8.3.3, Table 8.3.4.2, 8.3.4.3, A.8.3.3.2, A.8.3.4.2
Definition	3.3.18.1
Floor fire door assemblies	8.3.3.4
Definition	3.3.18.1.1
Floor/threshold level	7.2.1.3
Folding partitions	7.2.1.12
General	7.2.1.1, A.7.2.1.1.3
Hold-open devices, release of	9.6.5.2(1)
Horizontal exits	7.2.4.3.6 to 7.2.4.3.10, A.7.2.4.3.8, A.7.2.4.3.9
Industrial occupancies	40.2.2.2
Locks/latches	7.2.1.5, 7.2.1.6, 9.6.5.2(5), A.7.2.1.5
Lodging or rooming houses	26.2.3 to 26.2.8
Mirrors on exit doors	7.1.10.2.3, 7.5.2.2.3, 7.5.2.2.4
New ambulatory health care occupancies	20.1.1.4.1.2, 20.1.1.4.1.3, 20.2.2.2 to 20.2.2.4, 20.2.3.3, 20.3.2.1, 20.3.7.1, 20.3.7.9 to 20.3.7.13, A.20.3.7.9
New apartment buildings	30.2.2.2, 30.3.6.2 to 30.3.6.5, A.30.2.2.2.1
New assembly occupancies	12.2.2.2, 12.4.10.2, A.12.4.10.2(2)
New business occupancies	38.2.2.2, A.38.2.2.2.2
New day-care occupancies	16.2.2.2, 16.2.11.1.2(2), 16.7.3.2, 17.3.6(1), A.16.2.2.2.4, A.16.7.3.2
New detention and correctional occupancies	22.2.2.2, 22.2.11, 22.3.7.2, 22.3.7.6(2), 22.3.7.8, 22.3.7.9, A.22.2.11.3, A.22.2.11.7, A.22.3.7.1(2)
New educational occupancies	14.2.2.2, 14.2.5.4, 14.2.5.5, 14.3.6(1), 14.7.3.1, A.14.7.3.1
New health care occupancies	18.1.1.4.2 to 18.1.1.4.4, 18.2.2.2, 18.2.2.5.3, 18.3.6.3, 18.3.8, 18.4.3.7.2, A.18.2.2.2.4(2), A.18.2.2.2.6, A.18.3.6.3, A.18.3.7.7 to A.18.3.7.9, A.18.3.8
New hotels and dormitories	28.2.2.2, 28.3.6.2 to 28.3.6.5
New mercantile occupancies	36.2.2.2, A.36.2.2.2.2
New residential board and care occupancies	32.2.2.5, 32.3.2.2.2, 32.3.3.6.4 to 32.3.3.6.6, 32.3.3.7.13 to 32.3.3.7.19, A.32.3.3.7.13, A.32.3.3.7.17, A.32.3.3.7.18
One- and two-family dwellings	24.2.2.2, 24.2.2.3(A), 24.2.4, A.24.2.4.7
Panic hardware/fire exit hardware	7.2.1.7
Parking structures	42.8.2.2.2
Performance-based design option	5.3.2(3)
Powered	7.2.1.9, A.7.2.1.9
Revolving	<i>see</i> Revolving doors
Screen/storm	7.2.1.4.6
Self-closing devices	<i>see</i> Self-closing
Sliding horizontal	7.2.1.14
Smoke partitions	Table 8.3.4.2, 8.4.3, A.8.4.3.4
Smokeproof enclosures, door closure	7.2.3.11
Special hazard protection	8.7.1.3
Storage occupancies	42.2.2.2
Swing/force to open	7.2.1.4, 7.2.4.3.7, A.7.2.1.4.1, A.7.2.1.4.4
Turnstiles	<i>see</i> Turnstiles
Dormitories	<i>see</i> Hotels and dormitories
Draft stop	8.6.10, 28.3.5.4, 29.3.5.4, 30.3.5.5, 31.3.5.5
Definition	3.3.49
Drills, emergency egress/fire	4.7, A.4.7
Existing ambulatory health care occupancies	21.7.1.4 to 27.7.1.7, A.21.7.1.4

Existing assembly occupancies	13.7.6, A.13.7.6
Existing business occupancies	39.7.1
Existing day-care occupancies	17.7.2, A.17.7.2.1
Existing detention and correctional occupancies	23.7.1.3, A.23.7.1.3
Existing educational occupancies	15.7.2, A.15.7.2.1
Existing health care occupancies	19.7.1.4 to 19.7.1.7, A.19.7.1.4
Existing hotels and dormitories	29.7.3
Existing mercantile occupancies	37.7.1
Existing residential board and care occupancies	33.7.3
New ambulatory health care occupancies	20.7.1.4 to 20.7.1.7, A.20.7.1.4
New assembly occupancies	12.7.6, A.12.7.6
New business occupancies	38.7.1
New day-care occupancies	16.7.2, A.16.7.2.1
New detention and correctional occupancies	22.7.1.3.1, A.22.7.1.3
New educational occupancies	14.7.2, A.14.7.2.1
New health care occupancies	18.7.1.4 to 18.7.1.7, A.18.7.1.4
New hotels and dormitories	28.7.3, A.28.7.1.2
New mercantile occupancies	36.7.1
New residential board and care occupancies	32.7.3
Ducts, openings for	8.3.5.7, 8.5.4, 22.4.4.3, 23.2.2.5.3, A.22.4.4.3, A.23.2.2.5.3
Dumbwaiters	8.6.8.4, 9.4.2, 9.4.7, 32.3.6.3, 33.3.6.3
Dwelling units	<i>see also</i> One- and two-family dwelling units
Definition	3.3.50
One-family (definition)	3.3.50.2
Two-family (definition)	3.3.50.3

-E-

Earthquake protection, elevators	7.2.13.11
Educational occupancies	<i>see also</i> Existing educational occupancies; New educational occupancies
Classification of occupancy	6.1.3, 14.1.4, 15.1.4, A.6.1.3.1
Definition	3.3.152.6, 6.1.3.1, A.3.3.152.6, A.6.1.3.1
Incidental instruction	6.1.3.3
Occupant load factor	Table 7.3.1.2
Egress	<i>see</i> Means of egress
Electrical energy systems, stored	9.1.4
Electrical systems, essential	20.2.9, 21.2.9
Electrical wiring and equipment	9.1.2
Electroluminescent (definition)	3.3.52, A.3.3.52
Elevated platforms	7.2.11.1(3)
Elevator lobby	7.2.13.3, 7.4.1.6
Definition	3.3.54
Smoke detectors	9.6.3.2.1, 9.6.5.3, A.9.6.3.2.1
Elevator lobby doors	7.2.13.4, 7.2.13.5
Definition	3.3.47.1
Elevator machine rooms	9.4.5, 9.6.3.2.1, 9.6.5.3, A.9.4.5
Elevators	9.4; <i>see also</i> Bulk storage elevators; Grain storage elevators; Vertical openings
Accessible means of egress	7.5.4.5, 7.5.4.7
Ambulatory health care occupancies	20.5.3, 21.5.3
Apartment buildings	30.5.3, 31.5.3
Areas of refuge	7.2.12.2.2, 7.2.12.2.4, A.7.2.12.2.4
Assembly occupancies	12.5.3, 13.5.3
Business occupancies	38.5.3, 39.5.3
Communication systems	7.2.13.8, A.7.2.13.8
Day-care occupancies	16.5.3, 17.5.3
Detention and correctional occupancies	22.5.3, 23.5.3
Doors	7.4.1.5
Earthquake protection	7.2.13.11
Educational occupancies	14.5.3, 15.5.3
Evacuation system	
Capacity	7.2.13.2
Definition	3.3.218.1
Fire fighters' emergency operations	9.4.3

- Health care occupancies 18.5.3, 19.5.3
- Hoistway enclosures
 - Fire barrier walls A.8.6.2
 - Fire protection ratings Table 8.3.4.2
 - Number of cars per hoistway 8.6.8.3, 9.4.4
 - Smoke detectors 9.6.3.2.1, 9.6.5.3
- Hotels and dormitories 28.5.3, 29.5.3, A.28.5.3.2
- Industrial occupancies 40.5.3
- Lodging houses 26.5.3
- Maintenance 7.2.13.10
- Means of egress, use as 7.2.13, 9.4.1, A.7.2.13, A.9.4.1
- Mercantile occupancies 36.5.3, 37.5.3
- Occupant notification 9.6.3.6.6
- Operation 7.2.13.9, A.7.2.13.9
- Parking structures 42.8.5.3
- Power and control wiring 7.2.13.7, A.7.2.13.7
- Recall, alarms for 9.6.3.2.1, 9.6.5.3, A.9.6.3.2.1
- Residential board and care occupancies 32.2.5.3, 32.3.6.3, 33.3.6.3, A.32.3.6.3.2
- Rooming houses 26.5.3
- Service openings, closing devices for 8.6.8.4
- Signs 7.10.8.4, A.7.10.8.4
- Special structures 11.3.2.2.2
- Storage occupancies 42.5.3
- Water protection 7.2.13.6, A.7.2.13.6
- Emergency control** 9.6.1.8(3), 9.6.5, A.9.6.5.4
- Ambulatory health care occupancies 20.3.4.5, 21.3.4.5
- Health care occupancies 18.3.4.4, 19.3.4.4
- Location of controls 9.6.6
- Mall buildings 37.4.4.4.4
- Mercantile occupancies 36.4.4.4.4, 37.4.4.4.4
- Emergency egress drills** *see* Drills, emergency egress/fire
- Emergency forces notification** 9.6.4
- Existing ambulatory health care occupancies 21.3.4.4
- Existing apartment buildings 31.3.4.3.5
- Existing day-care occupancies 17.3.4.4
- Existing detention and correctional occupancies 23.3.4.3.2
- Existing educational occupancies 15.3.4.3.2
- Existing health care occupancies 19.3.4.3.2
- Existing hotels and dormitories 29.3.4.3.6, A.29.3.4.3.6
- Existing mercantile occupancies 37.3.4.3.2, 37.4.5.4.4
- Existing residential board and care occupancies 33.3.3.4.6, A.33.3.3.4.6
- Mall buildings 36.4.4.4.3.2, 37.4.4.4.3.2
- New ambulatory health care occupancies 20.3.4.4
- New apartment buildings 30.3.4.3.5
- New day-care occupancies 16.3.4.4
- New detention and correctional occupancies 22.3.4.3.2
- New educational occupancies 14.3.4.3.2
- New health care occupancies 18.3.4.3.2
- New hotels and dormitories 28.3.4.3.6, A.28.3.4.3.6
- New mercantile occupancies 36.3.4.3.2, 36.4.4.4.3.2, 36.4.5.4.4
- New residential board and care occupancies 32.3.3.4.6
- Emergency generators** 9.1.3
- Emergency instructions for guests/residents**
 - Apartment buildings 30.7, 31.7
 - Hotels and dormitories 28.7.4, 29.7.4, A.28.7.4.1, A.28.7.4.2, A.29.7.4.1, A.29.7.4.2
- Emergency lighting** 7.9, 9.6.5.2(4), A.7.9
- Existing ambulatory health care occupancies 21.2.9
- Existing apartment buildings 31.2.9
- Existing assembly occupancies 13.2.9
- Existing business occupancies 39.2.9
- Existing day-care occupancies 17.2.9
- Existing detention and correctional occupancies 23.2.9
- Existing educational occupancies 15.2.9
- Existing health care occupancies 19.2.9
- Existing hotels and dormitories 29.2.9
- Existing mercantile occupancies 37.2.9, 37.4.4.3.8
- Existing residential board and care occupancies 33.3.2.9
- Exit signs 7.10.4, 7.10.9.2, A.7.10.4
- High-rise buildings 11.8.4, A.11.8.4.2(A)
- Industrial occupancies 40.2.9, A.40.2.9
- Mall buildings 36.2.9, 37.4.4.3.8
- New ambulatory health care occupancies 20.2.9
- New apartment buildings 30.2.9
- New assembly occupancies 12.2.9
- New business occupancies 38.2.9
- New day-care occupancies 16.2.9
- New detention and correctional occupancies 22.2.9
- New educational occupancies 14.2.9
- New health care occupancies 18.2.9
- New hotels and dormitories 28.2.9
- New mercantile occupancies 36.2.9, 36.4.4.3.8
- New residential board and care occupancies 32.3.2.9
- Parking structures 42.8.2.9
- Performance 7.9.2, A.7.9.2
- Performance-based design option 5.3.2(11)
- Special structures 11.2.2.9, 11.3.2.9, 11.4.2.9
- Storage occupancies 42.2.9
- Testing, periodic 7.9.3, 7.10.9.2
- Emergency organization, hotels and dormitories** 28.7.1, 29.7.1, A.28.7.1.1, A.28.7.1.2, A.29.7.1.1, A.29.7.1.2
- Emergency plans** 4.8
- Bulk merchandising retail buildings 36.4.5.6, 37.4.5.6
- Existing ambulatory health care occupancies 21.7.1, 21.7.2, A.21.7.2.1
- Existing day-care occupancies 17.7.1, A.17.7.1
- Existing detention and correctional occupancies 23.7.1.3
- Existing educational occupancies 15.7.1
- Existing health care occupancies 19.7.1, 19.7.2.2
- Existing residential board and care occupancies 33.7.1
- New ambulatory health care occupancies 20.7.1, 20.7.2, A.20.7.2.1
- New day-care occupancies 16.7.1, A.16.7.1
- New detention and correctional occupancies 22.7.1.3
- New educational occupancies 14.7.1
- New health care occupancies 18.7.1, 18.7.2.2
- New residential board and care occupancies 32.7.1
- Emergency response personnel** 5.4.6
- Enclosed courts** *see* Courts
- Enclosures** *see also* Smoke partitions; Smokeproof enclosures
- Bulkheads 24.2.7
- Elevator hoistway *see* Elevators, hoistway enclosures
- Exit 7.1.3.2, 11.3.2.4.1(7), A.7.1.3.2.1, A.7.1.3.2.3
- Interior finish 7.1.4, A.7.1.4.1, A.7.1.4.2
- Exit passageways 7.2.6.2
- Floor opening 8.6.5, A.8.6.5 *see also* Vertical openings
- Ramps 7.2.5.5
- Rubbish chutes and laundry chutes 9.5.1
- Stairs 7.1.3.2, 7.2.1.5.7, 7.2.1.5.8, 7.2.2.5, 7.2.6.3, 9.6.3.6.5, A.7.1.3.2, A.7.1.3.2.1, A.7.1.3.2.3, A.7.2.1.5.7, A.7.2.2.5.2 to A.7.2.2.5.4
- Underground structures 11.7.4.5
- Visual enclosures, fire escape stairs 7.2.8.5
- Enforcement of code** 1.6
- Engineer** *see* Professional engineer
- Entrances** *see* Main entrances
- Equipment** *see* Fire protection equipment; Service equipment
- Equivalency to code** 1.4, A.1.4
- Escalators** 7.2.7, 8.6.3(3), 8.6.8.5, 8.6.8.6, 9.4.2
- Existing ambulatory health care occupancies 21.5.3
- Existing apartment buildings 31.2.2.8, 31.5.3, A.31.2.2.8
- Existing assembly occupancies 13.2.2.8, 13.5.3
- Existing business occupancies 39.2.2.8, 39.5.3
- Existing day-care occupancies 17.5.3
- Existing detention and correctional occupancies 23.5.3
- Existing educational occupancies 15.5.3
- Existing health care occupancies 19.5.3
- Existing hotels and dormitories 29.2.2.8, 29.5.3, A.29.2.2.8, A.29.2.7.2
- Existing mercantile occupancies 37.2.2.8, 37.5.3
- Exit discharge 7.7.4
- Industrial occupancies 40.2.2.8, 40.5.3

Lodging houses	26.5.3	Exits, maintenance of	21.7.3
New ambulatory health care occupancies	20.5.3	Exits, number of	21.2.4
New apartment buildings	30.5.3	Exit travel distance	21.2.6
New assembly occupancies	12.5.3	Extinguishment requirements	21.3.5
New business occupancies	38.5.3	Furnishings/bedding/decorations	21.7.5, A.21.7.5.1
New day-care occupancies	16.5.3	General requirements	21.1, A.21.1
New detention and correctional occupancies	22.5.3	Hazard of contents, classification of	21.1.2.6, 21.1.2.7, 21.1.5
New educational occupancies	14.5.3	Hazards, protection from	21.3.2, 21.3.5.1
New health care occupancies	18.5.3	Heating, ventilating, and air conditioning	21.5.2
New hotels and dormitories	28.5.3, A.28.5.3.2	Heating devices, portable space	21.7.8
New mercantile occupancies	36.5.3	Interior finish	21.3.3
New residential board and care occupancies	32.2.5.3	Maintenance	21.7.3, 21.7.6
Parking structures	42.8.5.3	Means of egress arrangement	19.2.5, 21.2.5
Rooming houses	26.5.3	Means of egress capacity	21.2.3
Storage occupancies	42.5.3	Means of egress components	21.2.2
Escape ...see Fire escape ladders; Fire escape stairs; Means of escape		Means of egress illumination	21.2.8
Evacuation ...see also Drills, emergency egress/fire		Means of egress marking	21.2.10
Apartment buildings as board and care occupancies	32.4.1.3, 33.4.1.3, A.32.4.1.3.1, A.33.4.1.3.1	Means of egress requirements	21.1.2.3 to 21.1.2.5, 21.2
Elevator evacuation system		Modernization/renovation/alteration	21.1.1.4.3
Capacity	7.2.13.2	Multiple occupancies	21.1.2, A.21.1.2.2
Definition	3.3.218.1	Occupant load	21.1.7
Existing ambulatory health care occupancies ...	21.7.1, A.21.7.1.4	Operating features	21.7, A.21.7
Existing detention and correctional occupancies	23.7.1, A.23.7.1.2, A.23.7.1.3	Protection	21.3, A.21.3.7.9
Existing health care occupancies	19.7.1, A.19.7.1.4	Rubbish/laundry chutes, incinerators	21.5.4
Existing residential board and care occupancies	33.1.7, 33.2.1.2, 33.2.1.3, 33.2.3.5.2, 33.2.3.5.3, 33.3.1.2, 33.4.1.3, A.33.1.7, A.33.2.1.2.1.1, A.33.3.1.2.1.1, A.33.3.1.2.2	Smoke control	21.7.7, A.21.7.7
New ambulatory health care occupancies	20.7.1, A.20.7.1.4	Smoking	21.7.4, A.21.7.4
New detention and correctional occupancies	22.7.1	Staff, procedure in fire	21.7.1, 21.7.2, A.21.7.2.1
New health care occupancies	18.7.1, A.18.7.1.4	Utilities	21.5.1
New residential board and care occupancies	32.4.1.3	Vertical openings, protection of	21.3.1
Evacuation capability		Existing apartment buildings	Chap. 31
Definition	3.3.57, A.3.3.57	Alternating tread devices	31.2.2.11
Impractical	33.2.1.3.3, 33.2.3.5.2.2, 33.2.3.5.2.5, 33.2.3.5.3, 33.3.1.2.2, A.33.3.1.2.2	Application	31.1.1
Definition	3.3.57.1	Areas of refuge	31.2.2.12, A.31.2.2.12
Prompt	33.2.1.3.1, 33.2.3.5.2.1, 33.2.3.5.2.3, 33.2.3.5.2.4, 33.3.1.2.1, A.33.3.1.2.1.1	Building services	31.5
Definition	3.3.57.2	Building spaces, subdivision of	31.3.7
Slow	33.2.1.3.2, 33.2.3.5.2.2, 33.2.3.5.2.3, 33.2.3.5.2.4, 33.3.1.2.1, A.33.3.1.2.1.1	Classification of occupancy	31.1.4
Definition	3.3.57.3	Corridors	31.3.6, A.31.3.6.1
Exhibitor (definition)	3.3.59	Detection/alarm/communication systems	31.3.4
Exhibits		Doors	31.2.2.2, 31.3.6.2 to 31.3.6.7
Definition	3.3.58	Elevators/escalators/conveyors	31.5.3
Existing assembly occupancies	13.7.4.3, A.13.7.4.3.4(3), A.13.7.4.3.7.1(3)	Emergency lighting	31.2.9
New assembly occupancies	12.7.4.3, A.12.7.4.3.4(3)	Escalators	31.2.2.8, A.31.2.2.8
Existing		Exit discharge	31.2.7
Approved existing (definition)	3.3.60.1	Exit passageways	31.2.2.7
Definition	3.3.60 see also Existing buildings	Exits, horizontal	31.2.2.5
Existing ambulatory health care occupancies	Chap. 21	Exits, number of	31.2.4
Application	21.1.1, A.21.1.1.1.6, A.21.1.1.2	Exit travel distance	31.2.6
Building services	21.5	Extinguishment requirements	31.3.5, A.31.3.5.3, A.31.3.5.10.2
Building spaces, subdivision of	21.3.7, A.21.3.7.9	Fire escape ladders	31.2.2.10
Changes of occupancy	21.1.1.4.2	Fire escape stairs	31.2.2.9
Classification of occupancy	21.1.4	General requirements	31.1, A.31.1, Table A.31.1
Construction	21.1.1.4.4, 21.1.6, 21.7.9	Hazard of contents, classification of	31.1.5
Detection/alarm/communication systems	21.3.4	Hazardous areas	31.3.2.1
Doors	21.1.1.4.1.2, 21.1.1.4.1.3, 21.2.2.2 to 21.2.2.4, 21.2.3.3, 21.3.2.1, 21.3.7.1, 21.3.7.9 to 21.3.7.11, A.21.3.7.9	Hazards, protection from	31.3.2
Drills	21.7.1.4 to 21.7.1.7, A.21.7.1.4	Heating, ventilating, and air conditioning	31.5.2
Electrical systems, essential	21.2.9	High-rise buildings	31.2.11, 31.3.5.10, 31.4.1
Elevators/escalators/conveyors	21.5.3	Interior finish	31.3.3
Emergency control	21.3.4.5	Means of egress, special features	A.31.2.11
Emergency lighting	21.2.9	Means of egress arrangement	31.2.5
Emergency plans	21.7.1, 21.7.2, A.21.7.2.1	Means of egress capacity	31.2.3
Evacuation	21.7.1, A.21.7.1.4	Means of egress components	31.2.2, A.31.2.2
Exit discharge	21.2.7	Means of egress illumination	31.2.8
		Means of egress marking	31.2.10
		Means of egress requirements	31.2, A.31.2
		Multiple occupancies	31.1.2
		Occupant load	31.1.7
		Operating features	31.7
		Protection	31.3
		Ramps	31.2.2.6
		Residents, emergency instructions for	31.7
		Rubbish/laundry chutes, incinerators	31.5.4
		Smoke barriers	31.3.7

- Smokeproof enclosures 31.2.2.4, 31.2.11, A.31.2.11
 Special provisions 31.4
 Stairs 31.2.2.3
 Utilities 31.5.1
 Vertical openings, protection of 31.3.1
Existing assembly occupancies Chap. 13
 Access/egress routes, requirements 13.2.5.4,
 A.13.2.5.4.2 to A.13.2.5.4.4
 Aisle accessways serving seating at tables 13.2.5.7, A.13.2.5.7
 Aisle accessways serving seating not at tables 13.2.5.5, A.13.2.5.5
 Aisle handrails 13.2.5.6.7, A.13.2.5.6.7
 Aisle marking 13.2.5.6.8, A.13.2.5.6.8
 Aisles, dead-end 13.2.5.6.2, 13.4.2.7
 Aisles serving seating at tables 13.2.5.8, A.13.2.5.8.1
 to A.13.2.5.8.3
 Aisles serving seating not at tables 13.2.5.6, A.13.2.5.6
 Aisle stair risers 13.2.5.6.6
 Aisle stairs/ramps 13.2.5.6.4, A.13.2.5.6.4
 Aisle stair treads 13.2.5.6.5, A.13.2.5.6.5
 Alternating tread devices 13.2.2.11
 Application 13.1.1
 Approval of layouts 13.2.5.9
 Areas of refuge 13.2.2.12
 Boxes/balconies/galleries 13.2.11.1
 Building services 13.5
 Classification of occupancy 13.1.4, A.13.1.4
 Clothing storage 13.7.11
 Construction, minimum requirements 13.1.6
 Cooking equipment/facilities 13.7.1, 13.7.4.3.9, A.13.7.1.4(5)
 Crowd managers 13.7.5, A.13.7.5
 Decorations 13.7.3, A.13.7.3.3
 Definitions A.13.1.3
 Detection/alarm/communication systems 13.3.4, A.13.3.4.2.2
 Doors 13.2.2.2
 Drills 13.7.6, A.13.7.6
 Emergency lighting 13.2.9
 Escalators 13.2.2.8
 Exhibits 13.7.4.3, A.13.7.4.3.4(3), A.13.7.4.3.7.1(3)
 Exit discharge 13.2.7
 Exit passageways 13.2.2.7
 Exits 13.2.3.6, 13.2.3.7, 13.2.4, A.13.2.4
 Exits, horizontal 13.2.2.5
 Exits, number of A.13.2.4
 Exit travel distance 13.2.6
 Exposition facilities 13.7.4, A.13.7.4.3.4(3), A.13.7.4.3.7.1(3)
 Extinguishment requirements 13.3.5
 Fire escape ladders 13.2.2.10
 Fire escape stairs 13.2.2.9
 Food service operations, provisions for 13.7.1, 13.7.4.3.9,
 A.13.7.1.4(5)
 Furnishings 13.7.3, A.13.7.3.3
 General requirements 13.1
 Grandstands 13.4.8
 Guards/railings 13.2.11.1
 Hazard of contents, classification 13.1.5
 Hazardous operations/processes 13.3.2.1
 Hazards, protection from 13.3.2
 High-rise buildings 13.4.4
 Interior finish 13.3.3
 Limited access/underground buildings 13.4.3
 Maintenance and operation 13.7.9, 13.7.10
 Means of egress arrangement 13.2.5, A.13.2.5
 Means of egress capacity 13.2.3, A.13.2.3.2, A.13.2.3.6.5
 Means of egress components 13.2.2
 Means of egress illumination 13.2.8
 Means of egress marking 13.2.10
 Means of egress requirements 13.2, A.13.2
 Moving walks 13.2.2.8
 Multiple occupancies 13.1.2, A.13.1.2.2
 Notification 13.3.4.3
 Occupant load 13.1.7, A.13.1.7.1
 Open flame devices 13.7.2, 13.7.4.3.8, A.13.7.2(3)(a)
 Operating features 13.7, A.13.7
 Panic hardware/fire exit hardware 13.2.2.2.3
 Projection booths/rooms 13.4.6
 Protection 13.3, A.13.3.1(1), A.13.3.4.2.2
 Pyrotechnic devices 13.7.2, A.13.7.2(3)(a)
 Ramps 13.2.2.6
 Seating 13.4.9
 Service equipment 13.3.2.1
 Smokeproof enclosures 13.2.2.4
 Smoke-protected assembly seating 13.4.2, A.13.4.2
 Smoking 13.7.7
 Special amusement buildings 13.4.7, A.13.4.7
 Special provisions 13.4, A.13.4
 Stages 13.4.5
 Stage scenery 13.7.3, A.13.7.3.3
 Stairs 13.2.2.3, A.13.2.2.3.1(1)
 Storage facilities 13.3.2.1
 Turnstiles 13.2.2.2.8, 13.2.2.2.9
 Vertical openings, protection of 13.3.1, A.13.3.1(1)
 Waiting spaces 13.1.7.2
Existing buildings
 Applicability of code to 1.3.1
 Definition 3.3.27.5, A.3.3.27.5
 Fire protection features 8.1.1
 Modification of requirements for 4.6.4, A.4.6.4
Existing business occupancies Chap. 39
 Alternating tread devices 39.2.2.11
 Application 39.1.1
 Areas of refuge 39.2.2.12
 Building services 39.5
 Classification of occupancy 39.1.4
 Detection/alarm/communication systems 39.3.4
 Doors 39.2.2.2, A.39.2.2.2
 Drills 39.7.1
 Elevators/escalators/conveyors 39.5.3
 Emergency lighting 39.2.9
 Escalators/moving walks 39.2.2.8
 Exit discharge 39.2.7
 Exit passageways 39.2.2.7
 Exits, horizontal 39.2.2.5
 Exits, number of 39.2.4
 Exit travel distance 39.2.6
 Extinguishment requirements 39.3.5, 39.7.2
 Fire escape ladders 39.2.2.10
 Fire escape stairs 39.2.2.9
 General requirements 39.1, A.39.1.2.2.2(4)
 Hazard of contents, classification of 39.1.5
 Hazards, protection from 39.3.2, A.39.3.2.1, A.39.3.2.2
 Heating, ventilating, and air conditioning 39.5.2
 High-rise buildings 39.4.2, A.39.4.2.2
 Interior finish 39.3.3
 Limited access/underground buildings 39.4.1
 Means of egress arrangement 39.2.5, A.39.2.5.2, A.39.2.5.3
 Means of egress capacity 39.2.3
 Means of egress components 39.2.2
 Means of egress illumination 39.2.8
 Means of egress marking 39.2.10
 Means of egress requirements 39.2
 Multiple occupancies 39.1.2, A.39.1.2.2.2(4)
 Occupant load 39.1.7
 Operating features 39.7
 Protection 39.3
 Ramps 39.2.2.6
 Rubbish/laundry chutes, incinerators 39.5.4
 Smokeproof enclosures 39.2.2.4
 Special provisions 39.4
 Stairs 39.2.2.3
 Utilities 39.5.1
 Vertical openings, protection of 39.3.1
Existing day-care homes 17.6, A.17.6.1.1.2, A.17.6.1.4.2
 Application 17.6.1.1, A.17.6.1.1.2
 Classification of occupancy 17.6.1.4, A.17.6.1.4.2

Conversion to day-care occupancy with more than 12 clients	17.1.4.3, 17.6.1.4.2, A.17.1.4.3, A.17.6.1.4.2	Smokeproof enclosures	17.2.2.4
Detection/alarm/communication systems	17.6.3.4	Special provisions	17.4
Exit discharge	17.6.2.7	Staff	17.7.5, A.17.7.5
Exits, number of	17.6.2.4	Stairs	17.2.2.3, A.17.2.2.3
Exit travel distance	17.6.2.6	Utilities	17.5.1
Extinguishment requirements	17.6.3.5	Vertical openings, protection of	17.3.1
General requirements	17.6.1, A.17.6.1.1.2, A.17.6.1.4.2	Windows	17.2.11.1
Hazard of contents, classification	17.6.1.5	Existing detention and correctional occupancies	Chap. 23
High-rise buildings	Table 17.1.6	Additions	23.1.1.3
Interior finish	17.6.3.3	Alternating tread devices	23.2.2.10
Location/construction	17.6.1.6	Application	23.1.1, A.23.1.1.2
Means of egress arrangement	17.6.2.5	Areas of refuge	23.2.2.11
Means of egress illumination	17.6.2.8	Building services	23.5
Means of escape requirements	17.6.2	Building spaces, subdivision of	23.3.7, 23.3.8, Table 23.3.8, A.23.3.7
Mixed occupancies	17.6.1.2	Classification of occupancy	23.1.4, A.23.1.4.1
Protection	17.6.3	Construction, minimum requirements	23.1.6
Vertical openings, protection of	17.6.3.1	Corridors	23.3.6
Existing day-care occupancies	Chap. 17;	Detection/alarm/communication systems	23.3.4, A.23.3.4.3.1(2), A.23.3.4.4.3
<i>see also</i> Existing day-care homes		Doors	23.2.2.2, 23.2.11, 23.3.7.2, 23.3.7.6, 23.3.7.8, 23.3.7.9, A.23.2.11.3, A.23.2.11.7, A.23.3.7.1(2), A.23.3.7.6(1)
Adult day-care, classification of	17.1.4.2	Drills	23.7.1.3, A.23.7.1.3
Alternating tread devices	17.2.2.9	Elevators/escalators/conveyors	23.5.3
Apartment buildings, in	17.1.2.2(2)	Emergency forces notification	23.3.4.3.2
Application	17.1.1, A.17.1.1	Emergency lighting	23.2.9
Areas of refuge	17.2.2.5.2, 17.2.2.10	Evacuation	23.7.1, A.23.7.1.2, A.23.7.1.3
Building services	17.5	Exit discharge	23.2.7
Classification of occupancy	17.1.4, A.17.1.4.3	Exit passageways	23.2.2.7
Conversion from day-care home	17.1.4.3, 17.6.1.4.2, A.17.1.4.3, A.17.6.1.4.2	Exits, horizontal	23.2.2.5, A.23.2.2.5.2, A.23.2.2.5.3
Corridors	17.2.11.1.2(5), 17.3.6	Exits, number of	23.2.4, A.23.2.4.1, A.23.2.4.2
Detection/alarm/communication systems	17.3.4	Exit travel distance	23.2.6
Doors	17.2.2.2, A.17.2.2.2.4	Extinguishment requirements	23.3.5, A.23.3.5.2, A.23.3.5.4(1)
Drills	17.7.2, A.17.7.2.1	Fire escape ladders	23.2.2.9
Elevators/escalators/conveyors	17.5.3	Fire escape stairs	23.2.2.8
Emergency lighting	17.2.9	Furnishings/bedding/decorations	23.7.4, A.23.7.4
Emergency plans	17.7.1, A.17.7.1	General requirements	23.1, A.23.1
Exit discharge	17.2.7	Hazard of contents, classification of	23.1.2.6, 23.1.2.7, 23.1.5
Exit passageways	17.2.2.7	Hazardous areas	23.3.2.1, A.23.3.2.1
Exits, horizontal	17.2.2.5	Hazards, protection from	23.3.2
Exits, number of	17.2.4	Heating, ventilating, and air conditioning	23.5.2, 23.7.6
Exit travel distance	17.2.6	High-rise buildings	23.3.5.1, 23.4.3
Extinguishment requirements	17.3.5	Interior finish	23.3.3
Fire escape ladders	17.2.2.8	Keys	23.2.11.6, 23.2.11.7.2, 23.7.5
Flexible plan day-care buildings	17.4.3	Limited access areas	23.4.1, A.23.4.1.2(2)
Furnishings/decorations	17.7.4	Means of egress arrangement	23.2.5, A.23.2.5.2
General requirements	17.1, A.17.1.1, A.17.1.4.3	Means of egress capacity	23.2.3
Hazard of contents, classification of	17.1.5	Means of egress components	23.2.2, A.23.2.2.5.2, A.23.2.2.5.3
Hazards, protection from	17.3.2, A.17.3.2.1(2)(a)	Means of egress illumination	23.2.8
Heating, ventilating, and air conditioning	17.5.2	Means of egress marking	23.2.10
High-rise buildings	Table 17.1.6, 17.4.2	Means of egress requirements	23.1.2.2, 23.1.2.4, 23.1.2.5, 23.2, A.23.2
Inspections	17.7.3	Modernization/renovation	23.1.1.4
Interior finish	17.3.3	Multiple occupancies	23.1.2, A.23.1.2
Limited access/underground buildings	17.4.1	Occupant load	23.1.7
Location/construction	17.1.6	Operating features	23.7, A.23.7
Locks/latches	17.2.2.2.3 to 17.2.2.2.5, A.17.2.2.2.4	Protection	23.3, A.23.3
Means of egress, special features	17.2.11	Ramps	23.2.2.6
Means of egress arrangement	17.2.5	Resident housing spaces, subdivision of	A.23.3.8
Means of egress capacity	17.2.3	Rubbish/laundry chutes, incinerators	23.5.4
Means of egress components	17.2.2, A.17.2.2.2.4, A.17.2.2.3	Smoke barriers	23.3.7, A.23.3.7
Means of egress illumination	17.2.8	Smokeproof enclosures	23.2.2.4
Means of egress marking	17.2.10	Special features	23.2.11
Means of egress requirements	17.2, 17.7.3.2, 17.7.3.3, A.17.2.2.3, A.17.7.3.2	Special provisions	23.4
Multiple occupancies	17.1.2	Staff, procedures in fire	23.7.1, A.23.7.1.2, A.23.7.1.3
Occupant load	17.1.7	Stairs	23.2.2.3
Open plan day-care buildings	17.4.3	Underground structures	23.4.2
Operating features	17.7, A.17.7	Use Conditions I to V	23.1.4.1 to 23.1.4.3, A.23.1.4.1 to A.23.1.4.3
Panic hardware/fire exit hardware	17.2.2.2.2	Utilities	23.5.1
Protection	17.3, A.17.3.2.1(2)(a)	Vertical openings, protection of	23.3.1, A.23.3.1
Ramps	17.2.2.6		
Rubbish/laundry chutes, incinerators	17.5.4		

- Existing educational occupancies** Chap. 15
- Aisles 15.2.5.6, 15.2.5.7
 - Alternating tread devices 15.2.2.9
 - Application 15.1.1
 - Areas of refuge 15.2.2.10
 - Balconies 15.2.5.8, A.15.2.5.8
 - Building services 15.5
 - Building spaces, subdivision of 15.3.7
 - Classification of occupancy 15.1.4
 - Corridors 15.2.5.4(1), 15.3.6, A.15.3.6(2)
 - Exterior 15.2.5.8, A.15.2.5.8
 - Minimum width 15.2.3.2
 - Detection/alarm/communication systems 15.3.4, A.15.3.4
 - Doors 15.2.2.2, 15.2.5.4, 15.2.5.5, 15.3.6
 - Drills 15.7.2, A.15.7.2.1
 - Elevators/escalators/conveyors 15.5.3
 - Emergency lighting 15.2.9
 - Exit discharge 15.2.7
 - Exit passageways 15.2.2.7
 - Exits, horizontal 15.2.2.5
 - Exits, number of 15.2.4
 - Exit travel distance 15.2.6
 - Extinguishment requirements 15.3.5
 - Fire escape ladders 15.2.2.8
 - Flexible/open plan buildings 15.4.3
 - Furnishings/decorations 15.7.4
 - General requirements 15.1
 - Hazard of contents, classification of 15.1.5
 - Hazards, protection from 15.3.2
 - Heating, ventilating, and air conditioning 15.5.2
 - High-rise buildings 15.4.2
 - Inspections 15.7.3, A.15.7.3.1
 - Interior finish 15.3.3
 - Limited access/underground buildings 15.4.1
 - Means of egress, special features 15.2.11, A.15.2.11.1
 - Means of egress arrangement 15.2.5
 - Means of egress capacity 15.2.3
 - Means of egress components 15.2.2, A.15.2.2.3
 - Means of egress illumination 15.2.8
 - Means of egress marking 15.2.10
 - Means of egress requirements 15.2, A.15.2
 - Multiple occupancies 15.1.2
 - Occupant load 15.1.7
 - Operating features 15.7, A.15.7.2.1, A.15.7.3.1
 - Panic hardware/fire exit hardware 15.2.2.2
 - Protection 15.3, A.15.3
 - Ramps 15.2.2.6
 - Rubbish/laundry chutes, incinerators 15.5.4
 - Smokeproof enclosures 15.2.2.4
 - Special provisions 15.4
 - Stairs 15.2.2.3, A.15.2.2.3
 - Utilities 15.5.1
 - Vertical openings, protection of 15.3.1
 - Windows 15.2.11.1, A.15.2.11.1
- Existing health care occupancies** Chap. 19
- Additions 19.1.1.4.1 to 19.1.1.4.4
 - Alternating tread devices 19.2.2.9
 - Anesthetizing locations 19.3.2.3
 - Application 19.1.1, A.19.1.1
 - Areas of refuge 19.2.2.10
 - Building services 19.5, A.19.5.2.2
 - Building spaces, subdivision of 19.3.7, A.19.3.7.3(2)
 - Changes of occupancy 19.1.1.4.5
 - Classification of occupancy 19.1.4
 - Construction, minimum requirements 19.1.6, A.19.1.6.5, A.19.1.6.7
 - Construction, repair, and improvement operations 19.1.1.4.7, 19.7.9
 - Cooking facilities 19.3.2.5, A.19.3.2.5.2
 - Corridors 19.2.3.4, 19.2.3.5, 19.3.4.5.1, 19.3.4.5.2, 19.3.6, A.19.3.6
 - Detection/alarm/communications systems 19.3.4, A.19.3.4.2, A.19.3.4.3.1(1)
 - Doors 19.2.2.2, 19.2.3.2, 19.2.3.6, 19.2.3.7, 19.3.2.1.3, 19.3.2.1.4, 19.3.6.3, 19.3.7.5 to 19.3.7.8, 19.3.8, A.19.2.2.2.4(2), A.19.2.2.2.6, A.19.2.2.2.8, A.19.2.2.5.3, A.19.3.6.3, A.19.3.7.5.1, A.19.3.7.6
 - Drills 19.7.1.4 to 19.7.1.7, A.19.7.1.4
 - Elevators/escalators/conveyors 19.5.3
 - Emergency control 19.3.4.4
 - Emergency lighting 19.2.9
 - Emergency plans 19.7.1, 19.7.2.2
 - Evacuation 19.7.1, A.19.7.1.4
 - Exit discharge 19.2.7
 - Exit passageways 19.2.2.7
 - Exits, horizontal 19.2.2.5, A.19.2.2.5.3
 - Exits, maintenance of 19.7.3
 - Exits, number of 19.2.4, A.19.2.4.3
 - Exit travel distance 19.2.6
 - Extinguishment requirements 19.3.5, A.19.3.5
 - Fire escape ladders 19.2.2.8
 - Firestopping 19.1.6.8
 - Furnishings/bedding/decorations 19.7.5, A.19.7.5.1
 - General requirements 19.1, A.19.1
 - Hazard of contents, classification of 19.1.2.8, 19.1.2.9, 19.1.5
 - Hazardous areas 19.3.2.1
 - Hazards, protection from 19.3.2
 - Heating, ventilating, and air conditioning 19.5.2, A.19.5.2.2
 - Heating devices, portable space 19.7.8
 - Interior finish 19.3.3, A.19.3.3.2
 - Laboratories 19.3.2.2, A.19.3.2.2
 - Limited access buildings 19.4.1
 - Means of egress arrangement 19.2.5, A.19.2.5.10
 - Means of egress capacity 19.2.3, A.19.2.3.4
 - Means of egress components 19.2.2, A.19.2.2
 - Means of egress illumination 19.2.8
 - Means of egress marking 19.2.10
 - Means of egress requirements 19.1.2.4 to 19.1.2.7
 - Medical gas 19.3.2.4
 - Modernization/renovation/rehabilitation 19.1.1.4, A.19.1.1.4.6.3, A.19.1.1.4.6.4
 - Multiple occupancies 19.1.2, A.19.1.2.2, A.19.1.2.3
 - Occupant load 19.1.7
 - Openings 19.3.1, 19.3.6.5
 - Operating features 19.7, A.19.7
 - Outside window/door 19.3.8
 - Protection 19.3, A.19.3
 - Ramps 19.2.2.6, 19.2.3.2, 19.2.3.4, 19.2.3.5
 - Rubbish/linen chutes, incinerators 19.5.4
 - Smoke barriers 19.3.7, A.19.3.7.6
 - Smoke control 19.7.7, A.19.7.7
 - Smokeproof enclosures 19.2.2.4
 - Smoking 19.7.4, A.19.7.4
 - Special provisions 19.4
 - Staff, procedure in fire 19.7.1, 19.7.2, A.19.7.2.1
 - Stairs 19.2.2.3
 - Testing 19.7.6
 - Transfer grilles 19.3.6.4
 - Utilities 19.5.1
 - Vertical openings, protection of 19.3.1
- Existing hotels and dormitories** Chap. 29
- Alternating tread devices 29.2.2.11
 - Application 29.1.1
 - Areas of refuge 29.2.2.12, A.29.2.2.12.2
 - Building services 29.5
 - Building spaces, subdivision of 29.3.7
 - Classification of occupancy 29.1.4
 - Corridors 29.3.6
 - Detection/alarm/communication systems 29.3.4, A.29.3.4.3.6, A.29.3.4.5
 - Doors 29.2.2.2, 29.3.6.2
 - Drills 29.7.1.2, 29.7.3, A.29.7.1.2
 - Elevators/escalators/conveyors 29.5.3
 - Emergency lighting 29.2.9
 - Escalators 29.2.2.8, A.29.2.2.8

Exit discharge	29.2.7, A.29.2.7.2	Multiple occupancies	37.1.2, A.37.1.2.2.2(4)
Exit passageways	29.2.2.7	Occupant load	37.1.7
Exits, horizontal	29.2.2.5	Open-air mercantile operations	37.4.3
Exits, number of	29.2.4	Operating features	37.7
Exit travel distance	29.2.6	Protection	37.3
Extinguishment requirements	29.3.5, A.29.3.5.3	Ramps	37.2.2.6
Fire escape ladders	29.2.2.10	Rubbish/laundry chutes, incinerators	37.5.4
Fire escape stairs	29.2.2.9	Smokeproof enclosures	37.2.2.4
Furnishings/decorations	29.3.3.4, A.29.3.3.4	Special provisions	37.4, A.37.4
General requirements	29.1	Stairs	37.2.2.3
Hazard of contents, classification of	29.1.5	Utilities	37.5.1
Hazardous areas	29.3.2.2	Vertical openings, protection of	37.3.1
Hazards, protection from	29.3.2	Existing residential board and care occupancies	Chap. 33
Heating, ventilating, and air conditioning	29.5.2	Apartment building suitability as	33.4, A.33.4
High-rise buildings	29.3.5.1, 29.4.1	Application	33.1.1, A.33.1.1
Interior finish	29.3.3, A.29.3.3.4	Building spaces, subdivision of	33.4.3.3
Means of egress arrangement	29.2.5	Construction	33.4.1.4
Means of egress capacity	29.2.3	Conversions	33.1.1.4
Means of egress components	29.2.2, A.29.2.2.12.2	Corridor wall construction	33.4.3.2
Means of egress illumination	29.2.8	Doors	33.2.3.6, 33.3.3.6.4 to 33.3.3.6.6
Means of egress marking	29.2.10	Drills	33.7.3
Means of egress requirements	29.2, A.29.2	Emergency plan	33.7.1
Multiple occupancies	29.1.2	Evacuation	33.1.7, 33.4.1.3, A.33.1.7
Occupant load	29.1.7	Evacuation capability, requirements based on	33.2.1.3, 33.2.3.5.2, 33.2.3.5.3
Operating features	29.7, A.29.7	Fire resistance requirements	33.1.5, A.33.1.5
Protection	29.3	Furnishings/bedding/decorations	33.7.5, A.33.7.5
Ramps	29.2.2.6	General requirements	33.1, A.33.1
Residents/guests, emergency instructions for	29.7.4, A.29.7.4.1, A.29.7.4.2	High-rise buildings	33.3.5.2
Rubbish/laundry chutes, incinerators	29.5.4	Interior finish	33.4.3.1
Smokeproof enclosures	29.2.2.4	Large facilities	33.3, A.33.3
Special provisions	29.4	Alternating tread devices	33.3.2.2.9
Stairs	29.2.2.3	Areas of refuge	33.3.2.2.10
Utilities	29.5.1	Building services	33.3.6
Vertical openings, protection of	29.3.1	Building spaces, subdivision of	33.3.3.7
Existing mercantile occupancies	Chap. 37	Construction, minimum requirements	33.3.1.3
Alternating tread devices	37.2.2.11	Corridors	33.3.3.6
Application	37.1.1	Detection/alarm/communication systems	33.3.3.4
Areas of refuge	37.2.2.12	Doors	33.3.2.2.2
Building services	37.5	Elevators/dumbwaiters/conveyors	33.3.6.3
Bulk merchandising retail buildings	37.4.5	Emergency forces notification	A.33.3.3.4.6
Classification of occupancy	37.1.4	Emergency lighting	33.3.2.9
Detection/alarm/communication systems	37.3.4, 37.4.4.4, 37.4.5.4	Evacuation capability, requirements based on	33.3.1.2, A.33.3.1.2.1.1, A.33.3.1.2.2
Doors	37.2.2.2, A.37.2.2.2.2	Exit discharge	33.3.2.7
Drills	37.7.1	Exit passageways	33.3.2.7
Elevators/escalators/conveyors	37.5.3	Exits, horizontal	33.3.2.2.5
Emergency control	37.4.4.4.4	Exits, number of	33.3.2.4
Emergency lighting	37.2.9, 37.4.4.3.8	Exit travel distance	33.3.2.6
Escalators/moving walks	37.2.2.8	Extinguishment requirements	33.3.3.5, A.33.3.3.5.1
Exit discharge	37.2.7, A.37.2.7.2	Fire escape ladders	33.3.2.2.8
Exit passageways	37.2.2.7, 37.4.4.6, A.37.2.2.7.2	General	33.3.1, A.33.3.1
Exits, horizontal	37.2.2.5	Hazards, protection from	33.3.3.2
Exits, number of	37.2.4	Heating, ventilating, and air conditioning	33.3.6.2
Exit travel distance	37.2.6	Interior finish	33.3.3.3
Extinguishment requirements	37.3.5, 37.4.5.5, 37.7.2	Means of egress arrangement	33.3.2.5
Fire escape ladders	37.2.2.10	Means of egress capacity	33.3.2.3
Fire escape stairs	37.2.2.9	Means of egress components	33.3.2.2
General requirements	37.1, A.37.1.2.2.2(4)	Means of egress illumination	33.3.2.8
Hazard of contents, classification of	37.1.5	Means of egress marking	33.3.2.10
Hazards, protection from	37.3.2, A.37.3.2.1, A.37.3.2.2	Means of egress requirements	33.3.2
Heating, ventilating, and air conditioning	37.5.2	Occupant load	33.3.1.4
Interior finish	37.3.3	Protection	33.3.3
Limited access/underground buildings	37.4.1	Ramps	33.3.2.2.6
Mall buildings	37.4.4, A.37.4.4	Rubbish/laundry chutes, incinerators	33.3.6.4
Means of egress arrangement	37.2.5, A.37.2.5.2, A.37.2.5.3, A.37.2.5.10	Size of facility, changes in	33.1.6
Means of egress capacity	37.2.3	Sleeping rooms, separation of	33.3.3.6
Means of egress components	37.2.2	Smokeproof enclosures	33.3.2.2.4
Means of egress illumination	37.2.8	Stairs	33.3.2.2.3
Means of egress marking	37.2.10	Utilities	33.3.6.1
Means of egress requirements	37.2, 37.4.5.2	Vertical openings, protection of	33.3.3.1
		Means of egress requirements	33.1.4, 33.4.2

- Means of escape 33.1.4
- Multiple occupancies 33.1.2
- Operating features 33.7, A.33.7
- Resident training 33.7.2
- Size of facility, changes in 33.1.6
- Small facilities 33.2, A.33.2
- Automatic extinguishing systems 33.2.3.5, A.33.2.3.5.2.1
- Building services 33.2.5
- Construction, minimum requirements 33.2.1.3
- Corridor walls, construction of 33.2.3.6
- Detection/alarm/communication systems 33.2.3.4, A.33.2.3.4.3
- Doors 33.2.2.5
- Evacuation capability 33.2.1.2, 33.2.3.5.2, 33.2.3.5.3, A.33.2.1.2.1.1
- General 33.2.1, A.33.2.1.2.1.1
- Hazardous areas 33.2.3.2
- Heating, ventilating, and air conditioning 33.2.5.2
- Interior finish 33.2.3.3
- Means of escape 33.2.2, A.33.2.2.3(3)
- Protection 33.2.3
- Size of facility, changes in 33.1.6
- Stairs 33.2.2.4, 33.2.2.6, A.33.2.2.6.3
- Utilities 33.2.5.1
- Vertical openings, protection of 33.2.3.1
- Smoking 33.7.4, A.33.7.4.1
- Exit access**
- Airport loading walkways 12.4.10.3, 13.4.10.3
- Capacity 7.3.4.2
- Corridors 7.1.3.1, 12.2.3.8
- Definition 3.3.63
- Educational occupancies 14.2.5.4, 14.2.5.5, 15.2.5.4, 15.2.5.5
- Elevator lobby 7.4.1.6
- Fire escape ladders 7.2.9.3
- Fire escape stairs 7.2.8.3
- Health care occupancies 18.2.3.4, 18.2.3.5
- Marking 7.10.1.5, A.7.10.1.5.2
- Outside stairs 7.2.2.6.1
- Smokeproof enclosures 7.2.3.6
- Exit discharge** 7.7, A.7.7.1
- Definition 3.3.64
- Existing ambulatory health care occupancies 21.2.7
- Existing apartment buildings 31.2.7
- Existing assembly occupancies 13.2.7
- Existing business occupancies 39.2.7
- Existing day-care occupancies 17.2.7, 17.6.2.7
- Existing detention and correctional occupancies 23.2.7
- Existing educational occupancies 15.2.7
- Existing health care occupancies 19.2.7
- Existing hotels and dormitories 29.2.7, A.29.2.7.2
- Existing mercantile occupancies 37.2.7, A.37.2.7.2
- Existing residential board and care occupancies 33.3.2.7
- Industrial occupancies 40.2.7
- Level of (definition) 3.3.64.1
- New ambulatory health care occupancies 20.2.7
- New apartment buildings 30.2.7
- New assembly occupancies 12.2.7
- New business occupancies 38.2.7
- New day-care occupancies 16.2.7, 16.6.2.7
- New detention and correctional occupancies 22.2.7
- New educational occupancies 14.2.7
- New health care occupancies 18.2.7
- New hotels and dormitories 28.2.7, A.28.2.7.2
- New mercantile occupancies 36.2.7, A.36.2.7.2
- New residential board and care occupancies 32.3.2.7
- Parking structures 42.8.2.7
- Smokeproof enclosures 7.2.3.5
- Special structures 11.2.2.7, 11.3.2.7, 11.4.2.7
- Storage occupancies 42.2.7
- Exit passageways** 7.2.6, A.7.2.6
- Discharge 7.7.4
- Enclosure 7.2.6.2
- Existing apartment buildings 31.2.2.7
- Existing assembly occupancies 13.2.2.7
- Existing business occupancies 39.2.2.7
- Existing day-care occupancies 17.2.2.7
- Existing detention and correctional occupancies 23.2.2.7
- Existing educational occupancies 15.2.2.7
- Existing health care occupancies 19.2.2.7
- Existing hotels and dormitories 29.2.2.7
- Existing mercantile occupancies 37.2.2.7, 37.4.4.6, A.37.2.2.7.2
- Existing residential board and care occupancies 33.3.2.2.7
- Floor 7.2.6.5
- Industrial occupancies 40.2.2.7
- New apartment buildings 30.2.2.7
- New assembly occupancies 12.2.2.7
- New business occupancies 38.2.2.7
- New day-care occupancies 16.2.2.7
- New detention and correctional occupancies 22.2.2.7
- New educational occupancies 14.2.2.7
- New health care occupancies 18.2.2.7
- New hotels and dormitories 28.2.2.7
- New mercantile occupancies 36.2.2.7, 36.4.4.6, A.36.2.2.7.2
- New residential board and care occupancies 32.3.2.2.7
- Parking structures 42.8.2.2.7
- Stair discharge 7.2.6.3
- Storage occupancies 42.2.2.7
- Width 7.2.6.4, A.7.2.6.4(1)
- Exits** *see also* Drills, emergency egress/fire;
- Fire exit hardware; Horizontal exits
- Aircraft servicing hangars 40.6.2
- Definition 3.3.62, A.3.3.62
- Existing ambulatory health care occupancies 21.7.3
- Existing assembly occupancies 13.2.3.6, 13.2.3.7, 13.2.4, A.13.2.3.6.5, A.13.2.4
- Existing health care occupancies 19.7.3
- Interior finish in 7.1.4, A.7.1.4.1, A.7.1.4.2
- New ambulatory health care occupancies 20.7.3
- New assembly occupancies 12.2.3.6 to 12.2.3.8, 12.2.4, A.12.2.3.6.5, A.12.2.4
- New health care occupancies 18.7.3, A.18.2.4.4
- Separation of means of egress 7.1.3.2, A.7.1.3.2.1, A.7.1.3.2.3
- Exits, number of** 4.5.3.1, 7.4
- Existing ambulatory health care occupancies 21.2.4
- Existing apartment buildings 31.2.4
- Existing assembly occupancies 13.2.4, A.13.2.4
- Existing business occupancies 39.2.4
- Existing day-care occupancies 17.2.4, 17.6.2.4
- Existing detention and correctional occupancies 23.2.4, A.23.2.4.1, A.23.2.4.2
- Existing educational occupancies 15.2.4
- Existing health care occupancies 19.2.4, A.19.2.4.3
- Existing hotels and dormitories 29.2.4
- Existing mercantile occupancies 37.2.4
- Existing residential board and care occupancies 33.3.2.4
- Industrial occupancies 40.2.4
- Lodging or rooming houses 26.2.1
- New ambulatory health care occupancies 20.2.4
- New apartment buildings 30.2.4
- New assembly occupancies 12.2.4, A.12.2.4
- New business occupancies 38.2.4
- New day-care occupancies 16.2.4, 16.6.2.4
- New detention and correctional occupancies 22.2.4
- New educational occupancies 14.2.4
- New health care occupancies 18.2.4
- New hotels and dormitories 28.2.4
- New mercantile occupancies 36.2.4
- New residential board and care occupancies 32.3.2.4
- One- and two-family dwellings 24.2.2.1
- Parking structures 42.8.2.4
- Special structures 11.2.2.4, 11.3.2.4, 11.4.2.4, 11.5.2, A.11.3.2.4
- Storage occupancies 42.2.4, 42.7.2, 42.7.4.1

Exit travel distance

Existing ambulatory health care occupancies	21.2.6
Existing apartment buildings	31.2.6
Existing assembly occupancies	13.2.6
Existing business occupancies	39.2.6
Existing day-care occupancies	17.2.6, 17.6.2.6
Existing detention and correctional occupancies	23.2.6
Existing educational occupancies	15.2.6
Existing health care occupancies	19.2.6
Existing hotels and dormitories	29.2.6
Existing mercantile occupancies	37.2.6
Existing residential board and care occupancies	33.3.2.6
Industrial occupancies	40.2.6
Limitations	7.6.5, Table A.7.6
Measurement of	7.6, A.7.6, Table A.7.6
New ambulatory health care occupancies	20.2.6
New apartment buildings	30.2.6
New assembly occupancies	12.2.6
New business occupancies	38.2.6
New day-care occupancies	16.2.6, 16.6.2.6
New detention and correctional occupancies	22.2.6, 22.4.4.5
New educational occupancies	14.2.6
New health care occupancies	18.2.6, 18.4.3.4
New hotels and dormitories	28.2.6
New mercantile occupancies	36.2.6
New residential board and care occupancies	32.3.2.6
Parking structures	42.8.2.6
Special structures	11.2.2.6, 11.3.2.6, 11.4.2.6
Storage occupancies	42.2.6, 42.7.4.2, A.42.2.6

Explosion protection 8.7.2, A.8.7.2**Explosive substances used for repairs or alterations** 4.6.11.3**Exposition (definition)** 3.3.65**Exposition facilities**

Definition	3.3.69.1
Existing assembly occupancies	13.7.4, A.13.7.4.3.4(3), A.13.7.4.3.7.1(3)
New assembly occupancies	12.7.4, A.12.7.4.3.4(3), A.12.7.4.3.7.1(3)

Exposure fire (definition) 3.3.67, A.3.3.67**Exterior ways of exit access** 7.5.3**Externally illuminated** *see* Illuminated**Extinguishers, portable fire** 9.7.4.1, A.9.7.4.1

Ambulatory health care occupancies	20.3.5.3, 21.3.5.3
Apartment buildings	30.3.5.11, 31.3.5.11
Assembly occupancies, exposition facilities	12.7.4.3.9(5), 13.7.4.3.9(5)
Business occupancies	38.3.5, 38.7.2, 39.3.5, 39.7.2
Detention and correctional occupancies	22.3.5.4, 22.7.1.4, 23.3.5.4, 23.7.1.4, A.22.3.5.4(1), A.23.3.5.4(1)
Health care occupancies	18.3.5.7, 19.3.5.7
Hotels and dormitories	28.3.5.7, 29.3.5.7
Membrane structures, temporary	11.10.3
Mercantile occupancies	36.3.5.3, 36.7.2, 37.3.5.3, 37.7.2
Residential board and care occupancies	32.3.3.5.6, 33.3.3.5.6
Tents	11.11.5

Extinguishing equipment 9.7; *see also* Extinguishers, portable fire; Sprinkler systems; Standpipe and hose systems

Automatic	9.7.3
Manual	9.7.4

Extinguishment requirements *see also* Hazards, protection from

Bulk merchandising retail buildings	36.4.5.5, 37.4.5.5
Existing ambulatory health care occupancies	21.3.5
Existing apartment buildings	31.3.5, A.31.3.5.3, A.31.3.5.10.2
Existing assembly occupancies	12.7.4.3.7, 13.3.5, 13.4.5.7.5
Existing business occupancies	39.3.5, 39.7.2
Existing day-care homes	17.6.3.5
Existing day-care occupancies	17.3.5
Existing detention and correctional occupancies	23.3.5, A.23.3.5.2, A.23.3.5.4(1)
Existing educational occupancies	15.3.5

Existing health care occupancies	19.3.5, A.19.3.5
Existing hotels and dormitories	29.3.5, A.29.3.5.3
Existing mercantile occupancies	37.3.5, 37.4.5.5
Existing residential board and care occupancies	33.2.3.5, 33.3.3.5, A.33.2.3.5.2.1, A.33.3.3.5.1
High-rise buildings	11.8.2, A.11.8.2.1
Industrial occupancies	40.4
Lodging houses	26.3.5, A.26.3.5.3.3
Membrane structures, temporary	11.10.3
New apartment buildings	30.3.5
New assembly occupancies	12.3.5, 12.7.4.3.7, A.12.3.5.2(2), A.12.7.4.3.7.1(3)
New business occupancies	38.3.5, 38.7.2
New day-care occupancies	16.3.5, A.16.3.2.1(2)(a)
New detention and correctional occupancies	22.3.5, A.22.3.5.4(1)
New educational occupancies	14.3.5
New health care occupancies	18.3.5, A.18.3.5
New hotels and dormitories	28.3.5
New mercantile occupancies	36.3.5, 36.4.5.5, 36.7.2
New residential board and care occupancies	32.2.3.5, 32.3.3.5, A.32.2.3.5
One- and two-family dwellings	24.3.5, A.24.3.5
Rooming houses	26.3.5, A.26.3.5.3.3
Special hazard protection	8.7.1.2
Special structures	11.2.3.5, 11.3.3.5, 11.4.3.5
Storage occupancies	42.4.1
Tents	11.11.5

-F-**Facilities**

Cooking	<i>see</i> Cooking equipment/facilities
Exposition	<i>see</i> Exposition facilities
Hyperbaric facilities	8.7.5, A.8.7.5
Limited care	<i>see</i> Limited care facilities
Storage	<i>see</i> Storage facilities

Family A.6.1.8.1.1**Family day-care homes** 16.6.1.4.1(A), 16.6.1.7.1,
17.6.1.4.1(A), 17.6.1.7.1**Festival seating** *see* Seating**Fire alarm systems** *see* Alarms and alarm systems**Fire barriers** 8.2.2.3, 8.3, A.8.3;
see also Hazards, protection from

Atriums	8.6.7(1)
Communicating spaces	8.6.6(4)
Definition	3.3.23.1, A.3.3.23.1
Fire resistance rating	8.3.1, 8.3.2.3, A.8.3.1(3)
Horizontal exits	7.2.4.3, A.7.2.4.3.8, A.7.2.4.3.9
Penetrations/openings in	7.2.4.3.3 to 7.2.4.3.5, 8.3.4, 8.3.5, 8.6.2, A.8.3.5.6.3(1)(c)
Smoke barriers, used as	8.5.3, 8.5.6.4
Special hazard protection	8.7.1.1
Structural elements supporting, fire resistance of	8.2.3.3

Fire barrier walls *see* Walls**Fireblocking** 8.3.5.6.3(1), A.8.3.5.6.3(1)(c)**Fire compartments** *see* Compartments**Fire department notification** *see* Emergency forces notification**Fire detection systems** *see* Detection systems**Fire door assemblies** *see* Assembly**Fire doors** *see* Doors**Fire drills** *see* Drills, emergency egress/fire**Fire emergency response plans** *see* Emergency plans**Fire escape ladders** 7.2.9, A.7.1.1

Access	7.2.9.3
Apartment buildings	30.2.2.10, 31.2.2.10
Assembly occupancies	12.2.2.10, 12.2.4.8, 13.2.2.10, 13.2.4.8
Business occupancies	38.2.2.10, 39.2.2.10
Construction/installation	7.2.9.2
Day-care occupancies	16.2.2.8, 17.2.2.8
Detention and correctional occupancies	22.2.2.9, 23.2.2.9
Educational occupancies	14.2.2.8, 15.2.2.8

- Health care occupancies 18.2.2.8, 19.2.2.8
- Hotels and dormitories 28.2.2.10, 29.2.2.10
- Industrial occupancies 40.2.2.10
- Mercantile occupancies 36.2.2.10, 37.2.2.10
- One- and two-family dwellings 24.2.2.3(D), 24.2.5.6
- Performance-based design option 5.3.2(6)
- Residential board and care occupancies 32.3.2.2.8, 33.3.2.2.8
- Special structures 11.2.2.2.1, 11.3.2.2.1
- Storage occupancies 42.2.2.9, 42.7.3
- Fire escape stairs** 7.2.8, Table 7.2.8.4.1(a), Table 7.2.8.4.1(b)
 - Access 7.2.8.3
 - Apartment buildings 31.2.2.9
 - Assembly occupancies 13.2.2.9
 - Business occupancies 39.2.2.9
 - Details 7.2.8.4
 - Detention and correctional occupancies 23.2.2.8
 - Guards/handrails 7.2.8.5
 - Hotels and dormitories 29.2.2.9
 - Industrial occupancies 40.2.2.9
 - Intervening spaces 7.2.8.8
 - Materials/strength 7.2.8.6
 - Mercantile occupancies 37.2.2.9
 - Openings, protection of 7.2.8.2
 - Parking structures 42.8.2.2.8
 - Slip resistance 7.2.8.4.2
 - Storage occupancies 42.2.2.8
 - Swinging stairs 7.2.8.7, A.7.2.8.7
 - Visual enclosures 7.2.8.5
- Fire exit hardware**
 - Assembly occupancies 12.2.2.2.3, 13.2.2.2.3
 - Day-care occupancies 16.2.2.2.2, 17.2.2.2.2
 - Definition 3.3.103.1
 - Doors 7.2.1.7
 - Educational occupancies 14.2.2.2.2, 15.2.2.2.2
- Fire models**
 - Definition 3.3.77, A.3.3.77
 - Performance-based design option 5.6.3.1, 5.6.3.2, 5.8.11, 5.8.12, A.5.8.11
- Fire protection equipment** Chap. 9; *see also* Alarms and alarm systems; Communication systems; Detection systems; Extinguishers, portable fire; Extinguishment requirements; Sprinkler systems
- Fire protection features** Chap. 8
 - Application 8.1.1
 - Atriums 8.6.7, A.8.6.7
 - Compartmentation 8.2.2, 8.6.1(1), A.8.2.2.3; *see also* Compartments
 - Concealed spaces 8.6.10
 - Construction 8.2.1, A.8.2.1.2
 - Fire barriers *see* Fire barriers
 - Mezzanines 8.6.9
 - Smoke barriers *see* Smoke barriers
 - Smoke-protected assembly seating *see* Seating
 - Special hazards 8.7, A.8.7
 - Stages 12.4.5.10, 12.4.5.12, 13.4.5.10, 13.4.5.12, A.12.4.5.7, A.12.4.5.12, A.13.4.5.12
 - Vertical openings *see* Vertical openings
- Fire protection rating (definition)** 3.3.177.1
- Fire resistance rating**
 - Definition 3.3.177.2
 - Fire barriers 8.3.1, 8.3.2.3, A.8.3.1(3)
 - Floor opening enclosures 8.6.5, A.8.6.5
 - Membrane structures 11.9.1.2(1)
 - Structural elements and building assemblies 8.2.3, A.8.2.3.1
- Fire resistance requirements**
 - Existing residential board and care occupancies .. 33.1.5, A.33.1.5
 - New residential board and care occupancies 32.1.5, A.32.1.5
- Fire-retardant coatings** 10.2.6, 10.3.6, A.10.2.6
- Fire safety goals** 4.1, A.4.1
- Fire scenarios**
 - Definition 3.3.80, A.3.3.80
 - Design fire scenario 5.5, 5.8.6, A.5.5
 - Definition 3.3.80.1
- Firestopping** 8.3.5.1 to 8.3.5.3, 8.3.5.5.1, 8.3.5.6.1, 8.3.5.6.2, 8.6.10.5, 19.1.6.8
- Fire watch** 9.6.1.7, A.9.6.1.7, A.9.7.6, A.9.7.6.1
 - Definition 3.3.81, A.3.3.81
- Fire window assembly** *see* Assembly
- Fixed seating** *see* Seating
- Flame resistance requirements**
 - Membrane structures
 - Permanent 11.9.1.6
 - Temporary 11.10.1.5
 - Tents 11.11.2
- Flame-retardant requirements**
 - Exhibit booths 12.7.4.3.4(3), 13.7.4.3.4(3), A.12.7.4.3.4(3), A.13.7.4.3.4(3)
 - Stages 12.4.5.11, 13.4.5.11
- Flame spread (definition)** 3.3.84, A.3.3.84
- Flammable or combustible liquids and gases** *see also* Hazards, protection from
 - Exposition facilities 12.7.4.5, 13.7.4.5
 - Special hazard protection 8.7.3, A.8.7.3.2
- Flammable substances used for repairs or alterations** 4.6.11.3
- Flashover (definition)** 3.3.85, A.3.3.85
- Flexible plan day-care buildings** 16.4.3, 17.4.3
 - Definition 3.3.27.6, A.3.3.27.6
- Flexible plan education buildings** 14.4.3, 15.4.3
 - Definition 3.3.27.6, A.3.3.27.6
- Floor area** 7.3.1.2, A.7.3.1.2
 - Gross floor area 7.3.1.2, 36.1.4.2.2, 37.1.4.2.2
 - Definition 3.3.16.2.1, A.3.3.16.2.1
 - Net floor area 7.3.1.2
 - Definition 3.3.16.2.2
- Floor fire door assemblies** 8.3.3.4
 - Definition 3.3.18.1.1
- Floors** *see also* Interior floor finish
 - Fire-resistance ratings Table A.8.2.1.2
 - Opening enclosures 8.6.5, A.8.6.5; *see also* Vertical openings
- Flow time (definition)** 3.3.88
- Fly galleries** 12.4.5.8
 - Definition 3.3.89
- Foamed plastics** *see* Cellular or foamed plastic
- Folding and telescopic seating** *see* Seating
- Folding partitions, doors in** 7.2.1.12
- Food court (definition)** 3.3.37.2
- Food service operations** *see* Cooking equipment/facilities
- Formulas** 1.5
- Foyers** *see* Vestibules
- Free Egress, Use Condition I**
 - Existing detention and correctional occupancies 23.1.4.1(1), 23.1.4.3, A.23.1.4.1, A.23.1.4.3(2)
 - New detention and correctional occupancies 22.1.4.1(1), 22.1.4.3, A.22.1.4.1, A.22.1.4.3
- Fuel load (definition)** 3.3.131.1, A.3.3.131.1
- Fundamental code requirements** 4.5, A.4.5.4
- Furnace rooms, means of egress** 7.12
- Furnishings** 10.2.4.5, 10.3, A.10.3
 - Definition 3.3.36
 - Existing ambulatory health care occupancies ... 21.7.5, A.21.7.5.1
 - Existing assembly occupancies 13.7.3, A.13.7.3.3
 - Existing day-care occupancies 17.7.4
 - Existing detention and correctional occupancies .. 23.7.4, A.23.7.4
 - Existing educational occupancies 15.7.4
 - Existing health care occupancies 19.7.5, A.19.7.5.1
 - Existing hotels and dormitories 29.3.3.4, A.29.3.3.4
 - Existing residential board and care occupancies .. 33.7.5, A.33.7.5
 - Means of egress 7.1.10.2
 - New ambulatory health care occupancies 20.7.5, A.20.7.5.1
 - New assembly occupancies 12.7.3, A.12.7.3.3
 - New day-care occupancies 16.7.4

New detention and correctional occupancies	22.4.4.13, 22.7.4, A.22.4.4.13, A.22.7.4
New educational occupancies	14.7.4
New health care occupancies	18.7.5, A.18.7.5.1
New hotels and dormitories	28.3.3.4, A.28.3.3.4
New residential board and care occupancies	32.7.5, A.32.7.5

-G-

Galleries	7.5.3.1, 7.5.3.2, 12.2.4.8, 12.4.5.9, 13.2.4.8, 13.4.5.9
Fly	12.4.5.8
Definition	3.3.89
Guards/railings	13.2.11.1
Stairs	12.2.2.3.2, 13.2.2.3.2
Gas equipment and piping	9.1.1
General industrial occupancies	<i>see</i> Industrial occupancies
General requirements	4.6, A.4.6
Gift shops	18.3.6.1(4), 19.3.6.1(4)
Goals	
Code	4.1, A.4.1
Definition	3.3.94
Grain storage elevators	7.2.11.1(2), 42.7, A.42.7
Grandstands	
Definition	3.3.95, A.3.3.95
Existing assembly occupancies	13.4.8, 13.7.9
Guards and railings	12.4.8.6, 13.4.8.6
Maintenance of	12.7.10, 13.7.9
New assembly occupancies	12.4.8, 12.7.10
Portable	12.4.8.4, 13.4.8.4
Seating	12.4.8.2, 13.4.8.2
Spaces underneath	12.4.8.5, 13.4.8.5
Wood	12.4.8.3, 13.4.8.3
Gridirons	12.2.4.8, 12.4.5.8, 12.4.5.9, 13.2.4.8, 13.4.5.9
Definition	3.3.96
Stairs	12.2.2.3.2, 13.2.2.3.2
Gross floor area	<i>see</i> Floor area
Gross leasable area	A.7.3.1.2
Definition	3.3.16.3
Group day-care homes	16.6.1.4.1(B), 16.6.1.7.2, 17.6.1.4.1(B), 17.6.1.7.2, 17.6.3.1.1
Guards	
Definition	3.3.99
Existing assembly occupancies	13.2.11.1, 13.4.8.6, 13.4.9.3
Fire escape stairs	7.2.8.5
Means of egress	5.3.2(2), 7.1.8, A.7.1.8
New assembly occupancies	12.2.11.1, 12.4.8.6, 12.4.9.3, A.12.2.11.1.1
Ramps	7.2.5.4
Stairs	7.2.2.4, A.7.2.2.4
Guest rooms	
Building spaces, subdivision of	28.3.7
Definition	3.3.100
Sprinkler systems	28.3.5.2, 29.3.5.5, A.29.3.5.3
Guest suites	
Building spaces, subdivision of	28.3.7
Definition	3.3.101
Sprinkler systems	28.3.5.2, 29.3.5.5

-H-

Hallways, one- and two-family dwellings	24.2.6
Handrails	
Aisles	12.2.5.6.3, 12.2.5.6.7, 13.2.5.6.7, A.12.2.5.6.3, A.12.2.5.6.7, A.13.2.5.6.7
Definition	3.3.102
Fire escape stairs	7.2.8.5
Ramps	7.2.5.4
Stairs	7.2.2.2.3.2(3) to (6), 7.2.2.2.3.3(6), 7.2.2.4, A.7.2.2.4
Hardware	<i>see</i> Fire exit hardware; Panic hardware
Hazard of contents	6.2, A.6.2
Classification	6.2.2, A.6.2.2.1 to A.6.2.2.4
Existing ambulatory health care occupancies	21.1.2.6, 21.1.5

Existing apartment buildings	31.1.5
Existing assembly occupancies	13.1.5
Existing business occupancies	39.1.5
Existing day-care occupancies	17.1.5, 17.6.1.5
Existing detention and correctional occupancies	23.1.2.6, 23.1.2.7, 23.1.5
Existing educational occupancies	15.1.5
Existing health care occupancies	19.1.2.8, 19.1.2.9, 19.1.5
Existing hotels and dormitories	29.1.5
Existing mercantile occupancies	37.1.5
High-rise buildings	11.1.5
Industrial occupancies	40.1.5
Lodging houses	26.1.5
New ambulatory health care occupancies	20.1.2.6, 20.1.2.7, 20.1.5
New apartment buildings	30.1.5
New assembly occupancies	12.1.5
New business occupancies	38.1.5
New day-care occupancies	16.1.5, 16.6.1.5
New detention and correctional occupancies	22.1.2.6, 22.1.2.7, 22.1.5
New educational occupancies	14.1.5
New health care occupancies	18.1.2.8, 18.1.2.9, 18.1.5
New hotels and dormitories	28.1.5
New mercantile occupancies	36.1.5
One- and two-family dwellings	24.1.5
Parking structures	42.8.1.5
Rooming houses	26.1.5
Special hazard protection	8.7, A.8.7
Special structures	11.1.5
Storage occupancies	42.1.5
Hazardous areas	
Definition	3.3.16.4
Detection systems	9.6.2.11
Existing ambulatory health care occupancies	21.3.5.1
Existing apartment buildings	31.3.2.1
Existing assembly occupancies	13.2.5.2
Existing detention and correctional occupancies	23.3.2.1, A.23.3.2.1
Existing health care occupancies	19.3.2.1
Existing hotels and dormitories	29.3.2.2
Existing residential board and care occupancies	33.2.3.2
New ambulatory health care occupancies	20.3.5.1
New apartment buildings	30.3.2.1
New assembly occupancies	13.2.5.2
New detention and correctional occupancies	22.3.2.1, 22.3.2.2, 22.4.4.7, A.22.3.2.1
New health care occupancies	18.3.2.1, A.18.3.2.1
New hotels and dormitories	28.3.2.2
New residential board and care occupancies	32.2.3.2, A.32.2.3.2.1
Smoke partitions enclosing	8.4.2(3)
Hazardous commodities, storage, arrangement, protection, and quantities of	36.4.5.3, 37.4.5.3
Hazardous operations/processes, assembly occupancies	12.3.2.1, 13.3.2.1
Hazards, protection from	
Existing ambulatory health care occupancies	21.3.2, 21.3.5.1
Existing apartment buildings	31.3.2
Existing assembly occupancies	13.3.2
Existing business occupancies	39.3.2, A.39.3.2.1, A.39.3.2.2
Existing day-care occupancies	17.3.2, A.17.3.2(2)
Existing detention and correctional occupancies	23.3.2
Existing educational occupancies	15.3.2
Existing health care occupancies	19.3.2
Existing hotels and dormitories	29.3.2
Existing mercantile occupancies	37.3.2, A.37.3.2.1, A.37.3.2.2
Existing residential board and care occupancies	33.3.3.2
Industrial occupancies	40.3.2, A.40.3.2
Membrane structures, temporary	11.10.2
New ambulatory health care occupancies	20.3.2
New apartment buildings	30.3.2

- New assembly occupancies 12.3.2
- New business occupancies 38.3.2, A.38.3.2.1, A.38.3.2.2
- New day-care occupancies 16.3.2, A.16.3.2.1(2)(a)
- New detention and correctional occupancies 22.3.2
- New educational occupancies 14.3.2
- New health care occupancies 18.3.2, 18.4.3.5, A.18.3.2
- New hotels and dormitories 28.3.2
- New mercantile occupancies 36.3.2, A.36.3.2.1, A.36.3.2.2
- New residential board and care occupancies 32.3.3.2
- Special structures 11.2.3.2, 11.3.3.2, 11.4.3.2
- Tents 11.11.4
- Headroom** 7.1.5, A.7.1.5
- Health care occupancies** *see also* Ambulatory health care occupancies; Existing health care occupancies; New health care occupancies
- Classification of occupancy 6.1.5, 18.1.4, 19.1.4, 20.1.4, 21.1.4, A.6.1.5.1
- Definition 3.3.152.7, 6.1.5.1, A.3.3.152.7, A.6.1.5.1
- Occupant load factor Table 7.3.1.2
- Heating, ventilating, and air conditioning** 9.2; *see also* Ventilation
- Ambulatory health care occupancies 20.5.2, 21.5.2
- Apartment buildings 30.5.2, 31.5.2
- Assembly occupancies 12.5.2, 13.5.2
- Business occupancies 38.5.2, 39.5.2
- Day-care occupancies 16.5.2, 17.5.2
- Detention and correctional occupancies 22.5.2, 23.5.2
- Educational occupancies 14.5.2, 15.5.2
- Health care occupancies 18.5.2, 19.5.2, A.18.5.2.2, A.19.5.2.2
- Hotels and dormitories 28.5.2, 29.5.2
- Industrial occupancies 40.5.2
- Lodging houses 26.5.2
- Mercantile occupancies 36.5.2, 37.5.2
- One- and two-family dwellings 24.5.1
- Parking structures 42.8.5.2
- Residential board and care occupancies 32.2.5.2, 32.3.6.2, 33.2.5.2, 33.3.6.2
- Rooming houses 26.5.2
- Shutdown 9.6.3.2.2, A.9.6.3.2.2
- Storage occupancies 42.5.2
- Heating equipment**
- Electric heaters 11.9.5.2, 11.10.7.2, 11.11.6.2
- Fired heaters 11.9.5.1, 11.10.7.1, 11.11.6.1
- Portable space 18.7.8, 19.7.8, 20.7.8, 21.7.8, 22.5.2.2, 22.7.6, 23.5.2.2, 23.7.6
- Unvented fuel-fired 16.5.2.2, 17.5.2.2, 24.5.1.2, 28.5.2.2, 29.5.2.2, 32.2.5.2.3, 33.2.5.2.3
- Heat release rate (HRR) (definition)** 3.3.106, A.3.3.106
- Heliports, health care occupancies** 18.3.2.6
- High hazard contents** 6.2.2.4, A.6.6.2.4
- High hazard contents occupancies** 7.11, A.7.11.1
- High hazard industrial occupancies** *see* Industrial occupancies
- High hazard storage occupancies** 42.3.4.3.4
- High-rise buildings** 11.8
- Central control station 11.8.5, A.11.8.5
- Classification of occupancy 11.1.4
- Definition 3.3.27.7, A.3.3.27.7
- Detection/alarm/communication systems 11.8.3, A.11.8.3.1
- Emergency lighting 11.8.4, A.11.8.4.2(A)
- Existing apartment buildings 31.2.11, 31.3.5.10, 31.4.1
- Existing assembly occupancies 13.4.4
- Existing business occupancies 39.4.2, A.39.4.2.2
- Existing day-care occupancies Table 17.1.6, 17.4.2
- Existing detention and correctional occupancies 23.3.5.1, 23.4.3
- Existing educational occupancies 15.4.2
- Existing hotels and dormitories 29.3.5.1, 29.4.1
- Existing residential board and care occupancies 33.3.3.5.2
- Extinguishment requirements 11.8.2, A.11.8.2.1
- General requirements 11.8.1
- Hazard of contents, classification of 11.1.5
- Industrial occupancies 40.4
- New apartment buildings 30.4.1
- New assembly occupancies *see* 12.4.4
- New business occupancies 38.4.2, A.38.4.2
- New day-care occupancies Table 16.1.6.1, 16.4.2
- New detention and correctional occupancies 22.3.5.1, 22.4.3
- New educational occupancies 14.4.2
- New health care occupancies 18.2.2.2.8, 18.4.2
- New hotels and dormitories 28.4.1
- New mercantile occupancies 36.4.2
- New residential board and care occupancies 32.3.3.4.5, 32.3.3.9.2
- Standby power 11.8.4, A.11.8.4.2(A)
- Storage occupancies 42.4.1
- Historic buildings**
- Definition 3.3.27.8, A.3.3.27.8
- General requirements 4.6.3, A.4.6.3
- Homes**
- Day-care *see* Day-care homes
- Nursing *see* Nursing homes
- Horizontal exits** 7.2.4, A.7.2.4
- Accessible means of egress 7.5.4.6
- Aircraft servicing hangars 40.6.2
- Aircraft storage hangars 42.6.1.3
- Bridges/balconies 7.2.4.4
- Definition 3.3.62.1, A.3.3.62.1
- Doors 7.2.4.3.6 to 7.2.4.3.10, A.7.2.4.3.8, A.7.2.4.3.9
- Existing apartment buildings 31.2.2.5
- Existing assembly occupancies 13.2.2.5
- Existing business occupancies 39.2.2.5
- Existing day-care occupancies 17.2.2.5
- Existing detention and correctional occupancies 23.2.2.5, A.23.2.2.5.2, A.23.2.2.5.3
- Existing educational occupancies 15.2.2.5
- Existing health care occupancies 19.1.2.5, 19.2.2.5, 19.2.3.2, A.19.2.2.5.3
- Existing hotels and dormitories 29.2.2.5
- Existing mercantile occupancies 37.2.2.5
- Existing residential board and care occupancies 33.3.2.2.5
- Fire barriers 7.2.4.3, A.7.2.4.3.8, A.7.2.4.3.9
- Fire compartments 7.2.4.2
- Industrial occupancies 40.2.2.5, 40.6.1.3, A.40.2.2.5.2
- New apartment buildings 30.2.2.5
- New assembly occupancies 12.2.2.5
- New business occupancies 38.2.2.5
- New day-care occupancies 16.2.2.5
- New detention and correctional occupancies 22.1.2.5, 22.2.2.5, 22.4.4.3, A.22.2.2.5.2, A.22.4.4.3
- New educational occupancies 14.2.2.5
- New health care occupancies 18.1.2.5, 18.2.2.5
- New hotels and dormitories 28.2.2.5
- New mercantile occupancies 36.2.2.5
- New residential board and care occupancies 32.3.2.2.5
- Opening protectives, fire protection ratings for Table 8.3.4.2
- Parking structures 42.8.2.2.5
- Storage occupancies 42.2.2.5, A.42.2.2.5.2
- Horizontal-sliding doors** 7.2.1.14
- Hospitals** *see also* Health care occupancies
- Accumulation space 18.2.2.5.1.1, 18.3.7.6.1, 19.2.2.5.1.1, 19.3.7.4.1
- Changes of occupancy 18.1.1.4.5, 19.1.1.4.5
- Definition 3.3.112
- Means of egress, capacity of 19.2.3
- Hotels and dormitories** *see also* Existing hotels and dormitories; New hotels and dormitories
- Classification of occupancy 28.1.4, 29.1.4
- Definitions
- Dormitory 3.3.48, 6.1.8.1.4, A.3.3.48, A.6.1.8.1.4
- Hotel 3.3.113, 6.1.8.1.3, A.3.3.113, A.6.1.8.1.3
- Multiple occupancies, classrooms 14.1.2.3, 15.1.2.3
- Occupant load factor Table 7.3.1.2
- Hyperbaric facilities** 8.7.5, A.8.7.5

-I-

Identification signs	<i>see also</i> Means of egress marking
Areas of refuge	7.2.12.3.5
Delayed egress locks	7.2.1.6.1(4), A.7.2.1.6.1(4)
Elevator	7.10.8.4, A.7.10.8.4
Occupant load, assembly occupancy	12.7.8.3, 13.7.8.3
Stairs	7.2.2.5.4, A.7.2.2.5.4
Illuminated	<i>see also</i> Emergency Lighting; Means of egress illumination
Externally illuminated	7.10.1.5.2, 7.10.1.6, 7.10.5.1, 7.10.6, A.7.10.5.1, A.7.10.6
Definition	3.3.114.1, A.3.3.114.1
Internally illuminated	7.1.10.1.7, 7.10.1.7, 7.10.5.1, 7.10.7, A.7.10.5.1, A.7.10.7.2
Definition	3.3.114.2, A.3.3.114.2
Impeded Egress, Use Condition IV	
Existing detention and correctional occupancies	23.1.4.1(4), 23.1.4.2, A.23.1.4.1, A.23.1.4.2
New detention and correctional occupancies	22.1.4.1(4), 22.1.4.2, A.22.1.4.1, A.22.1.4.2
Impractical evacuation capability	<i>see</i> Evacuation capability
Improvement operations	4.6.11, A.4.6.11.1, A.4.6.11.2; <i>see also</i> Construction; Renovation
Ambulatory health care occupancies	20.1.1.4.4, 20.7.9, 21.1.1.4.4, 21.7.9
Health care occupancies	18.1.1.4.7, 18.7.9, 19.1.1.4.7, 19.7.9
Incapacitation (definition)	3.3.116
Incinerators	9.5
Existing ambulatory health care occupancies	21.5.4
Existing apartment buildings	31.5.4
Existing assembly occupancies	13.5.4
Existing business occupancies	39.5.4
Existing day-care occupancies	17.5.4
Existing detention and correctional occupancies	23.5.4
Existing educational occupancies	15.5.4
Existing health care occupancies	19.5.4
Existing hotels and dormitories	29.5.4
Existing mercantile occupancies	37.5.4
Existing residential board and care occupancies	33.3.6.4
Industrial occupancies	40.5.4
New ambulatory health care occupancies	20.5.4
New apartment buildings	30.5.4
New assembly occupancies	12.5.4
New business occupancies	38.5.4
New day-care occupancies	16.5.4
New detention and correctional occupancies	22.5.4
New educational occupancies	14.5.4
New health care occupancies	18.5.4
New hotels and dormitories	28.5.4
New mercantile occupancies	36.5.4
New residential board and care occupancies	32.3.6.4
Parking structures	42.8.5.4
Storage occupancies	42.5.4
Industrial occupancies	Chap. 40
Aircraft servicing hangars, provisions for	40.6, A.40.6
Alternating tread devices	40.2.2.12
Ancillary facilities, means of egress arrangement	40.2.5.1
Application	40.1.1
Areas of refuge	40.2.2.13
Building services	40.5
Classification of occupancy	6.1.12, 40.1.4, A.6.1.12.1
Corridors	40.3.6
Definition	3.3.152.8, 6.1.12.1, A.3.3.152.8, A.6.1.12.1
Detection/alarm/communication systems	40.3.4
Doors	40.2.2.2
Elevators/escalators/conveyors	40.5.3
Emergency lighting	40.2.9, A.40.2.9
Escalators/moving walks	40.2.2.8
Exit discharge	40.2.7
Exit passageways	40.2.2.7
Exits, horizontal	40.2.2.5, 40.6.1.3, A.40.2.2.5.2
Exits, number of	40.2.4
Exit travel distance	40.2.6
Extinguishment requirements	40.4
Fire escape ladders	40.2.2.10
Fire escape stairs	40.2.2.9
General	40.1.4.1(1)
Definition	3.3.152.8.1, A.3.3.152.8.1
High-rise buildings	40.4
Occupant load factor	Table 7.3.1.2
General requirements	40.1
Hazard of contents, classification of	40.1.5
Hazards, protection from	40.3.2, A.40.3.2
Heating, ventilating, and air conditioning	40.5.2
High hazard	40.1.4.1(3), 40.3.4.3.4, A.40.1.4.1(3)
Definition	3.3.152.8.2, A.3.3.152.8.2
Occupant load factor	Table 7.3.1.2
High-rise buildings	40.4
Interior finish	40.3.3
Means of egress arrangement	40.2.5, A.40.2.5.5.1, A.40.2.5.5.2
Means of egress capacity	40.2.3
Means of egress components	40.2.2
Means of egress illumination	40.2.8
Means of egress marking	40.2.10
Means of egress requirements	40.2, 40.6.1, 40.6.2
Multiple occupancies	40.1.2
Occupant load	Table 7.3.1.2, 40.1.7, A.40.1.7
Protection	40.3
Ramps	40.2.2.6
Rubbish/laundry chutes, incinerators	40.5.4
Slide escapes	40.2.2.11
Smokeproof enclosures	40.2.2.4
Special industrial occupancies	8.6.9.2.1
Special provisions	40.4
Special-purpose	40.1.4.1(2), 40.4
Definition	3.3.152.8.3
Stairs	40.2.2.3
Utilities	40.5.1
Vertical openings, protection of	40.3.1
Input data specifications	5.4.2.1 to 5.4.2.3, 5.5.4.1 to 5.5.4.3
Definition	3.3.208.2
Inspections	
Day-care occupancies	16.7.3, 17.7.3, A.16.7.3.2, A.17.7.3.2
Educational occupancies	14.7.3, 15.7.3, A.14.7.3.1
Interior ceiling finish	<i>see</i> Interior wall/ceiling finish
Interior finish	Chap. 10
Apartment buildings as board and care occupancies	32.4.3.1, 33.4.3.1
Automatic sprinkler requirements	10.1.2, 10.2.8
Classification of	10.2.3, 10.2.7, Table A.10.2.2, A.10.2.3, A.10.2.7.2, A.10.2.7.3
Definition	3.3.120, A.3.3.120
Existing ambulatory health care occupancies	21.3.3
Existing apartment buildings	31.3.3
Existing assembly occupancies	13.3.3, 13.4.7.8, 13.7.4.3.4
Existing business occupancies	39.3.3
Existing day-care homes	17.6.3.3
Existing day-care occupancies	17.3.3
Existing detention and correctional occupancies	23.3.3
Existing educational occupancies	15.3.3
Existing health care occupancies	19.3.3, A.19.3.3.2
Existing hotels and dormitories	29.3.3
Existing mercantile occupancies	37.3.3
Existing residential board and care occupancies	33.2.3.3, 33.3.3.3, 33.4.3.1
Exits	7.1.4, A.7.1.4.1, A.7.1.4.2
Fire-retardant coatings	10.2.6, A.10.2.6
General	10.1, 10.2.1, A.10.2
Industrial occupancies	40.3.3
Lodging houses	26.3.2
New ambulatory health care occupancies	20.3.3
New apartment buildings	30.3.3
New assembly occupancies	12.3.3, 12.4.7.8, 12.7.4.3.4

- New business occupancies 38.3.3
 New day-care homes 16.6.3.3
 New day-care occupancies 16.3.3
 New detention and correctional occupancies 22.3.3, 22.4.4.8
 New educational occupancies 14.3.3
 New health care occupancies 18.3.3, 18.4.3.6, A.18.3.3.2
 New hotels and dormitories 28.3.3
 New mercantile occupancies 36.3.3
 New residential board and care occupancies 32.2.3.3, 32.3.3.3, 32.4.3.1
 One- and two-family dwellings 24.3.3
 Parking structures 42.8.3.3
 Rooming houses 26.3.2
 Special amusement buildings 12.4.7.8, 13.4.7.8
 Special structures 11.2.3.3, 11.3.3.3, 11.4.3.3
 Specific materials 10.2.4, A.10.2.4
 Storage occupancies 42.3.3
 Testing 10.2.3, 10.2.7, A.10.2.3, A.10.2.7.2, A.10.2.7.3
 Trim/incidental 10.2.5
 Use of 10.2.2, A.10.2.2
- Interior floor finish**
 Definition 3.3.120.2, A.3.3.120.2
 Existing apartment buildings 31.3.3.3
 Existing detention and correctional occupancies 23.3.3.3
 Existing health care occupancies 19.3.3.3
 Existing hotels and dormitories 29.3.3.3
 Existing residential board and care occupancies 33.3.3.3
 Exits 7.1.4.2, A.7.1.4.2
 Industrial occupancies 40.3.3.3
 New apartment buildings 30.3.3.3
 New assembly occupancies 12.3.3.5
 New business occupancies 38.3.3.3
 New day-care homes 16.6.3.3
 New day-care occupancies 16.3.3.3
 New detention and correctional occupancies 22.3.3.3, 22.4.4.8.2
 New educational occupancies 14.3.3.3
 New health care occupancies 18.4.3.6.3
 New hotels and dormitories 28.3.3.3
 New mercantile occupancies 36.3.3.3
 New residential board and care occupancies 32.2.3.3.3, 32.3.3.3.3, A.32.3.3.3
 Parking structures 42.8.3.3.3
 Sprinklers, automatic 10.1.2, 10.2.8.2
 Storage occupancies 42.3.3.3
 Testing and classification 10.2.7, A.10.2.7.2, A.10.2.7.3
 Use of 10.2.2.2, A.10.2.2.2
- Interior wall/ceiling finish** 10.2.2.1
 Cellular or foamed plastic 10.2.4.3
 Definitions 3.3.120.1, 3.3.120.3
 Existing apartment buildings 31.3.3.2
 Existing assembly occupancies 13.3.3.2, 13.3.3.3, 13.4.7.8, 13.7.4.3.4
 Existing business occupancies 39.3.3.2
 Existing day-care homes 17.6.3.3.2
 Existing day-care occupancies 17.3.3.2
 Existing detention and correctional occupancies 23.3.3.2
 Existing educational occupancies 15.3.3.2
 Existing health care occupancies 19.3.3.2, A.19.3.3.2
 Existing hotels and dormitories 29.3.3.2
 Existing mercantile occupancies 37.3.3.2
 Existing residential board and care occupancies 33.2.3.3, 33.3.3.3.2
 Exits 7.1.4.1, A.7.1.4.1
 Expanded vinyl 10.2.4.2, A.10.2.4.2
 Fire-retardant coatings 10.2.6, A.10.2.6
 Industrial occupancies 40.3.3.2
 Light-transmitting plastics 10.2.4.4, A.10.2.4.4
 Lodging houses 26.3.2.2
 New apartment buildings 30.3.3.2
 New assembly occupancies 12.3.3.2, 12.3.3.3, 12.4.7.8, 12.7.4.3.4
- New business occupancies 38.3.3.2
 New day-care homes 16.6.3.3.2
 New day-care occupancies 16.3.3.2
 New detention and correctional occupancies 22.3.3.2, 22.4.4.8.1
 New educational occupancies 14.3.3.2
 New health care occupancies 18.3.3.2, 18.4.3.6.2, A.18.3.3.2
 New hotels and dormitories 28.3.3.2
 New mercantile occupancies 36.3.3.2
 New residential board and care occupancies 32.2.3.3.2, 32.3.3.3.2
 One- and two-family dwellings 24.3.3.2
 Parking structures 42.8.3.3.2
 Rooming houses 26.3.2.2
 Sprinklers, automatic 10.1.2, 10.2.8.1
 Storage occupancies 42.3.3.2
 Testing and classification 10.2.3, A.10.2.3
 Textiles 10.2.4.1, 12.7.4.3.4(4), 13.7.4.3.4, A.10.2.4.1
 Trim and incidental finish 10.2.5
- Internally illuminated** *see* Illuminated
- J-**
- Joints**
 Smoke barriers 8.5.6, 18.3.7.11, 19.3.7.9, 21.3.7.14, 22.3.7.13, 23.3.7.13, A.18.3.7.11, A.19.3.7.9, A.21.3.7.14, A.22.3.7.13, A.23.3.7.13
 Smoke partitions 8.4.2(2), 8.4.5, A.8.4.2(2)
- K-**
- Keys** 22.2.11.6, 22.2.11.7.2(2), 22.7.5, 23.2.11.6, 23.2.11.7.2, 23.7.5, A.22.1.2.2.2, A.23.1.2.2.1; *see also* Locks/latches
- Kiosks, mercantile occupancies** 36.4.4.8, 37.4.4.8
- L-**
- Labeled (definition)** 3.2.4
- Laboratories**
 Existing ambulatory health care occupancies 21.3.2.2
 Existing health care occupancies 19.3.2.2, A.19.3.2.2
 New ambulatory health care occupancies 20.3.2.2
 New health care occupancies 18.3.2.2, A.18.3.2.2
 Special hazard protection 8.7.4
 Ventilating systems 9.2.4
- Ladders** *see* Fire escape ladders
- Landings**
 Areas of refuge 7.2.12.2.3
 One- and two-family dwellings 24.2.5.4
 Ramps 7.2.5.3.2
 Stair 7.2.2.3.1.2, 7.2.2.3.2, 7.2.2.3.3, A.7.2.2.3.3.2
- Laundry chutes** *see* Chutes, laundry or rubbish
- Legitimate stage** 12.4.5.3.2; *see also* Stages
- Definition** 3.3.210.1
- Level of exit discharge (definition)** 3.3.64.1
- Life safety compliance options** 4.4
- Life safety evaluation**
 Definition 3.3.126
 Existing assembly occupancies 13.1.7.3, 13.4.1, 13.4.2.2, A.13.4.1.1, A.13.4.1.3
 New assembly occupancies 12.1.7.3, 12.4.1, 12.4.2.2, A.12.4.1.1
- Lighting** *see* Emergency lighting; Means of egress illumination
- Light-transmitting plastics** 10.2.4.4, A.10.2.4.4
- Limited access structures**
 Assembly occupancies 12.4.3, 13.4.3
 Business occupancies 38.4.1, 39.4.1
 Day-care occupancies 16.4.1, 17.4.1
 Definition 3.3.217.3
 Detention and correctional occupancies 22.4.1, 22.4.4.12, 23.4.1, A.22.4.4.12.2(2), A.23.4.1.2(2)
 Educational occupancies 14.4.1, 15.4.1
 Health care occupancies 18.4.1, 19.4.1
 Mercantile occupancies 36.4.1, 37.4.1
 Special provisions 11.7, A.11.7.2

Limited care facilities	<i>see also</i> Health care occupancies
Accumulation space	18.2.2.5.1.1, 18.3.7.6.1, 19.2.2.5.1.1, 19.3.7.4.1
Changes of occupancy	18.1.1.4.5(3), 19.1.1.4.5(3)
Corridors	18.3.6.1(5), 19.3.6.1(5)
Definition	3.3.69.2, A.3.3.69.2
Limited-combustible (material) (definition)	3.3.135.2, A.3.3.135.2
Listed (definition)	3.2.5, A.3.2.5
Living area (definition)	3.3.16.5
Load	
Fuel (definition)	3.3.131.1, A.3.3.131.1
Occupant	<i>see</i> Occupant load
Locks/latches	
Ambulatory health care occupancies	20.2.2.2, 21.2.2.2
Apartment buildings	30.2.2.2.2, 31.2.2.2.2, A.30.2.2.2.2.1
Assembly occupancies	12.2.2.2.3 to 12.2.2.2.5, 13.2.2.2.3 to 13.2.2.2.5
Business occupancies	38.2.2.2.2, 38.2.2.2.4, 39.2.2.2.2 to 39.2.2.2.4, A.38.2.2.2.2, A.39.2.2.2.2
Day-care occupancies	16.2.2.2.3 to 16.2.2.2.5, 17.2.2.2.3 to 17.2.2.2.5, A.16.2.2.2.4, A.17.2.2.4
Detention and correctional occupancies	22.2.11.6 to 22.2.11.11, 23.2.11.6 to 23.2.11.8, A.22.1.2.2.2
Doors	7.2.1.5, 7.2.1.6, 9.6.5.2(5)
Educational occupancies	14.2.2.2.2, 14.2.2.2.3, 15.2.2.2.2, 15.2.2.2.3
Emergency power for	22.2.11.11
Health care occupancies	18.2.2.2.2 to 18.2.2.2.5, 18.7.3.2, 19.2.2.2.2 to 19.2.2.2.5, A.18.2.2.2.4(2), A.19.2.2.2.4(2)
Hotels and dormitories	28.2.2.2.2, 29.2.2.2.2
Industrial occupancies	40.2.2.2.2
Lodging or rooming houses	26.2.3.3 to 26.2.3.5
Mercantile occupancies	36.2.2.2.2, 36.2.2.2.4, 37.2.2.2.2, 37.2.2.2.4, A.36.2.2.2.2, A.37.2.2.2.2
One- and two-family dwellings	24.2.4.4, 24.2.4.5, 24.2.4.7, 24.2.4.10, A.24.2.4.7
Remote release	22.2.11.7 to 22.2.11.11, 23.2.11.7, 23.2.11.8, A.22.2.11.7, A.23.2.11.7
Residential board and care occupancies	32.2.2.5.4 to 32.2.2.5.8, 32.3.2.2.2, 33.2.2.5.4 to 33.2.2.5.8, 33.3.2.2.2
Storage occupancies	42.2.2.2.2
Lodging or rooming houses	Chap. 26
Application	26.1.1, A.26.1.1.1
Building services	26.5
Classification of occupancy	26.1.4
Definition	3.3.132, 6.1.8.1.2, A.6.1.8.1.1
Detection/alarm/communication systems	26.3.3, A.26.3.3.3.1
Doors	26.2.3
Elevators/escalators/conveyors	26.5.3
Extinguishment requirements	26.3.5, A.26.3.5.3.3
General requirements	26.1, A.26.1.1.1
Hazard of contents, classification of	26.1.5
Heating, ventilating, and air conditioning	26.5.2
Interior finish	26.3.2
Means of escape	26.2
Multiple occupancies	26.1.2
Occupant load	26.1.7
Protection	26.3, A.26.3
Separation of sleeping rooms	26.3.4
Stairs	26.2.2
Utilities	26.5.1
Vertical openings, protection of	26.3.1, A.26.3.1.2
Low hazard contents	6.2.2.2, A.6.2.2.2

-M-

Main entrances, assembly occupancies	12.2.3.6, 13.2.3.6, A.12.2.3.6.5, A.13.2.3.6.5
Maintenance	<i>see also</i> Testing
Alarms and alarm systems	9.6.1.3, 9.6.1.6, 9.6.1.9, 9.6.1.10
Ambulatory health care occupancies	20.7.3, 20.7.6, 21.7.3, 21.7.6
Elevators	7.2.13.10

Exits	18.7.3, 19.7.3, 20.7.3, 21.7.3
Exit signs	7.10.9
Folding and telescopic seating	12.7.10
Fundamental requirements	4.5.7
General requirements	4.6.13, A.4.6.13.2
Grandstands	12.7.9
Health care occupancies	18.7.3, 18.7.6, 19.7.3, 19.7.6
Membrane structures	
Permanent	11.9.4
Temporary	11.10.6
Rubbish chutes, laundry chutes, and incinerators	9.5.2
Smoke control systems	9.3.1, A.9.3.1
Sprinkler systems	9.7.5
Standpipes	9.7.5
Mall (definition)	3.3.133
Mall buildings	12.1.2.3, 13.1.2.3, 36.4.4, 37.4.4, A.36.4.4, A.37.4.4
Definition	3.3.27.9, A.3.3.27.9
Detection/alarm/communication systems	36.4.4.4, 37.4.4.4
Emergency control	36.4.4.4.4, 37.4.4.4.4
Emergency lighting	36.2.9, 37.4.4.3.8
Means of egress details	36.4.4.3, 37.4.4.3, A.36.4.4.3.5, A.36.4.4.3.7
Occupant load	Fig. 7.3.1.2(a), Fig. 7.3.1.2(b), Table 7.3.1.2, A.7.3.1.2
Occupant notification	9.6.3.6.4
Manual alarm stations	9.6.2.1 to 9.6.2.6
Detention and correctional occupancies	22.3.4.2, 22.4.4.9.1, 23.3.4.2
Educational occupancies	14.3.4.2.3, 15.3.4.2.3, A.14.3.4.2.3.1, A.15.3.4.2.3.1
Health care occupancies	18.7.2.3.3, 19.7.2.3.3, A.9.6.2.6
Mercantile occupancies	36.3.4.2(1), 37.3.4.2(1)
Residential board and care occupancies	32.2.3.4.1, 32.3.3.4.2, 33.2.3.4.1, 33.3.3.4.2
Manual extinguishing equipment	9.7.4; <i>see also</i> Extinguishers, portable fire
Marking	<i>see</i> Means of egress marking
Material	
Combustible (definition)	3.3.135.1
Limited-combustible (definition)	3.3.135.2, A.3.3.135.2
Noncombustible (definition)	3.3.135.3
Weathered-membrane (definition)	3.3.135.4
Means of egress	Chap. 7; <i>see also</i> Exits
Accessible	<i>see</i> Accessible means of egress
Aircraft servicing hangars	40.6.1, 40.6.2
Aircraft storage hangars	42.6
Alarms on	7.1.9
Application	7.1.1, A.7.1.1
Awareness of	4.5.3.3
Definition	3.3.136, A.3.3.136
Fundamental requirements	<i>see</i> Means of egress requirements
Furnishings/decoration	7.1.10.2
General	7.1, A.7.1
Guards	7.1.8, A.7.1.8
Headroom	7.1.5, A.7.1.5
High hazard occupancies, special provisions	7.11, A.7.11.1
Illumination	7.8, A.7.8
Impediments to egress	5.3.2(9), 7.1.9, 7.1.10, 7.5.2, A.7.1.10.1, A.7.5.2.2
Level, changes in	5.3.2(1), 7.1.7, A.7.1.7.2
Lighting	<i>see</i> Means of egress illumination
Mechanical equipment/boiler/furnace rooms	7.12
Number of	<i>see</i> Exits, number of
Obstructions to	<i>see</i> subheading: Impediments to egress
Performance-based design option	5.3.2
Reliability	7.1.10, A.7.1.10.1
Separation	7.1.3, A.7.1.3.2.1, A.7.1.3.2.3
Unobstructed	4.5.3.2
Walking surfaces	7.1.6, A.7.1.6.4
Elevation, changes in	7.1.6.2
Level	7.1.6.3
Slip resistance	7.1.6.4, A.7.1.6.4

- Width
 Measurement of 7.3.2
 Minimum 7.3.4, A.7.3.4.1.1
- Means of egress arrangement** 7.5, A.7.5
- Accessible *See* Accessible means of egress
- Existing ambulatory health care occupancies 21.2.5
- Existing apartment buildings 31.2.5
- Existing assembly occupancies 13.2.5, A.13.2.5
- Existing business occupancies 39.2.5, A.39.2.5.2, A.39.2.5.3
- Existing day-care homes 17.6.2.5
- Existing day-care occupancies 17.2.5
- Existing detention and correctional occupancies 23.2.5, A.23.2.5.2
- Existing educational occupancies 15.2.5
- Existing health care occupancies 19.2.5, A.19.2.5.10
- Existing hotels and dormitories 29.2.5
- Existing mercantile occupancies 37.2.5, A.37.2.5.2, A.37.2.5.3, A.37.2.5.10
- Existing residential board and care occupancies 33.3.2.5
- Exit access, exterior ways of 7.5.3
- Industrial occupancies 40.2.5, A.40.2.5.5.1, A.40.2.5.5.2
- New ambulatory health care occupancies 20.2.5
- New apartment buildings 30.2.5
- New assembly occupancies 12.2.5, A.12.2.5
- New business occupancies 38.2.5
- New day-care homes 16.6.2.5
- New day-care occupancies 16.2.5
- New detention and correctional occupancies 22.2.5
- New educational occupancies 14.2.5, A.14.2.5.8
- New health care occupancies 18.2.5
- New hotels and dormitories 28.2.5
- New mercantile occupancies 36.2.5, A.36.2.5.10
- New residential board and care occupancies 32.3.2.5
- Parking structures 42.8.2.5
- Special structures 11.2.2.5, 11.3.2.5, 11.4.2.5, 11.5.3
- Storage occupancies 42.2.5
- Means of egress capacity** 7.3, A.7.3.1.2, A.7.3.4.1.1
- Communicating spaces 8.6.6(6)
- Existing ambulatory health care occupancies 21.2.3
- Existing apartment buildings 31.2.3
- Existing assembly occupancies 13.2.3, A.13.2.3.2, A.13.2.3.6.5
- Existing business occupancies 39.2.3
- Existing day-care occupancies 17.2.3
- Existing detention and correctional occupancies 23.2.3
- Existing educational occupancies 15.2.3
- Existing health care occupancies 19.2.3, A.19.2.3.4
- Existing hotels and dormitories 29.2.3
- Existing mercantile occupancies 37.2.3
- Existing residential board and care occupancies 33.3.2.3
- Industrial occupancies 40.2.3
- New ambulatory health care occupancies 20.2.3
- New apartment buildings 30.2.3
- New assembly occupancies 12.2.3, A.12.2.3.2, A.12.3.6.5
- New business occupancies 38.2.3, A.38.2.3.2
- New day-care occupancies 16.2.3
- New detention and correctional occupancies 22.2.3
- New educational occupancies 14.2.3
- New health care occupancies 18.2.3, 18.4.3.3, A.18.2.3.4, A.18.2.3.5
- New hotels and dormitories 28.2.3, A.28.2.3.3
- New mercantile occupancies 36.2.3
- New residential board and care occupancies 32.3.2.3
- Occupant load 7.3.1, A.7.3.1.2, Table A.7.3.1.2
- Parking structures 42.8.2.3
- Performance-based design option 5.3.2(8)
- Special structures 11.2.2.3, 11.3.2.3, 11.4.2.3
- Storage occupancies 42.2.3
- Width
 Measurement of 7.3.2
 Minimum 7.3.4, A.7.3.4.1.1
- Means of egress components** 7.2, A.7.2;
see also specific components, e.g. Alternating tread devices
- Existing ambulatory health care occupancies 21.2.2
- Existing apartment buildings 31.2.2, A.31.2.2.8, A.31.2.2.12.2
- Existing assembly occupancies 13.2.2
- Existing business occupancies 39.2.2
- Existing day-care occupancies 17.2.2, A.17.2.2.4, A.17.2.2.3
- Existing detention and correctional occupancies 23.2.2, A.23.2.2.5.2, A.23.2.2.5.3
- Existing educational occupancies 15.2.2, A.15.2.2.3
- Existing health care occupancies 19.2.2, A.19.2.2
- Existing hotels and dormitories 29.2.2, A.29.2.2.12.2
- Existing mercantile occupancies 37.2.2
- Existing residential board and care occupancies 33.3.2.2
- Industrial occupancies 40.2.2
- New ambulatory health care occupancies 20.2.2
- New apartment buildings 30.2.2, A.30.2.2.2.1, A.30.2.2.12.2
- New assembly occupancies 12.2.2
- New business occupancies 38.2.2
- New day-care occupancies 16.2.2, A.16.2.2.4, A.16.2.2.3
- New detention and correctional occupancies 22.2.2, A.22.2.2.5.2
- New educational occupancies 14.2.2, A.14.2.2.3
- New health care occupancies 18.2.2, A.18.2.2
- New hotels and dormitories 28.2.2, A.28.2.2.12.2
- New mercantile occupancies 36.2.2
- New residential board and care occupancies 32.3.2.2
- Parking structures 42.8.2.2
- Special structures 11.2.2.2, 11.3.2.2, 11.4.2.2
- Storage occupancies 42.2.2, 42.8.2.2
- Means of egress illumination** 4.5.3.4, 7.8, A.7.8;
see also Emergency lighting
- Existing ambulatory health care occupancies 21.2.8
- Existing apartment buildings 31.2.8
- Existing assembly occupancies 13.2.8, 13.4.7.6
- Existing business occupancies 39.2.8
- Existing day-care homes 17.6.2.8
- Existing day-care occupancies 17.2.8
- Existing detention and correctional occupancies 23.2.8
- Existing educational occupancies 15.2.8
- Existing health care occupancies 19.2.8
- Existing hotels and dormitories 29.2.8
- Existing mercantile occupancies 37.2.8
- Existing residential board and care occupancies 33.3.2.8
- Industrial occupancies 40.2.8
- New ambulatory health care occupancies 20.2.8
- New apartment buildings 30.2.8
- New assembly occupancies 12.2.8, 12.4.7.5
- New business occupancies 38.2.8
- New day-care occupancies 16.2.8, 16.6.2.8
- New detention and correctional occupancies 22.2.8
- New educational occupancies 14.2.8
- New health care occupancies 18.2.8
- New hotels and dormitories 28.2.8
- New mercantile occupancies 36.2.8
- New residential board and care occupancies 32.3.2.8
- Parking structures 42.8.2.8
- Performance-based design option 5.3.2(10)
- Photoluminescent signs 7.10.7.2, A.7.10.7.2
- Power source 7.10.4, A.7.10.4
- Signs 7.10.1.5 to 7.10.1.8, 7.10.4 to 7.10.7, 7.10.8.1, 7.10.9, A.7.10.1.5.2, A.7.10.1.6 to A.7.10.1.8, A.7.10.4 to A.7.10.7
- Sources 7.8.2, A.7.8.2.1
- Special structures 11.2.2.8, 11.3.2.8, 11.4.2.8
- Storage occupancies 42.2.8
- Means of egress marking** 7.10, A.7.10
- Aisles 12.2.5.6.8, A.12.2.5.6.8
- Directional signs and indicators 7.10.2, 7.10.6.2, A.7.10.2, A.7.10.6.2
- Elevator signs 7.10.8.4, A.7.10.8.4
- Existing ambulatory health care occupancies 21.2.10
- Existing apartment buildings 31.2.10

Existing assembly occupancies	13.2.10	New detention and correctional occupancies	22.1.2.2
Existing business occupancies	39.2.10	to 21.1.2.5, 22.2, A.22.1.2.2.2, A.22.2	
Existing day-care occupancies	17.2.10	New educational occupancies	14.2, 14.7.3, A.14.2, A.14.7.3.1
Existing detention and correctional occupancies	23.2.10	New health care occupancies	18.1.2.4 to 18.1.2.7,
Existing educational occupancies	15.2.10	18.2, 18.4.3.3, 18.4.3.4, A.18.2	
Existing health care occupancies	19.2.10	New hotels and dormitories	28.2, A.28.2
Existing hotels and dormitories	29.2.10	New mercantile occupancies	36.2, 36.4.4.3, 36.4.5.2,
Existing mercantile occupancies	37.2.10	A.36.4.4.3.5, A.36.4.4.3.7	
Existing residential board and care occupancies	33.3.2.10	New residential board and care occupancies	32.1.4, 32.3.2,
Exit access, marking of	7.10.1.5, A.7.10.1.5.2	32.4.2	
Exit discharge	7.7.3	Parking structures	42.8.2
Floor proximity egress path marking	7.10.1.7, A.7.10.1.7	Special structures	11.2.2, 11.3.2, 11.4.2, 11.5.2,
Floor proximity exit signs	7.10.1.6, A.7.10.1.6	11.5.3, A.11.2.2, A.11.3.2.4	
Illumination of signs	7.10.1.5 to 7.10.1.8, 7.10.4 to	Storage occupancies	42.2, 42.6, 42.7, 42.8.2
7.10.7, 7.10.8.1, 7.10.9, A.7.10.1.5.2, A.7.10.1.6 to		Means of escape	A.7.1.1
A.7.10.1.8, A.7.10.4 to A.7.10.7		Buildings under construction	4.6.11.2, A.4.6.11.2
Industrial occupancies	40.2.10	Convenience openings	A.8.6.8.2(4)
New ambulatory health care occupancies	20.2.10	Definition	3.3.137
New apartment buildings	30.2.10	Existing assembly occupancies	13.2.4.8
New assembly occupancies	12.2.10	Existing day-care homes	17.6.2
New business occupancies	38.2.10	Existing residential board and care occupancies	33.1.4,
New day-care occupancies	16.2.10	33.2.2, A.33.2.2.3(3)	
New detention and correctional occupancies	22.2.10	Lodging houses	26.2
New educational occupancies	14.2.10	New assembly occupancies	12.2.4.8
New health care occupancies	18.2.10	New day-care homes	16.6.2
New hotels and dormitories	28.2.10	New residential board and care occupancies	32.1.4,
New mercantile occupancies	36.2.10	32.2.2, A.32.2.2.3.1(3)	
New residential board and care occupancies	32.3.2.10	One- and two-family dwellings	24.2, A.24.2
"No exit" signs	7.10.8.3, A.7.10.8.3	Rooming houses	26.2
Parking structures	42.8.2.10	Special structures	A.11.2.2
Performance-based design option	5.3.2(12)	Measurement, units of	1.5
Sign legend	7.10.3, A.7.10.3	Mechanical equipment rooms	7.12, 9.4.5, A.9.4.5
Special amusement buildings	12.4.7.7, 13.4.7.7,	Medical gas, health care occupancies	18.3.2.4, 19.3.2.4
A.12.4.7.7.3, A.13.4.7.7.3		Membrane (definition)	3.3.138
Special structures	11.2.2.10, 11.3.2.10, 11.4.2.10	Membrane penetrations	8.3.5.6, A.8.3.5.6.3(1)(c)
Stairs	7.2.2.5.4, 7.7.3	Membrane structures	<i>see also</i> Tensioned-membrane structures
Storage occupancies	42.2.10	Definition	3.3.217.4
Tactile signage, exit stair door	7.10.1.3, 7.10.1.4	Membrane structures, permanent	11.9, A.11.9.3.3.1
Testing and maintenance	7.10.9	Air-supported, air-inflated structures ...	11.9.3, 11.9.4, A.11.9.3.3.1
Visibility	7.10.1.8, A.7.10.1.8	Pressurization system	11.9.3.2
Means of egress, number of	<i>see</i> Exits, number of	Standby power system	11.9.3.3, A.11.9.3.3.1
Means of egress requirements		Flame resistance	11.9.1.6
Apartment buildings as board and care occupancies	32.4.2,	General	11.9.1
33.4.2		Maintenance and operation	11.9.4
Existing ambulatory health care occupancies	21.1.2.3	Services	11.9.5
to 21.1.2.5, 21.2		Electric heaters	11.9.5.2
Existing apartment buildings	31.2, A.31.2	Fired heaters	11.9.5.1
Existing assembly occupancies	13.2, A.13.2	Tensioned-membrane structures	11.9.2, 11.9.4
Existing business occupancies	39.2	Membrane structures, temporary	11.10
Existing day-care occupancies	17.2, 17.7.3.2, 17.7.3.3,	Air-supported, air-inflated structures	11.10.5
A.17.2.2.3, A.17.7.3.2		Pressurization system	11.10.5.2
Existing detention and correctional occupancies	23.1.2.2,	Standby power system	11.10.5.3
23.1.2.4, 23.1.2.5, 23.2, A.23.2		Fire extinguishing equipment	11.10.3
Existing educational occupancies ...	15.2, 15.7.3, A.15.2, A.15.7.3.1	Fire hazards	11.10.2
Existing health care occupancies	19.1.2.4 to 19.1.2.7,	Flame resistance	11.10.1.5
19.2, A.19.2		General	11.10.1.1
Existing hotels and dormitories	29.2, A.29.2	Maintenance and operation	11.10.6
Existing mercantile occupancies	37.2, 37.4.4.3,	Services	11.10.7
37.4.5.2, A.37.4.4.3.5		Electric heaters	11.10.7.2
Existing residential board and care occupancies	33.1.4,	Fired heaters	11.10.7.1
33.3.2, 33.4.2		Tensioned-membrane structures	11.10.1.3, 11.10.4
Fundamental requirements	4.5.3	Mercantile occupancies	<i>see also</i> Existing mercantile occupancies;
Industrial occupancies	40.2, 40.6.1, 40.6.2	New mercantile occupancies	
Mall buildings	36.4.4.3, 37.4.4.3, A.36.4.4.3.5,	Classification of occupancy	6.1.10, 36.1.4, 37.1.4, A.6.1.10.1
A.36.4.4.3.7, A.37.4.4.3.5		Combined, parking structures	36.1.2.2, 37.1.2.2,
New ambulatory health care occupancies	20.1.2.3 to	A.36.1.2.2.2(4), A.37.1.2.2.2(4)	
20.1.2.5, 20.2		Definition	3.3.152.9, 6.1.10.1, A.3.3.152.9, A.6.1.10.1
New apartment buildings	30.2, A.30.2.2.2.2.1, A.30.2.2.12.2	Mall buildings, assembly	
New assembly occupancies	12.2	and mercantile occupancies in	12.1.2.3, 13.1.2.3
New business occupancies	38.2	Occupant load factor	Table 7.3.1.2
New day-care occupancies	16.2, 16.7.3.2, 16.7.3.3,	Mezzanines	
A.16.2.2.2.4, A.16.2.2.3, A.16.7.3.2		Aircraft servicing hangars	40.6.2
		Aircraft storage hangars	42.6.2

- Definition 3.3.141
- Fire protection features 8.6.9
- Means of egress, number of 7.4.1.1, 12.2.4.5 to 12.2.4.7, 13.2.4.5 to 13.2.4.7
- Mercantile occupancies 36.1.4.2.3, 37.1.4.2.3
- Open stairways between A.7.6.2
- Mixed occupancies** 6.1.14.3; *see also* Multiple occupancies
- Day-care occupancies 16.1.2.2, 17.1.2.2
- Definition 3.3.152.10, 6.1.14.2.2
- Mobility impaired, accessible**
means of egress for *see* Accessible means of egress
- Modernization** *see also* Construction; Renovation and rehabilitation
- Ambulatory health care occupancies 20.1.1.4.3, 21.1.1.4.3
- Application of code 4.6.8, A.4.6.8
- Detention and correctional occupancies 22.1.1.4, 23.1.1.4
- Health care occupancies 18.1.1.4, 19.1.1.4, A.18.1.1.4.6.3, A.18.1.1.4.6.4, A.19.1.1.4.6.3, A.19.1.1.4.6.4
- Modification (definition)** 3.3.143, A.3.3.143; *see also* Construction; Renovation and rehabilitation
- Moving walks** 7.2.7, 8.6.3(3), 8.6.8.5, 8.6.8.6, 9.4.2
- Assembly occupancies 13.2.2.8
- Business occupancies 39.2.2.8
- Exit discharge 7.7.4
- Industrial occupancies 40.2.2.8
- Mercantile occupancies 37.2.2.8
- Multilevel play structures** 12.4.7.1, 13.4.7.1, A.12.4.7.1, A.13.4.7.1
- Definition 3.3.217.5
- Multiple occupancies**
Classification of occupancy 6.1.14, A.6.1.14.1.2
- Day-care 16.6.1.2, 17.6.1.2
- Definition 3.3.152.11, 6.1.14.2.1
- Existing ambulatory health care occupancies 21.1.2, A.21.1.2.2
- Existing apartment buildings 31.1.2
- Existing assembly occupancies 13.1.2, A.13.1.2.2
- Existing business occupancies 39.1.2, A.39.1.2.2.2(4)
- Existing day-care occupancies 17.1.2
- Existing detention and correctional occupancies 23.1.2, A.23.1.2
- Existing educational occupancies 15.1.2
- Existing health care occupancies 19.1.2, A.19.1.2.2, A.19.1.2.3
- Existing hotels and dormitories 29.1.2
- Existing mercantile occupancies 37.1.2, A.37.1.2.2.2(4)
- Existing residential board and care occupancies 33.1.2
- Industrial occupancies 40.1.2
- Lodging houses 26.1.2
- New ambulatory health care occupancies 20.1.2, A.20.1.2.2
- New apartment buildings 30.1.2
- New assembly occupancies 12.1.2, A.12.1.2.2
- New business occupancies 38.1.2, A.38.1.2.2.2(4)
- New day-care occupancies 16.1.2
- New detention and correctional occupancies 22.1.2, A.22.1.2
- New educational occupancies 14.1.2
- New health care occupancies 18.1.2, A.18.1.2.2, A.18.1.2.3
- New hotels and dormitories 28.1.2
- New mercantile occupancies 36.1.2, A.36.1.2.2.2(4)
- New residential board and care occupancies 32.1.2
- One- and two-family dwellings 24.1.2
- Parking structures 42.8.1.2
- Rooming houses 26.1.2
- Storage occupancies 42.1.2
- Multiple safeguards** 4.5.1
- Multiple station alarm device** 9.6.2.10.1, 16.6.3.4.3(1), 17.6.3.4.3(1)
- Definition 3.3.146
- Multipurpose assembly occupancies (definition)** 3.3.152.2.1
- N-
- Net floor area** 7.3.1.2
- Definition 3.3.16.2.2
- New ambulatory health care occupancies** Chap. 20
- Application 20.1.1, A.20.1.1.1.6, A.20.1.1.2
- Building services 20.5
- Building spaces, subdivision of 20.3.7, A.20.3.7.9
- Changes of occupancy 20.1.1.4.2
- Classification of occupancy 20.1.4
- Construction 20.1.1.4.4, 20.7.9
- Construction, minimum requirements 20.1.6
- Corridors 20.3.6
- Detection/alarms/communication systems 20.3.4
- Doors 20.1.1.4.1.2, 20.1.1.4.1.3, 20.2.2.2 to 20.2.2.4, 20.2.3.3, 20.3.7.1, 20.3.7.9 to 20.3.7.13, A.20.3.7.9
- Drills 20.7.1.4 to 20.7.1.7, A.20.7.1.4
- Electrical systems, essential 20.2.9
- Elevators/escalators/conveyors 20.5.3
- Emergency control 20.3.4.5
- Emergency lighting 20.2.9
- Emergency plans 20.7.1, 20.7.2, A.20.7.2.1
- Evacuation 20.7.1, A.20.7.1.4
- Exit discharge 20.2.7
- Exits, maintenance of 20.7.3
- Exits, number of 20.2.4
- Exit travel distance 20.2.6
- Extinguishment requirements 20.3.5
- Furnishings/bedding/decorations 20.7.5, A.20.7.5.1
- General requirements 20.1, A.20.1
- Hazard of contents, classification of 20.1.2.6, 20.1.2.7, 20.1.5
- Hazards, protection from 20.3.2, 20.3.5.1
- Heating, ventilating, and air conditioning 20.5.2
- Heating devices, portable space 20.7.8
- Interior finish 20.3.3
- Maintenance 20.7.3, 20.7.6
- Means of egress arrangement 20.2.5
- Means of egress capacity 20.2.3
- Means of egress components 20.2.2
- Means of egress illumination 20.2.8
- Means of egress marking 20.2.10
- Means of egress requirements 20.1.2.3 to 20.1.2.5, 20.2
- Modernization/renovation/alteration 20.1.1.4.3
- Multiple occupancies 20.1.2, A.20.1.2.2
- Occupant load 20.1.7
- Openings 20.3.1, 20.3.6.2
- Operating features 20.7, A.20.7
- Protection 20.3, 20.3.5.1, A.20.3.7.9
- Rubbish/laundry chutes, incinerators 20.5.4
- Smoke control 20.7.7, A.20.7.7
- Smoking 20.7.4, A.20.7.4
- Special provisions 20.4
- Staff, procedure in fire 20.7.2, A.20.7.2.1
- Utilities 20.5.1
- Vertical openings, protection of 20.3.1
- New apartment buildings** Chap. 30
- Alternating tread devices 30.2.2.11
- Application 30.1.1
- Areas of refuge 30.2.2.12, A.30.2.2.12.2
- Building services 30.5
- Building spaces, subdivision of 30.3.7
- Classification of occupancy 30.1.4
- Corridors 30.3.6
- Detection/alarm/communication systems 30.3.4, A.30.3.4.5.1, A.30.4.5.1
- Doors 30.2.2.2, 30.3.6.2 to 30.3.6.5, A.30.2.2.2.2.1
- Elevators/escalators/conveyors 30.5.3
- Emergency lighting 30.2.9
- Exit discharge 30.2.7
- Exit passageways 30.2.2.7
- Exits, horizontal 30.2.2.5
- Exits, number of 30.2.4
- Exit travel distance 30.2.6
- Extinguishment requirements 30.3.5
- Fire escape ladders 30.2.2.10
- General requirements 30.1

Hazard of contents, classification of	30.1.5	Multiple occupancies	A.12.1.2.2
Hazardous areas	30.3.2.1	Occupant load	12.1.7, 12.7.8.3, A.12.1.7.1
Hazards, protection from	30.3.2	Operating features	12.7, A.12.7
Heating, ventilating, and air conditioning	30.5.2	Panic hardware/fire exit hardware	12.2.2.2.3
High-rise buildings	30.4.1	Protection	12.3, A.12.3
Interior finish	30.3.3	Ramps	12.2.2.6
Means of egress arrangement	30.2.5	Smokeproof enclosures	12.2.2.4
Means of egress capacity	30.2.3	Smoke-protected assembly seating	12.4.2, A.12.4.2
Means of egress components	30.2.2, A.30.2.2.2.1, A.30.2.2.12.2	Special amusement buildings	12.4.7, A.12.4.7
Means of egress illumination	30.2.8	Special provisions	12.4, A.12.4
Means of egress marking	30.2.10	Stairs	12.2.2.3, A.12.2.2.3.1(1)
Means of egress requirements	30.2, A.30.2.2.2.1, A.30.2.2.12.2	Turnstiles	12.2.2.2.8, 12.2.2.2.9
Multiple occupancies	30.1.2	Vertical openings, protection of	12.3.1, A.12.3.1(1)
Occupant load	30.1.7	Waiting spaces	12.1.7.2
Operating features	30.7	New buildings	
Protection	30.3, A.30.3.4.5.1	Applicability of code to	1.3.1
Ramps	30.2.2.6	Fire protection features	8.1.1
Residents, emergency instructions for	30.7	New business occupancies	Chap. 38
Rubbish/laundry chutes, incinerators	30.5.4	Alternating tread devices	38.2.2.11
Smokeproof enclosures	30.2.2.4	Application	38.1.1
Special provisions	30.4	Areas of refuge	38.2.2.12
Stairs	30.2.2.3	Building services	38.5
Utilities	30.5.1	Classification of occupancy	38.1.4
Vertical openings, protection of	30.3.1	Corridors	38.3.6, A.38.3.6.1
New assembly occupancies	Chap. 12	Detection/alarm/communication systems	38.3.4
Access/egress routes	12.2.5.4, A.12.2.5.4.2 to A.12.2.5.4.4	Doors	38.2.2.2, A.38.2.2.2.2
Aisle accessways, seating at tables	12.2.5.7, A.12.2.5.7	Drills	38.7.1
Aisle accessways, seating not at tables	12.2.5.5, A.12.2.5.5	Elevators/escalators/conveyors	38.5.3
Aisle handrails	12.2.5.6.3, 12.2.5.6.7, A.12.2.5.6.3, A.12.2.5.6.7	Emergency lighting	38.2.9
Aisle markings	12.2.5.6.8, A.12.2.5.6.8	Exit discharge	38.2.7
Aisles serving seating at tables	12.2.5.8, A.12.2.5.8.1 to A.12.2.5.8.3	Exit passageways	38.2.2.7
Aisles serving seating not at tables	12.2.5.6, A.12.2.5.6	Exits, horizontal	38.2.2.5
Aisle stair risers	12.2.5.6.6	Exits, number of	38.2.4
Aisle stairs/ramps	12.2.5.6.4, A.12.2.5.6.4	Exit travel distance	38.2.6
Aisle stair treads	12.2.5.6.5, A.12.2.5.6.5(2)	Extinguishment requirements	20.3.5, 38.3.5, 38.7.2
Aisle termination	12.2.5.6.2, 12.4.2.7	Fire escape ladders	38.2.2.10
Alternating tread devices	12.2.2.11, 12.2.4.8	General requirements	38.1, A.38.1.2.2.2(4)
Application	12.1.1	Hazard of contents, classification of	38.1.5
Approval of layouts	12.2.5.9	Hazards, protection from	38.3.2, A.38.3.2.1, A.38.3.2.2
Areas of refuge	12.2.2.12	Heating, ventilating, and air conditioning	38.5.2
Building services	12.5	High-rise buildings	38.4.2, A.38.4.2
Classification of occupancy	12.1.4, A.12.1.4	Interior finish	38.3.3
Construction, minimum requirements	12.1.6	Limited access/underground buildings	38.4.1
Cooking equipment/facilities	12.7.1.4, 12.7.4.3.9	Means of egress arrangement	38.2.5
Corridors	12.3.6	Means of egress capacity	38.2.3, A.38.2.3.2
Crowd managers, use of	12.7.5	Means of egress components	38.2.2
Detection/alarm/communication systems	12.3.4, A.12.3.4.2.3	Means of egress illumination	38.2.8
Doors	12.2.2.2	Means of egress marking	38.2.10
Emergency lighting	12.2.9	Means of egress requirements	38.2
Exit discharge	12.2.7	Multiple occupancies	38.1.2, A.38.1.2.2.2(4)
Exit passageways	12.2.2.7	Occupant load	38.1.7
Exits	12.2.3.6 to 12.2.3.8, 12.2.4, A.12.2.3.6.5, A.12.2.4	Operating features	38.7
Exits, horizontal	12.2.2.5	Protection	38.3
Exit travel distance	12.2.6	Ramps	38.2.2.6
Extinguishment requirements	12.3.5, A.12.3.5.2(2)	Rubbish/laundry chutes, incinerators	38.5.4
Fire escape ladders	12.2.2.10, 12.2.4.8	Smokeproof enclosures	38.2.2.4
General requirements	12.1	Special provisions	38.4
Guards/railings	12.2.11.1, A.12.2.11.1.1	Stairs	38.2.2.3
Hazard of contents, classification of	12.1.5	Utilities	38.5.1
Hazards, protection from	12.3.2	Vertical openings, protection of	38.3.1
High-rise buildings	12.4.4	New day-care homes	
Interior finish	12.3.3	Application	16.6.1.1
Limited access/underground buildings	12.4.3	Classification of occupancy	16.6.1.4, A.16.6.1.4.2
Maintenance and operation	12.7.9, 12.7.10	Conversion to day-care occupancy with more than 12 clients	16.1.4.3, 16.6.1.4.2, A.16.1.4.3, A.16.6.1.4.2
Means of egress arrangement	12.2.5, A.12.2.5	Detection/alarm/communication systems	16.6.3.4
Means of egress capacity	12.2.3, A.12.2.3.2, A.12.2.3.6.5	Exits, number of	16.6.2.4
Means of egress components	12.2.2	Exit travel distance	16.6.2.6
Means of egress illumination	12.2.8	General requirements	16.6.1, A.16.6.1.4.2
Means of egress marking	12.2.10	Hazard of contents, classification of	16.6.1.5
Means of egress requirements	12.2	High-rise buildings	Table 16.1.6.1
Mixed occupancies	12.1.2		

- Interior finish 16.6.3.3
- Location/construction 16.6.1.6
- Means of egress arrangement 16.6.2.5
- Means of escape 16.6.2
- Mixed occupancies 16.6.1.2
- Protection 16.6.3
- Vertical openings, protection of 16.6.3.1
- New day-care occupancies** Chap. 16; *see also* New day-care homes
 - Adult day-care, classification of 16.1.4.2
 - Alternating tread devices 16.2.2.9
 - Apartment buildings, in 16.1.2.2(2)
 - Application 16.1.1, A.16.1.1
 - Areas of refuge 16.2.2.10
 - Building services 16.5
 - Classification of occupancy 16.1.4, A.16.1.4.3
 - Conversion from day-care home 16.1.4.3, 16.6.1.4.2, A.16.1.4.3, A.16.6.1.4.2
 - Corridors 16.3.6
 - Detection/alarm/communication systems 16.3.4
 - Doors 16.2.2.2, A.16.2.2.2.4
 - Drills 16.7.2, A.16.7.2.1
 - Elevators/escalators/conveyors 16.5.3
 - Emergency lighting 16.2.9
 - Emergency plans 16.7.1, A.16.7.1
 - Exit discharge 16.2.7, 16.6.2.7
 - Exit passageways 16.2.2.7
 - Exits, horizontal 16.2.2.5
 - Exits, number of 16.2.4
 - Exit travel distance 16.2.6
 - Extinguishment requirements 16.3.5
 - Fire escape ladders 16.2.2.8
 - Flexible plan day-care buildings 16.4.3
 - Furnishings/decorations 16.7.4
 - General requirements 16.1
 - Hazard of contents, classification of 16.1.5
 - Hazards, protection from 16.3.2, A.16.3.2.1(2)(a)
 - Heating, ventilating, and air conditioning 16.5.2
 - High-rise buildings Table 16.1.6.1
 - Inspections 16.7.3, A.16.7.3.2
 - Interior finish 16.3.3
 - Limited access/underground buildings 16.4.1
 - Location/construction 16.1.6
 - Locks/latches 16.2.2.2.3 to 16.2.2.2.5, A.16.2.2.2.4
 - Means of egress, special features 16.2.11
 - Means of egress arrangement 16.2.5
 - Means of egress capacity 16.2.3
 - Means of egress components 16.2.2, A.16.2.2.2.4, A.16.2.2.3
 - Means of egress illumination 16.2.8, 16.6.2.8
 - Means of egress marking 16.2.10
 - Means of egress requirements 16.2, 16.7.3.2, 16.7.3.3, A.16.2.2.2.4, A.16.2.2.3, A.16.7.3.2
 - Multiple occupancies 16.1.2
 - Occupant load 16.1.7
 - Open plan day-care buildings 16.4.3
 - Operating features 16.7, A.16.7
 - Panic hardware/fire exit hardware 16.2.2.2
 - Protection 16.3, A.16.3.2.1(2)(a)
 - Ramps 16.2.2.6
 - Rubbish/laundry chutes, incinerators 16.5.4
 - Smokeproof enclosures 16.2.2.4
 - Special provisions 16.4
 - Staff 16.7.5, A.16.7.5
 - Stairs 16.2.2.3, A.16.2.2.3
 - Utilities 16.5.1
 - Vertical openings, protection of 16.3.1
 - Windows 16.2.11.1
- New detention and correctional occupancies** Chap. 22
 - Additions 22.1.1.3
 - Alternating tread devices 22.2.2.10
 - Application 22.1.1, A.22.1.1.2(2)
 - Areas of refuge 22.2.2.11
 - Building services 22.5
 - Building spaces, subdivision of 22.3.7, 22.3.8, 22.4.4.10, 22.4.4.11, A.22.3.7, A.22.3.8
 - Classification of occupancy 22.1.4
 - Construction, minimum requirements 22.1.6, 22.4.4.2
 - Corridors 22.3.6
 - Detection/alarm/communication systems 22.3.4, 22.4.4.9, A.22.3.4
 - Doors 22.2.2.2, 22.2.11, 22.3.7.2, 22.3.7.6(2), 22.3.7.8, 22.3.7.9, A.22.2.11.3, A.22.2.11.7, A.22.3.7.1(2)
 - Drills 22.7.1.3.1, A.22.7.1.3
 - Elevators/escalators/conveyors 22.5.3
 - Emergency forces notification 22.3.4.3.2
 - Emergency lighting 22.2.9
 - Evacuation 22.7.1, A.22.7.1.2, A.22.7.1.3
 - Exit discharge 22.2.7
 - Exit passageways 22.2.2.7
 - Exits, horizontal 22.1.2.5, 22.2.2.5, 22.4.4.3, A.22.2.2.5.2, A.22.4.4.3
 - Exits, number of 22.2.4
 - Exit travel distance 22.2.6, 22.4.4.5
 - Extinguishment requirements 22.3.5
 - Fire escape ladders 22.2.2.9
 - Furnishings/bedding/decorations 22.4.4.13, 22.7.4, A.22.4.4.13, A.22.7.4
 - General requirements 22.1, A.22.1
 - Hazard of contents, classification of 22.1.2.6, 22.1.2.7, 22.1.5
 - Hazardous areas 22.3.2.1, 22.3.2.2, 22.4.4.7, A.22.3.2.1
 - Hazards, protection from 22.3.2
 - Heating, ventilating, and air conditioning 22.5.2, 22.7.6
 - High-rise buildings 22.3.5.1, 22.4.3
 - Interior finish 22.3.3, 22.4.4.8
 - Keys 22.2.11.6, 22.2.11.7.2(2), 22.7.5
 - Limited access areas 22.4.4.12, A.22.4.4.12.2(2)
 - Limited access structures 22.4.1
 - Means of egress arrangement 22.2.5
 - Means of egress capacity 22.2.3
 - Means of egress components 22.2.2, A.22.2.2.5.2
 - Means of egress illumination 22.2.8
 - Means of egress marking 22.2.10
 - Means of egress requirements 22.1.2.2 to 21.1.2.5, 22.2, A.22.1.2.2.2
 - Modernization/renovation 22.1.1.4
 - Nonsprinklered existing building renovations 22.4.4, A.22.4.4
 - Multiple occupancies 22.1.2, A.22.1.2
 - Occupant load 22.1.7
 - Operating features 22.7, A.22.7
 - Protection 22.3, 22.4.4.6 to 22.4.4.12, A.22.3, A.22.4.4.6.2, A.22.4.4.6.4
 - Ramps 22.2.2.6
 - Resident housing spaces, subdivision of Table 22.3.8, A.22.3.8
 - Rubbish/laundry chutes, incinerators 22.5.4
 - Smokeproof enclosures 22.2.2.4
 - Special features 22.2.11, A.22.2.11.3, A.22.2.11.7
 - Special provisions 22.4, A.22.4.4
 - Staff, procedures in fire 22.7.1, A.22.7.1.2, A.22.7.1.3
 - Stairs 22.2.2.3
 - Underground structures 22.4.2
 - Use Conditions I to V 22.1.4, A.22.1.4.1 to A.22.1.4.3
 - Utilities 22.5.1
 - Vertical openings, protection of 22.3.1, 22.4.4.6, A.22.3.1(2), A.22.4.4.6.2, A.22.4.4.6.4
- New educational occupancies** Chap. 14
 - Aisles 14.2.5.6, 14.2.5.7
 - Alternating tread devices 14.2.2.9
 - Application 14.1.1
 - Areas of refuge 14.2.2.10
 - Balconies 14.2.5.8, A.14.2.5.8
 - Building services 14.5
 - Building spaces, subdivision of 14.3.7
 - Classification of occupancy 14.1.4
 - Corridors, exterior 14.2.5.8, A.14.2.5.8

Corridors, interior	14.3.6	Exits, maintenance of	18.7.3
Corridors, minimum width	14.2.3.2	Exits, number of	18.2.4, A.18.2.4.4
Detection/alarm/communication systems	14.3.4	Exit travel distance	18.2.6, 18.4.3.4
Doors	14.2.2.2, 14.2.5.4, 14.2.5.5	Extinguishment requirements	18.3.5, A.18.3.5
Drills	14.7.2, A.14.7.2.1	Fire escape ladders	18.2.2.8
Elevators/escalators/conveyors	14.5.3	Furnishings/bedding/decoration	18.7.5, A.18.7.5.1
Emergency lighting	14.2.9	General requirements	18.1, A.18.1
Emergency plans	14.7.1	Hazard of contents, classification of	18.1.2.8, 18.1.2.9, 18.1.5
Exit discharge	14.2.7	Hazardous areas	18.3.2.1, A.18.3.2.1
Exit passageways	14.2.2.7	Hazards, protection from	18.3.2, 18.4.3.5, A.18.3.2
Exits, horizontal	14.2.2.5	Heaters, space	18.7.8
Exits, number of	14.2.4	Heating, ventilating, and air conditioning	18.5.2, A.18.5.2.2
Exit travel distance	14.2.6	Heliports	18.3.2.6
Extinguishment requirements	14.3.5	High-rise buildings	18.4.2
Fire escape ladders	14.2.2.8	Interior finish	18.3.3, 18.4.3.6, A.18.3.3.2
Flexible/open plan buildings	14.4.3	Laboratories	18.3.2.2
Furnishings/decorations	14.7.4	Limited access buildings	18.4.1
General requirements	14.1	Maintenance and testing	18.7.6
Hazard of contents, classification of	14.1.5	Means of egress arrangement	18.2.5
Hazards, protection from	14.3.2	Means of egress capacity ...	18.2.3, 18.4.3.3, A.18.2.3.4, A.18.2.3.5
Heating, ventilating, and air conditioning	14.5.2	Means of egress components	18.2.2, A.18.2.2
High-rise buildings	14.4.2	Means of egress illumination	18.2.8
Inspection	14.7.3, A.14.7.3.1	Means of egress marking	18.2.10
Interior finish	14.3.3	Means of egress requirements	18.1.2.4 to 18.1.2.7, 18.2, 18.4.3.3, 18.4.3.4, A.18.2
Limited access/underground buildings	14.4.1	Medical gas	18.3.2.4
Means of egress, special features	14.2.11, A.14.2.11.1	Modernization/renovation/rehabilitation	18.1.1.4, 18.4.3, A.18.1.1.4.6.3, A.18.1.1.4.6.4, A.18.4.3.1
Means of egress arrangement	14.2.5, A.14.2.5.8	Multiple occupancies	18.1.2, A.18.1.2.2, A.18.1.2.3
Means of egress capacity	14.2.3	Occupant load	18.1.7
Means of egress components	14.2.2, A.14.2.2.3	Openings	18.3.1, 18.3.6.5
Means of egress illumination	14.2.8	Operating features	18.7, A.18.7
Means of egress marking	14.2.10	Protection	18.3, 18.4.3.5 to 18.4.3.8, A.18.3, A.18.3.8
Means of egress requirements	14.2, A.14.2	Ramps	18.2.2.6, 18.2.3.4, 18.2.3.5
Multiple occupancies	14.1.2	Rubbish/laundry chutes, incinerators	18.5.4
Occupant load	14.1.7	Smoke barriers	18.3.7, A.18.3.7
Operating features	14.7, A.14.7.2.1, A.14.7.3.1	Smoke control	18.7.7, A.18.7.7
Panic hardware/fire exit hardware	14.2.2.2.2	Smokeproof enclosures	18.2.2.4
Protection	14.3, A.14.3	Smoking	18.7.4, A.18.7.4
Ramps	14.2.2.6	Special provisions	18.4
Rubbish/laundry chutes, incinerators	14.5.4	Staff, fire procedures of	18.7.1.8, 18.7.2, A.18.7.2.1
Smokeproof enclosures	14.2.2.4	Stairs	18.2.2.3
Special provisions	14.4	Transfer grilles	18.3.6.4
Stairs	14.2.2.3, A.14.2.2.3	Utilities	18.5.1
Utilities	14.5.1	Vertical openings, protection of	18.3.1
Vertical openings, protection of	14.3.1		
New health care occupancies	Chap. 18	New hotels and dormitories	Chap. 28
Additions	18.1.1.4.1 to 18.1.1.4.4	Alternating tread devices	28.2.2.11
Alternating tread devices	18.2.2.9	Application	28.1.1
Anesthetizing locations	18.3.2.3	Areas of refuge	28.2.2.12, A.28.2.2.12.2
Application	18.1.1, A.18.1.1	Building services	28.5, A.28.5.3.2
Areas of refuge	18.2.2.10	Building spaces, subdivision of	28.3.7
Building services	18.5, A.18.5.2.2	Classification of occupancy	28.1.4
Building spaces, subdivision of	18.3.7, 18.4.3.8, A.18.3.7	Corridors	28.3.6
Changes of occupancy	18.1.1.4.5, 19.1.1.4.5	Detection/alarm/communication systems	28.3.4, A.28.3.4, A.28.3.4.5
Classification of occupancy	18.1.4	Doors	28.2.2.2
Construction, minimum requirements	18.1.6, 18.4.3.2	Drills	28.7.1.2, 28.7.3, A.28.7.1.2
Construction/repair/improvement operations ...	18.1.1.4.7, 18.7.9	Elevators/escalators/conveyors	28.5.3, A.28.5.3.2
Cooking facilities	18.3.2.5	Emergency lighting	28.2.9
Corridors	18.2.3.4, 18.2.3.5, 18.3.6, 18.4.3.7, A.18.3.6	Exit discharge	28.2.7, A.28.2.7.2
Detection/alarm/communication systems	18.3.4, 18.7.2.3.3, A.18.3.4	Exit passageways	28.2.2.7
Doors	18.2.2.2, 18.2.2.5.3, 18.3.6.3, 18.3.7.7 to 18.3.7.9, 18.3.8, A.18.2.2.4(2), A.18.2.2.6, A.18.3.6.3, A.18.3.7.7 to A.18.3.7.9, A.18.3.8	Exits, horizontal	28.2.2.5
Drills	18.7.1.4 to 18.7.1.7	Exits, number of	28.2.4
Elevators/escalators/conveyors	18.5.3	Exit travel distance	28.2.6
Emergency control	18.3.4.4	Extinguishment requirements	28.3.5
Emergency lighting	18.2.9	Fire escape ladders	28.2.2.10
Emergency plans	18.7.1, 18.7.2.2	Furnishings/decorations	28.3.3.4, A.28.3.3.4
Evacuation	18.7.1, A.18.7.1.4	General requirements	28.1
Exit discharge	18.2.7	Hazard of contents, classification of	28.1.5
Exit passageways	18.2.2.7	Hazardous areas	28.3.2.2
Exits, horizontal	18.1.2.5, 18.2.2.5	Hazards, protection from	28.3.2
		Heating, ventilating, and air conditioning	28.5.2

- High-rise buildings 28.4.1
- Interior finish 28.3.3
- Means of egress arrangement 28.2.5
- Means of egress capacity 28.2.3, A.28.2.3.3
- Means of egress components 28.2.2, A.28.2.2.12.2
- Means of egress illumination 28.2.8
- Means of egress marking 28.2.10
- Means of egress requirements 28.2, A.28.2
- Multiple occupancies 28.1.2
- Occupant load 28.1.7
- Operating features 28.7, A.28.7
- Protection 28.3, A.28.3
- Ramps 28.2.2.6
- Residents/guests, emergency instructions for 28.7.4, A.28.7.4.1, A.28.7.4.2
- Rubbish/laundry chutes, incinerators 28.5.4
- Smokeproof enclosures 28.2.2.4
- Special provisions 28.4
- Staff, emergency organization and duties 28.7.1, 28.7.2, A.28.7.1.1, A.28.7.1.2
- Stairs 28.2.2.3
- Utilities 28.5.1
- Vertical openings, protection of 28.3.1
- New mercantile occupancies** Chap. 36
- Alternating tread devices 36.2.2.11
- Application 36.1.1
- Areas of refuge 36.2.2.12
- Building services 36.5
- Bulk merchandising retail buildings 36.4.5
- Classification of occupancy 36.1.4
- Construction, minimum requirements 36.4.5.1
- Corridors 36.3.6, A.36.3.6.1
- Detection/alarm/communication systems 36.3.4, 36.4.4.4, 36.4.5.4
- Doors 36.2.2.2, A.36.2.2.2.2
- Drills 36.7.1
- Elevators/escalators/conveyors 36.5.3
- Emergency control 36.4.4.4.4
- Emergency lighting 36.2.9
- Exit discharge 36.2.7, A.36.2.7.2
- Exit passageways 36.2.2.7, 36.4.4.6, A.36.2.2.7.2
- Exits, horizontal 36.2.2.5
- Exits, number of 36.2.4
- Exit travel distance 36.2.6
- Extinguishment requirements 36.3.5, 36.4.5.5, 36.7.2
- Fire escape ladders 36.2.2.10
- General requirements 36.1, A.36.1.2.2(4)
- Hazard of contents, classification of 36.1.5
- Hazards, protection from 36.3.2, A.36.3.2.1, A.36.3.2.2
- Heating, ventilating, and air conditioning 36.5.2
- High-rise buildings 36.4.2
- Interior finish 36.3.3
- Limited access/underground buildings 36.4.1
- Mall buildings 36.4.4, A.36.4.4
- Means of egress arrangement 36.2.5, A.36.2.5.10
- Means of egress capacity 36.2.3
- Means of egress components 36.2.2
- Means of egress details 36.4.4.3, A.36.4.4.3.5, A.36.4.4.3.7
- Means of egress illumination 36.2.8
- Means of egress marking 36.2.10
- Means of egress requirements 36.2, 36.4.5.2
- Multiple occupancies 36.1.2, A.36.1.2.2.2(4)
- Occupant load 36.1.7
- Open-air operations 36.4.3
- Operating features 36.7
- Protection 36.3, A.36.3
- Ramps 36.2.2.6
- Rubbish/laundry chutes, incinerators 36.5.4
- Smokeproof enclosures 36.2.2.4
- Special provisions 36.4, A.36.4
- Stairs 36.2.2.3
- Utilities 36.5.1
- Vertical openings, protection of 36.3.1
- New residential board and care occupancies** Chap. 32
- Apartment building suitability as 32.4, A.32.4
- Construction 32.4.1.4
- Corridor wall construction 32.4.3.2
- Evacuation 32.4.1.3
- Interior finish 32.4.3.1
- Means of egress requirements 32.4.2
- Application 32.1.1, A.32.1.1
- Conversions 32.1.1.4
- Doors 32.3.3.6.4 to 32.3.3.6.6, 32.3.3.7.13 to 32.3.3.7.19, A.32.3.3.7.13, A.32.3.3.7.17, A.32.3.3.7.18
- Drills 32.7.3
- Emergency plan 32.7.1
- Fire resistance rated assemblies 32.1.5, A.32.1.5
- Furnishings/bedding/decorations 32.7.5, A.32.7.5
- General requirements 32.1, A.32.1.1, A.32.1.5
- High-rise buildings 32.3.3.4.5, 32.3.3.9.2
- Large facilities 32.3, A.32.3
- Alternating tread devices 32.3.2.2.9
- Areas of refuge 32.3.2.2.10
- Building services 32.3.6
- Building spaces, subdivision of 32.3.3.7
- Construction, minimum requirements 32.3.1.3
- Corridors 32.3.3.6, A.32.3.3.6
- Detection/alarm/communication systems 32.3.3.4
- Doors 32.3.2.2.2
- Elevators/dumbwaiters/conveyors 32.3.6.3, A.32.3.6.3.2
- Emergency lighting 32.3.2.9
- Exit discharge 32.3.2.7
- Exit passageways 32.3.2.2.7
- Exits, horizontal 32.3.2.2.5
- Exits, number of 32.3.2.4
- Exit travel distance 32.3.2.6
- Extinguishment requirements 32.3.3.5
- Fire escape ladders 32.3.2.2.8
- General 32.3.1, A.32.1.1, A.32.1.5
- Hazards, protection from 32.3.3.2
- Heating, ventilating, and air conditioning 32.3.6.2
- Interior finish 32.3.3.3
- Means of egress 32.3.2
- Means of egress arrangement 32.3.2.5
- Means of egress capacity 32.3.2.3
- Means of egress components 32.3.2.2
- Means of egress illumination 32.3.2.8
- Means of egress marking 32.3.2.10
- Occupant load 32.3.1.4
- Protection 32.3.3
- Ramps 32.3.2.2.6
- Rubbish/laundry chutes, incinerators 32.3.6.4
- Sleeping rooms, separation of 32.3.3.6, A.32.3.3.6
- Smokeproof enclosures 32.3.2.2.4
- Stairs 32.3.2.2.3
- Utilities 32.3.6.1
- Vertical openings, protection of 32.3.3.1
- Means of egress/escape acceptability 32.1.4
- Multiple occupancies 32.1.2
- Operating features 32.7, A.32.7
- Protection 32.4.3
- Resident training 32.7.2
- Small facilities 32.2, A.32.2
- Building services 32.2.5
- Corridor walls, construction of 32.2.3.6
- Detection/alarm/communication systems 32.2.3.4
- Doors 32.2.2.5
- Elevators/escalators/conveyors 32.2.5.3
- Extinguishment requirements 32.2.3.5, A.32.2.3.5
- General 32.2.1
- Hazardous areas 32.2.3.2, A.32.2.3.2.1
- Heating, ventilating, and air conditioning 32.2.5.2
- Interior finish 32.2.3.3, A.32.3.3.3

Means of escape	32.2.2, A.32.2.2.3.1(3)
Protection	32.2.3, A.32.2.3
Stairs	32.2.2.4, 32.2.2.6, A.32.2.2.6.3
Utilities	32.2.5.1
Vertical openings, protection of	32.2.3.1
Smoking	32.7.4, A.32.7.4.1
Noncombustible (material) (definition)	3.3.135.3
Notification	9.6.1.8(2), 9.6.3, 9.6.4;
<i>see also</i> Emergency forces notification; Occupant notification	
Existing ambulatory health care occupancies	21.3.4.3, 21.3.4.4
Existing apartment buildings	31.3.4.3
Existing assembly occupancies	13.3.4.3
Existing business occupancies	39.3.4.3
Existing day-care occupancies	17.3.4.3, 17.3.4.4
Existing detention and correctional occupancies	23.3.4.3
Existing educational occupancies	15.3.4.3, A.15.3.4.3.1.1
Existing health care occupancies	19.3.4.3
Existing hotels and dormitories	29.3.4.3, A.29.3.4.3.6
Existing mercantile occupancies	37.3.4.3, 37.4.4.4.3,
37.4.5.4.3, 37.4.5.4.4	
Existing residential board and care occupancies	33.2.3.4.2,
33.3.3.4.4, 33.3.3.4.6, A.33.3.3.4.6	
Industrial occupancies	40.3.4.3
Lodging or rooming houses	26.3.3.3, A.26.3.3.3.1
New ambulatory health care occupancies	20.3.4.3, 20.3.4.4
New apartment buildings	30.3.4.3
New assembly occupancies	12.3.4.3
New business occupancies	38.3.4.3
New day-care occupancies	16.3.4.3, 16.3.4.4
New detention and correctional occupancies	22.3.4.3
New educational occupancies	14.3.4.3, A.14.3.4.3.1.1
New health care occupancies	18.3.4.3, A.18.3.4.3.1(2)
New hotels and dormitories	28.3.4.3, A.28.3.4.3
New mercantile occupancies	36.3.4.3, 36.4.4.4,
36.4.4.4.3, 36.4.5.4.3, 36.4.5.4.4	
New residential board and care occupancies	32.2.3.4.2,
32.3.3.4.4 to 32.3.3.4.6	
Parking structures	42.8.3.4.3
Storage occupancies	42.3.4.3
Nursing homes	<i>see also</i> Health care occupancies
Accumulation space	18.2.2.5.1.1, 18.3.7.6.1,
19.2.2.5.1.1, 19.3.7.4.1	
Changes of occupancy	18.1.1.4.5, 19.1.1.4.5
Definition	3.3.110.2
Detection systems	18.3.4.5.3, A.18.3.4.5.3
Means of egress, capacity of	18.2.3.6 to 18.2.3.7

-O-

Objectives

Code	4.2
Definition	3.3.151, A.3.3.151
Occupancy	<i>see also</i> Classification of occupancy;
specific occupancies	
Changes of	4.6.12, A.4.6.12
Conditions for	4.6.10
Definition	3.3.152

Occupant characteristics

Definition	3.3.153
Performance-based design option	5.4.5, 5.8.5, A.5.4.5

Occupant load

Definition	3.3.131.2
Existing ambulatory health care occupancies	21.1.7
Existing apartment buildings	31.1.7
Existing assembly occupancies	13.1.7, A.13.1.7.1
Existing business occupancies	39.1.7
Existing day-care homes	17.6.1.7
Existing day-care occupancies	17.1.7
Existing detention and correctional occupancies	23.1.7
Existing educational occupancies	15.1.7
Existing health care occupancies	19.1.7

Existing hotels and dormitories	29.1.7
Existing mercantile occupancies	37.1.7
Existing residential board and care occupancies	33.3.1.4
Industrial occupancies	40.1.7, A.40.1.7
Lodging houses	26.1.7
Means of egress capacity	7.3.1, A.7.3.1.2, Table A.7.3.1.2
New ambulatory health care occupancies	20.1.7
New apartment buildings	30.1.7
New assembly occupancies	12.1.7, 12.7.8.3, A.12.1.7.1
New business occupancies	38.1.7
New day-care occupancies	16.1.7
New detention and correctional occupancies	22.1.7
New educational occupancies	14.1.7
New health care occupancies	18.1.7
New hotels and dormitories	28.1.7
New mercantile occupancies	36.1.7
New residential board and care occupancies	32.3.1.4
Rooming houses	26.1.7
Special structures	11.1.7
Storage occupancies	42.1.7, A.42.1.7
Occupant notification	9.6.3, A.9.6.3
Existing ambulatory health care occupancies	21.3.4.3
Existing apartment buildings	31.3.4.3.1 to 31.4.3.4
Existing assembly occupancies	13.3.4.3
Existing business occupancies	39.3.4.3
Existing day-care occupancies	17.3.4.3
Existing detention and correctional occupancies	23.3.4.3.1, A.23.3.4.3.1(2)
Existing educational occupancies	15.3.4.3.1, A.15.3.4.3.1.1
Existing health care occupancies	19.3.4.3.1, A.19.3.4.3.1(1)
Existing hotels and dormitories	29.3.4.3.1, 29.3.4.3.2
Existing mercantile occupancies	37.3.4.3.1, 37.4.5.4.3
Existing residential board and care occupancies	33.2.3.4.2,
33.3.3.4.4	
Fundamental requirements	4.5.4, A.4.5.4
Industrial occupancies	40.3.4.3
Lodging houses	26.3.3.3, A.26.3.3.3.1
Mall buildings	36.4.4.4.3.1, 37.4.4.4.3.1
New ambulatory health care occupancies	20.3.4.3
New apartment buildings	30.3.4.3.1 to 30.4.3.4
New assembly occupancies	12.3.4.3
New business occupancies	38.3.4.3
New day-care occupancies	16.3.4.3
New detention and correctional occupancies	22.3.4.3.1,
A.22.3.4.3.1(2)	
New educational occupancies	14.3.4.3.1, A.14.3.4.3.1.1
New health care occupancies	18.3.4.3.1, A.18.3.4.3.1(2)
New hotels and dormitories	28.3.4.3.1 to 28.3.4.3.5,
A.28.3.4.3.1, A.28.3.4.3.3	
New mercantile occupancies	36.3.4.3.1, 36.4.4.4.3.1, 36.4.5.4.3
New residential board and care occupancies	32.2.3.4.2, 32.3.3.4.4, 32.3.3.4.5
Rooming houses	26.3.3.3, A.26.3.3.3.1
Storage occupancies	42.3.4.3
Occupant protection objective	4.2.1
One- and two-family dwelling units	Chap. 24
Application	24.1.1, A.24.1.1.1
Balconies/landings/porches	24.2.5.4
Building services	24.5
Classification of occupancy	24.1.4
Definition	3.3.50.1, 6.1.8.1.1, A.6.1.8.1.1
Detection/alarm/communication systems	24.3.4
Doors	24.2.2.3(A), 24.2.4, A.24.2.4.7
Extinguishment requirements	24.3.5, A.24.3.5
General requirements	24.1
Hallways	24.2.6
Hazard of contents, classification of	24.1.5
Heating, ventilating, and air conditioning	24.5.1
Interior finish	24.3.3
Means of escape requirements	24.2, A.24.2
Multiple occupancies	24.1.2
Protection	24.3, A.24.3.5

- Ramps 24.2.5
- Stairs 24.2.5
- One-family dwelling units (definition)** 3.3.50.2;
 see also One- and two-family dwelling units
- Open-air mercantile operations** 36.4.3, 37.4.3
- Definition 3.3.156
- Open flame devices, assembly occupancies** 12.7.2, 12.7.4.3.8,
 13.7.2, 13.7.4.3.8, A.12.7.2(3)(a), A.13.7.2(3)(a)
- Open flames, educational occupancies** 14.7.5, 15.7.5
- Openings/penetrations** *see* Penetrations/openings
- Open parking structures** 18.3.7.2(4), 28.3.5.6, 30.3.5.7
- Definition 3.3.217.7
- Open plan day-care buildings** 16.4.3, 16.7.3.3, 17.4.3, 17.7.3.3
- Definition 3.3.27.6, A.3.3.27.6
- Open plan education buildings** 14.4.3, 14.7.3.2, 15.4.3, 15.7.3.2
- Definition 3.3.27.6, A.3.3.27.6
- Open structures** 11.2, A.11.2.2
- Definition 3.3.217.6, A.3.3.217.6
- Operating features**
- Existing ambulatory health care occupancies 21.7, A.21.7
- Existing apartment buildings 31.7
- Existing assembly occupancies 13.7, A.13.7
- Existing business occupancies 39.7
- Existing day-care occupancies 17.7, A.17.7
- Existing detention and correctional occupancies 23.7, A.23.7
- Existing educational occupancies 15.7, A.15.7.2.1, A.15.7.3.1
- Existing health care occupancies 19.7, A.19.7
- Existing hotels and dormitories 29.7, A.29.7
- Existing mercantile occupancies 37.7
- Existing residential board and care occupancies 33.7, A.33.7
- Membrane structures
- Permanent 11.9.4
- Temporary 11.10.6
- New ambulatory health care occupancies 20.7, A.20.7
- New apartment buildings 30.7
- New assembly occupancies 12.7, A.12.7
- New business occupancies 38.7
- New day-care occupancies 16.7, A.16.7
- New detention and correctional occupancies 22.7, A.22.7
- New educational occupancies 14.7, A.14.7.2.1, A.14.7.3.1
- New health care occupancies 18.7, A.18.7
- New hotels and dormitories 28.7, A.28.7
- New mercantile occupancies 36.7
- New residential board and care occupancies 32.7, A.32.7
- Ordinary hazard contents** 6.2.2.3, A.6.2.2.3
- Outdoor assembly occupancies** *see also* Grandstands
- Existing assembly occupancies 13.1.7.4, 13.2.4.4, A.13.4.2
- New assembly occupancies 12.1.7.4, 12.2.4.4, A.12.4.2
- Outside doors, health care occupancies** 18.3.8, 19.3.8
- Outside ramps** 7.2.5.6, A.7.2.5.6.1, A.7.2.5.6.2
- Outside stairs** 7.2.2.6, A.7.2.2.6.2, A.7.2.2.6.5
- Definition 3.3.159, A.3.3.159
- Residential board and care occupancies 32.2.2.6.3,
 33.2.2.6.3, A.32.2.2.6.3, A.33.2.2.6.3
- Storage occupancies 42.7.3
- Travel distance to exit 7.6.3
- Outside windows**
- Health care occupancies 18.3.8, 19.3.8, A.18.3.8
- One- and two-family dwellings 24.2.2.3(C), A.24.2.2.3(C)
- Residential board and care occupancies 32.2.2.3.1(3),
 33.2.2.3(3), A.32.2.2.3.1(3), A.33.2.2.3(3)
- P-**
- Panic** 1.1.2, A.1.1.2
- Panic hardware**
- Assembly occupancies 12.2.2.2.3, 13.2.2.2.3
- Day-care occupancies 16.2.2.2.2, 17.2.2.2.2
- Definition 3.3.103.2
- Doors 7.2.1.7
- Educational occupancies 14.2.2.2.2, 15.2.2.2.2
- Parking structures** *see also* Open parking structures
- Application 42.8.1.1
- Areas of refuge 42.8.2.2.9
- Building services 42.8.5
- Classification of occupancy 42.8.1.4
- Combined
- Business occupancies 38.1.2.2, 39.1.2.2,
 A.38.1.2.2.2(4), A.39.1.2.2.2(4)
- Mercantile occupancies 36.1.2.2, 37.1.2.2,
 A.36.1.2.2.2(4), A.37.1.2.2.2(4)
- Corridors 42.8.3.6
- Detection/alarm/communication systems 42.8.3.4
- Doors 42.8.2.2.2
- Elevators/escalators/conveyors 42.8.5.3
- Emergency lighting 42.8.2.9
- Exit discharge 42.8.2.7
- Exit passageways 42.8.2.2.7
- Exits, horizontal 42.8.2.2.5
- Exits, number of 42.8.2.4
- Exit travel distance 42.8.2.6
- Fire escape stairs 42.8.2.2.8
- General requirements 42.8.1
- Hazard of contents, classification of 42.8.1.5
- Heating, ventilating, and air conditioning 42.8.5.2
- Interior finish 42.8.3.3
- Means of egress arrangement 42.8.2.5
- Means of egress capacity 42.8.2.3
- Means of egress components 42.8.2.2
- Means of egress illumination 42.8.2.8
- Means of egress marking 42.8.2.10
- Means of egress requirements 42.8.2
- Multiple occupancies 42.8.1.2
- Protection 42.8.3
- Ramps 42.8.2.2.6, 42.8.3.1.1.3
- Rubbish/laundry chutes, incinerators 42.8.5.4
- Smokeproof enclosures 42.8.2.2.4
- Stairs 42.8.2.2.3
- Utilities 42.8.5.1
- Vertical openings, protection of 42.8.3.1
- Partitions** *see also* Walls
- Folding, doors in 7.2.1.12
- Passageways** *see* Exit passageways
- Penetrations/openings** *see also* Vertical openings
- Ambulatory health care occupancies 20.3.1, 20.3.6.2, 21.3.1
- Detention and correctional occupancies 22.3.1, 22.4.4.3,
 22.4.4.6, 23.2.2.5.3, 23.3.1, A.22.3.1(2), A.22.4.4.3,
 A.22.4.4.6.2, A.22.4.4.6.4, A.23.2.2.5.3, A.23.3.1
- Ducts, openings for *see* Ducts, openings for
- Fire barriers 7.2.4.3.3 to 7.2.4.3.5, 8.3.4, 8.3.5, 8.6.2,
 A.8.3.5.6.3(1)(c)
- Fire barrier walls 8.3.5, A.8.3.5.6.3(1)(c)
- Fire escape stairs 7.2.8.2
- Firestops 8.3.5.1 to 8.3.5.3, 8.3.5.5.1, 8.3.5.6.1, 8.3.5.6.2
- Fire walls 8.3.5, A.8.3.5.6.3(1)(c)
- Health care occupancies 18.3.1, 18.3.6.5, 19.3.1,
 19.3.6.5, 19.3.7.5, A.19.3.7.5.1
- Horizontal exit duct penetrations 23.2.2.5.3,
 A.22.2.2.5.3, A.22.4.4.3
- Insulation and coverings 8.3.5.3
- Membrane penetrations 8.3.5.6, A.8.3.5.6.3(1)(c)
- Outside stairs 7.2.2.6.4
- Sleeves 8.3.5.2, 8.5.5.5
- Smoke barriers 8.3.4.2, 8.5.3 to 8.5.5, 8.6.1(2), A.8.3.4.2
- Smoke partitions 8.3.4.2, 8.4.3, 8.4.4, A.8.3.4.2,
 A.8.4.3.4, A.8.4.6.2
- Sprinklers, for 8.3.5.6.3(3), 8.5.5.4, A.8.4.2(2)
- Stages and platforms
- Proscenium openings 12.4.5.7, A.12.4.5.7
- Stage floors, through 12.4.5.3.3
- Transitions 8.3.5.5
- Vibrations, transmission of 8.3.5.4, 8.4.4.2, 8.5.5.6

Performance-based design option	4.4.3, Chap. 5, A.1.4.3
Application	5.1.1, A.5.1.1
Building characteristics affecting behavior or hazard development, identification of	5.4.3
Consistency of assumptions	5.4.9, A.5.4.9
Data sources	5.1.5
Design fire scenarios	5.5, 5.8.6, A.5.5
Design specifications and other conditions	5.4, 5.8.3, A.5.4
Documentation requirements	5.8, A.5.8
Emergency response personnel	5.4.6
Evaluation of proposed designs	5.6, 5.8.13, A.5.6
Goals and objectives	5.1.2
Final determination on meeting of	5.1.6
Performance criteria	5.2.1
Independent review	5.1.4, A.5.1.4
Maintenance of design features	5.1.7, A.5.1.7
Occupant characteristics	5.4.5, A.5.4.5
Response characteristics	5.4.5.2, A.5.4.5.2
Off-site conditions	5.4.8
Operational status/effectiveness of building features/systems	5.4.4, A.5.4.4
Performance criteria	5.2, 5.8.4, A.5.2.2
Post-construction conditions	5.4.7, A.5.4.7
Qualifications of preparer	5.1.3
Retained prescriptive requirements	5.3, 5.8.10, A.5.3.1
Safety factors	5.7, 5.8.9, A.5.7
Special definitions	5.1.8
Performance criteria	5.2, 5.8.4, A.5.2.2
Definition	3.3.161, A.3.3.161
Permanent structures (definition)	3.3.217.8;
<i>see also</i> Membrane structures, permanent	
Personal care (definition)	3.3.163, A.3.3.163
Photoluminescent	
Definition	3.3.164, A.3.3.164
Signs	7.10.7.2, A.7.10.7.2
Piers	11.5
Pinrails	12.4.5.8
Definition	3.3.165
Place of assembly	<i>see</i> Assembly occupancies
Plastic	
Cellular or foamed	<i>see</i> Cellular or foamed plastic
Light-transmitting	10.2.4.4, A.10.2.4.4
Signs, mercantile occupancies	36.4.4.7, 37.4.4.7
Platforms	
Assembly occupancies	12.4.5, 13.4.5
Definition	3.3.166, A.3.3.166
Elevated	7.2.11.1(3)
Temporary	12.4.5.2.1, 12.4.5.2.2
Definition	3.3.166.1
Plenum (definition)	3.3.167; <i>see also</i> Ducts, openings for
Pneumatic conveyors	<i>see</i> Conveyors
Point of safety (definition)	3.3.168
Porches	7.5.3.1, 7.5.3.2, 24.2.5.4
Powered doors	7.2.1.9, A.7.2.1.9
Prescriptive-based design option	4.4.2, A.1.4.3
Previously approved	4.6.2
Definition	3.3.169
Primary means of escape	
Lodging or rooming houses	26.2.1.1
One- and two-family dwellings	24.2.2.1.1, 24.2.2.2, 24.2.2.4
Residential board and care occupancies	32.2.2.2, 32.2.2.4, 33.2.2.2, 33.2.2.4
Private party tents	<i>see</i> Tents
Professional engineer	31.3.5.10.3
Definition	3.3.171
Projection rooms	12.4.6, 13.4.6
Safety film, for	12.4.6.6, 13.4.6.6
Prompt evacuation capability	<i>see</i> Evacuation capability
Proposed design (definition)	3.3.173, A.3.3.173
Proscenium opening protection	12.4.5.7, 13.4.5.7, A.12.4.5.7
Proscenium walls	12.4.5.6
Definition	3.3.229.2
Public way	A.7.7.1
Definition	3.3.175
Purpose of code	1.2, A.1.2
Pyrotechnic devices, assembly occupancies	12.7.2, 13.7.2, A.12.7.2(3)(a), A.13.7.2(3)(a)
-R-	
Raceways, surface nonmetallic	A.10.2.4
Railings	<i>see also</i> Handrails
Existing assembly occupancies	13.2.11.1, 13.4.8.6, 13.4.9.3
New assembly occupancies	12.2.11.1, 12.4.8.6, 12.4.9.3, A.12.2.11.1.1
Ramps	7.2.5, A.7.2.5.6.1, A.7.2.5.6.2
Definition	3.3.176, A.3.3.176
Details	7.2.5.3
Dimensional criteria	7.2.5.2
Drop-offs	7.2.5.3.3
Enclosure/protection	7.2.5.5
Existing apartment buildings	31.2.2.6
Existing assembly occupancies	13.2.2.6, Table 13.2.3.2, 13.2.5.6.4, A.13.2.5.6.4
Existing business occupancies	39.2.2.6
Existing day-care occupancies	17.2.2.6
Existing detention and correctional occupancies	23.2.2.6
Existing educational occupancies	15.2.2.6
Existing health care occupancies	19.2.2.6, 19.2.3.2, 19.2.3.4, 19.2.3.5
Existing hotels and dormitories	29.2.2.6
Existing mercantile occupancies	37.2.2.6
Existing residential board and care occupancies	33.3.2.2.6
Exit discharge	7.7.4
Guards/handrails	7.2.5.4
Industrial occupancies	40.2.2.6
Landings	7.2.5.3.2
New apartment buildings	30.2.2.6
New assembly occupancies	12.2.2.6, Table 12.2.3.2, 12.2.5.6.4, A.12.2.5.6.4
New business occupancies	38.2.2.6
New day-care occupancies	16.2.2.6
New detention and correctional occupancies	22.2.2.6
New educational occupancies	14.2.2.6
New health care occupancies	18.2.2.6, 18.2.3.4, 18.2.3.5
New hotels and dormitories	28.2.2.6
New mercantile occupancies	36.2.2.6
New residential board and care occupancies	32.3.2.2.6
One- and two-family dwellings	24.2.2.2, 24.2.5
Outside	7.2.5.6, A.7.2.5.6.1, A.7.2.5.6.2
Parking structures	42.8.2.2.6, 42.8.3.1.1.3
Performance-based design option	5.3.2(5)
Storage occupancies	42.2.2.6
Travel distance to exit	7.6.2, A.7.6.2
Rating	
Fire protection (definition)	3.3.177.1
Fire resistance	<i>see</i> Fire resistance rating
References	Chap. 2, 4.6.6, Annex B
Registered architect (definition)	3.3.178
Registered design professional (RDP)	5.1.3
Definition	3.3.179
Regular stages	12.4.5.3.1; <i>see also</i> Stages
Definition	3.3.210.2
Relocation area	4.7.5
Relocation drills	<i>see</i> Drills, emergency egress/fire
Renovation and rehabilitation	<i>see also</i> Construction
Application of code	4.6.8, A.4.6.8
Existing ambulatory health care occupancies	21.1.1.4.3
Existing detention and correctional occupancies	23.1.1.4
Existing health care occupancies	19.1.1.4, A.19.1.1.4.6.3, A.19.1.1.4.6.4
New ambulatory health care occupancies	20.1.1.4.3

- New detention and correctional occupancies 22.1.1.4
 Nonsprinklered existing building
 renovations 22.4.4, A.22.4.4
 New health care occupancies 18.1.1.4, 18.4.3,
 A.18.1.1.4.6.3, A.18.1.1.4.6.4, A.18.4.3.1
- Repair operations** 4.6.11, A.4.6.11.1, A.4.6.11.2;
see also Construction
- Ambulatory health care occupancies 20.1.1.4.4,
 20.7.9, 21.1.1.4.4, 21.7.9
- Health care occupancies 18.1.1.4.7, 18.7.9, 19.1.1.4.7, 19.7.9
- Rescue windows** *see* Windows
- Resident housing spaces, subdivision of** A.23.3.8
- Residential board and care occupancies;** *see also* Existing
 residential board and care occupancies; New residential
 board and care occupancies
- Apartment buildings, suitability of 32.4, 33.4, A.32.4, A.33.4
 Classification of occupancy 6.1.9, A.6.1.9.1, A.6.19.1
 Definition 3.3.152.13, 6.1.9.1, A.3.3.152.13,
 A.6.1.9.1, A.6.19.1
 Occupant load factor Table 7.3.1.2
- Residential board and care residents**
- Definition 3.3.182
 Training 32.7.2, 33.7.2
- Residential housing area** *see* Detention and correctional residential
 housing area
- Residential occupancies** *see also* specific occupancies,
 e.g. Apartment buildings
- Classification of occupancy 6.1.8, A.6.1.8.1
 Definition 3.3.152.12, 6.1.8.1, A.3.3.152.12, A.6.1.8.1
 Occupant load factor Table 7.3.1.2
- Revolving doors** 7.2.1.10
- Apartment buildings 30.2.2.2.3, 31.2.2.2.3
 Assembly occupancies 12.2.2.2.7, 13.2.2.2.7
 Business occupancies 38.2.2.2.8, 39.2.2.2.8
 Hotels and dormitories 28.2.2.2.3, 29.2.2.2.3
 Mercantile occupancies 36.2.2.2.8, 37.2.2.2.8
- Risers, stair**
- Aisles 12.2.5.6.6, 13.2.5.6.6
 Height 7.2.2.3.2(1), 7.2.2.3.3(2), 7.2.2.3.5,
 7.2.2.3.6, A.7.2.2.3.5
 Slope under tread 7.2.2.3.3
- Roofs**
- Alternating tread devices 7.2.11.1(1)
 Exit access by means of 7.5.3.1
 Exit discharge to 7.7.6
 Fire escape stairs 7.2.8.3.3
 Fire-resistance ratings Table A.8.2.1.2
 Membrane structures
 Permanent 11.9.1.2, 11.9.1.5, 11.9.2.3, 11.9.2.4
 Temporary 11.10.1.4, 11.10.4.3, 11.10.4.4
- Roof vents** 12.4.5.5.2, 13.4.5.5.2
- Rooming houses** *see* Lodging or rooming houses
- Rubbish chutes** *see* Chutes, laundry or rubbish
- S-
- Safe location (definition)** 3.3.184
- Safety factor (definition)** 3.3.185
- Safety margin (definition)** 3.3.186
- Sally port** 22.2.5.4, 23.2.5.4
 Definition 3.3.187
- Scenery**
- Existing assembly occupancies 13.7.3, A.13.7.3.3
 New assembly occupancies 12.7.3, A.12.7.3.3
- Scope of code** 1.1, A.1.1
- Screen/storm doors** 7.2.1.4.6
- Seating**
- Aisle accessways
- Existing assembly occupancies 13.2.5.5, 13.2.5.7,
 A.13.2.5.5, A.13.2.5.7
 New assembly occupancies 12.2.5.5, 12.2.5.7,
 A.12.2.5.5, A.12.2.5.7
- Aisles serving
- Existing assembly occupancies 13.2.5.6, 13.2.5.8,
 A.13.2.5.6, A.13.2.5.8.1 to A.13.2.5.8.3
 New assembly occupancies 12.2.5.6, 12.2.5.8,
 A.12.2.5.6, A.12.2.5.8.1 to A.12.2.5.8.3
- Continental A.12.2.5.5.4, A.13.2.5.5.4
- Definition 3.3.188.2
- Festival
- Definition 3.3.188.1, A.3.3.188.1
 Requirements 12.2.5.4.1
- Fixed 12.7.8.1, 13.7.8.1
 Definition 3.3.188.2
- Folding and telescopic 12.4.9, 13.4.9
 Definition 3.3.188.3
 Guards and railings 12.4.9.3, 13.4.9.3
 Maintenance and operation of 12.7.10, 13.7.10
- Grandstands 12.4.8.2, 13.4.8.2
- Occupant load factor 7.3.1.3.2
- Smoke-protected assembly
- Definition 3.3.188.4
 Existing assembly occupancies 13.4.2, A.13.4.2
 New assembly occupancies 12.4.2, A.12.4.2
 Unsecured 12.7.8.2, 13.7.8.2
- Secondary means of escape**
- Lodging or rooming houses 26.2.1.2
- One- and two-family dwellings 23.2.2.1, 24.2.2.3, A.24.2.2.3
- Residential board and care occupancies 32.2.2.3, 33.2.2.3,
 A.32.2.2.3.1(3), A.33.2.2.3(3)
- Security vestibule** *see* Sally port
- Self-closing**
- Definition 3.3.189
- Doors 7.2.1.8, 7.2.1.9.2, 8.3.3.3, 8.4.3.5, 8.5.3.4,
 8.7.1.3, 9.6.3.2.3, A.7.2.1.8.1, A.9.6.3.2.3
- Ambulatory health care occupancies 20.2.2.3, 20.2.2.4,
 20.3.7.1(3), 21.2.2.3, 21.2.2.4, 21.3.2.1, 21.3.7.1(3),
 21.3.7.9, A.21.3.7.9
- Health care occupancies 18.1.1.4.2, 18.2.2.2.6, 18.2.2.2.7,
 18.3.6.3.9, 18.4.3.7.2.2, 19.2.2.2.6 to 19.2.2.2.9,
 19.3.6.3.9, A.18.2.2.2.6, A.19.2.2.2.6, A.19.2.2.2.8
- Residential board and care occupancies 32.3.3.7.17,
 33.3.3.6.6.1, 33.3.3.6.6.2, A.32.3.3.7.17
- Service openings 8.6.8.4
- Self-luminous (definition)** 3.3.190, A.3.3.190
- Self-preservation, day-care occupancy
 (definition)** 3.3.191, A.3.3.191
- Sensitivity analysis** *see* Analysis
- Separate atmosphere (definition)** 3.3.20.2
- Separated occupancies** 6.1.14.4
 Definition 3.3.152.14, 6.1.14.2.3
- Separation of means of egress** 7.1.3, A.7.1.3.2.1, A.7.1.3.2.3
- Exit access corridors 7.1.3.1
- Exits 7.1.3.2, A.7.1.3.2.1, A.7.1.3.2.3
- Service equipment**
- Existing assembly occupancies 13.3.2.1
- Membrane structures
- Permanent 11.9.5
 Temporary 11.10.7
- New assembly occupancies 12.3.2.1
- Tents 11.11.6
- Severe mobility impairment (definition)** 3.3.195
- SFPE Engineering Guide to Performance-Based
 Fire Protection Analysis and Design of Buildings* A.5.6
- Shafts** 8.6.4; *see also* Vertical openings
- Shall (definition)** 3.2.6
- Should (definition)** 3.2.7
- Signal initiation** *see* Alarm initiation
- Signs** *see also* Identification signs; Means of egress marking
- Occupant load, assembly occupancy 12.7.8.3
- Plastic, mercantile occupancies 36.4.4.7, 37.4.4.7
- Single fire source, assumption of** 4.3.1
- Single station alarm** *see* Alarms and alarm systems
- SI units** 1.5

Sleeping rooms, separation of

- Lodging/rooming houses 26.3.4
- Residential board and care occupancies 32.3.3.6, 33.3.3.6, A.32.3.3.6

Slide escapes 7.2.10

- Capacity 7.2.10.2
- Industrial occupancies 40.2.2.11
- Storage occupancies 42.2.2.10

Sliding doors, horizontal 7.2.1.14**Slip resistance**

- Fire escape stairs 7.2.8.4.2
- Means of egress walking surface 7.1.6.4, A.7.1.6.4

Slow evacuation capability *see* Evacuation capability**Smoke alarms** *see* Alarms and alarm systems**Smoke barriers** 8.5, 8.6.1, A.8.5; *see also* Building spaces, subdivision of

- Accessible means of egress 7.5.4.6
- Definition 3.3.23.2, A.3.3.23.2
- Doors in 8.5.3.1 to 8.5.3.4, 18.3.7.7 to 18.3.7.9, 19.3.7.5 to 19.3.7.8, 20.3.7.9 to 20.3.7.13, 21.3.7.9 to 21.3.7.11, 22.3.7.2, 22.3.7.6(2), 22.3.7.8, 22.3.7.9, 23.3.7.2, 23.3.7.6, 23.3.7.8, 23.3.7.9, 32.3.3.7.13 to 32.3.3.7.19, A.8.5.1, A.8.5.3.1, A.8.5.3.2, A.8.5.3.4, A.18.3.7.7 to A.18.3.7.9, A.19.3.7.5.1, A.19.3.7.6, A.20.3.7.9, A.21.3.7.9, A.23.3.7.1(2), A.23.3.7.6(1), A.32.3.3.7.13, A.32.3.3.7.17, A.32.3.3.7.18
- Existing apartment buildings 31.3.7
- Existing detention and correctional occupancies 23.3.7, A.23.3.7
- Existing health care occupancies 19.3.7, 21.3.7.5 to 21.3.7.14, A.19.3.7.6, A.21.3.7.9
- Joints 20.3.7.14, A.20.3.7.14
- New detention and correctional occupancies 22.3.7, A.22.3.7
- New health care occupancies 18.3.7, 20.3.7, A.18.3.7, A.20.3.7.9
- Penetrations/openings in 8.3.4.2, 8.5.3 to 8.5.5
- Residential board and care occupancies 32.3.3.7, 33.3.3.7

Smoke compartments *see* Compartments**Smoke control** 9.3, 9.6.5.2(3), 13.4.5.5.1, A.9.3.1

- Ambulatory health care occupancies 20.7.7, 21.7.7, A.20.7.7, A.21.7.7
- Atriums 8.6.7(5), 8.6.7(6), A.8.6.7
- Detention and correctional occupancies 22.4.4.12.2, 23.4.1.2, A.22.4.4.12.2(A), A.23.4.1.2(2)
- Health care occupancies 18.7.7, 19.7.7, A.18.7.7, A.19.7.7
- Smoke-protected assembly seating 12.4.2.1(2)
- Stages 12.4.5.5.1, 13.4.5.5.1

Smoke dampers *see* Dampers, smoke**Smoke detectors and detection systems**

- Alarms for 9.6.2.10, A.9.6.2.10.3
- Complete 9.6.2.8
- Definition 3.3.201
- Door closing action initiated by *see* Self-closing
- Elevator recall 9.6.3.2.1, 9.6.5.3
- Existing apartment buildings 31.3.4.5.1
- Existing assembly occupancies 13.4.7.4, 13.4.7.6
- Existing day-care homes 17.6.3.4.2
- Existing detention and correctional occupancies 23.3.4.4, 23.3.7.12, A.23.3.4.4.3
- Existing residential board and care occupancies 33.3.3.4.8
- Heating, ventilating, and air conditioning shut down 9.6.3.2.2, A.9.6.3.2.2
- New assembly occupancies 12.4.7.4, 12.4.7.6
- New day-care homes 16.6.3.4.2, 16.6.3.4.3
- New day-care occupancies 16.3.4.5
- New detention and correctional occupancies 22.3.4.4, 22.3.7.12, 22.4.4.9.2, A.22.3.4.4
- New health care occupancies 18.3.4.5.3, 18.3.6.1(1), 18.3.6.1(2), A.18.3.4.5.3
- New hotels and dormitories 28.3.4.4
- New residential board and care occupancies 32.3.3.4.8
- One- and two-family dwellings 24.3.4
- Partial 9.6.2.9

- Releasing service 9.6.3.2.2, 9.6.3.2.3, A.9.6.3.2.2, A.9.6.3.2.3
- Smoke dampers, closing of 8.4.6.4, 8.5.4.7

Smoke partitions 8.3.4.2, 8.4, A.8.4

- Definition 3.3.202, A.3.3.202
- Educational occupancies 14.3.7.1, 15.3.7.1

Smokeproof enclosures 7.2.3, A.7.2.3.9.1

- Access 7.2.3.6
- Apartment buildings 30.2.2.4, 31.2.2.4, 31.2.11, A.31.2.11
- Assembly occupancies 12.2.2.4, 13.2.2.4
- Business occupancies 38.2.2.4, 39.2.2.4
- Day-care occupancies 16.2.2.4, 17.2.2.4
- Definition 3.3.203, A.3.3.203
- Detention and correctional occupancies 22.2.2.4, 23.2.2.4
- Discharge 7.2.3.5
- Door closers 7.2.3.11
- Educational occupancies 14.2.2.4, 15.2.2.4
- Elevators, area of refuge access 7.2.12.2.4
- Health care occupancies 18.2.2.4, 19.2.2.4
- Hotels and dormitories 28.2.2.4, 29.2.2.4
- Industrial occupancies 40.2.2.4
- Mercantile occupancies 36.2.2.4, 37.2.2.4
- Parking structures 42.8.2.2.4
- Residential board and care occupancies 32.3.2.2.4, 33.3.2.2.4
- Stair pressurization 7.2.3.9, 7.2.3.10, A.7.2.3.9.1
- Standby power 7.2.3.12
- Storage occupancies 42.2.2.4
- Testing 7.2.3.13
- Ventilation 7.2.3.7, 7.2.3.8, 7.2.3.10, 7.2.3.12

Smoke-protected assembly seating *see* Seating**Smoking**

- Assembly occupancies 12.7.7, 13.7.7
- Health care occupancies 18.7.4, 19.7.4, 20.7.4, 21.7.4, A.18.7.4, A.19.7.4, A.20.7.4, A.21.7.4
- Residential board and care occupancies 32.7.4, 33.7.4, A.32.7.4.1, A.33.7.4.1

Special amusement buildings

- Definition 3.3.27.10, A.3.3.27.10
- Existing assembly occupancies 13.4.7, A.13.4.7
- Exit marking 13.4.7.7, A.13.4.7.3
- Interior finish 12.4.7.8, 13.4.7.8
- Means of egress marking 12.4.7.7, A.12.4.7.3
- New assembly occupancy 12.4.7, A.12.4.7

Special hazard protection 8.7, A.8.7**Special inspections** 9.8

- Definition 3.3.206

Special-purpose industrial occupancy *see* Industrial occupancies**Special structures** 6.1.1.2, Chap. 11; *see also* High-rise buildings

- Application 11.1.1
- Classification of occupancy 11.1.4
- Corridors 11.3.3.6, 11.4.3.6
- Detection/alarm/communication systems 11.2.3.4, 11.3.3.4, 11.4.3.4
- Elevators 11.3.2.2.2
- Emergency lighting 11.2.2.9, 11.3.2.9, 11.4.2.9
- Exit discharge 11.2.2.7, 11.3.2.7, 11.4.2.7
- Exits, number of 11.2.2.4, 11.3.2.4, 11.4.2.4, 11.5.2, A.11.3.2.4
- Exit travel distance 11.2.2.6, 11.3.2.6, 11.4.2.6
- Extinguishment requirements 11.2.3.5, 11.3.3.5, 11.4.3.5
- Fire escape ladders 11.2.2.2.1, 11.3.2.2.1
- General requirements 11.1
- Hazard of contents, classification of 11.1.5
- Hazards, protection from 11.2.3.2, 11.3.3.2, 11.4.3.2
- Interior finish 11.2.3.3, 11.3.3.3, 11.4.3.3
- Limited access structures 11.7, A.11.7.2
- Means of egress arrangement 11.2.2.5, 11.3.2.5, 11.4.2.5, 11.5.3
- Means of egress capacity 11.2.2.3, 11.3.2.3, 11.4.2.3
- Means of egress components 11.2.2.2, 11.3.2.2, 11.4.2.2
- Means of egress illumination 11.2.2.8, 11.3.2.8, 11.4.2.8
- Means of egress marking 11.2.2.10, 11.3.2.10, 11.4.2.10
- Means of egress requirements 11.2.2, 11.3.2, 11.4.2, 11.5.2, 11.5.3, A.11.2.2, A.11.3.1.3.1(2), A.11.3.2.4

- Occupant load 11.1.7
 Open structures 11.2, A.11.2.2
 Piers 11.5, A.11.5
 Protection 11.2.3, 11.3.3, 11.4.3
 Towers 11.3, A.11.3.1.3.1(2), A.11.3.2.4
 Underground structures 11.7, A.11.7.2
 Vehicles and vessels 11.6, A.11.6
 Vertical openings, protection of 11.2.3.1, 11.3.3.1, 11.4.3.1
 Water-surrounded structures 11.4
- Specifications**
 Design 5.4, 5.8.3, A.5.4
 Definition 3.3.208.1, A.3.3.208.1
 Input data 5.4.2.1 to 5.4.2.3, 5.5.4.1 to 5.5.4.3
 Definition 3.3.208.2
- Spiral stairs** 7.2.2.2.3
 Apartment buildings 30.2.2.3.3, 31.2.2.3.3
 Assembly occupancies 12.2.2.3.2.2, 12.2.4.8, 13.2.2.3.2.2, 13.2.4.8
 Business occupancies 38.2.2.3.2, 39.2.2.3.2
 Detention and correctional occupancies 23.2.2.3.2
 Industrial occupancies 40.2.2.3.2
 One- and two-family dwellings 24.2.5.5
 Storage occupancies 42.2.2.3.2
- Sprinklers** 9.7.1, A.9.7.1.1, A.9.7.1.3
 Existing ambulatory health care occupancies 21.3.5.2
 Existing apartment buildings 31.3.5.4 to 31.3.5.8, A.31.3.5.3
 Existing health care occupancies 19.3.5.4, A.19.3.5.3, A.19.3.5.4, A.19.3.5.6
 Impairment procedures 9.7.6.2
 Interior finishes and 10.1.2, 10.2.8
 New ambulatory health care occupancies 20.3.5.2
 New apartment buildings 30.3.5.6
 New health care occupancies 18.3.5.4, 18.3.5.6, 18.3.6.1(1), A.18.3.5.1, A.18.3.5.4, A.18.3.5.6
 New hotels and dormitories 28.3.5.4, 28.3.5.5
 Penetrations for 8.3.5.6.3(3), 8.5.5.4, A.8.4.2(2)
- Sprinkler systems** 7.1.11, 8.1.2, 9.7;
see also Hazards, protection from
 Alarms for 9.6.2.5, 9.6.2.7, 9.7.2
 Atriums 8.6.7(1), 8.6.7(4), 8.6.7(6), A.8.6.7(1)
 Bulk merchandising retail buildings 36.4.5.5, 37.4.5.5
 Communicating spaces 8.6.6(4), 8.6.6(5)
 Convenience openings 8.6.8.6, A.8.6.8.6(4)
 Door closing action initiated by *see Self-closing*
 Exhibits 12.7.4.3.7, 13.7.4.3.7, A.12.7.4.3.7.1(3), A.13.7.4.3.7.1(3)
 Existing ambulatory health care occupancies 21.3.5.2
 Existing apartment buildings 31.3.5, A.31.3.5.3, A.31.3.5.10.2
 Existing assembly occupancies 13.3.5, 13.4.2.1(1), 13.4.4, 13.4.5.7.5, 13.4.5.10, 13.4.7.2, 13.4.7.3, 13.4.7.6, 13.7.4.3.7, A.13.4.7.2, A.13.7.4.3.7.1(3)
 Existing day-care occupancies 17.3.5, 17.3.6
 Existing detention and correctional occupancies 23.3.5.2, 23.3.5.3, A.23.3.5.2
 Existing educational occupancies 15.3.5, 15.3.6, A.15.3.6(2)
 Existing health care occupancies 19.1.1.4.6.3, 19.1.1.4.6.4, 19.2.3.3, 19.3.5, 19.3.6.1, A.19.1.1.4.6.3, A.19.1.1.4.6.4, A.19.3.5
 Existing hotels and dormitories 29.3.5, A.29.3.5.3
 Existing mercantile occupancies 37.3.5.1, 37.4.5.5
 Existing residential board and care occupancies 33.2.3.5, 33.3.3.5.1 to 33.3.3.5.5, A.33.2.3.5.2.1, A.33.3.3.5.1
 High-rise buildings 11.1.8
 Industrial occupancies 40.4
 Lodging or rooming houses 26.3.5
 Maintenance/testing 9.7.5
 New ambulatory health care occupancies 20.3.5.2, 20.3.6.2.2
 New apartment buildings 30.3.5
 New assembly occupancies 12.4.2.1, 12.4.5.10, 12.4.7.2, 12.4.7.3, 12.4.7.6, A.12.4.2.1(1), A.12.4.7.2
 New day-care occupancies 16.3.5, 17.3.6
 New detention and correctional occupancies 22.3.5.2, 22.3.5.3
 New educational occupancies 14.3.5, 14.3.6, 14.3.7.2(2)
 New health care occupancies 18.1.1.4.6.3, 18.3.5, 18.3.6.1(1), 18.3.6.1(4), 18.3.7.2(4), 18.4.3.4, 18.4.3.6.3.2(1), 18.4.3.8, A.18.1.1.4.6.3, A.18.3.5
 New hotels and dormitories 28.3.5
 New mercantile occupancies 36.3.5.1, 36.3.5.2, 36.4.5.5
 New residential board and care occupancies 32.2.3.5, 32.3.3.5.1, 32.3.5.4, A.32.2.3.5
 One- and two-family dwellings 24.3.5, A.24.3.5
 Out-of-service 9.7.6.1
 Shutdown 9.7.6, A.9.7.6
 Special amusement buildings 12.4.7.2, 12.4.7.3, 12.4.7.6, A.12.4.7.2
 Special structures 11.1.8, 11.3.1.3.1, A.11.3.1.3.1(2)
 Storage occupancies 42.4.1
 Supervision 9.7.2, A.9.7.2.1
- Staff**
 Bulk merchandising retail buildings, training 36.4.5.6, 37.4.5.6
 Day-care occupancies 16.7.5, 17.7.5, A.16.7.5, A.17.7.5
 Existing ambulatory health care occupancies 21.7.1, 21.7.2, A.21.7.2.1
 Existing business occupancies 39.7.2
 Existing detention and correctional occupancies 23.7.1, A.23.7.1.2, A.23.7.1.3
 Existing health care occupancies 19.7.1, 19.7.2, A.19.7.2.1
 Existing hotels and dormitories 29.7.1, 29.7.2, A.29.7.1.1, A.29.7.1.2
 Existing mercantile occupancies 37.4.5.6, 37.7.2
 Existing residential board and care occupancies 33.7.1, 33.7.6
 Definition 3.3.209
 New ambulatory health care occupancies 20.7.2, A.20.7.2.1
 New business occupancies 38.7.2
 New detention and correctional occupancies 22.7.1, A.22.7.1.2, A.22.7.1.3
 New health care occupancies 18.7.1.8, 18.7.2, A.18.7.2.1
 New hotels and dormitories 28.7.1, 28.7.2, A.28.7.1.1, A.28.7.1.2
 New mercantile occupancies 36.4.5.6, 36.7.2
 New residential board and care occupancies 32.7.1, 32.7.6
 Definition 3.3.209
 Performance-based design,
 staff assistance requirement 5.4.5.5, A.5.4.5.5
- Stages** 12.4.5, 13.4.5, 14.3.2.3, 15.3.2.3
 Accessory rooms 12.4.5.4
 Definition 3.3.210
 Fire protection 12.4.5.10, 12.4.5.12, 13.4.5.10, 13.4.5.12, A.12.4.5.7, A.12.4.5.12, A.13.4.5.12
 Flame-retardant requirements 12.4.5.11, 13.4.5.11
 Legitimate 12.4.5.3.2
 Definition 3.3.210.1
 Proscenium opening protection 12.4.5.7, 13.4.5.7, A.12.4.5.7
 Proscenium walls 12.4.5.6
 Definition 3.3.229.2
 Regular 12.4.5.3.1
 Definition 3.3.210.2
 Smoke control 12.4.5.5.1
 Standpipes 12.4.5.12, 13.4.5.12, A.12.4.5.12, A.13.4.5.12
 Ventilators 12.4.5.5, 13.4.5.5
- Stairs** 7.2.2; *see also Fire escape stairs*;
 Spiral stairs; Swinging stairs; Vertical openings
 Accessible means of egress 7.5.4.4
 Aisles 12.2.5.6.4, 13.2.5.6.4, A.12.2.5.6.4, A.13.2.5.6.4
 Areas of refuge 7.2.12.2.3
 Bulkhead enclosure 24.2.7.2
 Curved 7.2.2.2.2
 Details 7.2.2.3, A.7.2.2.3.3.2, A.7.2.2.3.4, A.7.2.2.3.5
 Dimensional criteria 7.2.2.2, A.7.2.2.2.1(2), A.7.2.2.2.4
 Discharge 7.7.3, 7.7.4
 Enclosures *see Enclosures*
 Existing apartment buildings 31.2.2.3

Existing assembly occupancies	13.2.2.3, Table 13.2.3.2, 13.2.5.6.4, A.13.2.2.3.1(1), A.13.2.5.6.4
Existing business occupancies	39.2.2.3
Existing day-care occupancies	17.2.2.3, 17.7.3.2, A.17.2.2.3, A.17.7.3.2
Existing detention and correctional occupancies	23.2.2.3
Existing educational occupancies	15.2.2.3, 15.7.3.1, A.15.2.2.3, A.15.7.3.1
Existing health care occupancies	19.2.2.3
Existing hotels and dormitories	29.2.2.3, 29.2.7.2, A.29.2.7.2
Existing mercantile occupancies	37.2.2.3
Existing residential board and care occupancies	33.2.2.4, 33.2.2.6, 33.3.2.2.3, A.33.2.2.6.3
Exposures	7.2.2.5.2, A.7.2.2.5.2
General	7.2.2.1
Guards	7.2.2.4, A.7.2.2.4
Handrails	7.2.2.4, A.7.2.2.4
Industrial occupancies	40.2.2.3
Interlocking (scissors)	7.5.1.4, A.7.5.1.4.2
Landings	7.2.2.3.1.2, 7.2.2.3.2, 7.2.2.3.3, A.7.2.2.3.3.2
Lodging or rooming houses	26.2.2
New apartment buildings	30.2.2.3
New assembly occupancies	12.2.2.3, Table 12.2.3.2, 12.2.5.6.4, A.12.2.2.3.1(1), A.12.2.5.6.4
New business occupancies	38.2.2.3
New day-care occupancies	16.2.2.3, 16.7.3.2, A.16.2.2.3, A.16.7.3.2
New detention and correctional occupancies	22.2.2.3
New educational occupancies	14.2.2.3, 14.7.3.1, A.14.2.2.3, A.14.7.3.1
New health care occupancies	18.2.2.3
New hotels and dormitories	28.2.2.3
New mercantile occupancies	36.2.2.3
New residential board and care occupancies	32.2.2.4, 32.2.2.6, 32.3.2.2.3, A.32.2.2.6.3
One- and two-family dwellings	24.2.2.2, 24.2.2.3(A), 24.2.5
Outside	<i>see</i> Outside stairs
Parking structures	42.8.2.2.3
Performance-based design option	5.3.2(4)
Pressurized	7.2.3.9, 7.2.3.10, 9.6.5.2(2), A.7.2.3.9.1
Protection of	7.2.2.5, 7.2.2.6.3, 7.2.2.6.4, A.7.2.2.5.2 to A.7.2.2.5.4
Riser height/tread depth	7.2.2.2.2, 7.2.2.2.3.2, 7.2.2.2.3.3, 7.2.2.3.3, 7.2.2.3.5, 7.2.2.3.6, A.7.2.2.3.3.2, A.7.2.2.3.5
Separation of	7.2.2.6.3
Signs	7.2.2.5.4, A.7.2.2.5.4
Storage occupancies	42.2.2.3
Travel distance to exit	7.6.2, A.7.6.2
Tread	7.2.2.3.3, A.7.2.2.3.3.2
Types	7.2.2.2.2 to 7.2.2.2.4, A.7.2.2.2.4
Usable space under	7.2.2.5.3, A.7.2.2.5.3
Winders	7.2.2.2.4, A.7.2.2.2.4
Apartment buildings	30.2.2.3.4, 31.2.2.3.4
Business occupancies	39.2.2.3.3
Industrial occupancies	40.2.2.3.3
Lodging or rooming houses	26.2.2.4
One- and two-family dwellings	24.2.5.5
Residential board and care occupancies	32.2.2.6.2, 33.2.2.6.2
Storage occupancies	42.2.2.3.3, 42.8.2.2.3.2
Stakeholder (definition)	3.3.211
Standby power	9.1.3, 9.1.4
Air-supported, air-inflated structures	11.9.3.3, A.11.9.3.3.1
Elevators	7.2.13.7, A.7.2.13.7
High-rise buildings	11.8.4, A.11.8.4.2(A)
Membrane structures, temporary	11.10.5.3
Smokeproof enclosures	7.2.3.12
Standpipe and hose systems	9.7.4.2
Definition	3.3.218.2
Existing detention and correctional occupancies	23.3.5.5, 23.3.5.6
Maintenance and testing	9.7.5
New detention and correctional occupancies	22.3.5.5, 22.3.5.6
New residential board and care occupancies	32.3.3.9
Stages	12.4.5.12, 13.4.5.12, A.12.4.5.12, A.13.4.5.12
Storage facilities	
Bulk merchandising retail buildings	36.4.5.3, 37.4.5.3
Existing assembly occupancies	13.3.2.1
New assembly occupancies	12.3.2.1
Storage occupancies	Chap. 42; <i>see also</i> Parking structures
Aircraft storage hangars, provisions for	42.6, A.42.6
Alternating tread devices	42.2.2.11
Application	42.1.1
Areas of refuge	42.2.2.12
Building services	42.5
Bulk storage elevators	42.7, A.42.7
Classification of occupancy	6.1.13, 42.1.4, A.6.1.13.1, A.6.13.1
Corridors	42.3.6
Definition	3.3.152.15, 6.1.13.1, A.3.3.152.15, A.6.1.13.1, A.6.13.1
Detection/alarm/communication systems	42.3.4
Doors	42.2.2.2
Elevators/escalators/conveyors	42.5.3
Emergency lighting	42.2.9
Exit discharge	42.2.7
Exit passageways	42.2.2.7
Exits, horizontal	42.2.2.5, A.42.2.2.5.2
Exits, number of	42.2.4, 42.7.2
Exit travel distance	42.2.6, A.42.2.6
Extinguishment requirements	42.4.1
Fire escape ladders	42.2.2.9
Fire escape stairs	42.2.2.8
General requirements	42.1
Grain storage elevators	42.7, A.42.7
Hazard of contents, classification of	42.1.5
Heating, ventilating, and air conditioning	42.5.2
High-rise buildings	42.4.1
Interior finish	42.3.3
Means of egress arrangement	42.2.5
Means of egress capacity	42.2.3
Means of egress components	42.2.2, 42.8.2.2
Means of egress illumination	42.2.8
Means of egress marking	42.2.10
Means of egress requirements	42.2, 42.6, 42.7, 42.8.2
Multiple occupancies	42.1.2
Occupant load	Table 7.3.1.2, 42.1.7, A.42.1.7
Protection	42.3
Ramps	42.2.2.6
Rubbish/laundry chutes, incinerators	42.5.4
Slide escapes	42.2.2.10
Smokeproof enclosures	42.2.2.4
Special provisions	42.4
Stairs	42.2.2.3
Underground spaces	42.7.4
Utilities	42.5.1
Vertical openings, protection of	42.3.1
Stored electrical energy systems	9.1.4
Storm doors	7.2.1.4.6
Story	
Accessible means of egress	7.5.4.7
Definition	3.3.214
Means of egress, number of	7.4.1.1, 7.4.1.2, 7.4.1.4
Occupiable (definition)	3.3.214.1, A.3.3.214.1
Street (definition)	3.3.215
Street floor (definition)	3.3.216, A.3.3.216
Structural integrity objective	4.2.2
Structures	
Air-inflated	<i>see</i> Air-inflated structures
Air-supported	<i>see</i> Air-supported structures
Definition	3.3.217, A.3.3.217
Limited access	<i>see</i> Limited access structures
Membrane	<i>see</i> Membrane structures
Multilevel play	<i>see</i> Multilevel play structures
Open	<i>see</i> Open structures
Open parking	<i>see</i> Open parking structures
Permanent (definition)	3.3.217.8

Temporary (definition) 3.3.217.9
 Tensioned-membrane *see* Tensioned-membrane structures
 Underground *see* Underground structures
 Water-surrounded *see* Water-surrounded structures
Supervision, sprinkler system 9.7.2, A.9.7.2.1
Swinging stairs 7.2.8.7, A.7.2.8.7
Systems
 Effectiveness of 4.2.3
 Elevator evacuation system
 Capacity 7.2.13.2
 Definition 3.3.218.1
 Standpipe *see* Standpipe and hose systems

-T-

Telescopic seating *see* Seating
Temporary platforms *see* Platforms
Temporary structures (definition) 3.3.217.9; *see also* Membrane structures, temporary
Tensioned-membrane structures 11.9.2
 Definition 3.3.217.10
 Maintenance and operation 11.9.4, 11.10.6
 Temporary 11.10.1.3, 11.10.4
Tents 11.11
 Definition 3.3.222, A.3.3.222
 Fire extinguishing equipment 11.11.5
 Fire hazards 11.11.4
 Flame resistance 11.11.2
 General 11.11.1
 Location and spacing 11.11.3
 Private party (definition) 3.3.222.1
 Services 11.11.6
 Electric heaters 11.11.6.2
 Fired heaters 11.11.6.1
Testing 4.6.13, A.4.6.13.2
 Alarms and alarm systems 9.6.1.3, 9.6.1.6, 9.6.1.9, 9.6.1.10, A.9.6.1.6
 Ambulatory health care occupancies 20.7.6, 21.7.6
 Elevators 9.4.6
 Emergency lighting 7.9.3, 7.10.9.2
 Exit signs 7.10.9
 Fire protection systems 9.8
 Foamed plastics 10.3.7, A.10.3.7
 Health care occupancies 18.7.6, 19.7.6
 Interior finish 10.2.7, A.10.2.7.2, A.10.2.7.3
 Smoke control systems 9.3.1, A.9.3.1
 Smokeproof enclosure ventilation equipment 7.2.3.13
 Sprinkler systems 9.7.5
 Standpipes 9.7.5
 Structural elements and building assemblies, fire resistance of 8.2.3.1, A.8.2.3.1
Textile wall/ceiling materials 10.2.4.1, 12.7.4.3.4(4), 13.7.4.3.4, A.10.2.4.1; *see also* Interior finish
Thermal barriers (definition) 3.3.23.3, A.3.3.23.3
Time allowed for compliance 4.6.5
Title of code 1.1.1
Towers 11.3, A.11.3.1.3.1(2), A.11.3.2.4
 Definition 3.3.224
 Elevators 7.2.13.1, A.7.2.13.1
 Tread devices, alternating 7.2.11.1(3)
Transfer grilles
 Apartment buildings 30.3.6.7, 31.3.6.7
 Health care occupancies 18.3.6.4, 19.3.6.4
 Hotels and dormitories 28.3.6.7, 29.3.6.7
 Residential board and care occupancies 32.2.3.6.3, 32.3.3.6.6, 33.2.3.6.3
Travel distance *see* Exit travel distance
Tread devices, alternating *see* Alternating tread devices
Treads, stair
 Aisles 12.2.5.6.5, A.12.2.5.6.5(2)

Depth 7.2.2.2.2, 7.2.2.2.3.2(2), 7.2.2.2.3.3(4), 7.2.2.3.3, 7.2.2.3.5, 7.2.2.3.6, A.7.2.2.3.3.2, A.7.2.2.3.5
 Existing assembly occupancies 13.2.5.6.5, A.13.2.5.6.5
 Slope 7.2.2.3.4, A.7.2.2.3.4
 Tripping hazards 7.2.2.3.3.2, A.7.2.2.3.3.2
Trim and incidental finish 10.2.5
Turnstiles 7.2.1.11
 Existing assembly occupancies 13.2.2.2.8, 13.2.2.2.9
 New assembly occupancies 12.2.2.2.8, 12.2.2.2.9
Two-family dwelling units (definition) 3.3.50.3; *see also* One- and two-family dwelling units

-U-

Uncertainty analysis *see* Analysis
Underground spaces, storage occupancies 42.7.4
Underground structures
 Assembly occupancies 12.4.3, 13.4.3
 Business occupancies 38.4.1, 39.4.1
 Day-care occupancies 16.4.1, 17.4.1
 Definition 3.3.217.11, A.3.3.217.11
 Detention and correctional occupancies 22.4.2, 23.4.2
 Educational occupancies 14.4.1, 15.4.1
 Mercantile occupancies 36.4.1, 37.4.1
 Special provisions 11.7, A.11.7.2
Units of measurement 1.5
Upholstered furniture *see* Furnishings
Use Conditions I to V
 Existing detention and correctional occupancies 23.1.4.1 to 23.1.4.3, A.23.1.4.1 to A.23.1.4.3
 New detention and correctional occupancies 22.1.4, A.22.1.4.1 to A.22.1.4.3
Utilities 9.1
 Ambulatory health care occupancies 20.5.1, 21.5.1
 Apartment buildings 30.5.1, 31.5.1
 Assembly occupancies 12.5.1, 13.5.1
 Business occupancies 38.5.1, 39.5.1
 Day-care occupancies 16.5.1, 17.5.1
 Detention and correctional occupancies 22.5.1, 23.5.1
 Educational occupancies 14.5.1, 15.5.1
 Health care occupancies 18.5.1, 19.5.1
 Hotels and dormitories 28.5.1, 29.5.1
 Industrial occupancies 40.5.1
 Lodging houses 26.5.1
 Mercantile occupancies 36.5.1, 37.5.1
 Parking structures 42.8.5.1
 Residential board and care occupancies 32.2.5.1, 32.3.6.1, 33.2.5.1, 33.3.6.1
 Rooming houses 26.5.1
 Storage occupancies 42.5.1

-V-

Vehicles
 Applicability of code to 1.3.2
 Exposition facilities, displayed in 12.7.4.4, 13.7.4.4
 Special provisions 11.6.1
Ventilation *see also* Heating, ventilating, and air conditioning
 Projection rooms 12.4.6.8, 13.4.6.8
 Smokeproof enclosures 7.2.3.7, 7.2.3.8, 7.2.3.10, 7.2.3.12
 Smoke-protected assembly seating 12.4.2.1(2), 13.4.2.1(2)
 Stages 12.4.5.5, 13.4.5.5
Verification method (definition) 3.3.227
Vertical openings *see also* Chutes, laundry or rubbish
 Ambulatory health care occupancies 20.3.1, 21.3.1
 Apartment buildings 30.3.1, 31.3.1
 Assembly occupancies 12.3.1, 13.3.1, A.12.3.1(1), A.13.3.1(1)
 Business occupancies 38.3.1, 39.3.1
 Communicating spaces 8.6.6, A.8.2.6.6(7)
 Convenience openings 8.6.8
 Day-care occupancies 16.3.1, 16.6.3.1, 17.3.1, 17.6.3.1

Definition	3.3.228
Detention and correctional occupancies	22.3.1, 22.4.4.6, 23.3.1, A.22.3.1(2), A.22.4.4.6.2, A.22.4.4.6.4, A.23.3.1
Educational occupancies	14.3.1, 15.3.1
Fire protection features	Table 8.3.4.2, 8.3.4.3, 8.6, A.8.6
Fundamental requirements	4.5.5
Health care occupancies	18.3.1, 19.3.1
Hotels and dormitories	28.3.1, 29.3.1
Industrial occupancies	40.3.1
Lodging houses	26.3.1, A.26.3.1.2
Mercantile occupancies	36.3.1, 37.3.1
Parking structures	42.8.3.1
Residential board and care occupancies	32.2.3.1, 32.3.3.1, 33.2.3.1, 33.3.3.1
Rooming houses	26.3.1, A.26.3.1.2
Service openings, closing devices for	8.6.8.4
Special structures	11.2.3.1, 11.3.3.1, 11.4.3.1
Storage occupancies	42.3.1
Vessels, marine	1.3.2, 11.6.2
Vestibules	7.2.3.4, 7.2.3.6, 7.7.2.5
Vinyl wall or ceiling coverings, expanded	10.2.4.2, A.10.2.4.2
Visual protection	
Fire escape stairs	7.2.8.5
Outside ramps	7.2.5.6.1, A.7.2.5.6.1
Outside stairs	7.2.2.6.2, A.7.2.2.6.2

-W-

Waiting spaces	
Existing assembly occupancies	13.1.7.2
New assembly occupancies	12.1.7.2
Walls	<i>see also</i> Corridor wall construction;
Interior wall/ceiling finish	
Fire, penetrations of	8.3.5, A.8.3.5.6.3(1)(c)
Fire barrier	8.3.2, 8.6.2; <i>see also</i> Fire barriers; Hazards, protection from
Definition	3.3.229.1
Penetrations of	8.3.5, A.8.3.5.6.3(1)(c)
Fire-resistance ratings	Table A.8.2.1.2

Openings in	<i>see</i> Penetrations/openings
Proscenium	12.4.5.6
Definition	3.3.229.2
Water accumulation	
Outside ramps	7.2.5.6.2, A.7.2.5.6.2
Outside stairs	7.2.2.6.5, A.7.2.2.6.5
Waterspray deluge systems	13.4.5.7.5
Water-surrounded structures	11.4
Definition	3.3.217.12
Weathered-membrane material (definition)	3.3.135.4
Winders, stair	<i>see</i> Stairs
Windows	7.2.1.1.2; <i>see also</i> Outside windows
Day-care occupancies	16.2.11.1, 17.2.11.1
Educational occupancies	14.2.11.1, 15.2.11.1, A.14.2.11.1, A.15.2.11.1
In fire barriers	8.3.3, A.8.3.3.6, A.8.3.4.2
Fire window assemblies	8.3.3, Table 8.3.4.2, 8.5.3.5, 19.3.6.2.7, 20.3.7.1(4), 20.3.7.7, 21.3.7.1(4), A.8.3.3.6, A.8.3.4.2
Definition	3.3.18.2

-Y-

Yards	
Definition	3.3.232
Exit discharge	7.7.1.1, 22.2.7.1, 22.2.7.2, 23.2.7.1, 23.2.7.2, A.7.7.1

-Z-

Zoned Egress, Use Condition II	
Existing detention and correctional occupancies	23.1.4.1(2), A.23.1.4.1
New detention and correctional occupancies	22.1.4.1(2), A.22.1.4.1
Zoned Impeded Egress, Use Condition III	
Existing detention and correctional occupancies	23.1.4.1(3), 23.1.4.2, A.23.1.4.1, A.23.1.4.2
New detention and correctional occupancies	22.1.4.1(3), 22.1.4.2, A.22.1.4.1, A.22.1.4.2

Tentative Interim Amendment

NFPA 101®

Life Safety Code®

2003 Edition

Reference: 12.2.5.4.1 and 13.2.5.4.1

TIA 03-1 (NFPA 101)

(SC 03-7-15/Log No. 737R)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101®, *Life Safety Code*®, 2003 edition. The TIA was processed by the Safety to Life Committee, and was issued by the Standards Council on July 25, 2003, with an effective date of August 14, 2003.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

Revise 12.2.5.4.1 and 13.2.5.4.1 to prohibit festival seating in assembly occupancies with occupant load more than 250 without a life safety evaluation as follows:

12.2.5.4.1 Festival seating, as defined in 3.3.188.1, shall be prohibited within a building, unless otherwise permitted by the following:

- (1) Festival seating shall be permitted in assembly occupancies having occupant loads of 250 ~~1000~~ or less.
- (2) Festival seating shall be permitted in assembly occupancies where occupant loads exceed 250 ~~1000~~ and where an approved life safety evaluation has been performed. (See 12.4.1.)

13.2.5.4.1 Festival seating, as defined in 3.3.188.1, shall be prohibited within a building, unless otherwise permitted by the following:

- (1) Festival seating shall be permitted in assembly occupancies having occupant loads of 250 ~~1000~~ or less.
- (2) Festival seating shall be permitted in assembly occupancies where occupant loads exceed 250 ~~1000~~ and where an approved life safety evaluation has been performed. (See 13.4.1.)

Tentative Interim Amendment

NFPA 101®

Life Safety Code®

2003 Edition

Reference: 12.3.5.1
TIA 03-4 (NFPA 101)
(SC 03-7-18/Log No. 741R)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101®, *Life Safety Code®*, 2003 edition. The TIA was processed by the Safety to Life Committee, and was issued by the Standards Council on July 25, 2003, with an effective date of August 14, 2003.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

Insert a new 12.3.5.1 (and renumber existing 12.3.5.1 through 12.3.5.3) to require sprinklers in new nightclubs and similar assembly occupancies as follows:

12.3.5.1 The following assembly occupancies shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7:

- (1) Bars
- (2) Dance Halls
- (3) Discotheques
- (4) Nightclubs
- (5) Assembly occupancies with festival seating

Tentative Interim Amendment

NFPA 101®

Life Safety Code®

2003 Edition

Reference: 12.7.1 and 13.7.1

TIA 03-5 (NFPA 101)

(SC 03-7-19/Log No. 742R)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101®, *Life Safety Code®*, 2003 edition. The TIA was processed by the Safety to Life Committee, and was issued by the Standards Council on July 25, 2003, with an effective date of August 14, 2003.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

Insert a new 12.7.1 and 13.7.1 (and renumber existing 12.7.1 through 12.7.11 and 13.7.1 through 13.7.11) to require means of egress inspections as follows:

12.7.1 Means of Egress Inspection.

12.7.1.1 The building owner or agent shall inspect the means of egress to ensure it is maintained free of obstructions, and correct any deficiencies found, prior to each opening of the building to the public.

12.7.1.2 The building owner or agent shall prepare and maintain records of the date and time of each inspection on approved forms, listing any deficiencies found and actions taken to correct them.

13.7.1 Means of Egress Inspection.

13.7.1.1 The building owner or agent shall inspect the means of egress to ensure it is maintained free of obstructions, and correct any deficiencies found, prior to each opening of the building to the public.

13.7.1.2 The building owner or agent shall prepare and maintain records of the date and time of each inspection on approved forms, listing any deficiencies found and actions taken to correct them.

Tentative Interim Amendment

NFPA 101®

Life Safety Code®

2003 Edition

Reference: 12.7.5 and 13.7.5

TIA 03-2 (NFPA 101)

(SC 03-7-16/Log No. 738)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101®, *Life Safety Code®*, 2003 edition. The TIA was processed by the Safety to Life Committee, and was issued by the Standards Council on July 25, 2003, with an effective date of August 14, 2003.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

Revise 12.7.5 and 13.7.5 to lower the threshold for crowd managers in assembly occupancies as follows:

12.7.5* Crowd Managers.

12.7.5.1 ~~In assembly occupancies having occupant loads exceeding 1000, shall be provided with a minimum of one trained crowd manager or crowd manager supervisor. Where the occupant load exceeds 250, additional~~ trained crowd managers or crowd manager supervisors shall be provided at a ratio of 1 crowd manager/supervisor for every 250 occupants unless otherwise permitted by the following:

- (1) This requirement shall not apply to assembly occupancies used exclusively for religious worship with an occupant load not exceeding 2000.
- (2) The ratio of trained crowd managers to occupants shall be permitted to be reduced where, in the opinion of the authority having jurisdiction, the existence of an approved, supervised automatic sprinkler system and the nature of the event warrant.

12.7.5.2 The crowd manager shall receive approved training in crowd management techniques.

13.7.5* Crowd Managers.

13.7.5.1 ~~In assembly occupancies having occupant loads exceeding 1000, shall be provided with a minimum of one trained crowd manager or crowd manager supervisor. Where the occupant load exceeds 250, additional~~ trained crowd managers or crowd manager supervisors shall be provided at a ratio of 1 crowd manager/supervisor for every 250 occupants unless otherwise permitted by the following:

- (1) This requirement shall not apply to assembly occupancies used exclusively for religious worship with an occupant load not exceeding 2000.
- (2) The ratio of trained crowd managers to occupants shall be permitted to be reduced where, in the opinion of the authority having jurisdiction, the existence of an approved, supervised automatic sprinkler system and the nature of the event warrant.

13.7.5.2 The crowd manager shall receive approved training in crowd management techniques.

Tentative Interim Amendment

NFPA 101®

Life Safety Code®

2003 Edition

Reference: 13.3.5.1

TIA 03-3 (NFPA 101)

(SC 03-7-17/Log No. 739R)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101®, *Life Safety Code*®, 2003 edition. The TIA was processed by the Safety to Life Committee, and was issued by the Standards Council on July 25, 2003, with an effective date of August 14, 2003.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

Insert a new 13.3.5.1 (and renumber existing 13.3.5.1 through 13.3.5.3) to require sprinklers in existing nightclubs and similar assembly occupancies with occupant load exceeding 100 as follows:

13.3.5.1 Where occupant load exceeds 100, the following assembly occupancies shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7:

- (1) Bars
- (2) Dance Halls
- (3) Discotheques
- (4) Nightclubs
- (5) Assembly occupancies with festival seating

Tentative Interim Amendment

NFPA 101[®]
Life Safety Code[®]

2003 Edition

Reference: Chapters 18 and 19
TIA 03-6 (NFPA 101)
(SC-04-4-17/Log 787)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101[®], *Life Safety Code*[®], 2003 edition. The TIA was processed by the Safety to Life Committee, and was issued by the Standards Council on April 15, 2004, with an effective date of May 5, 2004.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. Add new text to Chapter 18 for new health care occupancies as follows:

18.3.2.6* Alcohol-based Hand-rub Solutions. Alcohol-based hand-rub dispensers shall be protected in accordance with 8.7.3 unless all of the following conditions are met:

(1) Where dispensers are installed in a corridor, the corridor shall have a minimum width of 1830 mm (72 in.).

(2) The maximum individual dispenser fluid capacity shall be:

(a) 1.2 L (0.32 gal) for dispensers in rooms, corridors, and areas open to corridors

(b) 2.0 L (0.53 gal) for dispensers in suites of rooms

(3) The dispensers shall have a minimum horizontal spacing of 1220 mm (48 in.) from each other.

(4) Not more than an aggregate 37.8 L (10 gal) of alcohol-based hand-rub solution shall be in use in a single smoke compartment outside of a storage cabinet.

(5) Storage of quantities greater than 18.9 liters (5 gal) in a single smoke compartment shall meet the requirements of NFPA 30, *Flammable and Combustible Liquids Code*.

(6) The dispensers shall not be installed over or directly adjacent to an ignition source.

(7) In locations with carpeted floor coverings, dispensers installed directly over carpeted surfaces shall be permitted only in sprinklered smoke compartments.

18.3.2.7 ~~18.3.2.6~~ Heliports. Buildings that house health care occupancies, as indicated in 18.1.1.1.2, and have rooftop heliports shall be protected in accordance with NFPA 418, *Standard for Heliports*.

18.2.3.4* Aisles, corridors, and ramps required for exit access in a hospital or nursing home shall be not less than 2440 mm (96 in.) in clear and unobstructed width, unless otherwise permitted by the following:

(1)* Aisles, corridors, and ramps in adjunct areas not intended for the housing, treatment, or use of inpatients shall be not less than 1120 mm (44 in.) in clear and unobstructed width.

(2) Where minimum corridor width is 1830 mm (72 in.), projections of maximum 152 mm (6 in.) from the corridor wall, above the handrail height, shall be permitted for the installation of hand-rub dispensing units in accordance with 18.3.2.6.

(3) ~~(2)*~~ Exit access within a room or suite of rooms complying with the requirements of 18.2.5 shall be permitted.

18.2.3.5 Aisles, corridors, and ramps required for exit access in a limited care facility or hospital for psychiatric care shall be not less than 1830 mm (72 in.) in clear and unobstructed width, unless otherwise permitted by the following:

(1)* Aisles, corridors, and ramps in adjunct areas not intended for the housing, treatment, or use of inpatients shall be not less than 1120 mm (44 in.) in clear and unobstructed width:

(2) Where minimum corridor width is 1830 mm (72 in.), projections of maximum 152 mm (6 in.) from the corridor wall, above the handrail height, shall be permitted for the installation of hand-rub dispensing units in accordance with 18.3.2.6.

(3)* ~~(2)*~~ Exit access within a room or suite of rooms complying with the requirements of 18.2.5 shall be permitted.

A.18.3.2.6 The Centers for Disease Control and Prevention on October 25, 2002, issued the *Guidelines for Hand Hygiene in Health-Care Settings* [MMWR 2002; 51 (no. RR-16)], which highly recommends the placement of alcohol-based hand-rub solutions in convenient locations of patient care areas of health care organizations. Clinical studies indicate that the frequency of handwashing or antiseptic handwashing by personnel is affected by the accessibility of hand-hygiene facilities. By permitting the installation of hand-rub dispensers immediately outside the patient/residence bedroom or within suites of rooms, the overall efficacy of staff use has been proven to increase by over 20 percent.

According to the CDC, more than 88,000 patient deaths per year are attributed to hospital-acquired infections, and one of the principal methodologies for reducing this statistic is by the expanded use of alcohol-based hand-rub solutions. These products have been found to be more effective for standard handwashing or hand antisepsis by health care workers than soap or antimicrobial soaps.

To address the fire hazard of introducing additional alcohol-based materials, a fire-modeling project was initiated to study the overall effects of placing dispensers in corridors and suites of rooms. This modeling was accomplished using the Fire Dynamics Simulator (FDS) Version 3.1 published by the National Institute of Standards and Technology (NIST). Using the results of the FDS, model the potential hazards were evaluated by reviewing the data for tenability of the space, ignition of adjacent fuel loads/combustibles, and sprinkler activation.

The tenability value for this report was chosen to be conservative. The fire modeling does clearly show that up to (1.2-L) 0.32-gal container size in a corridor and up to a (2-L) 0.53-gal container size in a suite location to be acceptable for either Ethyl; or Isopropyl Alcohol-based products. Except for a scenario that modeled the (1.2-L) 0.32-gal Isopropyl Alcohol container in a 1830 mm (72 in.) wide corridor with all doors closed, all of the results with realistic conditions showed no issues. For that one scenario, the visibility did drop below the stated threshold, but since visibility is not an immediate health concern and it did not occur until the very end of the fire's burn time (final 15 seconds), only to improve dramatically to twice the allowable value, we feel that this is still an acceptable result. The scenario with 1830 mm (72 in.) corridors and all doors closed, which is a very extreme case compared to actual conditions, does show some concerns compared to our tenability criteria. The results showed that the corridor remained below the visibility and CO thresholds established. The temperature in this scenario did drop below the tenability threshold (which has a factor of safety of 10) but not significantly. This scenario helps to prove that the hazard is acceptable.

The results clearly indicate that the (2-L) 0.53-gal container size to be unacceptable in a corridor location. In addition, the results also indicate the scenario with a carpeted floor is a concern due to visibility problems. The scenario showed that the visibility in the corridor dropped slightly below our assigned threshold. The carpet scenario is based on assumptions (soot and CO yields) that are not validated via any test data or other available data sources. The yields used are based on engineering judgment and need further study to make a firm recommendation.

Visibility, unlike other tenability areas (for example, temperature, toxicity), is based on a number of factors, has limited real life test data, and is very subjective. The resources available have a wide range of values that could be considered acceptable based on various factors, such as type of smoke (irritating vs. non-irritating), travel distances, familiarity with escape routes, etc.

The results showed that none of the fuel targets put into the models would ignite based on the design fires chosen. This indicates the proposed spacing to be reasonable to prevent additional fire hazards. Sprinkler activation was not predicted for most of the scenarios modeled. When the sprinklers actuated it was most often after the conditions had exceeded the tenability thresholds and typically with the larger (2-L) 0.53-gal

spills. Due to the lack of sprinkler activation, it is important to address the hazard from products of combustion such as smoke or CO more than the hazards from heat or the actual fire.

2. Add new text to Chapter 19 for existing health care occupancies as follows:

19.3.2.6* Alcohol-based Hand-rub Solutions. Alcohol-based hand-rub dispensers shall be protected in accordance with 8.7.3 unless all of the following conditions are met:

(1) Where dispensers are installed in a corridor, the corridor shall have a minimum width of 1830 mm (72 in.).

(2) The maximum individual dispenser fluid capacity shall be:

(a) 1.2 L (0.32 gal) for dispensers in rooms, corridors, and areas open to corridors

(b) 2.0 L (0.53 gal) for dispensers in suites of rooms

(3) The dispensers shall have a minimum horizontal spacing of 1220 mm (48 in.) from each other.

(4) Not more than an aggregate 37.8 L (10 gal) of alcohol-based hand-rub solution shall be in use in a single smoke compartment outside of a storage cabinet.

(5) Storage of quantities greater than 18.9 L (5 gal) in a single smoke compartment shall meet the requirements of NFPA 30, *Flammable and Combustible Liquids Code*.

(6) The dispensers shall not be installed over or directly adjacent to an ignition source.

(7) In locations with carpeted floor coverings, dispensers installed directly over carpeted surfaces shall be permitted only in sprinklered smoke compartments.

19.2.3.4* Any required aisle, corridor, or ramp shall be not less than 1220 mm (48 in.) in clear width where serving as means of egress from patient sleeping rooms, unless otherwise permitted by the following:

(1) Aisles, corridors, and ramps in adjunct areas not intended for the housing, treatment, or use of inpatients shall be not less than 1120 mm (44 in.) in clear and unobstructed width.

(2) Where minimum corridor width is 1830 mm (72 in.), projections of maximum 152 mm (6 in.) from the corridor wall, above the handrail height, shall be permitted for the installation of hand-rub dispensing units in accordance with 19.3.2.6.

(3) ~~(2)~~ Exit access within a room or suite of rooms complying with the requirements of 19.2.5 shall be permitted.

A.19.3.2.6 The Centers for Disease Control and Prevention on October 25, 2002, issued the *Guidelines for Hand Hygiene in Health-Care Settings* [MMWR 2002; 51 (no. RR-16)], which highly recommends the placement of alcohol-based hand-rub solutions in convenient locations of patient care areas of health care organizations. Clinical studies indicate that the frequency of handwashing or antiseptic handwashing by personnel is affected by the accessibility of hand-hygiene facilities. By permitting the installation of hand-rub dispensers immediately outside the patient/residence bedroom or within suites of rooms, the overall efficacy of staff use has been proven to increase by over 20 percent.

According to the CDC, more than 88,000 patient deaths per year are attributed to hospital-acquired infections and one of the principal methodologies for reducing this statistic is by the expanded use of alcohol-based hand-rub solutions. These products have been found to be more effective for standard handwashing or hand antisepsis by health care workers than soap or antimicrobial soaps.

To address the fire hazard of introducing additional alcohol-based materials, a fire-modeling project was initiated to study the overall effects of placing dispensers in corridors and suites of rooms. This modeling was accomplished using the Fire Dynamics Simulator (FDS) Version 3.1, published by the National Institute of Standards and Technology (NIST). Using the results of the FDS model, the potential hazards were evaluated by reviewing the data for tenability of the space, ignition of adjacent fuel loads/combustibles, and sprinkler activation.

The tenability value for this report was chosen to be conservative. The fire modeling does clearly show that up to (1.2-L) 0.32-gal container size in a corridor and up to a (2-L) 0.53-gal container size in a suite location to be acceptable for either Ethyl or Isopropyl Alcohol based products. Except for a scenario that modeled the 0.32-gal (1.2-Liter) Isopropyl Alcohol container in a 1830 mm (72 in.) wide corridor with all doors closed, all of the results with realistic conditions showed no issues. For that one scenario, the visibility did drop below the stated threshold but since visibility is not an immediate health concern and it did not occur until the very end of the fire's burn time (final 15 seconds), only to improve dramatically to twice the allowable value, we feel that this is still an acceptable result. The scenario with 1830 mm (72 in.) corridors

and all doors closed, which is a very extreme case compared to actual conditions, does show some concerns compared to our tenability criteria. The results showed that the corridor remained below the visibility and CO thresholds established. The temperature in this scenario did drop below the tenability threshold (which has a factor of safety of 10) but not significantly. This scenario helps to prove that the hazard is acceptable.

The results clearly indicate the (2-L) 0.53-gal container size to be unacceptable in a corridor location. In addition, the results also indicate the scenario with a carpeted floor is a concern due to visibility problems. The scenario showed that the visibility in the corridor dropped slightly below our assigned threshold. The carpet scenario is based on assumptions (soot and CO yields) that are not validated via any test data or other available data sources. The yields used are based on engineering judgment and need further study to make a firm recommendation.

Visibility, unlike other tenability areas (for example, temperature, toxicity), is based on a number of factors, has limited real life test data, and is very subjective. The resources available have a wide range of values that could be considered acceptable based on various factors, such as type of smoke (irritating vs. non-irritating), travel distances, and familiarity with escape routes.

The results showed that none of the fuel targets put into the models would ignite based on the design fires chosen. This indicates the proposed spacing to be reasonable to prevent additional fire hazards. Sprinkler activation was not predicted for most of the scenarios modeled. When the sprinklers actuated it was most often after the conditions had exceeded the tenability thresholds and typically with the larger (2-L) 0.53-gal spills. Due to the lack of sprinkler activation, it is important to address the hazard from products of combustion such as smoke or CO more than the hazards from heat or the actual fire.

Tentative Interim Amendment

NFPA 101
Life Safety Code®

2003 Edition

Reference: 31.3.4.1.3(new)
TIA 03-7 (NFPA 101)
(SC 05-7-16)/Log No. 818)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 101® *Life Safety Code®*, 2003 edition. The TIA was processed by the Safety to Life Committee, and was issued by the Standards Council on July 29, 2005, with an effective date of August 18, 2005.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

Revise text as follows:

31.3.4 Detection, Alarm, and Communications Systems.

31.3.4.1 General.

31.3.4.1.1 Apartment buildings with more than three stories or with more than 11 dwelling units, other than those meeting 31.3.4.1.2 or 31.3.4.1.3, shall be provided with a fire alarm system in accordance with Section 9.6, except as modified by 31.3.4.2 through 31.3.4.5.2.

31.3.4.1.2 A fire alarm system shall not be required where each dwelling unit is separated from other contiguous dwelling units by fire barriers (see Section 8.3) having a fire resistance rating of not less than ½ hour, and where each dwelling unit has either its own independent exit or its own independent stairway or ramp discharging at grade.

31.3.4.1.3 A fire alarm system shall not be required in buildings that are protected throughout by an approved, automatic sprinkler system in accordance with 31.3.5.3 with listed quick-response or listed residential sprinklers installed throughout all dwelling units, that do not exceed four stories in height, and that contain not more than 16 dwelling units.

Copyright © 2005 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION

*Sequence of Events Leading to Publication
of an NFPA Committee Document*

Call goes out for proposals to amend existing document or for recommendations on new document.



Committee meets to act on proposals, to develop its own proposals, and to prepare its report.



Committee votes on proposals by letter ballot. If two-thirds approve, report goes forward. Lacking two-thirds approval, report returns to committee.



Report — *Report on Proposals* (ROP) — is published for public review and comment.



Committee meets to act on each public comment received.



Committee votes on comments by letter ballot. If two-thirds approve, supplementary report goes forward.

Lacking two-thirds approval, supplementary report returns to committee.



Supplementary report — *Report on Comments* (ROC) — is published for public review.



NFPA membership meets (Annual or Fall Meeting) and acts on committee report (ROP or ROC).



Committee votes on any amendments to report approved at NFPA Annual or Fall Meeting.



Appeals to Standards Council on Association action must be filed within 20 days of the NFPA Annual or Fall Meeting.



Standards Council decides, based on all evidence, whether or not to issue standard or to take other action, including upholding any appeals.

Committee Membership Classifications

The following classifications apply to Technical Committee members and represent their principal interest in the activity of a committee.

M *Manufacturer:* A representative of a maker or marketer of a product, assembly, or system, or portion thereof, that is affected by the standard.

U *User:* A representative of an entity that is subject to the provisions of the standard or that voluntarily uses the standard.

I/M *Installer/Maintainer:* A representative of an entity that is in the business of installing or maintaining a product, assembly, or system affected by the standard.

L *Labor:* A labor representative or employee concerned with safety in the workplace.

R/T *Applied Research/Testing Laboratory:* A representative of an independent testing laboratory or independent applied research organization that promulgates and/or enforces standards.

E *Enforcing Authority:* A representative of an agency or an organization that promulgates and/or enforces standards.

I *Insurance:* A representative of an insurance company, broker, agent, bureau, or inspection agency.

C *Consumer:* A person who is, or represents, the ultimate purchaser of a product, system, or service affected by the standard, but who is not included in the *User* classification.

SE *Special Expert:* A person not representing any of the previous classifications, but who has special expertise in the scope of the standard or portion thereof.

NOTE 1: "Standard" connotes code, standard, recommended practice, or guide.

NOTE 2: A representative includes an employee.

NOTE 3: While these classifications will be used by the Standards Council to achieve a balance for Technical Committees, the Standards Council may determine that new classifications of members or unique interests need representation in order to foster the best possible committee deliberations on any project. In this connection, the Standards Council may make such appointments as it deems appropriate in the public interest, such as the classification of "Utilities" in the National Electrical Code Committee.

NOTE 4: Representatives of subsidiaries of any group are generally considered to have the same classification as the parent organization.

FORM FOR PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

Mail to: Secretary, Standards Council

National Fire Protection Association, 1 Batterymarch Park, Quincy, Massachusetts 02269-9101

Fax No. 617-770-3500

Note: All proposals must be received by 5:00 p.m. EST/EDST on the published proposal-closing date.

If you need further information on the standards-making process, please contact the
Standards Administration Department at 617-984-7249.
For technical assistance, please call NFPA at 617-770-3000

Please indicate in which format you wish to receive your ROP/ROC: ☐ paper ☐ electronic ☐ download

(Note: In choosing the download option you intend to view the ROP/ROC from our website; no copy will be sent to you.)

Date 9/18/93 Name John B. Smith Tel. No. 617-555-1212

Company _____

Street Address 9 Seattle St., Seattle, WA 02255

Please Indicate Organization Represented (if any) Fire Marshals Assn. of North America

1. a) NFPA Document Title National Fire Alarm Code NFPA No. & Year NFPA 72, 1993 ed.

b) Section/Paragraph 1-5.8.1 (Exception No.1)

2. Proposal Recommends: (Check one) ☐ new text
☐ revised text
☒ deleted text

FOR OFFICE USE ONLY

Log # _____

Date Rec'd _____

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): (Note: Proposed text should be in legislative format: i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

Delete exception.

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that will be resolved by your recommendation; give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

A properly installed and maintained system should be free of ground faults. The occurrence of one or more ground faults should be required to cause a "trouble" signal because it indicates a condition that could contribute to future malfunction of the system. Ground fault protection has been widely available on these systems for years and its cost is negligible. Requiring it on all systems will promote better installations, maintenance and reliability.

5. ☒ This Proposal is original material. (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and, to the best of his/her knowledge, is not copied from another source.)

☐ This Proposal is not original material; its source (if known) is as follows: _____

Note 1: Type or print legibly in black ink.

Note 2: If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

I hereby grant the NFPA all and full rights in copyright, in this proposal, and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.

John B. Smith
Signature (Required)

9/99B

FORM FOR PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

Mail to: Secretary, Standards Council

National Fire Protection Association, 1 Batterymarch Park, Quincy, Massachusetts 02269-9101

Fax No. 617-770-3500

Note: All proposals must be received by 5:00 p.m. EST/EDST on the published proposal-closing date.

If you need further information on the standards-making process, please contact the
Standards Administration Department at 617-984-7249.
For technical assistance, please call NFPA at 617-770-3000

Please indicate in which format you wish to receive your ROP/ROC: ☐ paper ☐ electronic ☐ download

(Note: In choosing the download option you intend to view the ROP/ROC from our website; no copy will be sent to you.)

Date _____ Name _____ Tel. No. _____

Company _____

Street Address _____

Please Indicate Organization Represented (if any) _____

1. a) NFPA Document Title _____ NFPA No. & Year _____

b) Section/Paragraph _____

2. Proposal Recommends: (Check one) ☐ new text
☐ revised text
☐ deleted text

FOR OFFICE USE ONLY

Log # _____

Date Rec'd _____

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): (Note: Proposed text should be in legislative format: i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that will be resolved by your recommendation; give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

5. ☐ This Proposal is original material. (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and, to the best of his/her knowledge, is not copied from another source.)

☐ This Proposal is not original material; its source (if known) is as follows: _____

Note 1: Type or print legibly in black ink.

Note 2: If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

I hereby grant the NFPA all and full rights in copyright, in this proposal, and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.

Signature (Required)

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

(Continued from inside front cover)

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights asserted in connection with any items which are mentioned in or are the subject of NFPA codes, standards, recommended practices, and guides, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on these documents. Users of these documents are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

NFPA adheres to applicable policies of the American National Standards Institute with respect to patents. For further information, contact the NFPA at the address listed below.

Laws & Regulations

Users of these documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the NFPA. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making this document available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to this document.

Use of NFPA documents for regulatory purposes should be accomplished through adoption by reference. The term "adoption by reference" means the citing of title, edition and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA codes, standards, recommended practices, and guides and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

For more information about NFPA, visit the NFPA website at www.nfpa.org.